
MITSUBISHI

Mitsubishi Programmable Controller

MELSEC Q series

QnUCPU User's Manual

Function Explanation, Program Fundamentals



MODEL

-Q00UJCPU
-Q00UCPU
-Q01UCPU
-Q02UCPU
-Q03UD(E)CPU
-Q04UD(E)HCPU
-Q06UD(E)HCPU
-Q10UD(E)HCPU
-Q13UD(E)HCPU
-Q20UD(E)HCPU
-Q26UD(E)HCPU

●SAFETY PRECAUTIONS●

(Read these precautions before using this product.)

Before using this product, please read this manual and the relevant manuals carefully and pay full attention to safety to handle the product correctly.

In this manual, the safety precautions are classified into two levels: "◇! DANGER" and "△! CAUTION".

◇! DANGER	Indicates that incorrect handling may cause hazardous conditions, resulting in death or severe injury.
△! CAUTION	Indicates that incorrect handling may cause hazardous conditions, resulting in minor or moderate injury or property damage.

Under some circumstances, failure to observe the precautions given under "△! CAUTION" may lead to serious consequences.

Observe the precautions of both levels because they are important for personal and system safety.

Make sure that the end users read this manual and then keep the manual in a safe place for future reference.

[Design Precautions]

⚠ DANGER

● Configure safety circuits external to the programmable controller to ensure that the entire system operates safely even when a fault occurs in the external power supply or the programmable controller. Failure to do so may result in an accident due to an incorrect output or malfunction.

(1) Configure external safety circuits, such as an emergency stop circuit, protection circuit, and protective interlock circuit for forward/reverse operation or upper/lower limit positioning.

(2) The programmable controller stops its operation upon detection of the following status, and the output status of the system will be as shown below.

Status	Output
Overcurrent or overvoltage protection of the power supply module is activated.	All outputs are turned off.
The CPU module detects an error such as a watchdog timer error by the self-diagnostic function.	All outputs are held or turned off according to the parameter setting.

All outputs may turn on when an error occurs in the part, such as I/O control part, where the CPU module cannot detect any error. To ensure safety operation in such a case, provide a safety mechanism or a fail-safe circuit external to the programmable controller. For a fail-safe circuit example, refer to Chapter 10 LOADING AND INSTALLATION in the QCPU User's Manual (Hardware Design, Maintenance and Inspection).

(3) Outputs may remain on or off due to a failure of an output module relay or transistor. Configure an external circuit for monitoring output signals that could cause a serious accident.

[Design Precautions]

⚠ DANGER

- In an output module, when a load current exceeding the rated current or an overcurrent caused by a load short-circuit flows for a long time, it may cause smoke and fire. To prevent this, configure an external safety circuit, such as a fuse.

- Configure a circuit so that the programmable controller is turned on first and then the external power supply.
  If the external power supply is turned on first, an accident may occur due to an incorrect output or malfunction.

- For the operating status of each station after a communication failure, refer to relevant manuals for the network.
  Incorrect output or malfunction due to a communication failure may result in an accident.

- When changing data of the running programmable controller from a peripheral connected to the CPU module or from a personal computer connected to an intelligent function module, configure an interlock circuit in the sequence program to ensure that the entire system will always operate safely.
  For program modification and operating status change, read relevant manuals carefully and ensure the safety before operation.
  Especially, in the case of a control from an external device to a remote programmable controller, immediate action cannot be taken for a problem on the programmable controller due to a communication failure.
  To prevent this, configure an interlock circuit in the sequence program, and determine corrective actions to be taken between the external device and CPU module in case of a communication failure.

⚠ CAUTION

- Do not install the control lines or communication cables together with the main circuit lines or power cables.
  Keep a distance of 100mm (3.94 inches) or more between them.
  Failure to do so may result in malfunction due to noise.

- When a device such as a lamp, heater, or solenoid valve is controlled through an output module, a large current (approximately ten times greater than normal) may flow when the output is turned from off to on.
  Take measures such as replacing the module with one having a sufficient current rating.

[Installation Precautions]

⚠ CAUTION

- Use the programmable controller in an environment that meets the general specifications in the QCPU User's Manual (Hardware Design, Maintenance and Inspection).
  Failure to do so may result in electric shock, fire, malfunction, or damage to or deterioration of the product.

- To mount the module, while pressing the module mounting lever located in the lower part of the module, fully insert the module fixing projection(s) into the hole(s) in the base unit and press the module until it snaps into place.
  Incorrect mounting may cause malfunction, failure or drop of the module.
  When using the programmable controller in an environment of frequent vibrations, fix the module with a screw.
  Tighten the screw within the specified torque range.
  Undertightening can cause drop of the screw, short circuit or malfunction.
  Overtightening can damage the screw and/or module, resulting in drop, short circuit, or malfunction.

- When using an extension cable, connect it to the extension cable connector of the base unit securely.
  Check the connection for looseness.
  Poor contact may cause incorrect input or output.

- When using a memory card, fully insert it into the memory card slot.
  Check that it is inserted completely.
  Poor contact may cause malfunction.

- Shut off the external power supply for the system in all phases before mounting or removing the module. Failure to do so may result in damage to the product.
  A module can be replaced online (while power is on) on any MELSECNET/H remote I/O station or in the system where a CPU module supporting the online module change function is used.
  Note that there are restrictions on the modules that can be replaced online, and each module has its predetermined replacement procedure.
  For details, refer to the relevant sections in the QCPU User's Manual (Hardware Design, Maintenance and Inspection) and in the manual for the corresponding module.

- Do not directly touch any conductive part of the module.
  Doing so can cause malfunction or failure of the module.

- When using a Motion CPU module and modules designed for motion control, check that the combinations of these modules are correct before applying power.
  The modules may be damaged if the combination is incorrect.
  For details, refer to the user's manual for the Motion CPU module.

[Wiring Precautions]

⚠ DANGER

- Shut off the external power supply for the system in all phases before wiring.
  Failure to do so may result in electric shock or damage to the product.

- After wiring, attach the included terminal cover to the module before turning it on for operation.
  Failure to do so may result in electric shock.

⚠ CAUTION

- Ground the FG and LG terminals to the protective ground conductor dedicated to the programmable controller.
  Failure to do so may result in electric shock or malfunction.

- Use applicable solderless terminals and tighten them within the specified torque range. If any spade solderless terminal is used, it may be disconnected when the terminal screw comes loose, resulting in failure.

- Check the rated voltage and terminal layout before wiring to the module, and connect the cables correctly.
  Connecting a power supply with a different voltage rating or incorrect wiring may cause a fire or failure.

- Connectors for external connection must be crimped or pressed with the tool specified by the manufacturer, or must be correctly soldered.
  Incomplete connections could result in short circuit, fire, or malfunction.

- Tighten the terminal screw within the specified torque range.
  Undertightening can cause short circuit, fire, or malfunction.
  Overtightening can damage the screw and/or module, resulting in drop, short circuit, or malfunction.

- Prevent foreign matter such as dust or wire chips from entering the module.
  Such foreign matter can cause a fire, failure, or malfunction.

[Wiring Precautions]

DANGER

- A protective film is attached to the top of the module to prevent foreign matter, such as wire chips, from entering the module during wiring.
  Do not remove the film during wiring.
  Remove it for heat dissipation before system operation.

- Mitsubishi programmable controllers must be installed in control panels.
  Connect the main power supply to the power supply module in the control panel through a relay terminal block.
  Wiring and replacement of a power supply module must be performed by maintenance personnel who is familiar with protection against electric shock. (For wiring methods, refer to the QCPU User's Manual (Hardware Design, Maintenance and Inspection)).

[Startup and Maintenance Precautions]

DANGER

- Do not touch any terminal while power is on.
  Doing so will cause electric shock.

- Correctly connect the battery connector.
  Do not charge, disassemble, heat, short-circuit, solder, or throw the battery into the fire.
  Doing so will cause the battery to produce heat, explode, or ignite, resulting in injury and fire.

- Shut off the external power supply for the system in all phases before cleaning the module or retightening the terminal screws or module fixing screws.
  Failure to do so may result in electric shock.
  Undertightening the terminal screws can cause short circuit or malfunction.
  Overtightening can damage the screw and/or module, resulting in drop, short circuit, or malfunction.

[Startup and Maintenance Precautions]

⚠ CAUTION

- Before performing online operations (especially, program modification, forced output, and operation status change) for the running CPU module from the peripheral connected, read relevant manuals carefully and ensure the safety.
  Improper operation may damage machines or cause accidents.

- Do not disassemble or modify the modules.
  Doing so may cause failure, malfunction, injury, or a fire.

- Use any radio communication device such as a cellular phone or PHS (Personal Handy-phone System) more than 25cm (9.85 inches) away in all directions from the programmable controller.
  Failure to do so may cause malfunction.

- Shut off the external power supply for the system in all phases before mounting or removing the module. Failure to do so may cause the module to fail or malfunction.
  A module can be replaced online (while power is on) on any MELSECNET/H remote I/O station or in the system where a CPU module supporting the online module change function is used.
  Note that there are restrictions on the modules that can be replaced online, and each module has its predetermined replacement procedure.
  For details, refer to the relevant sections in the QCPU User's Manual (Hardware Design, Maintenance and Inspection) and in the manual for the corresponding module.

- After the first use of the product, do not mount/remove the module to/from the base unit, and the terminal block to/from the module more than 50 times (IEC 61131-2 compliant) respectively.
  Exceeding the limit of 50 times may cause malfunction.

- Do not drop or apply shock to the battery to be installed in the module.
  Doing so may damage the battery, causing the battery fluid to leak inside the battery.
  If the battery is dropped or any shock is applied to it, dispose of it without using.

- Before handling the module, touch a grounded metal object to discharge the static electricity from the human body.
  Failure to do so may cause the module to fail or malfunction.

[Disposal Precautions]

⚠ CAUTION
● When disposing of this product, treat it as industrial waste. When disposing of batteries, separate them from other wastes according to the local regulations. (For details of the battery directive in EU member states, refer to the QCPU User's Manual (Hardware Design, Maintenance and Inspection).)

[Transportation Precautions]

⚠ CAUTION
● When transporting lithium batteries, follow the transportation regulations. (For details of the regulated models, refer to the QCPU User's Manual (Hardware Design, Maintenance and Inspection).)

REVISIONS

*The manual number is given on the bottom left of the back cover.

Print date	Manual number	Revision
Dec., 2008	SH(NA)-080807ENG-A	First edition
Mar., 2009	SH(NA)-080807ENG-B	Built-in Ethernet port QCPU functions addition, Revision involving Built-in Ethernet port QCPU whose serial number (first five digits) is "11012" or later Partial correction SAFETY PRECAUTIONS, INTRODUCTION, MANUALS, MANUAL PAGE ORGANIZATION, GENERIC TERMS AND ABBREVIATIONS, Section 1.3, 1.6, 2.2.2, 2.2.3, 2.3, 2.3.3, 2.3.4, 2.4, CHAPTER 3, Section 3.3, CHAPTER 4, Section 4.1.2, 4.2.2, 4.2.3, 5.1.1, 5.1.3, 5.1.6, 5.1.7, 5.1.8, 5.1.10, 6.1, 6.3, 6.4, 6.5, 6.6.1, 6.6.5, 6.11.1, 6.11.3, 6.11.4, 6.12.1, 6.13.3, 6.14, 6.15, 6.15.1, 6.15.2, 6.16, 6.17, 6.18, 6.20, 6.28, 6.30, 7.1.2, 8.2, 8.3, 9.2, 9.2.5, 9.2.11, 9.7.4, 9.11, 9.14.2, 11.5, Appendix 1, Appendix 2, Appendix 3.1, Appendix 3.3.2, Appendix 4 Addition Appendix 3.4.2

Japanese manual version SH-080802-B

This manual confers no industrial property rights or any rights of any other kind, nor does it confer any patent licenses. Mitsubishi Electric Corporation cannot be held responsible for any problems involving industrial property rights which may occur as a result of using the contents noted in this manual.

© 2008 MITSUBISHI ELECTRIC CORPORATION

Memo

INTRODUCTION

This manual describes the memory maps, functions, programs, I/O number assignment, and devices of the Universal model QCPU.

Before using this product, please read this manual and the relevant manuals carefully and develop familiarity with the functions and performance of the Q series programmable controller to handle the product correctly.

■ Relevant CPU module

CPU module	Model
Universal model QCPU	Q00UJCPU, Q00UCPU, Q01UCPU, Q02UCPU, Q03UD(E)CPU, Q04UD(E)HCPU, Q06UD(E)HCPU, Q10UD(E)HCPU, Q13UD(E)HCPU, Q20UD(E)HCPU, Q26UD(E)HCPU

Remark

This manual does not describe the specifications of the power supply modules, base units, extension cables, memory cards, and batteries.
For details, refer to the following.

☞ QCPU User's Manual (Hardware Design, Maintenance and Inspection)

For multiple CPU systems, refer to the following.

☞ QCPU User's Manual (Multiple CPU System)

CONTENTS

SAFETY PRECAUTIONS ..... A - 1
REVISIONS ..... A - 9
INTRODUCTION ..... A - 11
MANUALS ..... A - 18
MANUAL PAGE ORGANIZATION ..... A - 20
GENERIC TERMS AND ABBREVIATIONS ..... A - 21

CHAPTER1 OVERVIEW 1-1 to 1-14

1.1 Processing Order in the CPU Module ..... 1 - 1
1.2 Storing and Executing Programs ..... 1 - 2
1.3 Structured Programming ..... 1 - 3
1.4 Devices and Instructions Useful for Programming ..... 1 - 6
1.5 Features ..... 1 - 11
1.6 Checking Serial Number and Function Version ..... 1 - 13

CHAPTER2 SEQUENCE PROGRAMS 2-1 to 2-43

2.1 Sequence Program Overview ..... 2 - 1
2.2 Sequence Program Configuration ..... 2 - 3
2.2.1 Main routine program ..... 2 - 4
2.2.2 Subroutine program ..... 2 - 5
2.2.3 Interrupt program ..... 2 - 6
2.3 Settings When Program is Divided ..... 2 - 13
2.3.1 Initial execution type program ..... 2 - 17
2.3.2 Scan execution type program ..... 2 - 20
2.3.3 Stand-by type program ..... 2 - 21
2.3.4 Fixed scan execution type program ..... 2 - 26
2.3.5 Changing the program execution type ..... 2 - 30
2.4 Data Used in Sequence Programs ..... 2 - 32
2.4.1 BIN (Binary Code) ..... 2 - 35
2.4.2 HEX (Hexadecimal) ..... 2 - 37
2.4.3 BCD (Binary-coded Decimal) ..... 2 - 38
2.4.4 Real number (Floating-point data) ..... 2 - 39
2.4.5 Character string data ..... 2 - 43

CHAPTER3 CPU MODULE OPERATION 3-1 to 3-14

3.1 Initial Processing ..... 3 - 1
3.2 I/O Refresh (Refresh Processing with Input/Output Modules) ..... 3 - 2
3.3 Program Operation ..... 3 - 2
3.4 END Processing ..... 3 - 2
3.5 Operation Processing in the RUN,STOP, or PAUSE Status ..... 3 - 3
3.6 Operation Processing during Momentary Power Failure ..... 3 - 5
3.7 Data Clear Processing ..... 3 - 6
3.8 I/O Processing and Response Delay ..... 3 - 8

3.8.1 Refresh mode ..... 3 - 9
3.8.2 Direct mode ..... 3 - 12

CHAPTER4 ASSIGNMENT OF BASE UNIT AND I/O NUMBER 4-1 to 4-17

4.1 Base Unit Assignment ..... 4 - 1
4.1.1 Base mode ..... 4 - 1
4.1.2 Base unit assignment setting ..... 4 - 2
4.2 I/O Number Assignment ..... 4 - 4
4.2.1 Concept of I/O number assignment ..... 4 - 5
4.2.2 Setting I/O numbers ..... 4 - 8
4.2.3 I/O number setting example ..... 4 - 13
4.2.4 Checking I/O numbers ..... 4 - 17

CHAPTER5 MEMORIES AND FILES USED FOR CPU MODULE 5-1 to 5-38

5.1 Memories Used for CPU Module ..... 5 - 1
5.1.1 Memory composition and storable data ..... 5 - 1
5.1.2 Program memory ..... 5 - 5
5.1.3 Program cache memory ..... 5 - 8
5.1.4 Standard ROM ..... 5 - 11
5.1.5 Standard RAM ..... 5 - 12
5.1.6 Memory card ..... 5 - 14
5.1.7 Writing to the Flash card by GX Developer ..... 5 - 18
5.1.8 Operating the program in the memory card (boot operation) ..... 5 - 23
5.1.9 Details of written files ..... 5 - 27
5.1.10 Specifying valid parameters (parameter-valid drive setting) ..... 5 - 28
5.2 Program File Structure ..... 5 - 30
5.3 File Operations by GX Developer and Handling Precautions ..... 5 - 32
5.3.1 File operations ..... 5 - 32
5.3.2 Precautions for handling files ..... 5 - 33
5.3.3 File size ..... 5 - 34
5.3.4 Units of file sizes ..... 5 - 36

CHAPTER6 FUNCTIONS 6-1 to 6-160

6.1 Function List ..... 6 - 1
6.2 Constant Scan ..... 6 - 4
6.3 Latch Function ..... 6 - 7
6.4 Output Mode at Operating Status Change (STOP to RUN) ..... 6 - 10
6.5 Clock Function ..... 6 - 13
6.6 Remote Operation ..... 6 - 18
6.6.1 Remote RUN/STOP ..... 6 - 18
6.6.2 Remote PAUSE ..... 6 - 21
6.6.3 Remote RESET ..... 6 - 23
6.6.4 Remote latch clear ..... 6 - 25

6.6.5 Relationship between remote operation and RUN/STOP status of the CPU module ..... 6 - 26
6.7 Q Series-compatible Module Input Response Time Selection (I/O Response Time) ..... 6 - 27
6.8 Error Time Output Mode Setting ..... 6 - 29
6.9 H/W Error Time PLC Operation Mode Setting ..... 6 - 30
6.10 Intelligent Function Module Switch Setting ..... 6 - 31
6.11 Monitor Function ..... 6 - 33
6.11.1 Monitor condition setting ..... 6 - 34
6.11.2 Local device monitor/test ..... 6 - 40
6.11.3 External input/output forced on/off ..... 6 - 43
6.11.4 Executional conditioned device test ..... 6 - 48
6.12 Writing Programs While CPU Module is in RUN Status ..... 6 - 58
6.12.1 Online change (ladder mode) ..... 6 - 58
6.12.2 Online change (files) ..... 6 - 61
6.12.3 Precautions for online change ..... 6 - 63
6.13 Execution Time Measurement ..... 6 - 69
6.13.1 Program monitor list ..... 6 - 69
6.13.2 Interrupt program monitor list ..... 6 - 72
6.13.3 Scan time measurement ..... 6 - 73
6.14 Sampling Trace Function ..... 6 - 77
6.15 Debug Function from Multiple GX Developers ..... 6 - 91
6.15.1 Simultaneous monitoring from multiple GX Developers function ..... 6 - 91
6.15.2 Online change function from multiple GX Developers ..... 6 - 93
6.16 Watchdog Timer (WDT) ..... 6 - 95
6.17 Self-diagnostic Function ..... 6 - 97
6.17.1 LEDs indicating errors ..... 6 - 104
6.17.2 Error clear ..... 6 - 104
6.18 Error History ..... 6 - 105
6.19 System Protection ..... 6 - 106
6.19.1 Password registration ..... 6 - 106
6.19.2 Remote password ..... 6 - 108
6.20 System Display of CPU Module with GX Developer ..... 6 - 113
6.21 LED Indication ..... 6 - 116
6.21.1 Methods for turning off the LEDs ..... 6 - 116
6.21.2 LED indication priority ..... 6 - 117
6.22 Interrupt from Intelligent Function Module ..... 6 - 119
6.23 Serial Communication Function ..... 6 - 120
6.24 Service Processing ..... 6 - 128
6.24.1 Service processing setting ..... 6 - 128
6.25 Initial Device Value ..... 6 - 135
6.26 Battery Life-prolonging Function ..... 6 - 139
6.27 Memory Check Function ..... 6 - 140
6.28 Latch Data Backup to Standard ROM Function ..... 6 - 141
6.29 Writing/Reading Device Data to/from Standard ROM ..... 6 - 146
6.30 CPU Module Change Function with Memory Card ..... 6 - 147
6.30.1 Backup function to memory card ..... 6 - 149
6.30.2 Backup data restoration function ..... 6 - 157

CHAPTER7 COMMUNICATIONS WITH INTELLIGENT FUNCTION MODULE 7-1 to 7-9

7.1 Communications between CPU Module and Intelligent Function Module ..... 7 - 1
7.1.1 Initial setting and auto refresh setting by GX Configurator ..... 7 - 2
7.1.2 Initial setting by initial device value ..... 7 - 5
7.1.3 Communications with the FROM and TO instructions ..... 7 - 5
7.1.4 Communications using the intelligent function module device ..... 7 - 6
7.1.5 Communications using the intelligent function module dedicated instruction ..... 7 - 8

CHAPTER8 PARAMETERS 8-1 to 8-25

8.1 PLC Parameters ..... 8 - 2
8.2 Network Parameters ..... 8 - 20
8.3 Remote Password ..... 8 - 25

CHAPTER9 DEVICES 9-1 to 9-94

9.1 Device List ..... 9 - 1
9.2 Internal User Device ..... 9 - 3
9.2.1 Input (X) ..... 9 - 6
9.2.2 Output (Y) ..... 9 - 8
9.2.3 Internal relay (M) ..... 9 - 9
9.2.4 Latch relay (L) ..... 9 - 10
9.2.5 Annunciator (F) ..... 9 - 11
9.2.6 Edge relay (V) ..... 9 - 15
9.2.7 Link relay (B) ..... 9 - 16
9.2.8 Link special relay (SB) ..... 9 - 18
9.2.9 Step relay (S) ..... 9 - 19
9.2.10 Timer (T) ..... 9 - 20
9.2.11 Counter (C) ..... 9 - 27
9.2.12 Data register (D) ..... 9 - 31
9.2.13 Link register (W) ..... 9 - 32
9.2.14 Link special register (SW) ..... 9 - 34
9.3 Internal System Devices ..... 9 - 35
9.3.1 Function devices (FX, FY, FD) ..... 9 - 35
9.3.2 Special relay (SM) ..... 9 - 38
9.3.3 Special register (SD) ..... 9 - 39
9.4 Link Direct Device (J\) ..... 9 - 40
9.5 Module Access Devices ..... 9 - 43
9.5.1 Intelligent function module device (U\G) ..... 9 - 43
9.5.2 Cyclic transmission area device (U3En\G) ..... 9 - 45
9.6 Index Register (Z)/Standard Device Resister (Z) ..... 9 - 46
9.6.1 Index register (Z) ..... 9 - 46
9.6.2 Standard device register (Z) ..... 9 - 48

9.6.3 Switching from the scan execution type program to the interrupt/fixed scan execution type program ..... 9 - 49
9.7 File Register (R) ..... 9 - 53
9.7.1 File register data storage location ..... 9 - 54
9.7.2 File register size ..... 9 - 54
9.7.3 Differences in available accesses by storage memory ..... 9 - 55
9.7.4 Registration procedure for the file register ..... 9 - 56
9.7.5 Specification methods of the file register ..... 9 - 61
9.7.6 Precautions for using the file register ..... 9 - 62
9.8 Extended Data Register (D) and Extended Link Register (W) ..... 9 - 64
9.9 Nesting (N) ..... 9 - 70
9.10 Pointer (P) ..... 9 - 71
9.10.1 Local pointer ..... 9 - 72
9.10.2 Common pointer ..... 9 - 74
9.11 Interrupt Pointer(I) ..... 9 - 76
9.11.1 List of interrupt pointer numbers and interrupt factors ..... 9 - 77
9.12 Other Devices ..... 9 - 78
9.12.1 SFC block device (BL) ..... 9 - 78
9.12.2 Network No. specification device (J) ..... 9 - 78
9.12.3 I/O No. specification device (U) ..... 9 - 79
9.12.4 Macro instruction argument device (VD) ..... 9 - 80
9.13 Constants ..... 9 - 81
9.13.1 Decimal constant (K) ..... 9 - 81
9.13.2 Hexadecimal constant (H) ..... 9 - 81
9.13.3 Real number (E) ..... 9 - 82
9.13.4 Character string (" ") ..... 9 - 83
9.14 Convenient Usage of Devices ..... 9 - 84
9.14.1 Global device ..... 9 - 84
9.14.2 Local device ..... 9 - 85

CHAPTER10 CPU MODULE PROCESSING TIME 10-1 to 10-17

10.1 Scan Time ..... 10 - 1
10.1.1 Scan time structure ..... 10 - 1
10.1.2 Time required for each processing included in scan time ..... 10 - 2
10.1.3 Factors that increase the scan time ..... 10 - 11

CHAPTER11 PROCEDURES FOR WRITING PROGRAM TO CPU MODULE 11-1 to 11-10

11.1 Items to be Considered for Creating Programs ..... 11 - 1
11.2 Hardware Check ..... 11 - 3
11.3 Procedure for Writing One Program ..... 11 - 5
11.4 Procedure for Writing Multiple Programs ..... 11 - 7
11.5 Procedure for Boot Operation ..... 11 - 10

CHAPTER12 SPECIAL RELAY LIST AND SPECIAL REGISTER LIST 12-1 to 12-78

12.1 SPECIAL RELAY LIST ..... 12 - 1
12.2 SPECIAL REGISTER LIST ..... 12 - 27

APPENDICES App-1 to App-72

Appendix 1 List of Parameter Numbers ..... App- 1
Appendix 2 Functions Added or Changed by Version Upgrade ..... App- 6
Appendix 3 Method of Replacing Basic Model QCPU or High Performance Model QCPU with Universal Model QCPU ..... App- 8
Appendix 3.1 Replacement Precautions ..... App- 8
Appendix 3.1.1 Replacing Basic model QCPU with Universal model QCPU ..... App- 8
Appendix 3.1.2 Replacing High Performance model QCPU with Universal model QCPU ..... App- 12
Appendix 3.2 Applicable devices and software ..... App- 19
Appendix 3.3 Instructions ..... App- 23
Appendix 3.3.1 Instructions not supported in the Universal model QCPU and replacing methods ..... App- 23
Appendix 3.3.2 Replacing programs using multiple CPU transmission dedicated instructions ..... App- 25
Appendix 3.3.3 Program replacement examples ..... App- 26
Appendix 3.4 Functions ..... App- 40
Appendix 3.4.1 Floating-point operation instructions ..... App- 40
Appendix 3.4.2 Error check processing for floating-point data comparison instructions ..... App- 48
Appendix 3.4.3 Range check processing for index-modified devices ..... App- 52
Appendix 3.4.4 Device latch function ..... App- 55
Appendix 3.4.5 File usability setting ..... App- 57
Appendix 3.4.6 Parameter-valid drive and boot file setting ..... App- 60
Appendix 3.4.7 External input/output forced on/off function ..... App- 63
Appendix 3.5 Special Relay and Special Register ..... App- 67
Appendix 3.5.1 Special relay list ..... App- 67
Appendix 3.5.2 Special register list ..... App- 70
Appendix 4 Device Point Assignment Sheet ..... App- 72

INDEX Index-1 to Index-5

MANUALS

To understand the main specifications, functions, and usage of the CPU module, refer to the basic manuals.
Read other manuals as well when using a different type of CPU module and its functions.
Order each manual as needed, referring to the following list.


● :Basic manual, ○ :Other CPU module manuals

Manual name < Manual number (model code) >	Description	Manual type
● User's manual		
QCPU User's Manual (Hardware Design, Maintenance and Inspection) < SH-080483ENG (13JR73) >	Specifications of the hardware (CPU modules, power supply modules, base units, extension cables, and memory cards), system maintenance and inspection, troubleshooting, and error codes	●
QnUCPU User's Manual (Function Explanation, Program Fundamentals) < SH-080807ENG (13JZ27) >	Functions, methods, and devices for programming	●
QCPU User's Manual (Multiple CPU System) < SH-080485ENG (13JR75) >	Information on multiple CPU system configuration (system configuration, I/O numbers, communication between CPU modules, and communication with the input/output modules and intelligent function modules)	○
QnUCPU User's Manual (Communication via Built-in Ethernet Port) < SH-080811ENG (13JZ29) >	Functions for the communication via built-in Ethernet port of the CPU module	○
● Programming manual		
QCPU Programming Manual (Common Instructions) < SH-080809ENG (13JW10) >	How to use sequence instructions, basic instructions, and application instructions	●
QCPU (Q Mode)/QnACPU Programming Manual (SFC) < SH-080041 (13JF60) >	System configuration, performance specifications, functions, programming, debugging, and error codes for SFC (MELSAP3) programs	○
QCPU (Q Mode) Programming Manual (MELSAP-L) < SH-080076 (13JF61) >	Programming methods, specifications, and functions for SFC (MELSAP-L) programs	○
QCPU (Q Mode) Programming Manual (Structured Text) < SH-080366E (13JF68) >	Programming methods using structured languages	○
QCPU (Q Mode) / QnACPU Programming Manual (PID Control Instructions) < SH-080040 (13JF59) >	Dedicated instructions for PID control	○

Other relevant manuals

Manual name	Description
CC-Link IE Controller Network Reference Manual < SH-080668ENG (13JV16) >	Specifications, procedures and settings before system operation, parameter setting, programming, and troubleshooting of the CC-Link IE controller network module
Q Corresponding MELSECNET/H Network System Reference Manual (PLC to PLC network) < SH-080049 (13JF92) >	Specifications, procedures and settings before system operation, parameter setting, programming, and troubleshooting of a MELSECNET/H network system (PLC to PLC network)
Q Corresponding MELSECNET/H Network System Reference Manual (Remote I/O network) < SH-080124 (13JF96) >	Specifications, procedures and settings before system operation, parameter setting, programming, and troubleshooting of a MELSECNET/H network system (remote I/O network)
Q Corresponding Ethernet Interface Module User's Manual (Basic) < SH-080009 (13JL88) >	Specifications, procedures for data communication with external devices, line connection (open/close), fixed buffer communication, random access buffer communication, and troubleshooting of the Ethernet module
Q Corresponding Ethernet Interface Module User's Manual (Application) < SH-080010 (13JL89) >	E-mail function, programmable controller CPU status monitoring function, communication via MELSECNET/H or MELSECNET/10, communication using the data link instructions, and file transfer function (FTP server) of the Ethernet module
CC-Link System Master/Local Module User's Manual < SH-080394E (13JR64) >	System configuration, performance specifications, functions, handling, wiring, and troubleshooting of the QJ61BT11N
Q Corresponding Serial Communication Module User's Manual (Basic) < SH-080006 (13JL86) >	Overview, system configuration, specifications, procedures before operation, basic data communication method with external devices, maintenance and inspection, and troubleshooting for using the serial communication module
Q Corresponding Serial Communication Module User's Manual (Application) < SH-080007 (13JL87) >	Special functions (specifications, usage, and settings and data communication method with external devices of the serial communication module
Q Corresponding MELSEC Communication Protocol Reference Manual < SH-080008 (13JF89) >	Communication method using the MC protocol, which reads/writes data to/from the CPU module via the serial communication module or Ethernet module
GX Developer Version 8 Operating Manual < SH-080373E (13JU41) >	Operating methods of GX Developer, such as programming and printout

MANUAL PAGE ORGANIZATION



* cining page components, and differs from an actual page.

Icons Universal model QCPU	Description
Universal	Icons indicate that specifications described on the page contain some precautions.

In addition, this manual uses the following types of explanations.

Point

In addition to description of the page, notes or functions that require special attention are described here.

Remark

The reference related to the page or useful information are described here.

GENERIC TERMS AND ABBREVIATIONS

Unless otherwise specified, this manual uses the following generic terms and abbreviations.

*☐ indicates a part of the model or version.

(Example): Q33B, Q35B, Q38B, Q312B → Q3☐B

Generic term/abbreviation	Description
■ Series	
Q series	Abbreviation for Mitsubishi MELSEC-Q series programmable controller
■ CPU module type	
CPU module	Generic term for the Universal model QCPU
Universal model QCPU	Generic term for the Q00UJCPU, Q00UCPU, Q01UCPU, Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, and Q26UDEHCPU
Built-in Ethernet port QCPU	Generic term for the Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, and Q26UDEHCPU
Motion CPU	Generic term for Mitsubishi motion controllers, Q172CPUN, Q173CPUN, Q172HCPU, Q173HCPU, Q172CPUN-T, Q173CPUN-T, Q172HCPU-T, Q173HCPU-T, Q172DCPU, and Q173DCPU
PC CPU module	Generic term for MELSEC-Q series PC CPU module, PPC-CPU852(MS)-512, manufactured by CONTEC Co., Ltd.
C Controller module	Generic term for the Q06CCPU-V-H01, Q06CCPU-V, and Q06CCPU-V-B C Controller modules
■ CPU module model	
QnUD(H)CPU	Generic term for the Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, and Q26UDHCPU
■ Base unit type	
Base unit	Generic term for the main base unit, extension base unit, slim type main base unit, redundant power main base unit, redundant power extension base unit, and multiple CPU high speed main base unit
Main base unit	Generic term for the Q3☐B, Q3☐SB, Q3☐RB, and Q3☐DB
Extension base unit	Generic term for the Q5☐B, Q6☐B, and Q6☐RB
Slim type main base unit	Another name for the Q3☐SB
Redundant power main base unit	Another name for the Q3☐RB
Redundant power extension base unit	Another name for the Q6☐RB
Multiple CPU high speed main base unit	Another name for the Q3☐DB
■ Base unit model	
Q3☐B	Generic term for the Q33B, Q35B, Q38B, and Q312B main base units
Q3☐SB	Generic term for the Q32SB, Q33SB, and Q35SB slim type main base units
Q3☐RB	Another name for the Q38RB main base unit for redundant power supply system
Q3☐DB	Generic term for the Q38DB and Q312DB multiple CPU high speed main base units
Q5☐B	Generic term for the Q52B and Q55B extension base units
Q6☐B	Generic term for the Q63B, Q65B, Q68B, and Q612B extension base units
Q6☐RB	Another name for the Q68RB extension base unit for redundant power supply system

Generic term/abbreviation	Description
■ Power supply module	
Power supply module	Generic term for the Q series power supply module, slim type power supply module, and redundant power supply module
Q series power supply module	Generic term for the Q61P-A1, Q61P-A2, Q61P, Q61P-D, Q62P, Q63P, Q64P, and Q64PN power supply modules
Slim type power supply module	Abbreviation for the Q61SP slim type power supply module
Redundant power supply module	Generic term for the Q63RP and Q64RP power supply modules for redundant power supply
■ Network	
MELSECNET/H	Abbreviation for the MELSECNET/H network system
Ethernet	Abbreviation for the Ethernet network system
CC-Link	Abbreviation for the Control & Communication Link
■ Memory card	
Memory card	Generic term for the SRAM card, Flash card, and ATA card
SRAM card	Generic term for the Q2MEM-1MBS, Q2MEM-2MBS, Q3MEM-4MBS, and Q3MEM-8MBS SRAM cards
Flash card	Generic term for the Q2MEM-2MBF and Q2MEM-4MBF Flash cards
ATA card	Generic term for the Q2MEM-8MBA, Q2MEM-16MBA, and Q2MEM-32MBA ATA cards
■ Others	
GX Developer	Product name for SW□D5C-GPPW-E GPP function software package compatible with the Q series
Extension cable	Generic term for the QC05B, QC06B, QC12B, QC30B, QC50B, and QC100B extension cables
Battery	Generic term for the Q6BAT, Q7BAT, and Q8BAT CPU module batteries, Q2MEM-BAT SRAM card battery, and Q3MEM-BAT SRAM card battery
GOT	Generic term for Mitsubishi Graphic Operation Terminal, GOT-A*** series, GOT-F*** series, and GOT1000 series

CHAPTER1 OVERVIEW

The CPU module performs sequence control by executing programs.
This chapter describes the processing order in the CPU module, locations where the created programs are stored, and devices and instructions useful for programming.

1.1 Processing Order in the CPU Module

The CPU module performs processing in the following order.




Figure 1.1 Processing order in the CPU module

(1) Initial processing (☞ Section 3.1)

The CPU module performs preprocessing required for program operations.
The preprocessing is performed only once when the module is powered on or reset.

(2) Refresh processing with input and output modules (☞ Section 3.2)

The CPU module takes on/off data from the input module or intelligent function module and outputs on/off data to the output module or intelligent function module.

(3) Program operation processing (☞ Section 3.3)

The CPU module sequentially executes the program stored in the module from the step 0 to the END or FEND instruction.

(4) END processing (☞ Section 3.4)

The CPU module performs refresh processing with network modules or communicates with external devices.

1.2 Storing and Executing Programs

This section describes where to store and how to execute the programs in the CPU module.

(1) Programming

Programs are created with GX Developer.

For details of program configuration and execution conditions, refer to CHAPTER 2.

(2) Storing programs

Created programs and set parameters are stored in the following memories of the CPU module.

(☞ Section 5.1)

- Program memory
- Standard ROM (parameters only)
- Memory card

(3) Executing programs

The CPU module executes the programs stored in the program memory.




Figure 1.2 Executing programs

To execute the programs stored in a memory card, the programs need to be booted to the program memory (☞ Section 5.1.8) when the CPU module is powered off and then on or reset.




Figure 1.3 Executing programs stored in a memory card

1.3 Structured Programming

The programs to be executed in the CPU module can be structured in the following two ways.

- In one program
- By dividing into multiple files

(1) Structuring in one program

Structured programming is available by creating one program as a collection of three program sections: main routine program (☞ Section 2.2.1), subroutine program (☞ Section 2.2.2), and interrupt program (☞ Section 2.2.3).




Figure 1.4 Structuring in one program

(2) Structuring by dividing into multiple files

A program is stored in a file.

Changing the file name allows the CPU module to store multiple programs.




Figure 1.5 Structuring by dividing into multiple files

Dividing into multiple files according to the processes or functions enables simultaneous programming by two or more designers. Managing the files separately eases reuse and utilization to other programs.

Structured programming is efficient in this way because only the corresponding file needs to be modified or debugged in case of change in the specifications.

(a) Dividing into multiple files according to the processes*1




Figure 1.6 Dividing into multiple files according to the processes

*1: The processing contents divided according to the processes can further be divided and managed according to the functions.

*2: The execution order can be set in the Program tab of the PLC parameter dialog box. (☞ Section 2.3(2)).

(b) Dividing into multiple files according to the functions




Figure 1.7 Dividing into multiple files according to the functions

*1: The execution order and conditions can be set in the Program tab of the PLC parameter dialog box. (☞ Section 2.3(2)).

1.4 Devices and Instructions Useful for Programming

The CPU module is provided with devices and instructions useful for programming.
This section describes the outline of these devices and instructions.

(1) Various ways of device specification

(a) Using each bit of a word device as a contact or coil

By specifying a bit of a word device, the bit can be used as a contact or coil.




Figure 1.8 Specifying a bit of a word device

(b) Easy direct processing in units of one point

Use of the direct access input (DX □) and direct access output (DY □) enables easy direct processing (in units of one point) in the program. (☞ Section 3.8.2)




Figure 1.9 Direct processing in units of one point

(c) No input pulse conversion required by using a differential contact

Pulse conversion processing for inputs is no longer required with the use of a differential contacts (⊣↑⊢ and ⊣↓⊢).




Figure 1.10 Use of a differential contact

(d) Direct access to the buffer memory of the intelligent function module

The buffer memory of the intelligent function module can be used as a device area in a program.

(☞ Section 9.5.1)




Figure 1.11 Direct access to the buffer memory of the intelligent function module

(e) Direct access to the link devices

The link devices (LX, LY, LB, LW, SB, or SW) in network modules can be directly accessed without the refresh setting. (☞ Section 9.4)




Figure 1.12 Direct access to the link devices

(2) Structural description of programs

Use of the index register and edge relay enables easy structured programming including the pulse conversion processing. (☞ Section 9.2.6)




Figure 1.13 Structured programming including the pulse conversion processing

(3) Easy data processing

(a) Using real numbers and character string constants without conversion

Real numbers (floating-point data) and character string constants can be used without conversion for programming.




Figure 1.14 Using real numbers and character string constants

*1: The NULL character represents "00H" (end of character strings).

(b) High-speed processing of bulk data

Extension of the data table operation instructions, such as the data table processing instruction, allows high-speed processing of bulk data.




Figure 1.15 Data processing with the table processing instruction

(4) Flexible management of subroutine programs

(a) Subroutine program sharing

The number of steps in a program can be reduced by sharing subroutine programs.
In addition, creating and managing programs become easier.

Subroutine programs can be created within the same program and called. Subroutine programs in other programs can also be called by using the common pointer.




Figure 1.16 Subroutine program sharing

(b) Subroutine call instruction with argument passing

Subroutine program that is called more than one time can be created easily.




Figure 1.17 Calling subroutine program with argument passing

*1: For input and output conditions for an argument, refer to Section 9.3.1.

1.5 Features

This section describes the features specific to the Universal model QCPU.

(1) High-speed processing more than ever

The processing time required for the basic instructions, floating-point operations, and accesses to the file register becomes shorter than the existing Q series CPU modules.

Use of a standard device register (Z)*1 achieves high-speed processing between register operations (transfer instruction).

*1: An index register used between register operations is designated as a standard device register.(☞ Section 9.6.2)

(2) Large-capacity file register

The file register whose capacity is 640K points at maximum (4086K points at maximum when a memory card is used)*2 can be set inside the CPU module.

*2: For the Q26UDHCPU and Q26UDEHCPU only

(3) Use of double-precision floating-point operation instructions

The double-precision floating-point operation instructions (64-bit instructions) are available as well as the existing single-precision floating-point operation instructions. (☞ Section 2.4.4)

This enables more accurate analog control and positioning control.

(4) Using the file register area as the data register and link register

The file register (ZR) area can be used as an pseudo extended area*3 of the data register (D) and link register (W). (☞ Section 9.8)

Programming using the extended data register (D) or extended link register (W) whose capacity is 640K points at maximum (4086K points at maximum when a memory card is used)*4 is available in addition to the internal user device.

*3: Extended areas of the data register (D) and link register (W) are called the extended data register (D) and extended link register (W), respectively.

*4: For the Q26UDHCPU and Q26UDEHCPU only




Figure 1.18 Extended data register (D) and extended link register (W)

(5) 32-bit index modification

Since the index modification range is expanded to 32 bits, index modification for the entire file register areas is possible. (☞ Section 9.6.1)




Figure 1.19 32-bit index modification

(6) Communication via the built-in Ethernet port of the CPU module

The Built-in Ethernet port QCPU can communicate with MELSOFT, GOT, and external devices using the built-in Ethernet port of the module.

☞ QnUCPU User's Manual (Communication via Built-in Ethernet Port)

(7) Communication with the personal computer and HMI by the serial communication function (☞ Section 6.23)

The Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU can communicate using the MELSEC communication protocol (hereafter, MC protocol) by connecting a RS-232 interface and personal computer or HMI.




Figure 1.20 Communication with the personal computer or HMI

Point

The CPU module functions are added at the update of serial number of CPU module or GX Developer version.
For functions added by the update, refer to Appendix 2.

1.6 Checking Serial Number and Function Version

The serial number and function version of the CPU module can be checked on the rating plate, on the front of the module, and on the System monitor screen in GX Developer.

(1) Checking on the rating plate

The rating plate is located on the side of the CPU module.




Figure 1.21 Rating plate

(2) Checking on the front of the module

The serial number on the rating plate is printed on the front (at the bottom) of the module. This applies only to the CPU module manufactured in mid-September, 2007 or later.




Figure 1.22 Front of the module

(3) Checking on the System monitor (Product Information List) screen

To open the screen for checking the serial number and function version, select [Diagnostics] → [System monitor] and click the Product Inf. List... button in GX Developer.

On the same screen, the serial number and function version of intelligent function modules can also be checked.




Figure 1.23 System monitor (Product Information List) screen

[Serial number, function version, and product number]

- The serial number of the module is displayed in the "Serial No." column.
- The function version of the module is displayed in the "Ver." column.
- The serial number (product number) printed on the rating plate of the module is displayed in the "Product No." column.
  Note that "-" is displayed for the module that does not support the product number display.

Point

The serial number displayed on the Product Information List screen of GX Developer may differ from that on the rating plate and on the front of the module.

- The serial number on the rating plate and on the front of the module indicates the management information of the product.
- The serial number displayed on the Product Information List screen indicates the functional information of the product.
  The functional information of the product will be updated when a function is added.

CHAPTER2 SEQUENCE PROGRAMS

2.1 Sequence Program Overview

(1) Definition

Sequence program is one of the programs that can be executed in the CPU module.
A sequence program consists of instructions, such as sequence instructions, basic instruction, and application instruction.




Figure 2.1 Sequence program

Remark

For the instructions used in sequence programs, refer to the following.
☞ QCPU Programming Manual (Common Instructions)


(2) Programming method

There are two programming modes for sequence programs.

- Ladder mode
- List mode

(a) Ladder mode

Ladder mode is a mode based on the concept of sequential control by relay circuits.
A program in ladder mode is similar to a schematic for a set of relay circuits. Programming in units of ladder blocks is available.
A ladder block, which starts from the left rail and ends at the right rail, is the minimum unit for operating sequence programs.



* X0 to X5: Input, Y20 to Y24: Output

Figure 2.2 Ladder mode

(b) List mode

List mode uses dedicated instructions for programming. The symbols, such as contacts and coils, used in ladder mode are replaced with dedicated instructions.
The following instructions are used for normally open contacts, normally closed contacts, and coils.

- Normally open contact ••• LD, AND, OR
- Normally closed contact ••• LDI, ANI, ORI
- Coil ••• OUT

Remark

There are two other types of programs that can be executed in the CPU module: SFC programs and ST programs.
For details, refer to the following.

☞ QCPU (Q Mode)/QnACPU Programming Manual (SFC)
☞ QCPU (Q Mode) Programming Manual (MELSAP-L)
☞ QCPU (Q Mode) Programming Manual (Structured Text)

(3) Sequence program operation

A sequence program is sequentially operated from the step 0 to the END or FEND instruction.
In ladder mode, a sequence program is operated from left to right and top to bottom in a ladder block.




Figure 2.3 Comparison between ladder mode and list mode

2.2 Sequence Program Configuration

Sequence programs are classified into the following three types.

- Main routine program
- Subroutine program
- Interrupt program




Figure 2.4 Sequence program classification

2.2.1 Main routine program

(1) Definition

Main routine program is an entire program from the step 0 to the END or FEND instruction.

(2) Program operation

A main routine program executes its operations from the step 0 to the END or FEND instruction and then performs END processing.

After the END processing, the program restarts its operations from the step 0.




Figure 2.5 Main routine program

Point

When multiple programs are executed, the main routine program operation after execution of the END or FEND instruction varies depending on the preset execution conditions. (☞ Section 2.3.1)

Remark

For details of the END and FEND instructions, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

2.2.2 Subroutine program

(1) Definition

Subroutine program is a program from a pointer (P□) to the RET instruction.
This program is executed only when it is called by a subroutine program call instruction (such as CALL(P), FCALL(P)) from a main routine program.

(2) Application

- Programming a program which is executed two or more times in one scan as a subroutine program can reduce the number of steps in the entire program.
- Programming a program which is executed only when a certain condition is satisfied as a subroutine program can shorten the scan time.

(3) Programming of subroutine programs

Create subroutine programs between the FEND and END instructions in the main routine program.




Figure 2.6 Programming location of subroutine programs

*1: The pointer numbers do not need to be specified in asending order.

Point

Subroutine programs can be managed as one separate program (stand-by type program).
(☞ Section 2.2.3)

Remark

Subroutine programs can be configured with the nesting.(☞ Section 9.9)

2.2.3 Interrupt program

(1) Definition

Interrupt program is a program from an interrupt pointer (I□) to the IRET instruction.




Figure 2.7 Interrupt program

The interrupt pointer (I□) number varies depending on the interrupt factor. (☞ Section 9.11)
When an interrupt factor occurs, the interrupt program of the interrupt pointer number corresponding to that factor is executed. (Interrupt programs are executed only when the corresponding interrupt factor occurs.)





Figure 2.8 Interrupt program execution timing

Point

Only one interrupt program can be created with one interrupt pointer number.



Remark

For details of the interrupt factors and interrupt pointers, refer to Section 9.11.

(2) Programming of interrupt programs

Create interrupt programs between the FEND and END instructions in the main routine program.




Figure 2.9 Programming location of interrupt programs

*1: The pointer numbers do not need to be specified in ascending order.

Point

Interrupt programs can be managed as one separate program (stand-by type program). (☞ Section 2.3.3)

(a) Before executing an interrupt program

Before executing the interrupt programs of the interrupt pointers I0 to I15, I28 to I31, I45, and I50 to I255, enable interrupts with the EI instruction.

Remark

For details of the EI instruction, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

(b) Restrictions on programming

1) PLS and PLF instructions

The PLS and PLF instructions perform off processing in the next scan of which the instruction is executed.

Therefore, the device which is turned on by the instruction remains on until the same instruction is reexecuted.




Figure 2.10 Device turned on by the PLS instruction in the interrupt program

2) EI and DI instructions

During execution of an interrupt program, interrupts are disabled (DI) so that any other interrupt processing will not be executed.

Do not execute the EI or DI instruction during interrupt program execution.

3) Timer (T) and counter (C)

Do not use the timer (T) and counter (C) in interrupt programs.

If more than one interrupts occur in one scan, the timer (T) and counter (C) in the interrupt program cannot measure the time correctly.

The OUT C□ instruction status causes the counter (C) measure the number of interrupts incorrectly.

4) Instructions not available in interrupt programs

Refer to sections corresponding to each instruction in the following.

☞ QCPU Programming Manual (Common Instructions)

(3) Operation when an interrupt factor occurs

There are restrictions on interrupt programs depending on the interrupt factor occurrence timing.

(a) When an interrupt factor occurs before the interrupt program execution status is enabled

The CPU module stores the interrupt factor occurred.

As soon as the interrupt program execution status is enabled, the CPU module executes the interrupt program corresponding to the stored interrupt factor.




Figure 2.11 When an interrupt factor occurs before interrupts are enabled

When the same interrupt factor occurs more than one time before the interrupt program execution status is enabled, the interrupt factors of I0 to I15, I28 to I31, I45, I50 to I255, and fixed scan execution type programs are stored only once.

Note that all interrupt factors occurred are discarded if they are masked by the IMASK instruction.

Remark

For details of the IMASK instruction, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

(b) When an interrupt factor occurs in the STOP or PAUSE status

The CPU module executes the interrupt program as soon as the interrupt program execution status is enabled after the CPU module status is changed to RUN.




Figure 2.12 When an interrupt factor occurs in the STOP or PAUSE status

(c) When multiple interrupt factors occur simultaneously in the interrupt program execution enabled status

The interrupt programs are executed in the order of interrupt pointers (I□) with high priority. (☞ Section 9.11.1)

Other interrupt programs have to wait until processing of the interrupt program being executed is completed.




Figure 2.13 When multiple interrupt factors occur simultaneously

(d) When the same interrupt factor as that of the interrupt program being executed occurs

When the same interrupt factor as that of the interrupt program being executed occurs more than one time before completion of interrupt program processing, the interrupt factors of I0 to I15, I45, and I50 to I255 are stored only once, and then the interrupt program corresponding to each stored interrupt factor is executed after completion of current interrupt program execution.

The interrupt factors of I28 to I31 and fixed scan execution type programs are all stored, and then all the interrupt programs corresponding to interrupt factors are executed after completion of current interrupt program execution.

(e) When an interrupt factor occurs during link refresh

The link refresh is suspended and an interrupt program is executed.

Even if the Block data assurance per station setting is enabled in the CC-Link IE controller network or MELSECNET/H network, this setting does not work when a device set as a refresh target is used in the interrupt program.

In the interrupt program, do not use any refresh target device.




Figure 2.14 When an interrupt factor occurs during link refresh

Remark

For the Block data assurance per station setting, refer to the following.

Reference manual for each network module

(f) Interrupt during END processing

When the constant scan function is used and an interrupt factor occurs during the waiting time in END processing, an interrupt program corresponding to the interrupt factor is executed.

(g) When an interrupt factor occurs during access to another module

When an interrupt factor occurs during access to another module (during service processing or instruction processing), the interrupt program becomes standby status until the service processing or the instruction in execution is completed.

To shorten the wait time of the interrupt, reduce the amount of data that access to other modules.

(4) Processing at program execution type change

When the program execution type is changed from the scan execution type to the interrupt, the CPU module saves and restores the following data. (☞ Section 9.6.3)

- Data in the index register
- File register block number

Whether to save and restore the data above can be set in the PLC parameter dialog box.
If the data is not saved or restored, the overhead time of the corresponding interrupt program can be shortened. (☞ Section 10.1.2)

(5) Restrictions

(a) When the same device is used

During execution of an instruction in a main routine program, an interrupt program may be executed, suspending the processing of the instruction being executed.
If the same device is used for the main routine program and interrupt program, device data may become inconsistent. In this case, take the following measures to prevent device data inconsistency.

1) Moving device data to another device

Do not directly specify the device where the data is written by the interrupt program in the main routine program. Use the data in another device by moving the data with the transfer instruction.

2) Disabling interrupts with the DI instruction

Disable interrupts with the DI instruction if instructions that may cause inconvenience for the main routine program are used.
However, interrupts do not occur during access to the device of the corresponding argument of the instruction. For this reason, data inconsistency will not occur in units of arguments.

2.3 Settings When Program is Divided

When one sequence program is divided into multiple programs, execution conditions, such as executing a program only once at start-up or executing a program at fixed intervals, can be set for each program.

(1) Control by multiple programs dividing one program

The CPU module can store multiple programs divided on the basis of each control unit.
This enables programming of one sequence program by two or more designers.




Figure 2.15 Control by multiple programs

(2) Settings required for execution of multiple programs

To execute multiple programs in the CPU module, names (file names) and execution conditions of the programs must be set.
Set them in the Program tab of the PLC parameter dialog box.




Figure 2.16 Program setting

(a) Program name

Enter the name (file name) of the program to be executed in the CPU module.

(b) Execute type

Select an execution type of the program set under "Program name".

The CPU module executes programs whose execution type has been set here according to the setting order.

1) Initial execution type ("Initial")

This program is executed only once when the CPU module is powered on or its status is switched from STOP to RUN. (☞ Section 2.3.1)

2) Scan execution type ("Scan")

This program is executed once in every scan, starting in the next scan of which the initial execution type program is executed and later. (☞ Section 2.3.2)

3) Stand-by type ("Wait")

This program is executed only when its execution is requested. (☞ Section 2.3.3)

4) Fixed scan execution type ("Fixed scan")

This program is executed at time intervals specified with fixed scan interval and unit. (☞ Section 2.3.4)

- Fixed scan interval ("Fixed scan interval")

  Enter the execution interval of fixed scan execution type program.

  The setting range varies depending on the setting unit.

  •When the unit is "ms" : 0.5 to 999.5ms (in increments of 0.5ms)

  •When the unit is "s" : 1 to 60s (in increments of 1s)

- Unit ("In unit")

  Select the unit ("ms" or "s") of the fixed scan interval.

(c) File usability setting Note2.1

For each program, determine whether to use the file specified for the local device in the PLC file tab of the PLC parameter dialog box.




Figure 2.17 File usability setting

The default is set to "Use PLC file setting".
When "Not used" is selected, data in the local device is not saved or restored when the program execution type is changed.

Note2.1 Universal

The Q00UJCPU does not support the file usability setting.
When using the file usability setting for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer. (Appendix 2)

(3) Program sequence in the CPU module

Figure 2.18 shows the program sequence after the CPU module is powered on or its operating status is changed from STOP to RUN.




Figure 2.18 Program sequence

Point

Use initial execution type program, stand-by type program, and fixed scan execution type program as required.

2.3.1 Initial execution type program

(1) Definition

Initial execution type program is executed only once when the CPU module is powered on or its operating status is changed from STOP to RUN.

This type of program can be used as a program that need not be executed from the next scan and later once it is executed, like initial processing to an intelligent function module.




Figure 2.19 When processing performed only once is separated as an initial execution type program

(2) Processing

(a) Execution order

After completion of all the initial execution type program execution, END processing is performed.

In the next scan and later, scan execution type programs are executed.




Figure 2.20 Execution order of the initial execution type programs

(b) Initial scan time

Initial scan time is the execution time of initial execution type program.

When multiple programs are executed, the initial scan time will be the time required for completing all the initial execution type program execution.

1) Initial scan time storage location

The CPU module measures the initial scan time and stores it into the special register (SD522 and SD523).

The initial scan time can be checked by monitoring SD522 and SD523.




Figure 2.21 Initial scan time storage location

Example If the stored values in SD522 and SD523 are 3 and 400 respectively, the initial scan time is 3.4ms.

2) Accuracy and measurement of the initial scan time

Accuracy of the initial scan time stored in the special register is ±0.1ms.

Even if the WDT instruction (instruction that resets the watchdog timer) is executed in the sequence program, the measurement of the initial scan time continues.

3) Execution of an interrupt program or fixed scan execution type program

When an interrupt program or fixed scan execution type program is executed before completion of the initial execution type program execution, the execution time of the executed program will be added to the initial scan time.

(3) Precautions on programming

Initial execution type programs do not support the instructions that require several scans (instructions with completion device).

Example SEND, RECV, and similar instructions

(4) Initial execution monitoring time setting

Initial execution monitoring time is a timer for monitoring initial scan time.
Set a time value in the PLC RAS tab of the PLC parameter dialog box.
The setting range is 10 to 2000ms (in increments of 10ms).
No default value is set.




Figure 2.22 PLC RAS setting (Initial execution monitoring time)

(a) When the initial scan time exceeds the preset initial execution monitoring time

"WDT ERROR" occurs and the CPU module stops program operations.
Set a time value so that the initial execution monitoring time becomes longer than actual initial scan time.

Point

An error of the measurement value is 10ms for the initial execution monitoring time setting.
If the initial execution monitoring time (t) parameter is set to 10ms, "WDT ERROR" occurs when actual initial scan time is within the range of 10ms < t < 20ms.

2.3.2 Scan execution type program

(1) Definition

Scan execution type program is executed once in every scan, starting in the next scan of which the initial execution type program is executed and later.




Figure 2.23 Execution order of the scan execution type programs

(2) Processing

When multiple scan execution type programs are executed, the scan time will be the time required for completing all the scan execution type program execution.

If an interrupt program or fixed scan execution type program is executed, execution time of the executed program will be added to the scan time.

2.3.3 Stand-by type program

(1) Definition

Stand-by type program is executed only when its execution is requested.
This type of program can be changed to any desired execution type by a sequence program instruction.

(2) Application

(a) Program library

Stand-by type program is used as a program library, a collection of subroutine programs and/or interrupt programs, and managed separately from a main routine program.
Multiple subroutine programs and/or interrupt programs can be created and managed in a single stand-by type program.




Figure 2.24 Program library using a stand-by type program

(b) Program type change

Stand-by type program is used to create and store programs available in all systems. Only required programs will be executed.
For example, a program preset as a stand-by ("Wait") type program in the PLC parameter dialog box can be changed to a scan execution type program and executed in the sequence program.

(3) Execution method

Execute stand-by type programs in either of the following methods.

- Create subroutine and/or interrupt programs in a stand-by type program and call them using a pointer or when an interrupt occurs.
- Change a stand-by type program to any other execution type using instructions.

(a) Creating subroutine and/or interrupt programs in a single stand-by type program

When creating subroutine and/or interrupt programs in a single stand-by type program, start the program from the step 0.

The FEND instruction used in creation of a subroutine or interrupt program is not required after a main routine program.




Figure 2.25 Creating subroutine programs in a single stand-by type program

1) Executing a subroutine program and interrupt program in a stand-by type program

After execution of the stand-by type program, the CPU module reexecutes the program that called a program in the stand-by type program.

Figure 2.26 shows the operation when the subroutine and interrupt programs in the stand-by type program are executed.




Figure 2.26 Operation when the subroutine and interrupt programs in the stand-by type program are executed

Point

- For restrictions on programming of subroutine and interrupt programs, refer to the following.
  - Subroutine program: Section 2.2.2
  - Interrupt program: Section 2.3.2

- Use common pointers. (Section 9.10.2)
  If local pointers are used, subroutine programs in a stand-by type program cannot be executed from any other program.


(b) Changing the program execution type using instructions

Use the PSCAN, PSTOP, or POFF instruction to change a program execution type.

1) Changing the execution type (in the case of scan execution type program)

- Set the programs "ABC" and "GHI" as scan execution type programs and the program "DEF" as a stand-by type program.
- When the condition is established (the internal relay (M0) in Figure 2.27 turns on), the program "DEF" is changed to a scan execution type program and the program "ABC" to a stand-by type program.

[Before execution of the PSCAN and PSTOP instructions]



[After execution of the PSCAN and PSTOP instructions]




Figure 2.27 Example of changing the execution type (in the case of scan execution type program)

2) Execution type change timing

The program execution type is changed in END processing.

Therefore, the execution type will not be changed in the middle of program execution.

If different types are set to the same program in the same scan, the program will be changed to the type specified by the last instruction executed.




Figure 2.28 Execution type change timing

*1: The programs "GHI" and "DEF" are executed in the order set in the Program tab of the PLC parameter dialog box.

(4) Precautions on programming

(a) Unavailable devices

Unavailable devices depend on the program type (subroutine program or interrupt program) or the execution type changed by an instruction.

(b) Use of local devices

For execution of a subroutine program using a local device, refer to Section 9.14.2.

2.3.4 Fixed scan execution type program

(1) Definition

Fixed scan execution type program is a program executed at specified time intervals.
This type of programs, unlike interrupt programs, can be interrupted in units of files without interrupt pointers or the IRET instruction.
For the restrictions on programming, refer to Section 2.2.3(2)(b).
(The restrictions on programming are the same as those for interrupt programs.)




Figure 2.29 Execution of a fixed scan execution type program

Point

To execute a fixed scan execution type program, execute the EI instruction in the initial execution type program or scan execution type program to enable interrupts.

(2) Processing

(a) When two or more fixed scan execution type programs exist

Each fixed scan execution type program is executed at specified time intervals.
If two or more fixed scan execution type programs reach the specified time at the same timing, programs will be executed in ascending order of the numbers set in the Program tab of the PLC parameter dialog box.

(b) When both fixed scan execution type program and interrupt program exist

When a fixed scan execution type program and an interrupt program (I28 to I31) reach the specified time at the same timing, the interrupt program will be given priority.

(c) When the execution condition is established during link refresh

The link refresh is suspended and a fixed scan execution type program is executed.
Even if the Block data assurance per station setting is enabled in the CC-Link IE controller network or MELSECNET/H network, this setting does not work when a device set as a refresh target is used in the fixed scan execution type program.
In the fixed scan execution type program, do not use any refresh target device.




Figure 2.30 When the execution condition is established during link refresh

Remark

For the Block data assurance per station setting, refer to the following.
☞ Reference manual for each network module

(d) When the execution condition is established during END processing

When the execution condition is established during the waiting time of the constant scan execution or the END instruction, a fixed scan execution type program is executed.




Figure 2.31 When the execution condition is established during the waiting time

(3) Processing at program execution type change

For how to save and restore data in the index register when the program execution type is changed, refer to Section 2.2.3(4). (The method is the same as that for interrupt programs.)

(4) Precautions

(a) Execution interval of a fixed scan execution type program

Execution interval of a fixed scan execution type program may increase from the preset interval depending on the time set for disabling interrupts by the DI instruction (interrupt disabled time). If the interrupt disabled time by the DI instruction becomes too long, use an interrupt program by fixed scan interrupt (I28 to I31) instead of a fixed scan execution type program.

Highest common factor of fixed scan execution interval *1 < Interrupt disabled time ••• Condition 1)

*1: This is the highest common factor of execution interval set to multiple fixed scan execution type programs

When the condition 1) is satisfied, the actual execution interval of a fixed scan execution type program may increase from the preset interval by the time shown in the expression below.

$$\frac{\text{Interrupt disabled time}}{\text{Highst common factor of scan execution interval}} \times \text{Fixed scan execution interval set to the corresponding program}$$

The following shows an example of the increase in execution time of a fixed scan execution type program.

Example

- Fixed scan execution interval ••• 10ms, 5ms, 1ms, 0.5ms
- Highest common factor of fixed scan execution interval ••• 0.5ms
- Interrupt disabled time (DI) ••• 5ms
  (Interrupt enabled time (EI) ••• less than 0.5ms)

With the settings above, the condition 1) will be 0.5ms < 5ms.




Figure 2.32 Program execution and interrupt enabled/disabled status

The execution time of a fixed scan execution type program whose execution interval is set to 10ms increases 100ms (5 ÷ 0.5 × 10 = 100) at the most.

2.3.5 Changing the program execution type

(1) Changing the execution type using instructions

(a) Instructions used to change the execution type

The execution type of sequence programs can be changed using instructions even during execution.

Use the PSCAN, PSTOP, or POFF instruction to change the execution type.




Figure 2.33 Pattern of execution type change

Table2.1 Timing of execution type change

Execution type before change	Instruction		
	PSCAN	PSTOP	POFF
Scan execution type	Remains unchanged.	Changes to the stand-by type.	Turns off outputs in the next scan. Changes to the stand-by type in two scans later.
Initial execution type	Changes to the scan execution type.	Changes to the stand-by type.	Turns off outputs in the next scan. Changes to the stand-by type in two scans later.
Stand-by type	Changes to the scan execution type.	Remains unchanged.	No processing
Fixed scan execution type	Changes to the scan execution type.	Changes to the stand-by type.	Turns off outputs in the next scan. Changes to the stand-by type in two scans later.

Point

Once the fixed scan execution type program is changed to another execution type, the type cannot be returned to the fixed scan execution type.

(b) Execution type change example

In a control program, a stand-by type program matching the preset condition is changed to a scan execution type program in the course of program execution.

An unused scan execution type program can also be changed to a stand-by type program.

Figure 2.34 shows the case where the execution type of the stand-by type programs "ABC", "DEF", "GHI", and "JKL" are changed in the control program.




Figure 2.34 Execution type change example

(2) Changing the execution type from the Program monitor list screen

The execution type of programs can be changed on the screen opened by selecting [Online] → [Monitor] → [Program monitor list]. (☞ Section 6.13.1)

2.4 Data Used in Sequence Programs

The CPU module represents numeric and alphabetic data using two symbols (states): 0 (off) and 1 (on). Data represented using these two symbols is called binary number (BIN).

The CPU module can also use hexadecimal (HEX) (each hexadecimal digit represents four binary bits), binary-coded decimal (BCD), or real numbers.

Table2.2 shows the numeric representations of BIN, HEX, BCD, and DEC (decimal).

Table2.2 Numeric representations of BIN, HEX,BCD,and DEC

DEC (Decimal)	HEX (Hexadecimal)	BIN (Binary)				BCD (Binary-coded decimal)			
0	0				0				0
1	1				1				1
2	2				10				10
3	3				11				11
.	.				.				.
.	.				.				.
.	.				.				.
9	9				1001				1001
10	A				1010			1	0000
11	B				1011			1	0001
12	C				1100			1	0010
13	D				1101			1	0011
14	E				1110			1	0100
15	F				1111			1	0101
16	10			1	0000			1	0110
17	11			1	0001			1	0111
.	.				.				.
.	.				.				.
.	.				.				.
47	2F			10	1111			100	0111
.	.								
.	.								
.	.								
32766	7FFE	0111	1111	1111	1110	-			
32767	7FFF	0111	1111	1111	1111	-			
-32768	8000	1000	0000	0000	0000	1000	0000	0000	0000
-32767	8001	1000	0000	0000	0001	1000	0000	0000	0001
.	.								
.	.								
.	.								
-2	FFFE	1111	1111	1111	1110	-			
-1	FFFF	1111	1111	1111	1111	-			

(1) Inputting numeric values externally to the CPU module

When setting a numeric value to the CPU module externally using a digital switch, BCD (binary-coded decimal) can be used as DEC (decimal) by the method given in (b).

(a) Numeric values used inside the CPU module

The CPU module performs program operations in binary.

If the value set in binary-coded decimal is used without conversion, the CPU module performs program operations regarding the set value as binary.

Therefore, the program operations are not performed correctly. (☞ (b) below)

(b) Using any numeric data regardless of the data type

To convert the data set in binary-coded decimal into binary, which can be used in the CPU module, use the BIN instruction.

The BIN instruction allows the CPU module to use any external numeric data regardless of the data type.




Figure 2.35 Inputting data from a digital switch to the CPU module

Remark

For details of the BIN instruction, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

(2) Outputting numeric values externally from the CPU module

When externally displaying numeric values operated in the CPU module, a digital indicator can be used.

(a) Outputting numeric values

The CPU module performs program operations in binary.

If the binary values used in the CPU module are output to a digital indicator, the indicator does not show the values correctly.

To convert the data set in binary into binary-coded decimal, which can be used in the external indicator, use the BCD instruction.

The BCD instruction allows the external indicator to display values in decimal.




Figure 2.36 Display of operation results in the CPU module by a digital indicator

Remark

For details of the BCD instruction, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

2.4.1 BIN (Binary Code)

(1) Definition

Binary is a numeral system that represents numeric values using two symbols, 0 (off) and 1 (on). Decimal notation uses the symbols 0 through 9. When the symbols for the first digit are exhausted (a digit reaches 9), the next-higher digit (to the left) is incremented, and counting starts over at 0.
In binary notation, only the symbols 0 and 1 are used. After a digit reaches 1, an increment resets it to 0 and the next digit (to the left) is incremented. (The numeric value becomes 10, which is equal to 2 in decimal.)
Table2.3 shows the numeric representations in BIN and DEC.

Table2.3 Numeric representations in BIN and DEC

DEC (Decimal)	BIN (Binary)	
0	0000	
1	0001	
2	0010	Carry
3	0011	
4	0100	Carry
5	0101	
6	0110	
7	0111	
8	1000	Carry
9	1001	
10	1010	
11	1011	

(2) Numeric representation in BIN

(a) Bit configuration of BIN used in the CPU module

Each register (such as the data register, link register) in the CPU module consists of 16 bits.

(b) Numeric data available in the CPU module

Each register in the CPU module can store numeric values in the range of -32768 to 32767.

Figure 2.37 shows the numeric representations for registers.




Figure 2.37 Numeric representations for registers in the CPU module

Point

A numeric value of 2^n is assigned for each bit of registers.
Note that an unsigned binary number (0 to 65535) cannot be used in the most significant bit position since the most significant bit is a sign bit.

- The most significant bit is "0"...Positive
- The most significant bit is "1"...Negative

2.4.2 HEX (Hexadecimal)

(1) Definition

Hexadecimal (HEX) is a numeral system that represents four binary bits as one digit.
With four binary bits, sixteen different numeric values, 0 to 15, can be represented.
Hexadecimal notation uses 16 symbols to represent numeric values 0 to 15 in one digit, the symbols 0 to 9 to represent values zero to nine, and AH to FH to represent values ten to fifteen. After a digit reaches FH, the next-higher digit (to the left) is incremented.
ï\2.4 shows the numeric representations in BIN, HEX, and DEC.

Table2.4 Numeric representations in BIN,HEX,and DEC

DEC (Decimal)	HEX (Hexadecimal)	BIN (Binary)	
0	0		0
1	1		1
2	2		10
3	3		11
.	.		.
.	.		.
.	.		.
9	9		1001
10	A		1010
11	B		1011
12	C		1100
13	D		1101
14	E		1110
15	F		1111
16	10	1	0000
17	11	1	0001
.	.		.
.	.		.
.	.		.
47	2F	10	1111

Carry

(2) Numeric representation in HEX

Each register (such as the data register, link register) in the CPU module consists of 16 bits.
In the 16-bit configuration register, 0 to FFFFH can be specified in hexadecimal.

2.4.3 BCD (Binary-coded Decimal)

(1) Definition

BCD is a numeral system that uses four binary bits to represent the decimal digits 0 through 9.
The difference from hexadecimal is that BCD does not use letters A to F.
Table2.5 shows the numeric representations in BIN, BCD, and DEC.

Table2.5 Numeric representations in BIN,BCD,and DEC

DEC (Decimal)	BIN (Binary)	BCD (Binary-coded Decimal)	
0	0000		0
1	0001		1
2	0010		10
3	0011		11
4	0100		100
5	0101		101
6	0110		110
7	0111		111
8	1000		1000
9	1001		1001
10	1010	1	0000
11	1011	1	0001
12	1100	1	0010



(2) Numeric representation in BCD

Each register (such as the data register, link register) in the CPU module consists of 16 bits.
Therefore, the numeric values can be stored in each register are those in the range between 0 to 9999 in BCD.

2.4.4 Real number (Floating-point data)

There are two types of real number data: single-precision floating-point data and double-precision floating-point data.

(1) Single-precision floating-point data

(a) Internal representation

Internal representation of real numbers used in the CPU module is given below.
Real number data can be represented as follows, using two word devices.

[Sign] 1. [Mantissa] × $2^{[Exponent]}$

The bit configuration and the meaning of each bit are described below.




Figure 2.38 Bit configuration of real number data

1) Sign

The most significant bit, b31, is the sign bit.

0: Positive

1: Negative

2) Exponent

The 8 bits, b23 to b30, represent the excess n of 2^n.

The following shows the excess n according to the binary values in b23 to b30.

b23 to b30	FFH	FEH	FDH		81H	80H	7FH	7EH		02H	01H	00H
n	Not used	127	126		2	1	0	-1		-125	-126	Not used

Figure 2.39 Relation between the exponent and excess n

3) Mantissa

Each of the 23 bits, b0 to b22, represents the "XXXXXX..." portion when the data is represented in binary, "1.XXXXXX...".

(b) Calculation example


Calculation examples are shown below. (The "X" in (nnnnnn) $_X$ indicates the numeral system used.)

1) Storing "10"

$(10)_{10} \rightarrow (1010)_2 \rightarrow (1.010000..... \times 2^3)_2$

Sign: Positive → 0
Exponent: 3 → 82H → $(10000010)_2$
Mantissa: $(010\ 00000\ 00000\ 00000\ 00000)_2$

In this case, the value will be encoded as 41200000H.




2) Storing "0.75"

$(0.75)_{10} \rightarrow (0.11)_2 \rightarrow (1.100..... \times 2^{-1})_2$

Sign: Positive → 0
Exponent: -1 → 7EH → $(01111110)_2$
Mantissa: $(100\ 00000\ 00000\ 00000\ 00000)_2$


In this case, the value will be encoded as 3F400000H.



Point

Values after the decimal point (in binary) is calculated as follows.

Example $(0.1101)_2$



$(0.1101)_2 = 2^{-1} + 2^{-2} + 2^{-4} = 0.5 + 0.25 + 0.0625 = (0.8125)_{10}$

(2) Double-precision floating-point data

(a) Internal representation

Real number data used in the CPU module is internally represented as follows, using four word devices.

[Sign] 1. [Mantissa] × $2^{[Exponent]}$

The bit configuration and the meaning of each bit are described below.




Figure 2.40 Bit configuration of real number data

1) Sign

The most significant bit, b63, is the sign bit.

0: Positive

1: Negative

2) Exponent

The 11 bits, b52 to b62, represent the excess n of 2^n.

The following shows the excess n according to the binary values in b52 to b62.

b52 to b62	7FFH	7FEH	7FDH		400H	3FFH	3FEH	3FDH	3FCH		02H	01H	00H
n	Not used	1023	1022		2	1	0	-1	-2		-1021	-1022	Not used

Figure 2.41 Relation between the exponent and excess n

3) Mantissa

Each of the 52 bits, b0 to b51, represents the "XXXXXX..." portion when the data is represented in binary, "1.XXXXXX...".

(b) Calculation example

Calculation examples are shown below. (The "X" in (nnnnnn) $_X$ indicates the numeral system used.)

1) Storing "10"


$(10)_{10} \rightarrow (1010)_2 \rightarrow (1.010000..... \times 2^3)_2$

Sign: Positive → 0

Exponent: 3 → 401H → $(100\ 0000\ 0001)_2$

Mantissa: $(0100\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000)_2$

In this case, the value will be encoded as 4014000000000000H.



2) Storing "0.75"


$(0.75)_{10} \rightarrow (0.11)_2 \rightarrow (1.100..... \times 2^{-1})_2$

Sign: Positive → 0

Exponent: -1 → 3FDH → $(011\ 1111\ 1101)_2$

Mantissa: $(1000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000\ 0000)_2$

In this case, the value will be encoded as 3FD8000000000000H.



Point

Values after the decimal point (in binary) is calculated as follows.

Example $(0.1101)_2$

0.	1	1	0	1
	↑	↑	↑	↑
	The bit represents 2^{-1}	The bit represents 2^{-2}	The bit represents 2^{-3}	The bit represents 2^{-4}

$(0.1101)_2 = 2^{-1} + 2^{-2} + 2^{-4} = 0.5 + 0.25 + 0.0625 = (0.8125)_{10}$

2.4.5 Character string data

(1) Definition

The CPU module uses ASCII code data.

(2) ASCII code character strings

Table2.6 lists the ASCII code character strings.

"00H" (NULL code) in Table2.6 is used at the end of a character string as a terminator.

Table2.6 ASCII code character strings

b8	b7	b6	b5	b4	b3	b2	b1	Low / Column	0	1	2	3	4	5	6	7	8	9	A	B	C	D	E	F
				0	0	0	0	0	NULL		(SP)	0	@	P	`	p								
				0	0	0	1	1			!	1	A	Q	a	q								
				0	0	1	0	2			"	2	B	R	b	r								
				0	0	1	1	3			#	3	C	S	c	s								
				0	1	0	0	4			$	4	D	T	d	t								
				0	1	0	1	5			%	5	E	U	e	u								
				0	1	1	0	6			&	6	F	V	f	v								
				0	1	1	1	7			'	7	G	W	g	w								
				1	0	0	0	8			(	8	H	X	h	x								
				1	0	0	1	9			)	9	I	Y	i	y								
				1	0	1	0	A			*	:	J	Z	j	z								
				1	0	1	1	B			+	;	K	[	k	{								
				1	1	0	0	C			(Comma) ,	<	L	\	l	|								
				1	1	0	1	D			(Minus) -	=	M	]	m	}								
				1	1	1	0	E			(Period) z	>	N	^	n	¯								
				1	1	1	1	F			/	?	O	(Under line) _	o									

CHAPTER3 CPU MODULE OPERATION

This chapter describes operation of the CPU module.

3.1 Initial Processing

The CPU module performs preprocessing required for sequence program operations.
The preprocessing is executed only once when any of the operations described in Table3.1 is performed to the CPU module.
When initial processing is completed, the CPU module will be placed in the operation status set by the RUN/STOP/RESET switch. (☞ Section 3.5)

Table3.1 Initial processing list


Initial processing item	CPU module status		
	Powered-on	Reset	Changed from STOP to RUN *1
The I/O module initialization	○	○	×
Boot from a memory card	○	○	×
PLC parameter check	○	○	○
Multiple CPU system parameter consistency check	○	○	○
Initialization of devices outside the latch range (bit device: off, word device: 0)	○	○	×
Automatic I/O number assignment of mounted modules	○	○	○
CC-Link IE controller network and MELSECNET/H information setting	○	○	×
Intelligent function module switch setting	○	○	×
CC-Link information setting	○	○	×
Ethernet information setting	○	○	×
Initial device value setting	○	○	○
Serial communication function setting	○	○	×

○ : Performed, × : Not performed

*1: The operation indicates that the status is changed back to RUN without resetting the module after any parameter or program was changed in the STOP status.
(The RUN/STOP/RESET switch is set from STOP to RUN (the RUN LED will flash), then back to STOP and to RUN again.)
Note that the PLS □ P instruction (instruction for pulse conversion) may not be executed properly with the above operation. This is because the previous information may not be inherited depending on the program changes.

Point

If any parameter or program is changed in the STOP status, reset the CPU module using the RUN/STOP/RESET switch.



3.2 I/O Refresh (Refresh Processing with Input/Output Modules)

The CPU module performs the following before sequence program operations.

- On/off data input from the input module or intelligent function module to the CPU module
- On/off data output from the CPU module to the output module or intelligent function module

When the constant scan time is set, I/O refresh is performed after the constant scan waiting time has elapsed. (I/O refresh is performed at each constant scan cycle.)

3.3 Program Operation

The CPU module sequentially executes the program stored in the module from the step 0 to the END or FEND instruction.(☞ CHAPTER 2)

3.4 END Processing

The CPU module performs refresh processing with network modules and communication with external devices.
END processing includes the following.

- Refresh with network modules (☞ CHAPTER 10)
- Auto refresh with intelligent function module (☞ Section 7.1.1)
- Intelligent function module dedicated instruction processing (☞ CHAPTER 10)
- Device data latch processing (☞ Section 6.3, CHAPTER 10)
- Service processing (☞ Section 6.24, CHAPTER 10)
- Watchdog timer reset (☞ Section 6.16)
- Auto refresh between multiple CPU modules (☞ QCPU User's Manual (Multiple CPU System))
- Device data collection using the sampling trace function (only when trace point is set to every scan (after END instruction execution)) (☞ Section 6.14)
- Self-diagnostics processing (☞ Section 6.17)
- Special relay/special register value setting (only for those that should be set during END processing) (☞ CHAPTER 12)

Point

When the constant scan function (☞ Section 6.2) is used, the results of processing performed in END processing are held for the period between after END processing is completed and until the next scan starts.

3.5 Operation Processing in the RUN,STOP, or PAUSE Status

There are three types of operating status of the CPU module.

- RUN status
- STOP status
- PAUSE status

This section describes program operation processing in the CPU module based on its operating status.

(1) Operation processing in the RUN status

RUN status is a status where sequence program operations are repeatedly performed in a loop between the step 0 and the END (FEND) instruction.

(a) Output status when entering the RUN status

The CPU module outputs either of the following according to the output mode parameter setting when its status is changed to RUN. (☞ Section 6.4)

- Output (Y) status saved immediately before entering the STOP status
- Result of operations performed for one scan after entering the RUN status

(b) Processing time required before operations

The processing time required for the CPU module to start sequence program operations after its operating status is changed from STOP to RUN varies depending on the system configuration and/or parameter settings. (It takes one to three seconds normally.)

(2) Operation processing in the STOP status

STOP status is a status where sequence program operations are stopped by the RUN/STOP/RESET switch or the remote STOP function (☞ Section 6.6.1).
The CPU module status will be changed to STOP when a stop error occurs.

(a) Output status when entering the STOP status

When entering the STOP status, the CPU module saves data in the output (Y) and turns off all outputs.
The device memory other than that of the output (Y) will be held.

(3) Operation processing in the PAUSE status

PAUSE status is a status where sequence program operations are stopped by the remote PAUSE function (☞ Section 6.6.2) after operations are performed for one scan, holding the output and device memory status.

(4) Operation processing in the CPU module when switch operation is performed

Table3.2 Operation processing when switch operation is performed

RUN/STOP status	CPU module operation processing			
	Sequence program operation processing	External output	Device memory	
			M,L,S,T,C,D	Y
RUN → STOP	The CPU module executes the program until the END instruction and stops.	The CPU module saves the output (Y) status immediately before its status is changed to STOP and turns off all the outputs.	The CPU module holds the device memory status immediately before its status is changed to STOP.	The CPU module saves the output (Y) status immediately before its status is changed to STOP and turns off all the outputs.
STOP → RUN	The CPU module executes the program from the step 0.	The CPU module outputs data according to the output mode parameter setting. (☞ Section 6.4)	The CPU module holds the device memory status immediately before its status is changed to STOP. Note that the CPU module uses initial device values if those values are preset. Local device data are cleared.	The CPU module outputs data according to the output mode parameter setting. (☞ Section 6.4)

Point

The CPU module performs the following in any of the RUN, STOP, or PAUSE status.

- Refresh processing with I/O modules
- Refresh processing with network modules
- Auto refresh processing with intelligent function modules
- Self-diagnostics processing
- Service processing
- Intelligent function module dedicated instruction processing (completion processing only)
- Operation processing of Multiple CPU high speed transmission function

Even if the CPU module is in the STOP or PAUSE status, the following operations can be executed.

- I/O monitor or test operation from GX Developer
- Read/write data from/to external devices using the MC protocol
- Communication with other stations using CC-Link IE controller network or MELSECNET/H
- Communication with CC-Link remote stations

3.6 Operation Processing during Momentary Power Failure

When the input voltage supplied to the power supply module drops below the specified range, the CPU module detects a momentary power failure and performs the following operation.

(1) When a momentary power failure occurs for a period shorter than the allowable power failure time

The CPU module registers error data and suspends the operation processing.
The CPU module, however, continues measurement in the timer device and holds the output status.

(a) When resume start is specified for the SFC program

Data in the system is saved.

(b) When power is recovered after a momentary power failure

The CPU module restarts its operation processing.

(c) Watchdog timer (WDT) measurement during a momentary power failure

Even if operation processing is suspended due to a momentary power failure, the CPU module continues the measurement of the watchdog timer (WDT).
For example, when the WDT setting of PLC parameter is 200ms and the scan time is 190ms, if a momentary power failure occurs for 15ms, "WDT ERROR" occurs.




Figure 3.1 Operation processing during a momentary power failure

(2) When a momentary power failure occurs for a period longer than the allowable power failure tim

The CPU module starts its operations initially.
Operation processing will be the same as that when any of the following is performed.

- Programmable controller is powered on.
- The CPU module is reset by the RUN/STOP/RESET switch.
- The CPU module is reset by GX Developer (the remote reset operation).

Point

- In a redundant power supply system, the CPU module does not suspend its operations if a momentary power failure occurs in either of the power supply modules. However, if a momentary power failure occurs under the condition where the power is supplied to only one of the power supply modules, operations are suspended.

- Information of a momentary power failure occurred in a redundant power supply system will be stored in SM1782 to SM1783 and SD1782 to SD1783.
  On the other hand, information of a momentary power failure occurred in a single power supply system will be stored in SM53 and SD53. (CHAPTER 12)

3.7 Data Clear Processing

This section describes how to clear data in the CPU module and the setting required for the latch data clear.

(1) Clearing data in the CPU module

Data in the CPU module are cleared when the reset operation (by the RUN/STOP/RESET switch or by powering the module off and then on) is performed.
However, data in (a) below cannot be cleared by the reset operation.

(a) Data that cannot be cleared by the reset operation

- Data in the program memory
- Data in the standard ROM
- Data in a memory card
- Data in latch-specified devices (☞ (2) in this section)
- Data in the file register

(b) Clearing data that cannot be cleared by the reset operation

1) Data in the program memory

Data can be cleared by:

- selecting the "Clear program memory" checkbox in the Boot file tab of the PLC parameter dialog box, or
- selecting [Online] → [Delete PLC data] in GX Developer.

2) Data in the standard ROM

Data can be cleared automatically when the data is written to the standard ROM.

3) Data in a memory card

Data can be cleared by selecting [Online] → [Delete PLC data] in GX Developer.

4) Data in latch-specified devices

Refer to (2) in this section.

5) Data in the file register

Data can be cleared by:

- resetting devices with the RST instruction,
- transferring K0 with the MOV or FMOV instruction, or
  ☞ QCPU Programming Manual (Common Instructions)
- executing "Clear all file registers" from the screen opened by selecting [Online] → [Clear PLC memory] in GX Developer.

(2) Latch specification of devices

Set a latch range for each latch-target device in the Device tab of the PLC parameter dialog box. (☞ Section 6.3(5))

(a) Latch range setting

Two kinds of latch range can be set by GX Developer.

1) Latch clear operation enable range ("Latch (1) start/end")

Data in this latch range can be cleared with the remote latch clear operation.

2) Latch clear operation disable range ("Latch (2) start/end")

Data in this latch range cannot be cleared with the remote latch clear operation.

(b) Clearing device data set in the latch clear operation enable range

Clear data with the remote latch clear operation (☞ Section 6.6.4).

(c) Clearing device data set in latch clear operation disable range

Clear data by:

- resetting devices with the RST instruction,
- transferring K0 with the MOV or FMOV instruction, or
  ☞ QCPU Programming Manual (Common Instructions)
- executing "Clear device's whole memory (including latch)" from the screen opened by selecting [Online] → [Clear PLC memory] in GX Developer.

Point

Latching devices increases the scan time.
When latching a device, consider the increase in the scan time. (☞ Section 10.1.2(9))

Remark

For the operation of GX Developer, refer to the following.
☞ GX Developer Version 8 Operating Manual

3.8 I/O Processing and Response Delay

The CPU module performs I/O processing in the refresh mode.
Using the direct access input/output in a sequence program, however, allows the CPU module to perform I/O processing in the direct mode at the time of each instruction execution.
This section describes these I/O processing modes of the CPU module and response delays.

(a) Refresh mode(☞ Section 3.8.1)

Refresh mode is a mode for the CPU module to access input/output modules and perform I/O processing collectively before the start of sequence program operations.

(b) Direct mode(☞ Section 3.8.2)

Direct mode is a mode for the CPU module to access input/output modules and perform I/O processing at the timing when each instruction is executed in a sequence program.
To access input/output modules in the direct mode, use the direct access input or direct access output in a sequence program.

(1) Differences between refresh mode and direct mode

The direct mode directly accesses input/output modules at execution of an instruction. Therefore, data input is faster than in refresh mode.
Processing time required for each instruction, however, is longer.

Table3.3 shows the availability of the refresh mode and the direct mode for each input and output.

Table3.3 Availability of modes

Item	Refresh mode	direct mode
Input/output modules	Available	Available
Input/output of intelligent function modules		
Remote input/output in CC-Link IE controller network, MELSECNET/H, or CC-Link	Available	Not available

3.8.1 Refresh mode

(1) Definition

Refresh mode is a mode for the CPU module to access input/output modules and perform I/O processing collectively before the start of sequence program operations.




Figure 3.2 Refresh mode


(2) Input

On/off data of an input module are batch-input to the area for communication with the input module in the CPU module before the start of sequence program operations.

The CPU module performs sequence program operations using the on/off data stored in the input (X) device memory.

(3) Output

The operation results of the sequence program is output to the output (Y) device memory in the CPU module every time program operation is performed. Then, the CPU module batch-outputs the on/off data in the output (Y) device memory to an output module before the start of sequence program operations.



•Input refresh:

Before the start of sequence program operations, the CPU module batch-reads input data 1) from an input module, performs a logical OR operation with data in the GX Developer input area or data in the remote input refresh area, and then stores the result in the input (X) device memory.

•Output refresh:

Before the start of sequence program operations, the CPU module batch-outputs data in the output (Y) device memory 2) to the output module.

•When a contact instruction for input is executed:

The CPU module reads input data 3) from the input (X) device memory and executes a sequence program.

•When a contact instruction for output is executed:

The CPU module reads output data 4) from the output (Y) device memory and executes a sequence program.

•When the OUT instruction for output is executed:

The CPU module stores the operation result of the sequence program 5) in the output (Y) device memory.

Figure 3.3 I/O data flow in refresh mode

*1: The remote input refresh area indicates the area to be used when auto refresh is set to the input (X) in the CC-Link IE controller network, MELSECNET/H, or CC-Link.
Data in the remote input refresh area will be refreshed automatically during END processing.

*2: Data in the GX Developer input area can be turned on/off by the following operation.
- •Test operation by GX Developer
- •Writing data from a network module

*3: Data in the output (Y) device memory can be turned on/off by the following operation.
- •Test operation by GX Developer
- •Refresh via CC-Link IE controller network or MELSECNET/H
- •Writing data from an external device using the MC protocol
- •Auto refresh via CC-Link

(4) Response delay

An output response which corresponds to the status change in the input module delays for two scans (maximum) depending on the on timing of an external contact.

Examples






Figure 3.4 Y5E turns on the earliest




Figure 3.5 Y5E turns on the latest

3.8.2 Direct mode

(1) Definition

The direct mode is a mode for the CPU module to access input/output modules and performs I/O processing at the timing when each instruction is executed in a sequence program.





Figure 3.6 Direct mode

With this mode, the CPU module uses the direct access input (DX) and direct access output (DY) to perform I/O processing.



•**When a contact instruction for input is executed:**

The CPU module performs a logical OR operation between input data from the input module 1) and input data in the GX Developer input area 2) or data in the remote input refresh area.

Then, the module stores the result in the input (X) device memory and executes a sequence program using the stored result as input data 3).

•**When a contact instruction for output is executed:**

The CPU module reads output data 4) from the output (Y) device memory and executes a sequence program.

•**When the OUT instruction for output is executed:**

The CPU module outputs the operation result of the sequence program 5) to the output module and also stores the result in the output (Y) device memory.

Figure 3.7 I/O data flow in direct mode

*1: The remote input refresh area indicates the area to be used when auto refresh is set to the input (X) in the CC-Link IE controller network, MELSECNET/H, or CC-Link.
Data in the remote input refresh area will be refreshed automatically during END processing.


*2: Data in the GX Developer input area can be turned on/off by the following operation.
- •Test operation by GX Developer
- •Writing data from a network module

*3: Data in the output (Y) device memory can be turned on/off by the following operation.
- •Test operation by GX Developer
- •Refresh via CC-Link IE controller network or MELSECNET/H
- •Writing data from an external device using the MC protocol
- •Auto refresh via CC-Link

(2) Response delay

An output response which corresponds to the status change in the input module delays for one scan (maximum) depending on the on timing of an external contact.

Examples






Figure 3.8 DY5E turns on the earliest




Figure 3.9 DY5E turns on the latest

CHAPTER4 ASSIGNMENT OF BASE UNIT AND I/O NUMBER

This chapter describes the base unit and I/O number assignment required for the CPU module to communicate data with I/O modules and/or intelligent function modules.

4.1 Base Unit Assignment

4.1.1 Base mode

Use this mode when assigning the number of available slots to the main base unit and extension base units.
The following two modes are available.

- Auto mode
- Detail mode

(1) Auto mode

Use this mode when assigning the number of slots equal to that on the base unit used.

(2) Detail mode

Use the detail mode when assigning the number of slots for each base unit.
Any number of slots can be assigned irrespective of the actual number of slots on the base unit to be used.

(a) Setting the number of slots greater than the actual one

Slots are occupied by the number of slots set.
The slots after actually used ones are regarded as empty slots.
For example, three slots will be the empty slots when a 5-slot base unit is used and the number of available slots are set to eight.




Figure 4.1 Setting the number of slots greater than the actual one

The number of points for the empty slots will be either value set on the PLC system tab, or on the I/O assignment tab in the PLC parameter dialog box. (The default is 16 points.)

(b) Setting the number of slots smaller than the actual one

Set the smaller number than the actual number of slots when slots with no module mounted need not be recognized.

For example, four slots from the right end of the base unit will be the prohibited slots when using a 12-slot base unit and setting the number of available slots to eight. (Mounting a module on a prohibited slot causes "SP.UNIT LAY ERR.".)




Figure 4.2 Setting the number of slots smaller than the actual one

4.1.2 Base unit assignment setting

Set base units on the I/O assignment tab of the PLC parameter dialog box.




Figure 4.3 I/O assignment setting

(1) Auto/Detail

Select the mode for the base unit assignment either from auto mode or detail mode.

(2) Base model name, Power model name, and Extension cable

Enter the model names of mounted base units, power supply modules, and extension cables to be used within 16 characters for user reference or when printing out parameters.

CPU modules do not use the entered model names.

(3) Slots

When "Detail" is set, select the number of slots on the base unit to use from the following.

2 (2 slots), 3 (3 slots), 5 (5 slots), 8 (8 slots), 10 (10 slots), or 12 (12 slots)

(4) 8 Slot Default/12 Slot Default

When "Detail" is set, select either of these items for batch-setting the base units to the specified number of slots.

Point

- In auto mode, when any extension base number is skipped at the setting using the base number setting connector, an empty extension base cannot be reserved.
  To reserve empty extension bases for future extension, select detail mode.

- In detail mode, set the number of slots to all base units used.
  Failure to do so may result in incorrect I/O assignment setting.

4.2 I/O Number Assignment

The I/O number indicates addresses used for sequence programs in the following cases.

- Input of on/off data to the CPU module
- Output of on/off data from the CPU module to the external device

(1) Input and output of on/off data

The input (X) is used to input on/off data to the CPU module, and the output (Y) is used to output on/off data from the CPU module.

(2) I/O number representation

The I/O numbers are represented in hexadecimal.

When a 16-point I/O module is used, the I/O number for each slot will be 16 point-sequence number from □□0 to □□F as shown in Figure 4.4.

"X" and "Y" is prefixed to the I/O number of input modules and the I/O number of output modules, respectively.




Figure 4.4 I/O numbers

4.2.1 Concept of I/O number assignment

The CPU module assigns I/O numbers at power on or reset, according to the I/O assignment setting.

(1) I/O number assignment

The Figure 4.5 shows an example of I/O number assignment to base units in the system where the CPU module is mounted on the main base unit.




Figure 4.5 I/O number assignment example

(a) Assignment order

For the main base unit, the I/O numbers are assigned to the modules from left to right in a sequential order, starting from 0H assigned to the module on the right of the CPU module.
For extension base units, the I/O numbers are continued from the last number of the I/O number of the main base unit.

(b) I/O number of each slot

Each slot on the base unit occupies I/O numbers by the number of I/O points of the mounted modules.

(2) I/O assignment on a remote I/O stations

CPU module device input (X) and output (Y) can be assigned to I/O modules and intelligent function modules, which allows to control the modules in the remote I/O system such as MELSECNET/H remote I/O network and CC-Link.

Also, inputs (X) and outputs (Y) can be used for the refresh target (devices on the CPU module side) of the MELSECNET/H module link I/O (LX and LY).




Figure 4.6 I/O number assignment on the remote station

(a) I/O numbers available on remote I/O stations

When the input (X) and output (Y) of the CPU module are used for the I/O numbers in the remote station, assign the I/O numbers later than those used for the I/O modules and intelligent function modules on the CPU module side.

Example When X/Y0 to X/Y3FF (1024 points) are used for the I/O modules and intelligent function modules on the CPU module side, X/Y400 and later can be used in the remote stations.

(b) Precautions for using remote station I/O numbers

1) Setting for future extension

When the input (X) and output (Y) of the CPU module are used for the I/O numbers on the remote station, consider future extension of I/O modules and/or intelligent function modules on the CPU module side.




Figure 4.7 Remote station I/O number assignment

2) When MELSECNET/H and CC-Link are used

I/O numbers to the refresh target (CPU module side device) of MELSECNET/H and to the CC-Link remote I/O system must be unique.

Point

- When network parameter setting has not been made in the CC-Link system, X/Y 1000 to 17FF (2048 points) are assigned to the CC-Link system master/local modules of lower numbers.
- There are no restrictions on the I/O number assignment order for the MELSECNET/H remote I/O networks, CC-Link, or other networks.
- Space can be provided between the I/O area for MELSECNET/H remote I/O station and the I/O area for CC-Link remote station.

4.2.2 Setting I/O numbers

Set the I/O number on the I/O assignment tab.

(1) Purpose of I/O number assignment

(a) Reserving points for future module changes

The number of points can be reserved to prevent the I/O number modification when the current module is changed in the future to the one with the different number of occupied I/O points.

(b) Preventing I/O numbers from changing

The change in the I/O numbers can be prevented when an I/O module or intelligent function module, whose occupied I/O points are other than 16, is removed due to failure.

(c) Changing the I/O numbers to those used in the program

When the I/O numbers used in the actual system differ from those in the designed program, the I/O numbers of each module on the base unit can be changed to the ones in the designed program.

Point

- If any of the I/O modules whose number of I/O points are other than 16 fails without I/O assignment setting, the I/O numbers assigned following to the failed module may change, leading to a malfunction.For this reason, making the I/O assignment setting is recommended.

- I/O assignment setting allows the following settings as well.
  - Input response time (I/O response time) (☞ Section 6.7)
  - Error time output mode (☞ Section 6.8)
  - CPU module operation during a hardware error of intelligent function modules (☞ Section 6.9)
  - Switch setting of intelligent function modules and interrupt modules(☞ Section 6.10)

  The I/O assignment is required for the input response time and switch settings.

(2) I/O assignment

The I/O assignment is set on the I/O assignment tab of the PLC parameter dialog box.
On the I/O assignment tab, the following items can be set for each slot on the base unit.

- "Type" (module type)
- "Points" (I/O points)
- "Start XY" (start I/O number)

For example, to change the I/O number of the specified slot, setting is allowed only to the number of points.
For other items that are not set, settings are completed based on the installation status of the base unit.




Figure 4.8 I/O assignment

(a) Slot

The slot number and location of the slot are displayed.
When the base unit is set in Auto mode, the base unit number is indicated in "*", and the slot number is counted from slot 0 of the main base unit.

(b) Type

Select the type of the mounted module from the followings:

- Empty (empty slot)
- Input (input module)
- Hi input (high-speed input module)
- Output (output module)
- I/O Mix (I/O combined module)
- Intelli. (intelligent function module)
- Interrupt (interrupt module)

If the type is not specified, the type of the actually mounted module is used.

(c) Type

Enter the model names of mounted modules within 16 characters.
CPU modules do not use entered model names. (Use the entered model names for user reference.)

(d) Points

When changing the number of I/O points for each slot, the selections are as follows.

0 points, 16 points, 32 points, 48 points, 64 points, 128 points, 256 points, 512 points, 1024 points

If the number of points is not selected, the points of the actually mounted module is used.
For empty slots, the points that are set on the PLC system tab of the PLC parameter dialog box is assigned. (Default: 16 points)

(e) Start XY

When changing the I/O number for each slot, enter a new start I/O number.
If start XY is not specified for a slot, the I/O number continuing from the last number of the current setting is assigned.

(3) Precautions

(a) Type setting

The type set to the I/O assignment tab must be the same as that of the mounted module.
Setting a different type may cause incorrect operation.
For the intelligent function module, the I/O points must also be the same in addition to the I/O assignment setting.

Table4.1 shows the operations when the mounted module type differs from the one in the I/O assignment tab.

Table4.1 Incorrect operation when the module type differs

Mounted module	I/O assignment setting	Result
Input module, output module, I/O combined module	• Intelli. • Interrupt	Error (SP.UNIT.LAY.ERR.)
Intelligent function module	• Input • Hi. input • Output • I/O combined	Error (SP.UNIT.LAY.ERR.)
Empty slot	• Input • Hi. input • Output • I/O combined • Intelli. • Interrupt	Empty slot
All modules	• Empty	Empty slot
Other combinations	-	Error does not occur but incorrect operation may be caused. Or, error (PARAMETER ERROR (error code: 3000)).

(b) I/O points of slots

The number of I/O points for each slot selected in the I/O assignment tab is set in priority to those of mounted modules.

1) When the preset number of I/O points is less than those of mounted I/O modules

The available points for the mounted I/O module will be decreased.
For example,when the number of I/O points is set to 16 points in the I/O assignment setting of PLC parameter to the slot where a 32-point input module is mounted, the second half 16 points of the 32-point input module becomes unavailable.

2) When the preset number of I/O points exceeds those of mounted I/O modules

The exceeded number of points will not be used in I/O modules.

3) Last I/O number

Set the last I/O number within the I/O point range.
Failure to do so causes an error ("SP. UNIT LAY ERR."). ("***" is displayed as an I/O address on the System monitor screen of GX Developer.)

(c) Start XY setting

When the start XY has not been entered, the CPU module automatically assigns it.The CPU module automatically assigns the start XY if it is not set. For this reason, the start XY setting of each slot may be duplicated with the one assigned by the CPU module in the case of 1) or 2) below.

1) Start XY values are not in the correct order.

2) Slots with and without the start XY setting (automatically assigned slot) are mixed

An example of start XY duplication is given in Figure 4.9 below.




Figure 4.9 I/O assignment setting with start XY duplication




Figure 4.10 Start XY set by above (Figure 4.9) I/O assignment

Do not set duplicated start XY for each slot.
Duplication of start XY will result in an error ("SP. UNIT LAY ERR.").

Point

Setting "Empty" and "0" to Type and Points respectively even occupies one slot.
To set on and after the specific slot unoccupied, set the number of slots in Detail mode. (Section 4.1.1)

4.2.3 I/O number setting example

I/O number setting examples are provided as follows.

(1) Changing the number of points of an empty slot from 16 to 32

Reserve 32 points for the currently empty slot (Slot 3) so that the I/O numbers of Slot No. 4 and later do not change when a 32-point input module is mounted there in the future.

(a) System configuration and I/O number assignment before I/O assignment using GX Developer




Figure 4.11 I/O number assignment (Before changing points of the empty slot)

(b) I/O assignment

Select "32 points" for the number of I/O points of Slot 3 in the I/O assignment setting of PLC parameter in GX Developer.




Figure 4.12 I/O assignment setting (When changing points of Slot 3)

(c) I/O number assignment after the I/O assignment using GX Developer




Figure 4.13 I/O numbers after I/O assignment (After changing points of the empty slot)

(2) Changing the I/O number of an empty slot

Change the I/O number of the currently empty slot (Slot 3) to X200 through 21F so that the I/O numbers of Slot 4 and later do not change when a 32-point input module is mounted there in the future.

(a) System configuration and I/O number assignment before the I/O assignment using GX Developer




Figure 4.14 I/O number assignment (Before changing slot I/O numbers)

(b) I/O assignment

Set "200" for the start XY of Slot 3 and "70" to Slot 4 in the I/O assignment setting of PLC parameter in GX Developer.




Figure 4.15 I/O assignment setting (When changing I/O numbers of Slot 3)

(c) I/O number assignment after the I/O assignment using GX Developer




Figure 4.16 I/O number assignment (After changing slot I/O numbers)

4.2.4 Checking I/O numbers

Information of mounted modules and their I/O numbers can be checked on the System monitor screen of GX Developer. (☞ Section 6.20)

CHAPTER5 MEMORIES AND FILES USED FOR CPU MODULE

5.1 Memories Used for CPU Module

5.1.1 Memory composition and storable data

This section describes the memories used for the Universal model QCPU and data that can be stored in the memories.

(1) Memory composition




Figure 5.1 Memory composition of the Universal model QCPU

*1: The Q00UJCPU, Q00UCPU, and Q01UCPU cannot be used with a memory card.
*2: The Q00UJCPU does not have the standard RAM.

(a) Program memory (☞ Section 5.1.2)

This memory is for storing programs and parameters for CPU module operation.
The CPU module transfers a program from the program memory to the program cache memory for operation.
(☞Section 5.1.3)

(b) Standard ROM (☞ Section 5.1.4)

This memory is for storing data such as parameters and programs.

(c) Standard RAM (☞ Section 5.1.5)

This memory is for using file registers, local devices, and sampling trace files without a memory card.

(d) Memory card (☞ Section 5.1.6)

This memory is for expansion of built-in memory in the CPU module.
Three types of memory cards are available: SRAM card, Flash card, and ATA card.

(2) Data that can be stored in each memory

Table5.1 provides the data that can be stored in each memory.

Table5.1 Data that can be stored in each memory

Item	CPU module built-in memory			Memory card (RAM)	Memory card (ROM)		File name and extension	Remarks
	Program memory	Standard RAM	Standard ROM	SRAM card	Flash card	ATA card		
	Drive 0 *1	Drive 3 *1	Drive 4 *1	Drive 1 *1	Drive 2 *1			
Parameter	○	×	○	○	○	○	PARAM.QPA	1 data/drive
Intelligent function module parameter*2	○	×	○	○	○	○	IPARAM.QPA	1 data/drive
Program	◎	×	○ *3	○ *4	○ *4	○ *4	***.QPG	-
Device comment	○ *5	×	○ *6	○ *6	○ *6	○ *6	***.QCD	-
Initial device value	○	×	○	○	○	○	***.QDI	-
Device data	×	×	○	×	×	×	***.QST	-
File register	×	○ *7*8	×	○	○ *9	×	***.QDR	-
Local device	×	○ *7	×	○	×	×	***.QDL	1 data/CPU module
Sampling trace file	×	○ *7	×	○	×	×	***.QTD	-
Error history data	×	×	×	×	×	×	***.QFD	-
Device data storage file	×	×	○	×	×	×	DEVSTORE.QST	-
Backup data file	×	×	×	○	○	○	MEMBKUP0.QBP	-
Programmable controller user data	×	×	○	×	×	○ *10	***.***	-
User setting system area*11	○	×	×	×	×	×	-	-

◎ : Required, ○ : Storable, × : Not storable

*1: A drive number is used to specify a memory to be written/read by the external device using a sequence program or MC protocol.
Since the memory name is used to specify the target memory by GX Developer, the drive number needs not to be considered.

*2: Store the intelligent function module parameters in the same drive with the parameters.
When they are stored in different drives, the intelligent function module parameters do not become valid.

*3: A program stored in the standard ROM cannot be executed.
Store the program to the program memory before execution.

*4: To execute a program stored in the memory card, make the setting in the Boot file tab of the PLC parameter dialog box.

*5: The device comments cannot be read by instructions in a sequence program.

*6: Reading from a sequence program requires several scans.

*7: Only each one of file register, one local device, and/or sampling trace file can be stored in the standard RAM.

*8: For the number of storable file register points, refer to Section 9.7.

*9: A sequence program allows reading only. No data can be written from the sequence program.

*10: Data can be written or read with the following instructions.
•SP.FREAD (batch-reads data from the specified file in the memory card.)
•SP.FWRITE (batch-writes data to the specified file in the memory card.)

*11: Set an area used by the system. (☞ Section 5.1.2(2)(b))

(3) Memory capacities and necessity of formatting

Table5.2 provides the memory capacities and necessity of formatting of each memory.
Format a memory requiring formatting by GX Developer beforehand.

Table5.2 Memory capacities and necessity of formatting

		Q00UJCPU	Q00UCPU	Q01UCPU	Q02UCPU	Q03UDCPU, Q03UDECPU	Q04UDHCPU, Q04UDEHCPU	Formatting
Program memory		40K bytes (10K steps)	40K bytes (10K steps)	60K bytes (15K steps)	80K bytes (20K steps)	120K bytes (30K steps)	160K bytes (40K steps)	Necessary*1
Standard ROM		256K bytes	512K bytes	512K bytes	512K bytes	1024K bytes	1024K bytes	Unnecessary
Standard RAM		-	128K bytes	128K bytes	128K bytes	192K bytes	256K bytes	Necessary*1
Memory card	SRAM card	-			Q2MEM-1MBS: 1M byte Q2MEM-2MBS: 2M bytes Q3MEM-4MBS: 4M bytes Q3MEM-8MBS: 8M bytes			Necessary (Use GX Developer.)
	Flash card	-			Q2MEM-2MBF: 2M bytes Q2MEM-4MBF: 4M bytes			Unnecessary
	ATA card	-			Q2MEM-8MBA: 8M bytes Q2MEM-16MBA: 16M bytes Q2MEM-32MBA: 32M bytes			Necessary (Use GX Developer.)

		Q06UDHCPU, Q06UDEHCPU	Q10UDHCPU, Q10UDEHCPU	Q13UDHCPU, Q13UDEHCPU	Q20UDHCPU, Q20UDEHCPU	Q26UDHCPU, Q26UDEHCPU	Formatting
Program memory		240K bytes (60K steps)	400K bytes (100K steps)	520K bytes (130K steps)	800K bytes (200K steps)	1040K bytes (260K steps)	Necessary*1
Standard ROM		1024K bytes	2048K bytes	2048K bytes	4096K bytes	4096K bytes	Unnecessary
Standard RAM		768K bytes	1024K bytes	1024K bytes	1280K bytes	1280K bytes	Necessary*1
Memory card	SRAM card	Q2MEM-1MBS: 1M byte Q2MEM-2MBS: 2M bytes Q3MEM-4MBS: 4M bytes Q3MEM-8MBS: 8M bytes					Necessary (Use GX Developer.)
	Flash card	Q2MEM-2MBF: 2M bytes Q2MEM-4MBF: 4M bytes					Unnecessary
	ATA card	Q2MEM-8MBA: 8M bytes Q2MEM-16MBA: 16M bytes Q2MEM-32MBA: 32M bytes					Necessary (Use GX Developer.)

*1: When the memory contents become indefinite in initial status or due to the end of battery life, the memory is automatically formatted after the CPU module is powered off and then on or is reset.

Point

- When files are written to each memory, the unit of stored file size depends on the target CPU module and memory area.(☞ Section 5.3.4)
- In memory capacity calculation, 1 step is equal to 4 bytes.

5.1.2 Program memory

(1) Definition

This memory is for storing programs and parameters for CPU module operation.
The CPU module transfers a program from the program memory to the program cache memory for operation. (☞ Section 5.1.3)

Point

If the total size of data to be stored exceeds the program memory capacity:

- reduce the user setting system area, or
- transfer data other than programs to the standard ROM or memory card.

(2) Before using the program memory

Format the program memory by GX Developer.

(a) Formatting

Select [Online] → [Format PLC memory] in GX Developer.
Select "Program memory/Device memory" in “Target memory”.




Figure 5.2 Formatting the program memory

(b) Creating a user setting system area

When formatting a program memory, set the capacity of user setting system area.

1) Do not create a user setting system area (the necessary system area only)

The user setting system area is not created during formatting.

2) Create a user setting system area

The user setting system area is created during formatting.
Table5.3 provides the type of user setting system area.

Table5.3 Type of user setting system area

System area	Description
High speed monitor area from other station.	Setting this area increases the monitoring speed in the GX Developer connected to such as a serial communication module. When using RS-232 and USB together with GX Developer, this area is used to register monitor data from GX Developer connected to such as a serial communication module.

Point

When a user setting system area is created, the available area reduces by the number of steps created in the area.

(c) Checking the memory capacity after formatting

Select [Online] → [Read from PLC] in GX Developer.

1) Select "Program memory/Device memory" in “Target memory” on the Read from PLC screen.

2) Click the Free space volume button.

3) The memory capacity appears in “Total free space volume”.




Figure 5.3 Procedure for checking the memory capacity

(3) Writing to the program memory

Select [Online] → [Write to PLC] in GX Developer.

Select "Program memory/Device memory" in “Target memory” on the Write to PLC screen.




Figure 5.4 Write to PLC screen

Point

The file size has its minimum unit. (☞ Section 5.3.4)
The occupied memory capacity may be greater than the actual file size.
Note that as the number of files increases, the difference between the occupied memory capacity and the actual file size increases.

5.1.3 Program cache memory

(1) Definition

This memory is for program operation.

The CPU module transfers a program from the program memory to the program cache memory for operation.

The program is transferred during:

- initial processing after the CPU module is powered on, or
- initial processing after the CPU module is reset.

Figure 5.5 provides the flow of program operations.




Figure 5.5 Flow of program operation

(2) Writing a program

When writing data from GX Developer, programs and parameters are written to the program cache memory in the CPU module. After the completion of the writing, the data are transferred to the program memory.
Figure 5.6 provides the flow of writing a program.




Figure 5.6 Flow of writing a program

(3) Transferring data to the program memory by GX Developer

Data can also be batch-transferred from the program cache memory to the program memory by selecting [Online] → [Program memory batch transfer] in GX Developer.
Figure 5.4 provides the transfer time required when data are batch-transferred to the program memory while the CPU module is in the RUN status.

Table5.4 Transfer time of program memory batch-transfer

CPU module	Transfer time
Q00UJCPU, Q00UCPU, Q01UCPU, Q02UCPU	Ts × 320 + 4.8 (s)
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU	Ts × 260 + 4.7 (s)
Q10UDHCPU, Q10UDEHCPU	Ts × 439 + 6.2 (s)
Q13UDHCPU, Q13UDEHCPU	Ts × 600 + 8.0 (s)
Q20UDHCPU, Q20UDEHCPU	Ts × 839 + 11.4 (s)
Q26UDHCPU, Q26UDEHCPU	Ts × 1100 + 15.0 (s)

Ts: scan time (s)

(4) Checking status during data transfer to the program memory

The status during data transfer to the program memory can be checked either in the progress screen of GX Developer or by the special relay and special register.

(a) Checking the status in the progress screen

Figure 5.7 provides the progress screen of GX Developer.




Figure 5.7 Screen showing status of data transfer to the program memory

(b) Checking the status by the special relay and special register

The status can be checked by SM681 and SD681.

(5) Checking whether data are transferred to the program memory Note5.1

Whether data are transferred from the program cache memory to the program memory can be checked by SM165.

Note5.1 Universal

When checking the transfer status to the program memory in the Q02UCPU, Q03UDCPU, Q04UDHCPU, or Q06UDHCPU, check the versions of the CPU module and GX Developer. (Appendix 2)

5.1.4 Standard ROM

(1) Definition

This memory is for storing data such as parameters and programs.

(2) Checking the memory capacity

Select [Online] → [Read from PLC] in GX Developer.

1) Select "Standard ROM" in “Target memory” on the Read from PLC screen.

2) Click the Free space volume button.

3) The memory capacity appears in “Total free space volume”.




Figure 5.8 Procedure for checking the memory capacity

(3) Writing to the standard ROM

Select [Online] → [Write to PLC] in GX Developer.

Select "Standard ROM" in “Target memory”.

Point

The file size has its minimum unit. (☞ Section 5.3.4)
The occupied memory capacity may be greater than the actual file size.
Note that as the number of files increases, the difference between the occupied memory capacity and the actual file size increases.

5.1.5 Standard RAM Note5.2

(1) Definition

This memory is for using file registers, local devices, and sampling trace files without a memory card.
Storing the file registers in the standard RAM allows fast access as data registers do.

Point

If the size of files to be stored exceeds the standard RAM capacity:

- store the files in the memory card, or
- reduce the number of points of the file register, local device, or sampling trace.

Note when file registers are stored in the memory card, the access speed will be slower than when they are stored in the standard RAM.

(2) Before using the standard RAM

Format the standard RAM by GX Developer.

(a) Formatting

Select [Online] → [Format PLC memory] in GX Developer.
Select "Standard RAM" in “Target memory”.




Figure 5.9 Formatting the standard RAM

Note5.2 Universal

The Q00UJCPU does not have the standard RAM.

(b) Checking the memory capacity after formatting

Select [Online] → [Read from PLC] in GX Developer.

1) Select "Standard RAM" in “Target memory” on the Read from PLC screen.

2) Click the Free space volume button.

3) The memory capacity appears in “Total free space volume”.




Figure 5.10 Procedure for checking the memory capacity

(3) Writing to the standard RAM

Select [Online] → [Write to PLC] in GX Developer.

Select "Standard RAM" in “Target memory” on the Write to PLC screen.




Figure 5.11 Write to PLC screen

Point

The file size has its minimum unit. (☞ Section 5.3.4)
The occupied memory capacity may be greater than the actual file size.
Note that as the number of files increases, the difference between the occupied memory capacity and the actual file size increases.

5.1.6 Memory card Note5.3

(1) Definition

This memory is for expansion of a memory in the CPU module.
The following three types are available:

- SRAM card
- Flash card
- ATA card

(a) SRAM card

File registers in the SRAM card can be written or read by the sequence program.
The SRAM card is used when:

- the number of file register points is greater than the standard RAM capacity, or
- the sampling trace function is used. (☞ Section 6.14)

When storing file registers to the SRAM card, the file registers can be written or read by the sequence program up to 4086K points.

(b) Flash card

Write data by GX Developer and read it by the sequence program. (Data can be read only by the sequence program.)
Use the Flash card when data are not changed.
File registers can be stored up to 2039K points.

(c) ATA card

This card is used for programmable controller user data (general-purpose data).
With the file access instruction (such as the SP. FWRITE instruction) in the sequence program, access the programmable controller user data in the ATA card in CSV format/binary format.

Note5.3 Universal

The Q00UJCPU, Q00UCPU, and Q01UCPU cannot be used with a memory card.

(2) Before using the SRAM card or ATA card

Format the SRAM card or ATA card by GX Developer.

(a) Formatting

Select [Online] → [Format PLC memory] in GX Developer.

- When formatting the SRAM card, select "Memory card (RAM)" in “Target memory”.
- When formatting the ATA card, select "Memory card (ROM)" in “Target memory”.




Figure 5.12 Formatting the SRAM card or ATA card

Point

- Use only GX Developer to format the ATA card.
  If formatting the ATA card by such as the formatting function of Microsoft® Windows® , the card may not be used with the CPU module.
- When formatting the SRAM card or ATA card, the memory card information area is automatically secured. Therefore, the card capacity reduces by the area size.

Remark

Formatting is not required for the Flash card.

(b) Checking the memory capacity after formatting

Select [Online] → [Read from PLC] in GX Developer.

1) Select "Memory card (RAM)" or "Memory card (ROM)" in “Target memory” on the Read from PLC screen.

2) Click the Free space volume button.

3) The memory capacity appears in “Total free space volume”.




Figure 5.13 Procedure for checking the memory capacity

(3) Writing to the memory card

The following describes the operations before writing and the methods for writing.

(a) Writing to the SRAM card or the ATA card

Select [Online] → [Write to PLC] in GX Developer.

- When writing data to the SRAM card, select "Memory card (RAM)" in “Target memory” on the Write to PLC screen.
- When writing data to the ATA card, select "Memory card (ROM)" in “Target memory” on the Write to PLC screen.




Figure 5.14 Write to PLC screen

(b) Writing to the Flash card

The following two methods are available.

- Writing by "Write the program memory to ROM" (☞ Section 5.1.7(1)(a))
- Writing by "Write to PLC (Flash ROM)" (☞ Section 5.1.7(1)(b))

Point

The file size has its minimum unit. (☞ Section 5.3.4)
The occupied memory capacity may be greater than the actual file size.
Note that as the number of files increases, the difference between the occupied memory capacity and the actual file size increases.

(4) How to use the program stored in the memory card

Boot the program stored in the memory card to the program memory before its execution.(☞ Section 5.1.8)

5.1.7 Writing to the Flash card by GX Developer

(1) Methods for writing data to the Flash card and applications

Figure 5.15 provides the methods for writing data to the Flash card.




Figure 5.15 Methods for writing data to the Flash card

(a) Writing by “Write the program memory to ROM”

Data in the program memory are batch-written to the Flash card.

To batch-write the data, select [Online] → [Write to PLC (Flash ROM)] → [Write the program memory to ROM] in GX Developer.

Use this method when:

- debugging the program in the program memory and writing the debugged program to the Flash card without change for boot operation (☞ Section 5.1.8), or
- storing the data in the program memory to the Flash card without battery backup.

(b) Writing by “Write to PLC (Flash ROM)”

Files specified by GX Developer are batch-written to the Flash card.

To batch-write the files, select [Online] → [Write to PLC (Flash ROM)] → [Write to PLC (Flash ROM)] in GX Developer.

Use this method when:

- storing parameters, initial device values, or device comments whose size exceeds the program memory capacity to the Flash card, or
- using file registers storied in the Flash card.

(2) Writing to the Flash card

The following describes the operations before writing and the methods for writing.

(a) Before writing

Check the following.

1) Preparing files to be written

Writing a file to the Flash card automatically deletes all files stored in the Flash card.
Also write all files same as the stored files together.

2) Boot operation

When storing parameters to the Flash card at boot operation, make the boot file setting described in Section 5.1.8.

(b) Writing procedure

The following describes a procedure for writing a file to the Flash card.

1) Procedure for [Write the program memory to ROM] in GX Developer

- Select [Online] → [Write to PLC (Flash ROM)] → [Write the program memory to ROM].
- The program memory data into ROM screen appears.




Figure 5.16 Copy program memory data into ROM screen

- Select the memory to be written in "Target" to write the program memory file to the Flash card.

Point

- When files are written by “Write the program memory to ROM”, the capacity of used target memory is equal to that of used program memory.
  To fully use the capacity of the target memory, write the files by “Write to PLC (Flash ROM)”.
- When writing data that cannot be stored to the program memory (file register) to the Flash card, write it by “Write to PLC (Flash ROM)”.

2) Procedure using [Write to PLC (Flash ROM)] in GX Developer

- Select [Online] → [Write to PLC (Flash ROM)] → [Write to PLC (Flash ROM)].
- The Write to PLC (Flash ROM) screen appears.




Figure 5.17 Write to PLC (Flash ROM) screen

- Select the target memory.
- Select a file to be written and write it to the Flash card.

(3) Adding or changing a file in the Flash card

Add or change the file by either of the following methods (stored files cannot be added or changed directly).

(a) When writing files using [Write the program memory to ROM] in GX Developer

- To read all files in the program memory, select [Online] → [Read from PLC].
- Add or change the read files.
- Write the added or changed files to the program memory.
- Select [Online] → [Write to PLC (Flash ROM)] → [Write the program memory to ROM] and write the files to the Flash card.

(b) When writing files using [Write to PLC (Flash ROM)] in GX Developer

- To read all files in the Flash card, select [Online] → [Read from PLC].
- Add or change the read files.
- Select [Online] → [Write to PLC (Flash ROM)] → [Write to PLC (Flash ROM)] and write the files to the Flash card.

(4) Precautions

(a) Setting the communication time check period in GX Developer

Since writing a file to the Flash card takes time, set "Check at communication time" in GX Developer to 60 seconds or longer.

If the set time is short, GX Developer may time out.




Figure 5.18 Check at communication time setting

(b) Writing a file from GX Developer in another station via CC-Link

Since writing a file to the Flash card takes time, make the CPU monitoring time setting (SW000A) of CC-Link to 60 seconds or longer.

(The default value of 90 seconds can be used.)




Figure 5.19 Writing a file from GX Developer in another station(via CC-Link)

Remark

For settings of the communication time check period and CPU monitoring time, refer to the following.

GX Developer Version8 Operating Manual

(c) Time required for “Write to PLC (Flash ROM)”

Using "Write to PLC (Flash ROM)” writes data to the entire space in the Flash card.
Therefore, even if a program having the small number of steps is written to the Flash card, the processing takes time.
(Writing using the Q2MEM-4MBF at a communication speed of 115.2Kbps with an RS-232 interface requires 14 minutes.)
When writing data to the Flash card, increase the transmission speed or use an USB.
Communication time takes time when “Write to PLC (Flash ROM)” is executed from another station.

(d) Online change (Only “Write to PLC (Flash ROM)” can be used.)

“Write to PLC (Flash ROM)” can be executed during the RUN status except the following cases.
Execute “Write to PLC (Flash ROM)” after setting the RUN/STOP/RESET switch to STOP when:

1) File registers stored in the Flash card are used in the sequence program, or
2) although "Not used" is set to the file registers by the PLC parameter dialog box, they are used in the sequence program.

If “Write to PLC (Flash ROM)” is executed during the RUN status in either above situations of 1) or 2), an error may occur, resulting the CPU module to stop.

(e) Writing/reading data during execution of “Write to PLC (Flash ROM)”

While “Write to PLC (Flash ROM)” is executed, data cannot be read from/written to other modules.
Therefore, time-out may occur in other modules.

(f) When “Write to PLC (Flash ROM)” is executed during the STOP status

Do not set the RUN/STOP/RESET switch to RUN during the writing.
The CPU module may not enter the RUN status normally during execution of "Write to PLC (Flash ROM)".
Set the RUN/STOP/RESET switch to RUN after the writing.

5.1.8 Operating the program in the memory card (boot operation)

This section describes methods for operating the program stored in the memory card.

(1) Operating the program in the memory card

To execute the boot operation, set the names of files to be booted in the Boot file tab of the PLC parameter dialog box. (☞ (3) in this section, (4))

The program stored in the memory card, whose file name is specified in the Boot file tab, is booted with the program memory after the CPU module is powered off and then on or is reset.




Figure 5.20 Boot operation

(2) Bootable files, transfer source, and transfer destination

Table Table5.5 provides the combinations of bootable file, transfer source, and transfer destination.

Table5.5 Combinations of bootable file, transfer source, and transfer destination

File name	Transfer source	Transfer destination	
		Program memory	Standard ROM
Parameter	Memory card	○	○
Sequence program		○	×
Device comment		○	○
Initial device value		○	○
Label program		○	○

○ : Bootable, × : Cannot be booted.

(3) Procedure before boot operation

The following explains the procedures to store the files to be booted in the memory card and then start boot operation.

(a) Creating a program

Create a program.

(b) Boot file setting

Set the names of files to be booted to the program memory in the Boot file tab of the PLC parameter dialog box.




Figure 5.21 Boot file tab

(c) Mounting the memory card

Mount the memory card to the CPU module.

(d) Writing to the memory card

Write the parameters and programs set in the Boot file tab to the memory card.

(e) Executing the program

Set the RUN/STOP/RESET switch to RESET.

The BOOT LED turns on after a boot from the specified memory is completed.

(f) Checking whether a boot is normally completed

The following status indicates normal completion of boot operation.

- The BOOT LED turns on.
- The special relay (SM660) turns on.
- The data written to the transfer source memory and the data in the program memory are found the same by verification made by selecting [Online] → [Verify with PLC] in GX Developer.

(4) Operation for stopping boot operation

To stop boot operation and operate the CPU module by the parameters and program files written to the program memory, perform the following operations.

1) Remove the memory card and write parameters without boot file setting to the program memory by GX Developer.
2) Power on the programmable controller again or reset the CPU module.

(5) Boot operation precautions

(a) Storage location of parameters

- Store the parameters set in the Boot file tab of the PLC parameter dialog box to the memory card. If the parameters set in the Boot file tab are stored in the program memory or standard ROM, the CPU module ignores the parameter settings. (☞ Section 5.1.10)
- When both of the following status 1) and 2) occurs, the CPU module is not operated by the parameters in the memory card, but by the parameters in the program memory.
  1) There are parameters in the program memory.
  2) The parameters in the memory card are not set in the Boot file tab.

(b) Online change in boot operation

1) Memory card (RAM)

When data are written to a program in the program memory in the RUN status (☞ Section 6.12), the change can be updated to the program in the boot source memory card (RAM).

2) Memory card (ROM)

Even if a program in the program memory is written in the RUN status, the change is not updated to the program in the boot source memory card (ROM).
Therefore, write the same file whose program was written to the program memory to the memory card (ROM) by Write to PLC (Flash ROM). (☞ Section 5.1.7)

(c) Maximum number of settable boot files

Set the maximum number of settable boot files in the Boot file tab of the PLC parameter dialog box so that it may be the same with the number of files storable to the program memory.
However, the number of boot files reduces by 1 when:

- a heading is set, or
- the parameters set in the Boot file tab of the PLC parameter dialog box and stored in the memory card is booted.

(d) Boot operation when the ATA card is used

When data are booted from the ATA card, the processing time of maximum 200ms may be required per 1K step (4K bytes).

(e) When data in the program memory are changed after the CPU module is powered off and then on or is reset

If the program memory data are changed after the sequence program is written to the program memory and the CPU module is powered off and then on or is reset, a boot operation may be active.
While the BOOT LED on the front of the CPU module is on, the boot operation is active. Refer to (4) in this section and stop the boot operation.

(f) Size after a boot from the memory card

The size unit of a file stored in each memory differs between the memory card and the program memory. (☞Section 5.3.4)
Therefore, note that files transferred from the memory card to the program memory differ in memory capacity between before and after the transfer.

(g) Program written to the memory card

Set the programmable controller type (model name of the CPU module) for the program written to the memory card (program set in the Boot file tab) and the model name of the CPU module to be booted to the same.

5.1.9 Details of written files

For each file written to the CPU module, its name, size, and created date and time set at the file creation are appended.
The file is displayed on the Read from PLC screen, opened by selecting [Online] → [Read from PLC] in GX Developer, as shown below.




Figure 5.22 Displaying the details of a file

(a) File name

1) File name structure and file specification

Each file name is composed of a name (up to 8 characters in one byte/4 characters in double bytes) and an extension (3 characters).
Create a file name with upper-case characters only.
An extension is automatically appended according to the type set when the file was created.

2) Characters that cannot be used for a file name

The following reserved words for Microsoft® Windows® cannot be used as a file name.
COM1 to COM9, PRN, LPT1 to LPT9, NULL, AUX, CLOCK$, CON

3) How to specify a file name in the sequence program

Since the sequence program is not case-sensitive, the file can be named by both upper-case and lower-case characters.
*Both "ABC" and "abc" are treated as "ABC".
In double-byte characters, an upper-case character and lower-case character are distinguished. Name a file by an upper-case character.
*"ABC" and "abc" are distinguished.

(b) Date and time

The date and time when a file was written to the CPU module is shown.
The date and time are appended according to the clock set on the GX Developer (personal computer) side.

(c) Size

The file size when the file was written from GX Developer to the CPU module is shown in units of bytes (To display the latest data, select [Online] → [Read from PLC] and click the Refresh view button). At least 64 bytes (136 bytes for a program) are added to the file created by an user except a file register file.
(☞ Section 5.3.3)

5.1.10 Specifying valid parameters (parameter-valid drive setting)

Drives (memories) storing valid parameters are automatically specified by the system.
The valid parameters are determined by the priority of the drives where parameters are stored.
Settings by an user is unnecessary.

(1) Priority of the parameter-valid drives

Table5.6 provides the priority of the drives where parameters are stored.
Write parameters to be validated to the higher priority drives.

Table5.6 Priority of the drives

Priority		Parameter drive
High	1	Drive 0 (program memory)
↑	2	Drive 1 (memory card RAM)
↓	3	Drive 2 (memory card ROM)
Low	4	Drive 3 (standard ROM)

Figure 5.23 provides the operation flowchart for the CPU module to select parameter drives.




Figure 5.23 Flowchart to specify drives storing parameters

(2) When to determine valid parameters

The CPU module automatically searches for parameters in the following timing and operates by the settings of the parameters stored in the drives when:

- the CPU module is powered off and then on, or
- it is reset.

When storing parameters by Write to PLC in GX Developer, the timing for validating the parameters depends on the drive that stores the parameters.

(a) When parameters are stored to the drive different from the one that stores the parameters in operation

The parameters are validated according to the priority set to the drive after the CPU module is powered off and then on or is reset.

(b) When parameters are stored to the drive same as the one that stores the parameters in operation

Only the setting made in the Device tab of the PLC parameter dialog box is validated after “Write to PLC” is performed.

To validate all parameter settings, power off and then on or reset the CPU module.

5.2 Program File Structure

A program file consists of a file header, execution program, and reserved area for online change.




Figure 5.24 Program file structure

(1) Details of each structure

The capacity of the programs stored in the CPU module program memory is the total of above three areas.

(a) File header

This area stores the name, size, and created date of files.
The file header size ranges from 25 to 35 steps (100 to 140 bytes) depending on the setting made in the Device tab of the PLC parameter dialog box (34 steps is set by default).

(b) Execution program

This area stores the created program.

(c) Reserved area for online change

This area is used when the number of steps is increased after writing data in the RUN status from GX Developer.
When such operation is performed, the remaining reserved area for online change is shown.

1) Default

500 steps (2000 bytes) is set by default.

2) Setting change

To change the number of steps, select [Online] → [Write to PLC] → <<Program>> tab in GX Developer.
This setting can be made when data are written in the RUN status. (☞ Section 6.12.1)

(2) Displaying the program capacity on the GX Developer screen

During programming by GX Developer, the program size (total of the file header size and the number of steps in the created program) is displayed by the number of steps as shown in Figure 5.25.





Figure 5.25 Displaying the program size

Point

- The program size displayed during programming by GX Developer is the total of the file header and execution program, and the capacity of the reserved area for online change (500 steps) is not included.

  Example The size of program having the execution program area of 491 steps is displayed on the GX Developer screen as shown below (The file header is fixed to 34 steps).



Display on the GX Developer screen:
34 steps + 491 steps = 525 steps

Figure 5.26 File status displayed on the GX Developer screen

- Since files are stored in units of file sizes in the program memory, the program size displayed during programming by GX Developer may differ from the program file size in the CPU module.
  (☞ Section 5.3.3)

5.3 File Operations by GX Developer and Handling Precautions

5.3.1 File operations

Table5.7 shows the functions can be performed to files stored in the program memory, standard ROM, and memory card by the online functions of GX Developer.
However, the executable operations depends on the password registration setting by GX Developer and CPU module status (RUN/STOP).

Table5.7 File operations executable from GX Developer

File operation	Operation detail	Operability		
		While write protection password is set to the file	While write/read protection password is set to the file	While the CPU module is in the RUN status
Read from PLC	Reads a file from the target memory.	○	△	○
Write to PLC	Writes a file to the program memory or SRAM card.	△	△	○
	Writes a file to the standard ROM.	△	△	○
Verify with PLC	Verifies the file in the target memory and the file of GX Developer.	△	△	○
Write the program memory to ROM	Batch-writes files stored in the program memory to the Flash card.	○	○	○
Write to PLC (Flash ROM)	Batch-writes specified files from GX Developer to the Flash card.	△	△	○
Format PLC memory	Formats a memory.	○	○	×
Arrange PLC memory	Rearranges files stored in a memory at random.	○	○	×
Online change (ladder mode)	Writes data changed in the ladder mode to the program memory.	△	△	○

○ : Executable, △ : Executable when entered password matches, × : Cannot be executed

5.3.2 Precautions for handling files

(1) Power-off or reset at file operation

When the CPU module is powered off or reset at file operation, files in each memory are held (for a memory card, when the CPU module where a memory card has been mounted before power-off is powered on).

Point

When the programmable controller is powered off during an operation in which a file is moved, the data in operation are held in the internal memory of the CPU module.
The held data are recovered at power-on.
To hold the internal memory data, battery backup is required.

(2) Concurrent writing from multiple GX Developers to one file

GX Developers other than the one writing data to a file cannot access the file until the writing ends.
Also, GX Developers other than the one accessing a file cannot write data to the file until the access ends.
Therefore, write data to one file from multiple GX Developers one by one.

(3) Concurrent access from multiple GX Developers to different files

Except the currently viewed GX Developer, maximum 10 GX Developers can access to different files in one CPU module concurrently.

5.3.3 File size

The size of a file used for the CPU module depends on the file type.
When a file is written to the memory area, the unit of the stored file depends on the CPU module and memory area to be written. (☞ Section 5.3.4)
When using the program memory, standard RAM, standard ROM, or memory card, calculate the rough size of each file with reference to Table5.8.

Table5.8 Calculation of file size

<table>
<tr><th>Function</th><th>Rough file size (unit: Byte)</th></tr>
<tr><td>Drive heading</td><td>72</td></tr>
<tr><td>Parameter</td><td>Default: 464 (can be increased by parameter setting.)*1
Reference
Boot setting → 84 + (18 × (number of files))*2
• With CC-Link IE controller network setting →
• 72 + (total parameter sizes of each module) + (size of the routing setting) + (size of the data link transfer setting)
• Parameter size of each module: Up to 10368 (when only LB/LW(1) is set, 1826 + 16 × (number of refresh transfer points))
• Routing setting size: 6 + 8 × (number of routing settings)
• Size of data link transfer setting: 6 + 12 × (number of transfer settings) + 86 × (number of modules)
• With the MELSECNET/H setting → Increase up to 6180/module
• With the Ethernet setting → Increase up to 922/module
• With the CC-Link setting → Increase up to the values in the following table (The values indicate an increment of each module).
<table>
<tr><th rowspan="2">CC-Link setting</th><th colspan="3">Mode setting</th></tr>
<tr><th>Ver.1 mode</th><th>Ver.2 mode</th><th>Ver.2 additional mode</th></tr>
<tr><td>1st module</td><td>550 bytes</td><td>572 bytes</td><td>624 bytes</td></tr>
<tr><td>2nd to 4th modules</td><td>536 bytes</td><td>558 bytes</td><td>610 bytes</td></tr>
<tr><td>5th module</td><td>550 bytes</td><td>566 bytes</td><td>618 bytes</td></tr>
<tr><td>6th to 8th modules</td><td>536 bytes</td><td>558 bytes</td><td>610 bytes</td></tr>
</table>
• With the remote password setting →92 + (number of target modules × 10), increase up to 172/module</td></tr>
<tr><td>Sequence program</td><td>148*3 + (4 × ((number of steps) + (number of steps of reserved area for online change)))</td></tr>
<tr><td>Device comment</td><td>74 + 8 + (total comment data size of each device)
Comment data size per device = 10 + 10250 × a + 40 × b
• a: Quotient of ((number of device points)/256)
• b: remainder of ((number of device points/256))</td></tr>
<tr><td>Initial device value</td><td>66 + 44 × n + 2 × (total number of device points set to the initial device value) + 8
n: number of settings of the initial device value</td></tr>
<tr><td>User setting area</td><td>Setting value at formatting (0 to 15K)</td></tr>
<tr><td>File register*6</td><td>2 × (number of file register points)</td></tr>
</table>

(To the next page)

Table5.8 Calculation of file size(continued)

Function	Rough file capacity (unit: Byte)
Sampling trace file*6	362 + (number of word device points + number of bit device points) × 12 + (N1 + N2 + N3 + number of word device points × 2 + (number of bit device points/16) × 2) × the number of traces (total number of executions)*4 • Apply the following values to N1 to N3 according to the items set in "Trace additional information" of the Trace condition settings screen. (☞ Section 6.14(4)(b)) N1: When "Time" is set, apply "4". N2: When "Step no." is set, apply "10". N3: When "Program name" is set, apply "8".
Device data backup file	Setting value at formatting (2 to 1024K)
Local device*6	72 + 6 × (set device type) + 2 × ((total number of M and V points)/16 + (number of D points) + 18 × (total number of T, ST, and C points)/16)) × (number of programs where local devices are used*5) • M, V, D, T, ST, and C indicate the following set devices. M: internal relay V: edge relay D: data register T: timer ST: retentive timer C: counter Z: index register*7

*1: The value is adjusted by the system so that the total bytes with the addition of the network parameter setting may be multiple of four.
*2: The value is adjusted by the system so that the bytes may be multiple of four.
*3: 148 is set by default (This value depends on the parameter setting).
*4: After the decimal point of a value found by the number of bit device points/16 is rounded up.
*5: For the Universal model QCPU, if the serial number (first five digits) is "10011" or earlier, apply the number of execution programs.
*6: The Q00UJCPU does not support this function.
*7: For the Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q13UDEHCPU, or Q26UDEHCPU, if the serial number (first five digits) is "10101" or earlier, the index register cannot be stored as local devices. (☞ Section 9.14.2)

Remark

For calculation example of memory capacity, refer to Section 5.3.4.

5.3.4 Units of file sizes

(1) Definition

When a file is written to the memory area, the unit of the stored file depends on the CPU module and memory area to be written. This unit is referred to as a file size unit.

(a) File size unit for each memory area

The following table shows the file size unit depending on the CPU module and memory area to be written.

Table5.9 File size unit for each CPU module and memory area

CPU module model	Memory area	
	Program memory, standard ROM, Flash card*1	Standard RAM
Q00UJCPU	Program memory: 1 step/4 bytes Standard ROM: 64 steps/256 bytes	-
Q00UCPU, Q01UCPU	Program memory: 1 step/4 bytes Standard ROM: 128 steps/512 bytes	512 bytes
Q02UCPU, Q03UDCPU, Q04UDHCPU,Q06UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU	Program memory: 1 step/4 bytes Standard ROM, Flash card: 128 steps/512 bytes	
Q10UDHCPU,Q10UDEHCPU,Q13UDHCPU,Q13UDEHCPU	Program memory: 1 step/4 bytes Standard ROM: 256 steps/1024 bytes Flash card: 128 steps/512 bytes	
Q20UDHCPU,Q20UDEHCPU,Q26UDHCPU,Q26UDEHCPU	Program memory: 1 step/4 bytes Standard ROM: 512 steps/2048 bytes Flash card: 128 steps/512 bytes	

*1: The file size unit of the Flash card is applied when a file is written to the Flash card by [Online] → [Write the program memory to ROM] in GX Developer. (☞ Section 5.1.7(1)(a))

(b) File size unit for each memory card

Table5.10 File size unit for each memory card

Type	Memory card model	File size unit (cluster size)
SRAM card	Q2MEM-1MBS	512 bytes
	Q2MEM-2MBS	1024 bytes
	Q3MEM-4MBS	1024 bytes
	Q3MEM-8MBS	4096 bytes
Flash card*1	Q2MEM-2MBF	1024 bytes
	Q2MEM-4MBF	1024 bytes
ATA card	Q2MEM-8MBA	4096 bytes
	Q2MEM-16MBA	4096 bytes
	Q2MEM-32MBA	2048 bytes

*1: The file size unit of the Flash card is applied when:

- file is written to the Flash card by [Online] → [Write to PLC (Flash ROM)] in GX Developer. (☞ Section 5.1.7(1)(b))
- file is written to the Flash card by GX Developer without accessing the CPU module

(2) Calculation example of memory capacity

The following shows an calculation example of memory capacity when the parameters and sequence program are written to the program memory.

(a) Conditions

1) CPU module to be written: Q26UDHCPU

2) Writing file

Table5.11 File sizes

File name	File size*1
PARAM.QPA (parameter file)	464 bytes
MAIN.QPG (sequence program)	525 steps/2100 bytes*2

*1: For the file size, refer to (1)(a) in this section.

*2: This indicates the program size (file header + execution program) displayed on the GX Developer screen.

(☞ Section 5.2)

3) Reserved area for online change: 500 steps/2000 bytes

(b) Memory capacity calculation

The memory capacity is calculated in units of file sizes of the CPU module to be written.

The file size unit of the Q26UDHCPU in this example is 1 step/4 bytes.(☞ (1) in this section)

1) Calculation of parameter file size

Since the parameter file size is 464 bytes, 116 steps/464 bytes is occupied in the program memory.




Figure 5.27 Occupation in units of the file size (parameter file)

2) Calculation of program size

The program size is found by the formula: sequence program size + reserved area for online change.
Since a program is stored in units of file sizes (1 step), only the amount equal to the program size is occupied.

3) Result

The calculation results of the memory capacities are as shown below.

Table5.12 Calculation results of memory capacities

File name	File size		Memory capacity
PARAM.QPA	464 bytes		116 steps (464 bytes)
MAIN.QPG	Sequence program size	525 steps	1025 steps (4100 bytes)
	Reserved area for online change	500 steps	
	Total	1025 steps	
Total memory capacity			1141 steps (4564 bytes)

CHAPTER6 FUNCTIONS

This chapter describes the functions of the Universal model QCPU.

6.1 Function List

Table6.1 lists the functions of the Universal model QCPU.

Table6.1 Function list

Item	Description	Q00UJ CPU	Q00UCPU, Q01UCPU	Q02U CPU	QnUD(H) CPU	Built-in Ethernet port QCPU	Reference
Constant scan	Executes a program in a set time interval regardless of its scan time.	○	○	○	○	○	Section 6.2
Latch function	Holds the device data even at power OFF or reset.	○	○	○	○	○	Section 6.3
Output status selection when the status changed from STOP to RUN	Selects the output (Y) status (outputting the same status prior to STOP or clearing the status) when the CPU module status is switched from STOP to RUN.	○	○	○	○	○	Section 6.4
Clock function	Reads the internal clock data of the CPU module to use it for time management.	○	○	○	○	○	Section 6.5
Remote RUN/STOP	Runs or stops the program operations in the CPU module externally.	○	○	○	○	○	Section 6.6.1
Remote PAUSE	Stops the program operations in the CPU module externally, holding the status of outputs (Y).	○	○	○	○	○	Section 6.6.2
Remote RESET	Resets the CPU module externally when the CPU module is in a STOP status.	○	○	○	○	○	Section 6.6.3
Remote latch clear	Clears the latch data in the CPU module when the CPU module is in a STOP status.	○	○	○	○	○	Section 6.6.4
Input response time selection	Selects input response time values for the Q series-compatible input modules, I/O combined modules, high-speed input modules, and interrupt modules.	○	○	○	○	○	Section 6.7
Error time output mode setting	Sets whether to clear or retain the output to the Q series compatible output modules, I/O combined modules, intelligent function modules, and interrupt modules at the time of a stop error of the CPU module.	○	○	○	○	○	Section 6.8

○: Supported, △: Partly supported, ×: Not supported

(To the next page)

Table6.1 Function list (Continued)

Item	Description	Q00UJ CPU	Q00UCPU, Q01UCPU	Q02U CPU	QnUD(H) CPU	Built-in Ethernet port QCPU	Reference
H/W error time PLC operation mode setting	Sets whether to stop or continue operations in the CPU module when a hardware error has occurred in an intelligent function module or interrupt module.	○	○	○	○	○	Section 6.9
Intelligent function module switch setting	Makes settings for the intelligent function modules and interrupt modules. (Refer to manuals of intelligent function modules and interrupt modules for setting details.)	○	○	○	○	○	Section 6.10
Monitor function	Reads the status of programs and devices in the CPU module by GX Developer.	○	○	○	○	○	Section 6.11
Monitor condition setting	Specifies the monitoring timing of the CPU module with device condition or step number.	×	×	△ *1	△ *1	○	Section 6.11.1
Local device monitor/test	Monitors and/or tests the local devices of the specified program by GX Developer.	×	○	○	△ *1	○	Section 6.11.2
External input/output forced on/off	Forcibly turns on/off the external input/output of the CPU module by GX Developer.	○	○	△ *1	△ *1	○	Section 6.11.3
Executional conditioned device test	Changes a device value within the specified step of a sequence program.	○	○	△ *1	△ *1	○	Section 6.11.4
Online change	Writes programs when the CPU module is in the RUN status.	○	○	○	○	○	Section 6.12
Program monitor list	Displays the scan time and execution status of the program being executed.	○	○	○	○	○	Section 6.13.1
Interrupt program monitor list	Displays the number of executions of interrupt programs.	○	○	○	○	○	Section 6.13.2
Scan time measurement	Measures the execution time of the area specified by the steps in a program.	○	○	△ *1	△ *1	○	Section 6.13.3
Sampling trace function	Continuously samples the specified device data at a preset timing.	×	○	○	○	○	Section 6.14
Debug function from multiple GX Developers	Enables simultaneous debugging by multiple GX Developers.	○	○	○	○	○	Section 6.15
Watchdog timer	Monitors operational delays caused by hardware failure or program error of the CPU module.	○	○	○	○	○	Section 6.16
Self-diagnostic function	Self-diagnoses the CPU module to see whether an error exists or not.	○	○	○	○	○	Section 6.17
Error history	Stores the result of self-diagnostics to the memory as error history data.	○	○	○	○	○	Section 6.18

○: Supported, △: Partly supported, ×: Not supported

(To the next page)

Table6.1 Function list (Continued)

Item	Description	Q00UJ CPU	Q00UCPU, Q01UCPU	Q02U CPU	QnUD(H) CPU	Built-in Ethernet port QCPU	Reference
System protection	Prevents the programs from being modified from GX Developer, serial communication module, and Ethernet module.	○	○	○	○	○	Section 6.19
Password registration	Prohibits writing/reading data to/from each file in the CPU module using GX Developer.	○	○	○	○	○	Section 6.19.1
Remote password	Prevents unauthorized access from external devices such serial communication module and Ethernet module.	○	○	○	○	○	Section 6.19.2
System display	Monitors the system configuration using GX Developer.	○	○	○	○	○	Section 6.20
LED indication	Displays the operating status of the CPU module with LEDs on the front of the module.	○	○	○	○	○	Section 6.21
LED indication priority	Sets whether to indicate an error with LED according to the priority of each error.	○	○	○	○	○	Section 6.21.2
Interrupt from intelligent function module	Executes an interrupt program at the time of interrupt request from the intelligent function module.	○	○	○	○	○	Section 6.22
Serial communication function	Connects the RS-232 interface of the CPU module and the personnel computer or HMI with RS-232 cable and communicates in the MC protocol.	○	○	△ *1	×	×	Section 6.23
Service processing setting	Specifies the service processing count or time to be executed in END processing.	○	○	○	○	○	Section 6.24.1
Initial device value	Registers data used in programs with devices and the buffer memories of the intelligent function modules and special function modules without programs.	○	○	○	○	○	Section 6.25
Battery life-prolonging function	Prolongs a battery life by holding only clock data in the battery.	○	○	○	○	○	Section 6.26
Memory check function	Checks whether data in the memories of the CPU module are not changed due to excessive electric noise.	○	○	○	○	○	Section 6.27
Latch data backup to standard ROM function	Backs up latch data such as device data and error history without using a battery.	○	○	○	○	○	Section 6.28
Writing/reading device data to/from standard ROM	Writes/reads device data to/from standard ROM.	○	○	○	○	○	Section 6.29
CPU module change function with memory card	Backs up data in the CPU module to a memory card and restores the backup data to another CPU module.	×	×	△ *1	△ *1	△ *1	Section 6.30

○: Supported, △: Partly supported, ×: Not supported

*1: Availability depends on the version of the CPU module. (☞ Appendix 2)

6.2 Constant Scan

(1) Definition

Scan time of the CPU module is not constant because the processing time varies depending on the execution status of instructions used in a sequence program.

This function allows sequence programs to be executed repeatedly, maintaining its scan time constant.

(2) Application

I/O refresh is performed before every sequence program execution.

This function is used to maintain I/O refresh intervals constant even if the execution time of each sequence program differs.




Figure 6.1 Constant scan operation

(3) Constant scan time setting

Set a constant scan time value in the PLC RAS tab of the PLC parameter dialog box.
The setting range is 0.5 to 2000ms (in increments of 0.5ms).
When not executing the constant scan function, leave the constant scan time setting box blank.




Figure 6.2 When the constant scan time is set to 10ms

(a) Condition

The constant scan time needs to satisfy the following relational expression.

(WDT setting time) > (Constant scan setting time) >
(Sequence program maximum scan time)

If the sequence program scan time is longer than the constant scan setting time, the CPU module detects “PRG. TIME OVER” (error code: 5010).
In this case, the constant scan setting will be ignored and the sequence program scan time will be applied.




Figure 6.3 Operation when the scan time is longer than the constant scan setting time

If the sequence program scan time is longer than the WDT setting time, the CPU module detects “WDT ERROR”.
In this case, the program execution will be stopped.

(4) Waiting time from when END processing is executed until next scan starts

Sequence program processing is stopped during the waiting time from when END processing of a sequence program is executed until next scan starts.

(a) When an interrupt factor occurs during waiting time

Either of the following programs is executed.

- Interrupt program
- Fixed scan execution type program

(b) When a service processing parameter is set

The communication service processing with peripherals (such as GX Developer) and intelligent function modules is enabled during the waiting time by setting a service processing parameter. (☞ Section 6.24.1)

(5) Constant scan accuracy

The constant scan accuracy is 0.01ms.

However, when any program indicated below is being executed, the constant scan time may increase.

(a) Interrupt program or fixed scan execution type program

Interrupts are disabled while an interrupt program or fixed scan execution type program is executed. Even if the constant scan time runs out during execution of an interrupt program or fixed scan execution type program, the constant scan cannot be finished.

In this case, the constant scan time may increase by the execution time of the program executed.

6.3 Latch Function

(1) Definition

This function holds data in each device of the CPU module when:

- the CPU module is powered off and then on,
- the CPU module is reset, or
- power failure occurs exceeding the allowable momentary power failure time.

Data in each device of the CPU module is cleared and set back to its default (bit device: off, word device: 0) without using the latch function.

(2) Application

This function is used to hold the data managed by sequential control and continue control operation especially when the CPU module is powered off and then on.

(3) Program operation when the latch function is use

Program operation is the same, regardless of the latch status.

(4) Devices that can be latched

The following devices can be latched.(By default, only the latch relay is enabled for latch.)

- Latch relay (L)
- Link relay (B)
- Annunciator (F)
- Edge relay (V)
- Timer (T)
- Retentive timer (ST)
- Counter (C)
- Data register (D)
- Link register (W)

Point

When the battery life-prolonging function (☞ Section 6.26) is set, the latch relay cannot be latched.

(5) Latch range setting

Set a latch range in the Device tab of the PLC parameter dialog box.

There are two types of latch range settings: the latch clear operation enable range setting (Latch (1)) and the latch clear operation disable range setting (Latch (2)).




Figure 6.4 Latch range setting

Point

The latch range of the file register (ZR), extended data register (D), and extended link register (W) can also be set.

After selecting "Use the following file." and setting the capacity of the file register in the PLC file tab of the PLC parameter dialog box, set a latch range of the file register (ZR), extended data register (D), and extended link register (W). (For the extended data register (D) and extended link register (W), assign a part of the file register area.)

If "Use the same file name as the program." is selected in the PLC file tab of the PLC parameter dialog box, a latch range of the file register (ZR), extended data register (D), and extended link register (W) cannot be set. (All data in the file register will be latched.)

The data outside the latch range will be cleared when the CPU module is powered off and then on or is reset.




Figure 6.5 Latch range setting

When the file register file to be used is switched with the QDRSET instruction, the latch range setting of the file register will be invalid.

After switching, regardless of the latch range setting, whole range of the file register will be latched.

(6) Device data latch method and influence on the scan time

Data latch processing is performed during END processing.

For this reason, the scan time increases.

Consider an influence on the scan time when latching devices. (☞ Section 10.1.2)

Point

To shorten the scan time due to latch, minimize the number of latch points (latch (1) setting, latch (2) setting, and latch relay (L)) as much as possible.
The number of latch points can be reduced by performing the following.

- Move data to be latched to the file register.
- Store device data that is less frequently updated in the standard ROM with the SP.DEVST instruction. (The device data stored in the standard ROM can be read with the S(P).DEVLD instruction.)
  ☞ QCPU Programming Manual (Common Instructions)

(7) Device data latch clear

Table6.2 shows the status of device data when the latch clear operation is performed.

Table6.2 Status when the latch clear operation is performed

Latch setting	Status of data
Device data without latch setting	Cleared
Device data in the "Latch (1)" range	Cleared
Device data in the "Latch (2)" range	Held*1

*1: For the clearing method, refer to Section 3.7.

Point

Data in the file register (R or ZR) will not be cleared by the latch clear operation.
To clear data in the file register (R or ZR), perform data clear operation by a sequence program or GX Developer.
(☞ Section 9.7.3)

(8) Precautions

(a) When a local device or initial device value is specified

Device data cannot be latched even if the device has been latch-specified,

(b) Use of battery

Device data in the latch range are held with the battery installed to the CPU module.

- Even for the boot operation, the battery is required to latch device data.
- Note that if the battery connector is disconnected from the connector of the CPU module while the power supply for the programmable controller is off, device data in the latch range will not be held and will become undefined.

6.4 Output Mode at Operating Status Change (STOP to RUN)

(1) Definition

When the operating status is changed from RUN to STOP, the CPU module internally stores the outputs (Y) in the RUN status and then turns off all the outputs (Y).
The status of the outputs (Y) when the operating status of the CPU module is changed back from STOP to RUN can be selected from the following two options in the parameter setting in GX Developer.

- Output the output (Y) status prior to STOP. (“Previous state”)
- Clear the output (Y) status. (“Recalculate (output is 1 scan later)”)

(2) Application

This function is used to determine the status of outputs (whether to resume the outputs from the previous status or not) when the operating status is changed from STOP to RUN in the holding circuit.



Figure 6.6 Holding circuit

- When outputting the output (Y) status prior to STOP




Figure 6.7 Timing chart when the parameter is set to "Previous state"

- When clearing the output (Y) status




Figure 6.8 Timing chart when the parameter is set to "Recalculate (output is 1 scan later)"

(3) Operation when the operating status is changed from STOP to RUN

(a) Previous state (Default)

The CPU module outputs the output (Y) status immediately before changing to the STOP status and then performs sequence program operations.

(b) Recalculate (output is 1 scan later)

All outputs are turned off.

The CPU module outputs the output (Y) status after sequence program operations are completed.

For the operation of the CPU module when the output (Y) status is forcibly turned on in the STOP status, refer to (5) in this section.




Figure 6.9 Operation when the operating status is changed from STOP to RUN

(4) Setting the output mode when the operating status is changed from STOP to RUN

Set the output mode when the operating status is changed from STOP to RUN in the PLC system tab of the PLC parameter dialog box.




Figure 6.10 PLC system setting

(5) Precautions

Table6.3 shows the output status of the CPU module when the operating status is changed from STOP to RUN after the outputs (Y) are forcibly turned on in the STOP status.

Table6.3 Output status when the operating status is changed from STOP to RUN after the output forced on operation is performed

Output mode ("Output mode at STOP to RUN") selected	Output status
Previous state	The output status prior to STOP is output. Even if the outputs are forcibly turned on, the on status is not held if the output status prior to STOP was off.
Recalculate (output is 1 scan later)	The on status is held and output.

6.5 Clock Function

(1) Definition

This function reads the internal clock data of the CPU module by a sequence program and uses it for time management.

The clock data is used for time management required for some functions in the system, such as storing date into the error history.

Remark

The Built-in Ethernet port QCPU can set the time in the CPU module automatically by using the time setting function (SNTP client).

☞ QnUCPU User's Manual (Communication via Built-in Ethernet Port)

(2) Clock operation at power off and momentary power failure

Clock operation continues by the internal battery of the CPU module even when the programmable controller is powered off or power failure occurs exceeding the allowable momentary power failure time.

(3) Clock data

Table6.4 shows the details of clock data, which is used internally in the CPU module.

Table6.4 Clock data details

Data name	Description	
Year	Four digits (from 1980 to 2079)	
Month	1 to 12	
Day	1 to 31 (Automatic leap year detection)	
Hour	0 to 23 (24 hours)	
Minute	0 to 59	
Second	0 to 59	
Day of the week	0	Sunday
	1	Monday
	2	Tuesday
	3	Wednesday
	4	Thursday
	5	Friday
	6	Saturday

(4) Changing and reading clock data

(a) Changing clock data

Clock data can be changed either by GX Developer or a program.

1) Changing clock data by GX Developer

Select [Online] → [Set time] to open the Set time screen and change the clock data.




Figure 6.11 Set time screen

2) Changing clock data by a program

Use the DATEWR instruction (instruction for writing clock data) to change the clock data.

Figure 6.12 shows a program for writing the set clock data to D0 to D6.




Figure 6.12 Program example for writing clock data

For details of the DATEWR instruction, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

Point

- When clock data is changed, the clock of 1/1000 second is reset to 0.
- Year data settable by GX Developer is up to 2037.

(b) Reading clock data

To read clock data to the data register, use either of the following instructions in the program.

- DATERD (instruction for reading clock data)
- S(P).DATERD (instruction for reading extended clock data)

Figure 6.13 shows a program for storing the clock data read with the DATERD instruction to D10 to D16.



Figure 6.13 Program example for storing clock data

*1: Figure 6.14 shows the clock data stored in D10 to D16.




Figure 6.14 Clock data stored

For details of the DATERD and S(P).DATERD instructions, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

Point

Clock data can also be written or read by the special relay (SM210 to SM213) and special register (SD210 to SD213). For details of the special relay and special register, refer to CHAPTER 12.

(5) Precautions

(a) Initial clock data setting

No clock data is set at the factory.

Clock data is required for some functions of the CPU module used in the system, such as error history storage, or for intelligent function modules.

Before using the CPU module for the first time, set the time correctly.

(b) Clock data correction

If a part of the clock data is corrected, rewrite the entire clock data to the CPU module.

(c) Clock data setting range

When changing clock data, write data within the range given in (3) in this section.

If data outside of clock range is written to the CPU module, the clock function does not operate normally.

However, the CPU module does not detect an error if the clock data is out of the range.

Table6.5 Example of clock data

	Write operation to the CPU module	CPU module operation
February 30	Executed	An error is not detected.
32 of month 13	Not executed	When the DATEWR instruction is executed, "OPERATION ERROR" (error code: 4100) is detected. When SM210 is turned on, SM211 turns on.

(d) Use for clock data of 1/1000 sec.

1) Function that clock data of 1/1000 sec. can be used

Only the following instructions can use the clock data of 1/1000 sec.

- S(P).DATERD
- S(P).DATE+
- S(P).DATE-

Other instructions cannot use the clock data of 1/1000 sec.

(Such as for reading data by SM/SD, storing the time of error occurrence as error history data, reading data by GX Developer, or reading data by dedicated instructions of other modules.)

2) When clock data is changed

When clock data is changed by GX Developer or instructions (including dedicated instruction of other modules), the clock of 1/1000 sec. is reset to 0.

(6) Clock data accuracy

Accuracy of the clock data varies depending on the ambient temperature as shown below.

Table6.6 Clock data accuracy

Ambient temperature (℃)	Accuracy (Day difference, S)
0	-2.96 to +3.74 (TYP.+1.42)
+ 25	-3.18 to +3.74 (TYP.+1.50)
+ 55	-13.20 to +2.12 (TYP.-3.54)

(7) Clock data comparison

To compare clock data in a sequence program, read the clock data with the DATERD instruction (instruction for reading clock data).

Since the DATERD instruction reads the year data in four digits, the data can be compared by the comparison instruction without any modifications.

6.6 Remote Operation

Remote operation allows to change the operating status of the CPU module externally (by GX Developer or external devices using the MC protocol, with link dedicated instructions of the CC-Link IE controller network module or MELSECNET/H module, or using remote contacts).

There are four types of remote operations:

- Remote RUN/STOP : ☞ Section 6.6.1
- Remote PAUSE : ☞ Section 6.6.2
- Remote RESET : ☞ Section 6.6.3
- Remote latch clear : ☞ Section 6.6.4

6.6.1 Remote RUN/STOP

(1) Definition

This operation changes the operating status of the CPU module externally to RUN or STOP, keeping the RUN/STOP/RESET switch of the CPU module in the RUN position.

(2) Application

This operation is useful to run or stop the CPU module remotely when:

- the CPU module is inaccessible, or
- the CPU module is in a control panel.

(3) Program operation

The program operation will be as follows when the remote RUN/STOP operation is performed.

(a) Remote STOP

The CPU module executes a program until the END instruction and changes its operating status to STOP.

(b) Remote RUN

The CPU module changes its operating status to RUN and executes a program from the step 0. (The remote RUN operation must be performed to the CPU module whose operating status has been changed to STOP by the remote STOP operation.)

(4) Executing method

There are three methods for performing the remote RUN/STOP operation.

- Using a RUN contact
- By GX Developer or an external device using the MC protocol
- With link dedicated instructions of the CC-Link IE controller network module or MELSECNET/H module

(a) Using a RUN contact

Set a RUN contact in the PLC system tab of the PLC parameter dialog box.

The settable device range is X0 to 1FFF.

The remote RUN/STOP operation can be performed by turning on/off the set RUN contact.

- When the RUN contact is turned off, the CPU module status changes to RUN.
- When the RUN contact is turned on, the CPU module status changes to STOP.




Figure 6.15 Remote RUN/STOP using a RUN contact

(b) By GX Developer or an external device using the MC protocol

Select [Online] → [Remote operation] in GX Developer.

To perform the remote RUN/STOP operation from an external device, use the MC protocol command.

☞ Q Corresponding MELSEC Communication Protocol Reference Manual




Figure 6.16 Remote RUN/STOP by GX Developer or an external device

(c) With link dedicated instructions of the CC-Link IE controller network module or MELSECNET/H module

The remote RUN/STOP operation by link dedicated instructions of the CC-Link IE controller network module or MELSECNET/H module can change the RUN/STOP status of the CPU module.
For details, refer to the following.

☞ Reference manual of each network module

(5) Precautions

Pay attention to the following since the STOP status is given priority over the RUN status.

(a) Timing of changing to the STOP status

The operating status of the CPU module is changed to STOP when the remote STOP operation is performed from any one of the following: RUN contact, GX Developer, or an external device using the MC protocol.

(b) When changing the status back to RUN

To change the operating status back to RUN after the CPU module status was changed to STOP by the remote STOP operation, perform the remote RUN operation in the same order for the remote STOP operation.

Point

- The definitions of the RUN/STOP status are described below.
  - RUN status•••A status where sequence program operations are repeatedly performed in a loop between the step 0 and the END or FEND instruction.
  - STOP status•••A status where sequence program operations are stopped. All outputs (Y) are turned off.
- After being reset, the operating status of the CPU module becomes the one set with the RUN/STOP/RESET switch.

6.6.2 Remote PAUSE

(1) Definition

This operation changes the operating status of the CPU module externally to PAUSE, keeping the RUN/STOP/RESET switch of the CPU module in the RUN position.
PAUSE status is a status where sequence program operations in the CPU module are stopped, holding the status (on or off) of all outputs (Y).

(2) Application

This operation is useful, especially during the process control, to hold the on status of outputs (Y) even after the operating status of the CPU module is switched from RUN to STOP.

(3) Executing method

There are two methods for performing the remote PAUSE operation.

- Using a PAUSE contact
- By GX Developer or an external device using the MC protocol

(a) Using a PAUSE contact

Set a PAUSE contact in the PLC system tab of the PLC parameter dialog box.
The settable device range is X0 to 1FFF.

- The PAUSE contact (SM204) turns on during END processing of the scan where both the PAUSE contact and PAUSE enable coil (SM206) turn on.
  The CPU module executes one more scan until the END instruction after the scan where the PAUSE contact turns on, and then changes its operating status to PAUSE. In the PAUSE status, the program operations are stopped.
- When the PAUSE contact or SM206 is turned off, the PAUSE status will be canceled and the CPU module will restart the sequence program operation from the step 0.




Figure 6.17 Remote PAUSE using a PAUSE contact

Point

Setting of only a PAUSE contact is not allowed.
When setting a PAUSE contact, set a RUN contact as well.

(b) By GX Developer or an external device using the MC protocol

Select [Online] → [Remote operation] in GX Developer.

To perform the remote PAUSE operation from an external device, use the MC protocol command.

☞ Q Corresponding MELSEC Communication Protocol Reference Manual

- The PAUSE contact (SM204) turns on during END processing of the scan where the remote PAUSE command is executed.
  The CPU module executes one more scan until the END instruction after the scan where the PAUSE contact turns on, and then changes its operating status to PAUSE. In the PAUSE status, the program operations are stopped.
- Upon execution of the remote RUN command, the CPU module will restart the sequence program operations from the step 0.




Figure 6.18 Remote PAUSE by GX Developer or an external device

(4) Precautions

(a) When forcibly keeping output status

To forcibly keep the output status (on or off) in the PAUSE status, provide an interlock with the PAUSE contact (SM204).




Figure 6.19 Program example for forcibly keeping output status in the PAUSE status

6.6.3 Remote RESET

(1) Definition

This operation resets the CPU module externally when the CPU module is in the STOP status.
Even if the RUN/STOP/RESET switch is in the RUN position, this operation can be performed when the module is stopped due to an error detected by the self-diagnostics function.

(2) Application

This operation is useful to reset the CPU module remotely when an error occurs in the CPU module placed in an inaccessible location.

(3) Executing method

This operation can only be performed by GX Developer or an external device using the MC protocol.

- Select [Online] → [Remote operation] in GX Developer.
- To perform the remote RESET operation from an external device, use the MC protocol command.

☞ Q Corresponding MELSEC Communication Protocol Reference Manual

Point

Before performing the remote RESET operation, select the "Allow" checkbox for the remote RESET operation in the PLC system tab of the PLC parameter dialog box, and then write the parameter setting to the CPU module.
Without the preset parameter setting, the operation cannot be performed.




Figure 6.20 Parameter setting required for the remote RESET operation

(4) Precautions

(a) Remote RESET in the RUN status

When the CPU module is in the RUN status, the remote RESET operation cannot be performed. To perform the operation, change the operating status of the CPU module to STOP by the remote STOP or similar operation.

(b) Status after reset processing

After reset processing of the remote RESET operation is completed, the CPU module will be placed in the operating status set by the RUN/STOP/RESET switch.

If the RUN/STOP/RESET switch is set to STOP, the CPU module will be in the STOP status. If the switch is set to RUN, the CPU module will be in the RUN status.

Point

- If the remote RESET operation is performed to the CPU module which is stopped due to an error, note that the CPU module will be placed in the operating status set by the RUN/STOP/RESET switch after reset processing is completed.

- If the CPU module cannot be reset by the remote RESET operation from GX Developer, check that the "Allow" checkbox for the remote RESET operation in the PLC system tab of the PLC parameter dialog box is selected.
  If the checkbox is not selected, the CPU module cannot be reset even after the remote RESET processing from GX Developer is completed.

(c) When an error occurs due to noise

Note that the CPU module may not be reset by the remote RESET operation from GX Developer. In this case, reset the CPU module using the RUN/STOP/RESET switch or power off and then on the CPU module.

6.6.4 Remote latch clear

(1) Definition

This function resets the latched device data from GX Developer or an external device when the CPU module is in the STOP status.

(2) Application

This function is useful in the following cases if used together with the remote RUN/STOP operation.

- When the CPU module is inaccessible
- To clear latched device data in the CPU module in a control panel externally

(3) Executing method

This operation can only be performed by GX Developer or an external device using the MC protocol.

- Select [Online] → [Remote operation] in GX Developer.
- To execute the remote latch clear operation from an external device, use the MC protocol command.

  ☞ Q Corresponding MELSEC Communication Protocol Reference Manual

To perform the remote latch clear operation, follow the following steps.

1) Change the operating status of the CPU module to STOP by the remote STOP operation.
2) Clear the latched device data in the CPU module by the remote latch clear operation.
3) After remote latch clear processing is completed, perform the remote RUN operation to return the operating status to RUN.

(4) Precautions

(a) Latch clear in the RUN status

The latch clear operation cannot be performed when the CPU module is in the RUN status.

(b) Latch clear enabled range

There are two kinds of latch range can be set in the Device tab of the PLC parameter dialog box: latch clear operation enable and disable range.
Remote latch clear operation resets only the data set in the "Latch (1)" (latch clear operation enable range).
For the method for resetting the device data in the latch clear operation disable range, refer to Section 3.7(2)(c).

(c) Devices that are reset by the remote latch clear operation

Devices that are not latched are also reset when the remote latch clear operation is performed.

6.6.5 Relationship between remote operation and RUN/STOP status of the CPU module

(1) Relationship between remote operation and RUN/STOP status of the CPU module

Table6.7 shows the operating status of the CPU module according to the combination of remote operation and RUN/STOP status.

Table6.7 Operating status of the CPU module

RUN/STOP status	Remote operation				
	RUN[*1]	STOP	PAUSE[*2]	RESET[*3]	Latch clear
RUN	RUN	STOP	PAUSE	Operation disabled[*4]	Operation disabled[*4]
STOP	STOP	STOP	STOP	RESET[*5]	Latch clear

*1: When performing the operation using a RUN contact, "RUN-PAUSE contact" must be set in the PLC system tab of the PLC parameter dialog box.

*2: When performing the operation using a PAUSE contact, "RUN-PAUSE contact" must be set in the PLC system tab of the PLC parameter dialog box.
In addition, the PAUSE enable coil (SM206) must be turned on.

*3: The "Allow" checkbox for the remote RESET operation must be selected in the PLC system tab of the PLC parameter dialog box.

*4: The remote RESET and remote latch clear operations are enabled if the CPU module status is changed to STOP by the remote STOP operation.

*5: The STOP status includes a case where the CPU module is stopped due to an error.

(2) Remote operations from a single GX Developer

When remote operations are performed from a single GX Developer, the operating status of the CPU module will be the status of the last remote operation performed.

(3) Remote operations from multiple GX Developers

Any remote operation from other GX Developers via other stations cannot be performed to the CPU module where remote operations are being performed from GX Developer connected.
To perform any remote operations from another GX Developer, cancel the remote operation by performing the remote RUN operation from the same GX Developer that is performing the current remote operation.
For example, even if the remote STOP or RUN operation is performed from another GX Developer to the CPU module where the remote PAUSE operation has been performed by GX Developer connected, the CPU module remains in the PAUSE status.
Once after the remote RUN operation is performed from the same GX Developer that is performing the remote PAUSE operation, remote operations from another GX Developer will be enabled.

6.7 Q Series-compatible Module Input Response Time Selection (I/O Response Time)

(1) Definition

This function changes the input response time for each Q series-compatible module.

Table6.8 shows the modules available for input response time change and selectable time settings.

Table6.8 Modules available for input response time change

Module name	Type	Settable time setting
Input module	"Input"	1ms, 5ms, 10ms, 20ms, 70ms (Default: 10ms)
I/O combined module	"I/O Mix"	
High-speed input module	"Hi Input"	0.1ms, 0.2ms, 0.4ms, 0.6ms, 1ms (Default: 0.2ms)
Interrupt module	"Interrupt"	

The Q series-compatible modules in the table above take in external inputs within the set time here.




Figure 6.21 Input response time

(2) Input response time setting

Set input response time values in the I/O assignment tab of the PLC parameter dialog box.

1) Make I/O assignment for the target module.

2) Click the Detailed setting button.

3) On the screen opened, select an input response time value ("I/O response time").




Figure 6.22 Input response time setting

(3) Precautions

(a) When input response time is shortened

The shorter the input response time is, the more the CPU module is susceptible to noise. Consider the operating environment when setting input response time values.

(b) Enabling the setting

The input response time setting will be enabled when:

- the CPU module is powered off and then on, or
- the CPU module is reset.

6.8 Error Time Output Mode Setting

(1) Definition

This function determines the output mode (clear or hold) from the CPU module to the Q series-compatible output modules, I/O combined modules, intelligent function modules, and/or interrupt module when a stop error occurs in the CPU module.

(2) Error time output mode setting

Set the error time output mode in the I/O assignment tab of the PLC parameter dialog box.

1) Make I/O assignment for the target module.

2) Click the Detailed setting button.

3) On the screen opened, select "Clear" or "Hold". (Default: "Clear")




Figure 6.23 Error time output mode setting

(3) Precautions

The error time output setting will be enabled when:

- the CPU module is powered off and then on, or
- the CPU module is reset.

Failure to perform either of the operations above after changing the error time output mode setting will result in "PARAMETER ERROR" (error code: 3000).

6.9 H/W Error Time PLC Operation Mode Setting

(1) Definition

This function determines the program operation mode (stop or continue) of the CPU module when a hardware error occurs in an intelligent function module or interrupt module.

(2) H/W error time PLC operation mode setting

Set the H/W error time PLC operation mode in the I/O assignment tab of the PLC parameter dialog box.

1) Make I/O assignment for the target module.

2) Click the Detailed setting button.

3) On the screen opened, select "Stop" or "Continue". (Default: "Stop")




Figure 6.24 H/W error time PLC operation setting

(3) Precautions

The H/W error time PLC operation setting will be enabled when:

- the CPU module is powered off and then on, or
- the CPU module is reset.

6.10 Intelligent Function Module Switch Setting

(1) Definition

This function sets the switches of each Q series-compatible intelligent function module and interrupt module in GX Developer.

(2) Writing the switch settings

The switch settings will be written from the CPU module to each intelligent function module and interrupt module when:

- the CPU module is powered off and then on, or
- the CPU module is reset.




Figure 6.25 Writing the switch settings to each intelligent function module

(3) Switch settings

Set the switch details for each intelligent function module and interrupt module in the I/O assignment tab of the PLC parameter dialog box.

1) Make I/O assignment for the target module.

2) Click the Switch setting button.

3) Set the switch details for each module.




Figure 6.26 Switch settings

(4) Precautions

(a) Switch setting details of each module

For the switch setting details of each intelligent function module or interrupt module, refer to the manual for the intelligent function module or interrupt module used.

(b) Enabling the setting

The switch settings of each intelligent function module or interrupt module will be enabled when:

- the CPU module is powered off and then on, or
- the CPU module is reset.

6.11 Monitor Function

(1) Definition

This function reads program and device data in the CPU module, and intelligent function module status using GX Developer.

Table6.9 List of monitor functions and availability

Monitor function	Availability					Reference
	Q00UJ CPU	Q00UCPU, Q01UCPU	Q02UCPU	QnUD(H) CPU	Built-in Ethernet port QCPU	
Ladder monitor	○	○	○	○	○	GX Developer Version 8 Operating Manual
Device/buffer memory batch monitor	○	○	○	○	○	
Entry data monitor	○	○	○	○	○	
Device test	○	○	○	○	○	
Entry ladder monitor	○	○	○	○	○	
Monitor condition setting	×	×	△ *1	△ *1	○	Section 6.11.1
Local device monitor/test	×	○	○	○	○	Section 6.11.2
External input/output forced on/off	○	○	△ *1	△ *1	○	Section 6.11.3
Executional conditioned device test	○	○	△ *1	△ *1	○	Section 6.11.4

○ : Available, △ : Available with restrictions, × : Not available

*1: Availability depends on the version of the CPU module. (☞ Appendix 2)

(2) Monitor request timing and displayed data

The CPU module processes monitor requests from GX Developer during END processing.
For this reason, the data in the CPU module at the time of END processing will be displayed in GX Developer.

(3) Monitor with monitor condition settings

By setting the monitor condition in GX Developer during debugging, the program operation status in the CPU module can be monitored under the specified condition.
Besides, the monitoring status under the specified condition can be held by setting the monitoring stop condition.

(4) Local device monitor

If multiple programs are executed and local devices are used, data in local devices of each program can also be monitored.

6.11.1 Monitor condition setting Note6.1

This function is used to monitor data in the CPU module under the specified condition.

(1) Monitor condition setting for ladder monitor

Switch GX Developer into monitor mode.

Select [Online] → [Monitor] → [Monitor condition setup] to open the Monitor condition screen.

Set the condition as shown below to monitor data on the rising edge of Y70.




Figure 6.27 Monitor condition setting screen

(a) When only a step number is specified

Monitor data is collected when the status immediately before execution of the specified step becomes the specified status.

The following status can be specified.

- When the operation of the specified step changes from the non-execution status to the execution status: <-P->
- When the operation of the specified step changes from the execution status to the non-execution status: <-F->
- Always only when the operation of the specified step is in execution: <ON>
- Always only when the operation of the specified step is in non-execution: <OFF>
- Always regardless of the status of the operation of the specified step: <Always>

Note6.1 Universal

The Q00UJCPU, Q00UCPU, and Q01UCPU do not support the monitor condition setting.

When setting monitor condition for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer. (Appendix 2)

Point

- If a step between the AND/OR blocks is specified as a monitor condition, monitor data is collected when the status previous to execution of the specified step is specified by the LD instruction.
  The monitor timing depends on the step specified as a monitor condition.
  The following shows examples of monitoring when the step 2 is on (Step No. [2] = <ON>).

  - When the step 2 is connected by the AND instruction:
    In Figure 6.28, the monitor execution condition is established when both X0 and X1 are on.




Figure 6.28 When the step 2 is connected by the AND instruction

  - When the step 2 is connected in the middle of the AND/OR block:
    In Figure 6.29, the monitor execution condition is established when X1 turns on. (The on/off status of X0 does not affect the establishment of the monitor execution condition.)




Figure 6.29 When the step 2 is connected in the middle of the AND/OR block

  - If the start of a ladder block other than the step 0 is specified for the step number as a detailed condition, monitor data is collected when the execution status of the instruction immediately before execution becomes the specified status.
    If (Step No. [2] = <ON>) is specified in the following ladder, monitor data is collected when OUT Y10 turns on.




Figure 6.30 When the start of a ladder block other than the step 0 is specified for the step number

- Be sure to set the condition of the step set as step No.0 to "Always".

(b) When only a device is specified

Either word device or bit device can be specified.

1) When a word device is specified

Monitor data is collected when the current value of the specified word device becomes the specified value.
Enter the current value (in decimal or hexadecimal).

2) When a bit device is specified

Monitor data is collected when the execution status of the specified bit device becomes the specified status.
Select the execution condition (on the rising edge or falling edge).

(c) When a step number and device are specified

Monitor data is collected when the status previous to execution of the specified status or the status (current value) of the specified bit device (word device) becomes the specified value.

Point

When "Step No.[100]=<-P->, Word device [D1]=[K5]" is specified as an execution condition, a monitor execution condition is established on the rising edge of the step 100 and also D1=5.



Figure 6.31 When the rising edge of the step 100 and D1=5 are specified

The monitor interval of GX Developer depends on the processing speed of GX Developer.
For the monitor execution conditions established at the interval shorter than the monitor interval of GX Developer, monitor is executed only when the monitor execution condition is established at the monitor timing of GX Developer.




Figure 6.32 Monitor timing of GX Developer

(2) Monitor stop condition setting

Set a monitor stop condition on the screen opened by selecting [Online] → [Monitor] → [Monitor stop condition setup].

Set the condition as shown in Figure 6.33 to stop a monitor operation on the rising edged of Y71.




Figure 6.33 Monitor stop condition screen

(a) When a device is specified

Either word device or bit device can be specified.

1) When a word device is specified

A monitor operation is stopped when the current value of the specified word device becomes the specified value.

Enter the current value (in decimal, hexadecimal, 16-bit integer, 32-bit integer, or real number).

2) When a bit device is specified

A monitor operation is stopped when the execution status of the specified bit device becomes the specified status.

Select the execution condition (on the rising edge or falling edge).

(b) When a step number is specified

A monitor operation is stopped when the execution status of the step specified as a monitor condition becomes the specified status.

The following status can be specified.

- When the operation of the specified step changes from the non-execution status to the execution status: <-P->
- When the operation of the specified step changes from the execution status to the non-execution status: <-F->
- Always only when the operation of the specified step is in execution: <ON>
- Always only when the operation of the specified step is in non-execution: <OFF>
- Always regardless of the status of the operation of the specified step: <Always>

If a step number is not specified, a monitor operation is stopped after END processing of the CPU module.

(3) Precautions

(a) Files to be monitored

When monitor conditions are set, GX Developer monitors the file displayed on the screen.
Select [Online] → [Read from PLC] in GX Developer and read data from the CPU module so that the file name in the CPU module to be monitored matches the file named displayed on the screen of GX Developer.

(b) No file register setting

If the file register is monitored when there is no file register used, "FFFFH" is displayed.

(c) Device assignment

For monitor operation, device assignment in the CPU module and GX Developer must be the same.

(d) Monitoring the buffer memory of an intelligent function module

When monitoring the buffer memory of an intelligent function module, the scan time increases for the same reason for execution of the FROM/TO instructions.

(e) Monitoring by multiple users

When multiple users are performing monitoring at the same time, pay attention to the following.

- High speed monitor can be performed by increasing 1K step per monitor file of other stations in the system area when formatting the program memory or setting a parameter in the Boot file tab of the PLC parameter dialog box.
  Up to 15 stations can be set as the station monitor file, but the program space will be reduced.
- If the monitor condition or monitor stop condition is set, only one user can perform monitoring.

(f) Setting a monitor stop condition

A monitor stop condition can be set only in the ladder monitor.

(g) Specifying the same device as a condition

When specifying the same device as a monitor condition or monitor stop condition, set the on/off status as well.

(h) Specifying a step number as a monitor condition

If an instruction in the specified step is not executed in such cases described below, the monitor condition will not be established.

- The specified step is skipped with the CJ, SCJ, or JMP instruction.
- The specified step is the END instruction and never be executed because the FEND instruction also exists in the program.

(i) During monitor condition registration

Do not reset the CPU module while monitoring conditions are being registered.

(j) Monitor operation with monitor condition setting

When monitor operation with monitor condition setting is performed, other applications on the same personal computer cannot execute any online function using the same route for the monitor operation. The following applications must be noted.

- GX Developer
- Application using MX Component
- MX Sheet

If any online function is executed by other applications using the same route for the monitor operation, the following situations may occur.

- No response is returned from the CPU module for the online function executed. (An online communication function time-out occurs.)
- The CPU module detects an error (error code: 4109) for the online function executed.
- Even when the monitor condition is established in the CPU module, monitoring results cannot be updated for the monitor operation with monitor condition setting.

6.11.2 Local device monitor/test Note6.2

This operation is useful for debugging a program, monitoring local devices (☞ Section 9.14.2) in the program monitored by GX Developer.

(1) Monitoring a local device

Table6.10 shows the monitor operation when the CPU module executes three programs "A", "B", and "C" and D0 to D99 are set as a local device.
(Three programs are to be executed in the order of A→B→C→(END processing)→A→B....)

Table6.10 Data displayed when three programs are executed

Setting	Monitor device	
	D0 (Local device)	D100 (Global device)
When the device is not set as a local device	D0 in the program "C" is monitored.	D100 after the program "C" is executed is monitored.
When the device is set as a local device	D0 in the displayed program is monitored.	D100 after the program "C" is executed is monitored.

Note6.2 Universal
The Q00UJCPU does not support the use of local devices.

When local devices are set to be monitored and the program "B" is displayed for monitoring, the local device(s) used in the program "B" can be monitored.




Figure 6.34 Local device monitor example

(2) Monitoring procedure

The following shows the local device monitoring procedure.




Figure 6.35 Local device monitoring procedure

(3) Precautions

(a) Local devices that can be monitored/tested by a single GX Developer

A single GX Developer can monitor or test local devices in one program at a time.
Local devices in multiple programs cannot be monitored or tested simultaneously.

(b) Number of programs that can be monitored/tested

Local devices in 16 programs can be monitored or tested simultaneously from multiple GX Developers connected to the RS-232 interface of the CPU module or the serial communication module.

(c) Monitoring local devices in a stand-by type program

When local devices in a stand-by type program are monitored, data in local devices are saved and restored.
For this reason, the scan time increases. (☞ Section 9.14.2)

(d) Monitoring local devices in a fixed scan execution type program

When local devices in a fixed scan execution type program are monitored, data in local devices cannot be acquired and "0" is displayed.

6.11.3 External input/output forced on/off Note6.3

The external input/output can forcibly be turned on/off on the screen opened by selecting [Online] → [Debug] → [Forced input output registration/cancellation] in GX Developer.
The information registered for forced on/off can be cancelled by an operation from GX Developer.




Figure 6.36 Forced input output registration/cancellation screen

(1) Input/output operation when a forced on/off operation is performed

There are three kinds of forced on/off operations: forced on ("Set forced ON"), forced off ("Set forced OFF"), and forced on/off cancellation ("Cancel it").
Table6.11 shows the CPU module operation when a forced on/off operation is performed.

Table6.11 Input/output operation when a forced on/off operation is performed

Operation	Input (X) operation	Output (Y) operation
Forced on/off cancellation (no operation)	The CPU module performs sequence program operations using external inputs.	The CPU module outputs the results of sequence program operations externally.
Forced on	The CPU module performs sequence program operations using inputs forcibly turned on.	The CPU module outputs "on" externally regardless of the results of sequence program operations.
Forced off	The CPU module performs sequence program operations using inputs forcibly turned off.	The CPU module outputs "off" externally regardless of the results of sequence program operations.

Note6.3 Universal

When performing an external input/output forced on/off operation for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer. (☞ Appendix 2)

Figure 6.37 shows the input/output operation when a forced on/off operation is performed.




Figure 6.37 Input/output operation when a forced on/off operation is performed

(2) Specifications

(a) CPU module status where input/output can forcibly be turned on/off

Forced on/off can be registered regardless of the operating status (RUN/STOP) of the CPU module.
Note, however, that only input can be forcibly turned on/off during a stop error.
The CPU module outputs on/off data only to Y device.

(b) Registerable devices

Forced on/of can be registered as many as the number of I/O device points in the CPU module.

(c) Target input/output

The following input/output are targeted for a forced on/off operation.

- Input(X) and output (Y) of modules mounted on the base unit
- Input(X) and output (Y) of the CPU module to be refreshed from LX/LY of a CC-Link IE controller network or MELSECNET/H module
- Input(X) and output (Y) of the CPU module to be refreshed from RX/RY of a CC-Link module

When forcibly turning on/off the devices outside the above refresh ranges (for example, empty slots), only input/output in the CPU module device memory are turned on/off and the results are not output externally.

Point

In multiple CPU systems, inputs and outputs of control modules can forcibly turned on/off.
Even when inputs and outputs of non-control modules are registered for forced on/off, the input/output devices in other CPU modules and inputs and outputs of modules controlled by other CPU modules cannot be forcibly turned on/off. (The input/output devices in the host CPU module can forcibly turned on/off.)

(d) Cancelling on/off registration data

The registered forced ON/OFF data can be canceled by GX Developer.

Once the registered data is canceled, the status of the forced on/off registered devices will be as follows.

Table6.12 Status of devices after forced on/off registration data is canceled

Forced on/off registered device		Sequence program operations (on/off) performed	Sequence program operations (on/off) not performed
Input	Input from modules mounted on the base unit	Uses the on/off status input from modules.	
	Input of the CPU module to be refreshed from LX of a CC-Link IE controller network or MELSECNET/H module	Used the on/off status refreshed via CC-Link IE controller network or MELSECNET/H.	
	Input of the CPU module to be refreshed from RX of a CC-Link module	Uses the on/off status refreshed via CC-Link.	
	Input other than above (outside of the refresh range)	Uses the results of sequence program operations.	Holds the forced on/off status.
Output	Output from modules mounted on the base unit	Outputs the results of sequence program operations.	Holds the registered on/off status.
	Output of the CPU module to be refreshed from LY of a CC-Link IE controller network or MELSECNET/H module		
	Output of the CPU module to be refreshed from RY of a CC-Link module		
	Output other than above (outside of the refresh range)	Outputs the results of sequence program operations. (The results are not output externally.)	Holds the forced on/off status.

Forced on/off setting can be cleared by:

- powering off and then on the CPU module,
- resetting the CPU module by the RUN/STOP/RESET switch, or
- resetting the CPU module by the remote RESET operation.

(e) External input/output forced on/off timing

Table6.13 shows the external input/output forced on/off timing.

Table6.13 Forced on/off timing

Refresh area	Input	Output
Input and output of modules mounted on the base unit	• During END processing (input refresh) • At execution of the COM instruction (input refresh) • At execution of an instruction using direct access input (DX) (LD, LDI, AND, ANI, OR, ORI, LDP, LDF, ANDP, ANDF, ORP, ORF) • At execution of the RFS or MTR instruction • At execution of an instruction used for a system interrupt (UDCNT1, UDCNT2, SPD)	• During END processing (output refresh) • At execution of the COM instruction (output refresh) • At execution of an instruction using direct access input (DX) (OUT, SET, DELTA, RST, PLS, PLF, FF, MC, SFT) • At execution of the RFS or MTR instruction • At execution of an instruction used for a system interrupt (PLSY, PWM)
Input and output of the CPU module to be refreshed from LX/LY of a CC-Link IE controller network or MELSECNET/H module	• During END processing (refresh via CC-Link IE controller network or MELSECNET/H) • At execution of the COM instruction • At execution of the ZCOM instruction	
Input and output of the CPU module to be refreshed from RX/RY of a CC-Link module	• During END processing (auto refresh) • At execution of the COM instruction (auto refresh) • At execution of the ZCOM instruction (auto refresh)	

(f) Number of registerable devices

Forced on/off can be registered for 32 devices in total.

(g) When output Y contact is used in a sequence program

On/off operations in a sequence program are given priority.

(h) Checking forced on/off registration status

Forced on/off execution status can be checked by:

- reading the forced on/off registration status by GX Developer,
- flashing of the MODE LED (green), (The MODE LED flashes in green when at least one forced on/off is registered.) or
- the on status of the 1st bit in SD840 (Debug function usage).

Point

- The MODE LED also flashes in green when the executional conditioned device test function is used.
  To check the registration status using the MODE LED, check the status of the executional conditioned device test function as well. (☞ Section 6.11.4)

- When using SD840 to check the registration or cancellation status, remind that SD840 is used to check the status of the executional conditioned device test function as well.

(i) Forcibly turning input or output on/off from multiple GX Developers

Forced on/off can be registered to a single CPU module from multiple GX Developers connected via network. In this case, the last registration will be effective.

For this reason, the forced on/off status which is different from the status actually registered in the CPU module may be displayed on the screen of GX Developer that registered forced on/off earlier.

When the forced on/off registration is performed from multiple GX Developers, click the "Update status" button to update the registered data and execute the function.

(3) Operating procedure

Operating procedure is described below.

- To register forced on/off for a device, select [Online] → [Debug] → [Forced input output registration/cancellation] in GX Developer.
- On the screen opened, specify a device and click the "Set forced ON" or "Set forced OFF" button.




Figure 6.38 Forced input output registration/cancellation screen

Table6.14 Items on the Forced input output registration/cancellation screen

No.	Item	Description
1)	Device	Select the I/O number for which forced on/off is to be registered or cancelled.
2)	Registration status display area	Displays the forced on/off registration status.
3)	Update status	Reads the forced on/off registration status from the CPU module.
4)	Set forced ON/OFF	Registers forced on/off for a device specified.
5)	Cancel it	Cancels forced on/off registered for the device specified.
6)	Clear all	Cancels all forced on/off registration.

6.11.4 Executional conditioned device test Note6.4

This function changes a device value within the specified step of a program.

This enables debugging of the specified ladder block without modifying the program.*1

*1: The executional conditioned device test is not available for the SFC program.

(1) Operation of the executional conditioned device test

A device value will be changed based on the registration data once after the executional conditioned device test setting is registered.

The changed device value becomes effective in the ladder blocks of the specified step number and later.




Figure 6.39 Operation of the executional conditioned device test

Note that a device value is changed within the specified step regardless of an execution status of the instruction in the specified step.




Figure 6.40 Operation example of the executional conditioned device test

Note6.4 Universal

When using the executional conditioned device test in the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer.(Appendix 2)

(2) Available devices and number of settable devices

Table6.15 Available devices and number of settable devices

Type	Available device	Number of settable devices
Bit device	X, Y, M, L, B, F, SB, V, SM, T (contact), ST (contact), C (contact), J□\X, J□\Y, J□\B, J□\SB, FX, FY, DX, and DY	Up to 32 (in total)
Word device	T (current value), ST (current value), C (current value), D*1, SD, W*2, SW, R, ZR, Z, U□\G□, U3E□\G□, J□\W□, J□\SW□, and FD	
	Digit-specified bit device: X, Y, M, L, F, SM, V, B, SB, J□\X, J□\Y, J□\B, and J□\SB	
	Indirect specification (@D0): D, SD, W, SW, R, and ZR (devices specified with @)	

*1: The extended data register (D) is included.
*2: The extended link register (W) is included.

(3) How to check the execution status

The execution status of registered executional conditioned device test can be checked in three different ways:

- By the flash of the MODE LED in green
- By the on status of the first bit of SD840 (Debug function usage)
- By the display on the screen for checking the registration status in GX Developer
  (☞ (4)(d) in this section)

Point

- The MODE LED also flashes in green when the external input/output forced on/off function is used.
  To check the execution status using the MODE LED, check the status of the external input/output forced on/off function as well. (☞ Section 6.11.3)

- When using SD840 to check the execution status, remind that SD840 is used to check the status of the external input/output forced on/off function as well.

(4) Operating instructions

(a) Registering executional conditioned device test settings

Select the registration target step number on the program editing screen in GX Developer. Then, select [Online] → [Debug] → [Executional conditioned device test] → [Register executional conditioned device test].




Figure 6.41 Screen for registering executional conditioned device test settings


Table6.16 Items on the screen for registering executional conditioned device test settings

No.	Item	Setting range	
		For bit device	For word device
1)	Program name	Name of a program registered in the CPU module	
2)	Step No.	0 to (Step number for the END instruction)	
3)	Device	Device listed in (2) in this section	
4)	Execution timing	Before executing instruction / After executing instruction	
5)	Setting value	- (Not specified)	Setting range corresponding to each data type
6)	DEC / HEX	- (Not specified)	DEC (decimal) / HEX (hexadecimal)
7)	Data type*1	- (Not specified)	16 bit integer / 32 bit integer / Real number (single precision) / Real number (Double precision)

*1: When a word device which is index-modified or indirectly-specified is set, only "16 bit integer" can be specified.

1) Multiple executional conditioned device test registrations for the same step number

Multiple executional conditioned device test settings can be registered for one step number.



However, if multiple executional conditioned device test settings with same device name and same execution timing are registered for the same step number, the registration data will be overwritten. (Even though the same device is specified, if the execution timing differs, two settings can be registered for one step.)

Point

- When setting a word device with a different data type, a device is regarded as the same device.

  Example When a word device is set in the order of "D100 (16 bit integer)" and then "D100 (Real number (single precision))", "D100 (Real number (single precision))" is registered.

- When setting a device with a different modification method (such as a bit-specified word device, digit-specified bit device, or index-modified device), a device is regarded as a different device.

  Example When a word device is set in the order of "D100.F" and then "D100Z0 (Real number (single precision)), both devices are registered.

2) Step to be specified for executional conditioned device test registration

Any step number (0 to step number for the END instruction) in a sequence program can be specified.


Point

Be sure to specify the start step of each instruction.

3) Execution timing

Timing of changing a device value can be specified. A device value can be changed either before or after an instruction of the specified step is executed. Figure 6.42 shows the module operation based on the execution timing.

<Program example>



<Operation>




Figure 6.42 CPU module operation based on execution timing

Note that there may be a case where a device value will not be changed depending on the execution timing even though the specified step is executed.
The following instructions need to be noted when registering executional conditioned device test settings.

- Instructions that do not change device values[*1]
  A device value will not be changed by executing the excutional conditioned device test when the execution timing has been set to "After executing instruction", specifying the step for instructions that do not execute the next step, such as branch instructions.

*1: If the execution condition of an instruction is not satisfied, a device value will be changed based on the registration data.

Table6.17 lists the instructions that do not change device values.

Table6.17 Instructions that do not change device values

No.	Classification	Instruction	Operation
1	Stop	STOP	• When the execution condition for an instruction is satisfied A device value will not be changed even when the specified step is executed. • When execution condition for an instruction is not satisfied A device value will be changed after the specified step is executed.
2	Jump	CJ	
3		SCJ	
4		GOEND	
5	Repeat (Loop)	BREAK(P)	
6	Subroutine program call	CALL(P)	
7		FCALL(P)	
8		ECALL(P)	
9		EFCALL(P)	
10		XCALL	
11	End	FEND	A device value will not be changed even when the specified step is executed.
12	Jump	JMP	
13	Return from subroutine program	RET	
14	Return from interrupt program	IRET	

- FOR/NEXT instructions
  When the executional conditioned device test setting is registered specifying the step for the FOR or NEXT instruction, timing of device value change is different from the timing when steps for other instructions are specified.
  Table6.18 shows the device value change timing based on the execution timing.

Table6.18 Device value change timing when a step for the FOR or NEXT instruction is specified

Instruction of the specified step	Execution timing setting	
	Before executing instruction	After executing instruction
FOR	Executed once before the start of loop processing.	Executed once after the start of loop processing. (Executed before the operation of the program between the FOR and NEXT instructions.)
NEXT	Executed every loop processing. (Executed after the operation of the program between the FOR and NEXT instructions.)	Executed once after the start of loop processing.

- END instruction
  When the executional conditioned device test setting is registered specifying the step for the END instruction, the execution timing is restricted to "Before executing instruction" only. If "After executing instruction" is set, the CPU module returns a registration error to GX Developer.

4) Number of settings that can be registered simultaneously in one scan

Eight executional conditioned device test settings can be registered into the CPU module simultaneously in one scan.

When nine or more executional conditioned device test settings are to be registered simultaneously by GX Developer, they will be registered over multiple scans.

(b) Disabling executional conditioned device test settings

Select the disabling target step number on the program editing screen in GX Developer. Then, select [Online] → [Debug] → [Executional conditioned device test] → [Check/disable executional conditioned device test].




Figure 6.43 Screen for checking/disabling executional conditioned device test settings

Table6.19 Items on the screen for checking/disabling executional conditioned device test settings

Item	Setting range	
	For bit device	For word device
Program name	Name of a program registered in the CPU module	
Step No.	0 to (Step No. for the END instruction)	
Device	Device listed in (2) in this section	
Execution timing	Before executing instruction/After executing instruction	

1) Number of settings that can be disabled simultaneously in one scan

Eight executional conditioned device test settings can be disabled simultaneously in one scan.

When nine or more executional conditioned device test settings are to be disabled simultaneously by GX Developer, they will be disabled over multiple scans.

(c) Batch-disabling executional conditioned device test settings

Select [Online] → [Debug] → [Executional conditioned device test] → [Batch disable executional conditioned device test] in GX Developer.




Figure 6.44 Screen for batch-disabling executional conditioned device test settings

(d) Checking executional conditioned device test settings

Select [Online] → [Debug] → [Executional conditioned device test] → [Check/disable executional conditioned device test].




Figure 6.45 Screen for checking executional conditioned device test settings

Remark

1. For the operating instruction of checking or disabling executional conditioned device test settings, refer to the following.
   ☞ GX Developer Version 8 Operating Manual

2. Usage of the executional conditioned device test can be checked in the special register (SD840).

(e) Cases where executional conditioned device test settings cannot be registered or disabled

In the following cases, executional conditioned device test setting cannot be registered or disabled.
When multiple settings are to be registered, no setting can be registered if any of the settings applies to the cases below.

1) Executional conditioned device test settings cannot be registered

- Specified program does not exist.
- Specified step does not exist.
- Specified device does not exist.
- The number of registered executional conditioned device test settings exceeds 32.

2) Executional conditioned device test settings cannot be disabled

- Specified program does not exist.
- Specified step does not exist.
- Specified device does not exist.
- No executional conditioned device test setting has been registered.

(5) Precautions

(a) Operations from multiple GX Developers

Executional conditioned device test setting can be registered in the same CPU module from multiple GX Developers connected via network.

Note, however, that if multiple executional conditioned device test settings are registered with the same device name in the same step, the registration data will be overwritten.

When registering executional conditioned device data setting from multiple GX Developers update the data first by clicking the Read file button, and then register the setting.

(b) Priority

If any of the following functions is set in the same step number that is specified by the executional conditioned device test setting, the executional conditioned device test is given the priority to other functions.

- Monitor condition setting
- Sampling trace function (trace point)
- Sampling trace function (trigger point)
- Scan time measurement (start step)
- Scan time measurement (end step)

(c) Disabling executional conditioned device test settings

Executional conditioned device test setting can be disabled by any of the following operations, in addition to the operation by GX Developer.

- Powering off and then on the CPU module
- Resetting the CPU module
- Writing program files to the program memory while the CPU module is in the STOP status
- Clearing the program memory while the CPU module is in the STOP status
- Formatting the program memory while the CPU module is in the STOP status

(d) Writing data to the running CPU module

The CPU module operation will be as follows if the executional conditioned device test and the online change function are executed simultaneously.

1) When the executional conditioned device test is executed during execution of the online change function

The online change function completes normally. However, the executional conditioned device test cannot be executed.

The following message box will appear. Execute the executional conditioned device test again after the online change has completed.




Figure 6.46 Message box (when the executional conditioned device test is executed during execution of the online change function)

2) When the online change function is executed during execution of the executional conditioned device test

The Online change function completes normally. If any executional conditioned device test setting has been registered in the program to be changed online, the corresponding setting will be disabled.

(☞ (5)(e) in this section)


(e) Online change of the CPU module with executional conditioned device test registration

1) Online change (ladder mode)

If any executional conditioned device test setting has been registered in the ladder block to be changed online, the CPU module disables the corresponding setting.

Example 1) Step numbers of registrations 1 to 3 are specified in the executional conditioned device test settings. When the ladder block including the registration 2 is changed online, the registration 2 is disabled during execution of the online change function.

Since the registrations 1 and 3 are not included in the change target program, they are not disabled.




* The shaded area is the ladder block to be changed online.

Figure 6.47 Adding a ladder block online

Example 2) When multiple ladder blocks are to be changed online, ladder blocks between the change target ladder blocks will be included in the change target.

For this reason, if the online change function is executed as shown in Figure 6.48, all registrations 1 to 3 are disabled.



* The shaded area is the ladder block to be changed online.

Figure 6.48 Changing multiple ladder blocks online

Example 3) When a ladder block is to be added online, the executional conditioned device test setting included in the ladder block followed after the added ladder block will be disabled.
For this reason, if the online change function is executed as shown in Figure 6.49, the registration 2 is disabled.




Figure 6.49 Adding a ladder block online

2) Online change (files)

All executional conditioned device test settings registered to the program in the online change target file are disabled.

(f) Precautions for specifying an index-modified device

If an index-modified device name is specified to register the executional conditioned device test setting, the CPU module does not check whether the specified device is within the setting range.
If the index-modified device is out of the device range or on the boundary of devices, a device value will not be changed within the specified step.

(g) Precautions for specifying an indirectly-specified device

If indirectly-specified device name is specified to register the executional conditioned device test setting, the CPU module does not check whether the specified device is within the setting range.
If the indirectly-specified device is out of the device range or on the boundary of devices, a device value will not be changed within the specified step.

(h) Precautions for specifying the file register

If the file register is specified to register the executional conditioned device test setting, the CPU module does not check the file register file assignment and the file register number range.
A file register value will not be changed within the specified step in the following cases.

- The file register file is not assigned.
- The specified file register number is out of the file register range.

6.12 Writing Programs While CPU Module is in RUN Status

There are two ways of writing programs in the RUN status.

- Online change (ladder mode) : ☞ Section 6.12.1
- Online change (files) : ☞ Section 6.12.2

Data can also be written in the RUN status using a pointer. (☞ Section 6.15.2)

6.12.1 Online change (ladder mode)

(1) Definition

This function writes programs to the CPU module in the RUN status.

This function enables the program to be changed without stopping the program operation in the CPU module.




Figure 6.50 Outline of online change (ladder mode)

This function also can write programs by GX Developer connected to another station on the network.




Figure 6.51 Outline of online change via network

(2) Memory for online change

A program cache memory (program memory) is available.

(3) Number of steps that can be batch-written by online change

Up to 512 steps can be batch-written.

(4) Changing the reserved area for online change

A program file has an area designated as reserved area for online change to support the online change that changes program file size.

The following provides precautions when changing the size of reserved area for online change.

(a) Size of a program file

The size of a program file is addition of created program size and reserved area for online change.

(b) When program file size is increased from the secured capacity

If the size secured for the program file (size including reserved area for online change) is exceeded after a program is written in the RUN status, the reserved area for online change can be re-set before the writing if the user memory area has space.

(c) Increase in the scan time

The scan time is increased when reserved area for online change is re-set when programs are written in the RUN status.

For increase in the scan time, refer to Section 10.1.3.

(5) Operations prohibited when programs are written to the CPU module in the RUN status, T/C setting value is changed, or data are transferred from a program cache memory to a program memory

Refer to Section 6.12.3(2).

(6) Instructions that do not operate normally when programs are written to the CPU module in the RUN status

Refer to Section 6.12.3(3).

6.12.2 Online change (files)

(1) Definition

This function batch-writes files shown in Table 6.20 to the CPU module in the RUN status by online operation from GX Developer.

Table6.20 Files that can be written to the CPU module in the RUN status

File name	CPU module built-in memory			Memory card (RAM)	Memory card (ROM)	
	Program memory	Standard RAM	Standard ROM	SRAM card	Flash card	ATA card
Parameter	△	○	×	×	×	×
Intelligent function module parameter	×	×	×	×	×	×
Program	○	×	○	○	×	×
Device comment	○	×	△ *1	△ *1	×	△ *1
Initial device value	×	×	×	×	×	×
File register	×	△ *1	×	△ *1	×	×
Local device	×	×	×	×	×	×
Sampling trace file	×	○	×	○	×	×
Programmable controller user data	×	×	○	×	×	○

○ : Can be written, △ : Partially restricted, × : Cannot be written

*1: The file can be written if not being accessed by a sequence program.




Figure 6.52 Outline of online change (files)

(2) Availability

(a) For the Q00UJCPU,Q00UCPU,and Q01UCPU

The function cannot be performed in the following cases.

- A program memory does not have enough area for storing a program file to be written.
- A program memory stores the maximum number of files can be stored.

(b) For the Q02UCPU,QnUD(H)CPU, and Built-in Ethernet port QCPU

A file can be written to the CPU module in the RUN status regardless of space of a memory to be written and the number of files to be stored.

(3) Increase in the scan time

The scan time increases when a program file is written to the CPU module in the RUN status.
For increase in the scan time, refer to Section 10.1.3.

(4) When a file is accessed by a sequence program instruction

An instruction in a program cannot access to the file being written to the CPU module in the RUN status. If
If doing so, the instruction will not be executed.

(5) Online change(files) from multiple locations

Do not simultaneously write files to one CPU module in the RUN status from multiple locations.
Doing so may delete program files.

(6) Online change (files) of SFC programs

SFC programs cannot be written in units of files to the CPU module in the RUN status.

(7) Operations prohibited when programs are written to the CPU module in the RUN status, T/C setting value is changed, or data are transferred from a program cache memory to a program memory

Refer to Section 6.12.3(2).

(8) Instructions that do not operate normally when files are written to the CPU module in the RUN status

Refer to Section 6.12.3(3).

6.12.3 Precautions for online change

The following shows precautions for online change.

(1) Online change during boot operation

When data are written to the CPU module in the RUN status during boot operation, the status of boot source program is not changed.

(2) Operations prohibited when programs are written to the CPU module in the RUN status, T/C setting value is changed, or data are transferred from a program cache memory to a program memory

Do not perform the following operations.

(a) Power-off or reset

The following operations are not normally completed if they are performed during online change, TC setting value change, or data transfer from the program cache memory to the program memory.
If performed, write the data to the CPU module again.

- Power-off
- Reset

(b) Operations from GX Developer

The following operations cannot be performed during online change, TC setting value change, or data transfer from the program cache memory to the program memory. If performed, an error is displayed on GX Developer.
Perform the following operations after online change, TC setting value change, or data transfer from the program cache memory to the program memory.

(Ladder mode, writing files during RUN, and function block)
TC setting value change
Data transfer to the program memory

- Online change (ladder mode), online change (files)
- TC setting value change
- Data transfer to the program memory
- Write to PLC (Flash ROM)

(3) Instructions do not operate normally during online change

When data are written to the CPU module in the RUN status, the following instructions do not operate normally.

- Fall instruction
- Rise instruction
- SCJ instruction

(a) Fall instruction

The fall instruction is executed when the instruction is in the data written to the CPU module in the RUN status, even if the execution condition (on → off) is not met.

For preventing the fall instruction execution during online change, refer to POINT in this section.




Figure 6.53 Operation of the fall instruction

The corresponding fall instructions are LDF, ANDF, ORF, MEF, PLF, FCALLP, and EFCALLP.

(b) Rise instruction

The rise instruction is not executed when the instruction is in the data written to the CPU module in the RUN status, even if the execution condition (off → on) is met.




Figure 6.54 Operation of the rise instruction

The corresponding rise instructions are PLS and □P.

(c) SCJ instruction

When the SCJ instruction is in the data written to the CPU module in the RUN status and the execution condition is on at completion of the writing, a jump to the specified pointer is made without a wait of one scan.




Figure 6.55 Operation of the SCJ instruction

Point

To avoid execution of the fall instruction even when the execution condition (on → off) is not met after data are written to the CPU module in the RUN status, select "Trailing edge instructions are not executed" in the Options screen in GX Developer. The option is deselected by default.

Selecting this option avoids execution of the fall instruction whose execution condition is "off".




Figure 6.56 Options screen

Figure 6.57 shows operations of the fall instruction depending on the setting of "Trailing edge instructions are not executed" in GX Developer.




Figure 6.57 Operation comparison of the fall instruction

(4) Writing to the program memory during online change and T/C setting value change

Contents changed due to online change and TC setting value change are automatically transferred to the program memory simultaneously when the data are written to the program cache memory.
The time required for writing data to the CPU module in the RUN status and changing T/C setting value is increased due to automatic transfer of the program memory by the time shown in Table6.21.

Table6.21 Time increased due to automatic transfer of data to the program memory

CPU module	Transfer time
Q00UJCPU,Q00UCPU,Q01UCPU,Q02UCPU	Ts × 320 + 4.8 (s)
Q03UDCPU,Q04UDHCPU,Q06UDHCPU,Q03UDECPU, Q04UDEHCPU,Q06UDEHCPU	Ts × 260 + 4.7 (s)
Q10UDHCPU,Q10UDEHCPU	Ts × 439 + 6.2 (s)
Q13UDHCPU,Q13UDEHCPU	Ts × 600 + 8.0 (s)
Q20UDHCPU,Q20UDEHCPU	Ts × 839 + 11.4 (s)
Q26UDHCPU,Q26UDEHCPU	Ts × 1100 + 15.0 (s)

Ts: Scan time (s)

Since the number of writes to the program memory (Flash ROM) is limited (up to 100,000 times), set the automatic transfer to the program memory to be disabled when data are written to the CPU module in the RUN status and changing T/C setting value frequently.

Point

Automatic transfer to the program memory can be set to be disabled in the Options screen of GX Developer.





Figure 6.58 Online change/TC setting value change program memory transfer settings

When the automatic transfer is set to be disabled, the following message appears after online change.



Selecting "Yes" transfers data to the program memory.
Selecting "No" does not transfer data to the program memory.

When selecting "No", execute "Program memory batch transfer" by GX Developer.

Program transfer status can be checked by the special relay (SM165). Note6.5
When SM165 is on, the program memory batch transfer has not completed.
When SM165 is off, the program memory batch transfer has completed.

Note6.5 Universal

When checking the batch transfer status to the program memory with the Q02UCPU,Q03UDCPU,Q04UDHCPU, or Q06UDHCPU, check the versions of the CPU module and GX Developer.(Appendix 2)

6.13 Execution Time Measurement

(1) Definition

This function displays the processing time of the program being executed.

(2) Applications and types

This function can be used to know the effect of processing time of each program on the total scan time when the system is adjusted.

There are following three types.

- Program monitor list : ☞ Section 6.13.1
- Interrupt program list monitor : ☞ Section 6.13.2
- Scan time measurement : ☞ Section 6.13.3

6.13.1 Program monitor list

(1) Definition

This function displays the processing time of the program being executed.

The scan time, number of execution times, and processing time by item can be displayed for each program.

(2) Execution

Selecting [Online] → [Monitor] → [Program monitor list] displays the Program monitor list screen.*1

Figure 6.59 shows an example of executing the program monitor list.




Figure 6.59 Program monitor list screen

*1: During execution of a fixed scan execution type program, the scan time of the fixed scan execution type program is not displayed.
"-" is displayed in the Scan time column.

(a) Total Scan Time

The monitoring time set in "WDT (Watchdog timer) setting" of the PLC RAS tab of the PLC parameter dialog box and total scan time for each program type during execution by the CPU module are displayed.

1) Monitor time

The monitoring time of each program is displayed.
If the scan time exceeds this time, the CPU module detects ”WDT ERROR".

2) Sum of scan time

The total time of each item in "Scan execution part, detailed scan time" is displayed.
When constant scan time is set, the constant scan time is displayed.

(b) Scan execution part, detailed scan time

The details of the scan time are displayed.

1) Program

The total execution time of the scan execution type program is displayed.

2) END operation time

The END processing time is displayed.

3) Low speed program

Since a low-speed execution type program is not used "0.000" is displayed.

4) Constant waiting

The constant scan waiting time is displayed when the constant scan time is set.

(c) Execution status of each program

The execution status of a program selected at the program tab of the PLC parameter dialog box is displayed.

1) Program

The program name is displayed in the order set in the PLC parameter dialog box.

2) Execution

The program type set in the PLC parameter dialog box is displayed.

3) Scan time

The actual scan time (current value) is displayed.
When a program is in stop (standby) status, the scan time is displayed as 0.000 ms.

4) Execute count

The number of execution times of programs before monitoring is displayed, setting the measurement start as "0". The number of execution times is displayed up to 65535 and returns to 0 when the 65536 is measured.
The execution times is held even when the program is stopped.

Remark

When the POFF instruction is executed, a non-execution processing is performed for one scan.
The number of execution times displayed is the addition of the execution times of the non-execution processing.

For details of the POFF instruction, refer to the following.
QCPU Programming Manual (Common Instructions)

(3) Program start and stop

Program cannot be started and stopped from the Program list monitor screen.

(4) Precautions

The scan time of a fixed scan execution type program is not displayed during its execution.
"-" is displayed in the Scan time column.

6.13.2 Interrupt program monitor list

(1) Definition

This function displays the number of executions of an interrupt program.

This function is used to check the execution status of the interrupt program.

(2) Execution

Selecting [Online] → [Monitor] → [Interrupt program monitor list] of GX Developer displays the Interrupt program monitor list screen.

Figure Figure 6.60 shows an execution example of the interrupt program monitor list.




Figure 6.60 Interrupt program monitor list screen

(a) Execute count

The number of executions of an interrupt program is displayed.

This function starts counting after the CPU module is in the RUN status.

When the counting reaches 65536 times, it is reset to 0.

(b) Common comment

Device comments created to an interrupt pointer is displayed.

6.13.3 Scan time measurement Note6.6

(1) Definition

This function displays the processing time of set program section during ladder monitoring.
The time required for the subroutine and interrupt programs can be measured.

(2) Range specification of scan time measurement

There are following two types for specifying a scan time measurement range.

- Setting on the ladder monitor screen
- Setting on the scan time measurement screen

(3) When the subroutine program call instruction is in the measurement range

When the subroutine program call instruction (CALL) is in the range of scan time measurement, the scan time includes the time required for processing a subroutine program.




Figure 6.61 When subroutine program is in measurement range

(4) When interrupt programs/fixed scan execution type programs are executed in the scan time measurement range

The execution time of interrupt programs and fixed scan execution type programs are added.


Note6.6 Universal

When using the scan time measurement for the Q02UCPU, Q03UDCPU,Q04UDHCPU,Q06UDHCPU,Q13UDHCPU, and Q26UDHCPU, check the versions of CPU module and GX Developer.(Appendix 2)

(5) Execution

Measure the scan time by the following procedure.

- Display the start of the ladder program where scan time is measured in GX Developer and set the monitor mode.
- Select [Online] → [Monitor] → [Scan time measurement] to open the Scan time measurement screen.



- Enter the start and end steps and click the Start button.

Example When the start step is 52 and the end step is 105




Figure 6.62 Scan time measurement screen

Remark

When displaying the Scan time measurement screen after specifying the scan time measurement rage in the monitor mode, the start and end steps are set in the specified range.
To specify the range, press the "Shift" key and click the mouse (The specified part is inverted).




Figure 6.63 Measurement range specification

(6) Precautions

(a) Measurement range setting

Set the measurement range so that "Start step < End step" is satisfied.

(b) Minimum unit of measurement time

The minimum unit of measurement time is 0.01ms.

If the measurement time is less than 0.01ms, 0.000ms is displayed.

(c) When between the FOR and NEXT instructions is specified


The execution time of one scan between the specified steps is displayed.

(d) When scan time cannot be measured

Scan time cannot be updated on the Scan time measurement screen in the following cases.


- When the branch instruction is specified the to end step

  Example The JMP instruction is specified to the end step.




- When only the start step is executed

  Example The specified end step is not executed by the JMP instruction.




• When the end step is executed before the start step

Example The start step is specified as the next step of the CALL instruction and the end step is specified in a subroutine program executed by the CALL instruction.



• When the start step is executed continuously

Example Only the start step is specified between the FOR and NEXT instructions.



6.14 Sampling Trace Function Note6.7

(1) Definition

This function samples the data of the specified device at a preset timing and at a preset interval (sampling cycle), and then stores the trace results in the sampling trace file.

(2) Application

This function is useful to check the change of the device data used in the program during debugging at a preset timing.

In addition, this function is used to read the device data at trigger condition establishment.

(3) Sampling trace file

This file stores the trace setting necessary for executing the function and trace results.

Point

Sampling trace file can be stored only in the Standard RAM or SRAM card. (☞ Section 5.1.1)

Note6.7 Universal

The Q00UJCPU does not support the sampling trace function.

(4) Sampling trace operation

(a) Operation of the CPU module

When a sampling trace trigger is issued by GX Developer, the CPU module executes traces for the preset number of times.

The number of traces will be a value of which the number of bytes for the sampling trace area divided by the number of bytes of the specified device (N1 + N2 + N3 + word device points × 2 + (bit device points/16) × 2).*1 *2

*1: Round up the result of "bit device points/16" in the expression to the right of the decimal point.

*2: Add the following values to N1 to N3 according to the items selected under the trace additional information of the trace condition setting.

- •N1: When "Time(sec)" is selected, add "4".
- •N2: When "Step no." is selected, add "10".
- •N3: When "Program name" is selected, add "8".




Figure 6.64 Sampling trace operation

*3: When the trigger is issued, the CPU module samples data for the preset number of times and latches the data in the sampling trace area.

(b) Operation of the special relay

1) When the sampling trace is executed normally

The execution status of the sampling trace can be checked in the special relay listed in Table6.22.

Table6.22 Execution status of the sampling trace

Number	Name	Description
SM800	Trace preparation	Turns on when the trace setting in GX Developer is written to the CPU module. The relay is used to check the sampling trace enable status.
SM801	Trace start	Turns on when the sampling trace is started.
SM802	Trace execution in progress	Turns on during sampling trace execution. The relay is used to check the sampling trace execution status.
SM803	Trace trigger	A trigger turns on upon the status change of the relay (off → on).
SM804	After trace trigger	Turns on when any of the following condition is established. • A trigger is issued by GX Developer. • The TRACE instruction is executed. • SM803 turns on. • Detailed setting (Device and Step No.) The relay is used to check the trigger condition establishment status.
SM805	Trace completed	Turns on when the sampling trace is completed.
SM826	Trace error	Turns on when an error occurs during sampling trace execution.

Figure 6.65 shows the operation flow chart of the special relay for sampling trace execution.




Figure 6.65 Operation flow chart of the special relay (for sampling trace execution)

2) When the sampling trace is interrupted

If SM801 (Trace start) is turned off during sampling trace, execution of the sampling trace will be interrupted.

When the sampling trace is interrupted, the trace count is cleared.

The sampling trace restarts by turning on SM801.




Figure 6.66 Operation flow chart of the special relay (for sampling trace interruption)

*1: SM801 also turns off when the sampling trace is interrupted by GX Developer.

(5) Operating procedure

Select [Online] → [Trace] → [Sampling trace...] in GX Developer.

On the screen opened, select the method for operating the sampling trace.

- "Wizard setting/execution"

  (☞ GX Developer Version 8 Operating Manual)
- "Individual setting/execution"

  (☞ (5)(a) in this section)

(a) Setting "Trace data (setting + result) storage" and "Trace execution method"

On the screen opened, set the trace data storage location and trace execution method.




Figure 6.67 Sampling trace screen

1) Trace data (setting + result) storage

Select the memory for storing the trace data and the file for writing the trace conditions.

Select either "Standard RAM" or "Memory card (RAM)" for the target memory setting.

Trace results will be stored in the memory set here under the selected file name.

2) Trace execution method

Select either of the following trace execution method.

- "Execute trace after overwriting the current trace setting to the PLC":

  The CPU module executes the sampling trace after the trace settings are overwritten to the existing sampling trace file.
- "Execute trace for the settings written in PLC":

  The CPU module executes the sampling trace with the trace settings in the sampling trace file selected for "Trace data (setting + result) storage".

(b) Setting trace conditions

Set trace conditions on the screen opened by clicking the Trace condition setting button on the screen shown in Figure 6.67.

On the Trace condition settings screen, set the following items.

- Number of traces ("No. of traces", "After trigger number of times")
- Trace point setting ("Trace point setup")
- Trigger point setting ("Trigger point setup")
- Additional information ("Trace additional informaton")
- Auto start setting ("Auto start trace")




Figure 6.68 Trace condition settings screen

1) No. of traces

There are two items need to be set: "No. of times" and "After trigger number of times".

- No. of times: Select the number of executions from the start to the end of sampling trace.
- After trigger number of times: Select the number of executions from the trigger point to the end of sampling trace.




Figure 6.69 Relationship between two setting items

Set the numbers for each items within the following setting range.

("After trigger number of times") ≦ ("No. of times") ≦ (8192)

2) Trace point setup

Select the timing for collecting trace data from the items listed in Table6.23.

Table6.23 Trace point setup item

Item	Description
Each scan	Collects trace data during END processing of each scan.
Interval	Collects trace data at specified time intervals.
Each multiple CPU high speed communication cycle[*1]	Collects trace data in a cycle of 0.88m × specified time intervals. Since data is collected at the timing of interrupt program (I45) execution, trace data can be collected only when the following conditions are all satisfied. • The multiple CPU high-speed main base unit (Q3 □ DB) is used. • The multiple CPU system where two or more CPU modules are used and the multiple CPU high speed transmission function is set. • Interrupt pointer (I45) exists in a program. • Interrupts are enabled and interrupt mask of I45 is cancelled.
Detail	A trace point (device and/or step number) needs to be set. The following devices can be set as a trace point. • Bit device: X(DX), Y(DY), M, L, F, SM, V, B, SB, T(contact), ST(contact), C(contact), FX, FY, J □ \X, J □ \Y, J □ \B, J □ \SB, BL □ \S • Word device: T(current value), ST(current value), C(current value), D[*1], SD, W[*2], SW, R, Z, ZR, FD, U □ \G, J □ \W, J □ \SW, U3E □ \G The following modifications are available for the above devices. • Digit specification of bit device • Bit specification of word device • Indirect specification of word device • Index modification The setting method and trace data collection timing are same as those for the monitor condition setting in Section 6.11.1. If a device is set as a trace point, the timing when the word device value is changed can be selected as a data collection timing.

*1: The extended data register (D) is included.
*2: The extended link register (W) is included.

3) Trace additional information

Set the information added for each trace.

Select one or more items from the following. (If not necessary, do not select any item.)

- Time(sec.): Stores the time when the trace was executed.
- Step no.: Stores the step number where the trace was executed.
- Program name: Stores the program name where the trace was executed.

4) Trigger point setup

Select the trigger point from the items listed in Table6.24.

Table6.24 Trigger point setup item

Item	Description
At the time of TRACE instuction execution	The time of execution of the TRACE instruction is set as a trigger.
At the time of trigger operation from GX Developer	The time when a trigger is issued by GX Developer is set as a trigger.
Detail	A trace point (device and/or step number) needs to be set. The following devices can be set as a trace point. • Bit device: X(DX), Y(DY), M, L, F, SM, V, B, SB, T(contact), ST(contact), C(contact), FX, FY • Word device: T(current value), ST(current value), C(current value), D*1, SD, W*2, SW, R, ZR The following modification is available for the above devices. • Bit specification of word device Indirectly-specified devices cannot be set. The setting method and trace data collection timing are same as those for the monitor condition setting in Section 6.11.1. If a device is set as a trace point, the timing when the word device value is changed can be selected as a data collection timing.

*1: The extended data register (D) is included.
*2: The extended link register (W) is included.

5) Auto start trace Note6.8

When the checkbox is selected, the sampling trace will be started automatically when:

- the CPU module is powered off and then on after the trace settings are written, or
- the CPU module status is changed from STOP to RUN.

Point

When the CPU module is powered off and then on, reset, or the CPU module status is changed from STOP to RUN to rewritten the sampling trace settings, the settings cannot be rewritten to the CPU module regardless of the status of SM829 (Forced registration specification of trace setting) if the trigger condition has already been established.
In this case, the CPU module will be in the status where the sampling trace setting registration has been canceled. SM800 (Trace preparation) turns off.

Note6.8 Universal

When using the sampling trace auto start function for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer. (Appendix 2)

(c) Setting trace data

Set trace data on the screen opened by clicking the Trace data setting button on the screen shown in Figure 6.67.

Table6.25 shows the devices can be set as trace data.




Figure 6.70 Trace data settings screen

Table6.25 Devices can be set as trace data

Item	Description
Bit device	The following bit devices can be set up to 50 points. X, DX, Y, DY, M, L, F, SM, V, B, SB, T(contact), T(coil), ST(contact), ST(coil), C(contact), C(coil), J □ \X, J □ \Y, J □ \B, J □ \SB, BL □ \S
Word device	The following word devices can be set up to 50 points. T (current value), ST (current value), C (current value), D*1, SD, W*2,SW, R, Z, ZR, U □ \G, J □ \W, J □ \SW, U3E □ \G The following modifications are available for the above devices. • Digit specification of bit device • Bit specification of word device • Index modification Indirectly-specified devices cannot be set.

*1: The extended data register (D) is included.
*2: The extended link register (W) is included.

(d) Writing the trace condition settings and trace data settings

Write the set trace conditions and trace data to the memory selected as a sampling trace file for "Trace data (setting + result) storage".

Click the Write to PLC button on the screen shown in Figure 6.67 to write the settings.

Point

When storing the sampling trace file into a memory card (SRAM card), more than one sampling trace files can be stored by changing the file name.
For the standard RAM, only one sampling trace file can be stored.
When multiple sampling trace files are used, use the memory card (SRAM card).

(e) Executing the sampling trace

Click the Trace execution button on the screen shown in Figure 6.67 to open the Execute sampling trace screen.

Select an item shown in Table6.26 and click the Execute button.




Figure 6.71 Execute sampling trace screen

Table6.26 Trace point setting

Item	Description
Start trace	Starts the function, and starts counting the number of sampling trace executions.
Stop trace	Stops the function, and clears the total sampling trace execution count and the execution count after trigger. (To restart the function, select "Start trace" again.)
Execute trigger	Executes a trigger, and starts counting the number of sampling trace executions after trigger. The function will be ended when the trace execution count after trigger reaches the preset count.
Registry trace (For start trace from Program)	Registers trace data when a program is executed.

(f) Displaying trace results

Read trace results form the CPU module and display the data.

1) Click the Trace result PLC read button on the screen shown in Figure 6.71 to read trace results.

2) Click the Trace result button on the same screen to display the trace results read.

The trace results shows the on/off status of each bit device for every sampling cycle and the current value of each word device.




Figure 6.72 Trace result screen

Point

Specified devices are read when the condition selected in "Trigger point setup" (trigger condition) is established. Therefore, when devices are sampled in every scan and the sampling is finished by trigger operation from a peripheral, the data is sampled twice because timing of the sampling is the same with that of the establishment of trigger condition.




Figure 6.73 Trace result

(6) Method for clearing trace execution status

The trace execution status can be cleared by latch clear using the remote latch clear operation.

(☞ Section 6.6.4)

To perform the sampling trace again after latch clear, select “Start trace” or “Registry trace”.

(7) Precautions

(a) Areas where sampling trace can be performed

The sampling trace can be performed from other stations on the network or serial communication module. However, it cannot be performed from multiple devices simultaneously. It can be performed from one device to the CPU module.

(b) Holding and clearing the trace setting

The trace setting (sampling trace file) registered with the CPU module is latched.

Even if the CPU module is powered off and then on or is reset, the sampling trace can be performed again with the trace setting at registration.

However, the previous trace result cannot be read.

Also in the following cases, even when the trigger condition of the sampling trace is established, the latched trace setting will be cleared since the condition is not recognized as the trigger condition (SM800 (Trace preparation) turns off).

Register the trace setting again with GX Developer.

1) When selecting "Standard RAM" in "Target memory", configuring the setting that changes the local device size in the standard RAM[*1], writing parameters to the CPU module, and then performing any of the following operations
   - The CPU module is powered off and then on
   - The CPU module is reset.
   - The CPU module is set from STOP to RUN.

*1: The operation includes when a local device is created.

2) When selecting "Standard RAM" in "Target memory” and the sampling trace file is corrupt, either of the following operations were performed.
   - The CPU module is powered off and then on.
   - The CPU module is reset.

Point

To keep the trace result to the personal computer even after configuring the setting that changes the local device size, perform the following operations.

- Click the Trace result PLC read button on the screen shown in Figure 6.71 to read the trace result to the personal computer.
- Click the Trace result button on the screen shown in Figure 6.71 to display the trace result.
- Click the Create CSV file button on the screen shown in Figure 6.72 to save the trace result in CSV format.

3) When selecting "Memory card (RAM)" in "Target memory" while the SRAM card where the sampling trace file has been registered is not mounted, either of the following operations were performed.

- The CPU module is powered off and then on.
- The CPU module is reset.

4) When selecting "Memory card (RAM)" in "Target memory" and the sampling trace file is corrupt, either of the following operations were performed.

- The CPU module is powered off and then on.
- The CPU module is reset.

(c) Reading trace result in the STOP status

The trace result cannot be read while the CPU module is in the STOP status.
When reading the trace result, read it while the CPU module is in the RUN status.

(d) Sampling trace registration while the trigger condition is established

Even if the trigger condition is established, the sampling trace setting can be registered by the following procedure.

1) Turn on SM829 (Forced registration specification of trace setting).
2) Select “Individual setting/execution” in the screen shown in Figure 6.67.
3) Click the Trace execution button, select “Registry trace (For start trace from Program)”, and click the Execute button.

Point

- When the sampling trace is registered by the procedures above (d) 1) to 3), start the sampling trace in status where the trigger condition is not established.
  If the trigger condition has been established when the sampling trace starts, the trigger may not be normally executed.
- When selecting "Wizard setting/execution" in the Sampling trace screen shown in (d) 2), and starting the sampling trace, the trigger may not be normally executed, although the sampling trace setting can be registered.

(e) When a file register is selected as a specified device by the detail setting of trace conditions

When a file register is selected as a specified device by the detail setting of trace point setting and trigger point setting, do not change the block numbers of file register file and file register after trace registration.
Trace data may not be normally sampled.

(f) Trace point setting

When setting the trace point setting per each time or per multiple CPU high speed transmission cycle, pay attention to the sampling interval and sampling processing time for one sampling since the sampling trace is performed as interrupt processing.
If the sampling processing time for one sampling is long, “WDT ERROR” may be detected.

(g) Performing sampling trace during execution of another sampling trace

The first sampling trace is performed normally. The second sampling trace cannot be performed.

(h) Executing online change

When sampling trace and online change are performed simultaneously, they operate as follows.

1) Performing sampling trace during online change

- The trace point or trigger point is specified by the step number:
  The online change is completed normally but the sampling trace is not performed.
- The trace point and trigger point are specified by except the step number:
  Both the online change and sampling trace can be performed.

2) Performing online change during execution of sampling trace

- The trace point or trigger point is specified by the step number:
  The sampling trace is suspended but the online change is normally performed.
- The trace point and trigger point are specified by except the step number:
  Both the online change and sampling trace can be performed.

6.15 Debug Function from Multiple GX Developers

(1) Definition

This function allows debugs from multiple GX Developers connected to such as a CPU module or serial communication module.

When files are divided according to the processes or functions, this function can be used when multiple GX Developers debug different files.

(2) Description

Table6.27 shows combinations of the debug functions executable from multiple GX Developers.

Table6.27 Combinations of the debug functions

Function in execution	Function executed later			
	Monitor	Online change	Execution time measurement	Sampling trace
Monitor	○ *1	○ *2	○	○
Online change	○ *2	× *3	×	×
Scan measurement	○	○	×	○
Sampling trace	○	×	○	×

○ : Can be performed simultaneously, × : Can be performed from one GX Developer.

*1: Since only one GX Developer can set the monitor conditions (Section 6.11.1), other GX Developers cannot set them.

*2: The monitoring with monitor conditions and online change cannot be performed simultaneously.

*3: For how to perform Nonline change to a file from multiple GX Developers, refer to Section 6.15.2.

6.15.1 Simultaneous monitoring from multiple GX Developers function

(1) Definition

This function allows simultaneous monitoring from multiple GX Developers connected to such as a CPU module or serial communication module.




Figure 6.74 Simultaneous monitoring

Creating a user setting system area allows high-speed monitoring from multiple GX Developers (Setting a monitoring file for the host station is unnecessary).

(2) Setting for simultaneous monitoring from multiple GX Developers

Create a user setting system area in the following procedure.

- Select [Online] → [Format PLC memory] in GX Developer to open the screen shown in Figure 6.75.
- Select "Program memory/Device memory" in "Target Memory".
- Select "Create a user setting system area" in "Format Type".
- Set the number of steps for the system area (in increments of: 1K step).




Figure 6.75 System area setting (when 1K step is set)

Table6.28 shows the maximum number of steps settable in the system area.
1K step is available for a monitoring file from another station.

Table6.28 Maximum size of steps settable in the system area

Maximum size of settable step	System area for monitoring from another station
Maximum 15K steps	Maximum 15

(3) Precautions

(a) Monitor condition setting

The monitor conditions can be set from one GX Developer.

(b) Necessity of system area setting

Although multiple GX Developers in other stations can simultaneously monitor a CPU module without the user setting system area, the monitor speed will be slow.
Since the system area is set in the program memory, the area for storing programs reduces by the size of set system area.

(c) The number of GX Developers for which high-speed monitoring can be set

The number of GX Developers that can simultaneously monitor a CPU module at high-speed is “the number of user setting system areas (the number of K steps) + 1”.
For example, when user setting system area of 15K steps is created, maximum 16 GX Developers can simultaneously monitor a CPU module at high-speed.

6.15.2 Online change function from multiple GX Developers

(1) Definition

This function allows multiple GX Developers to perform online change to one file or different files.

- Online change to one file:
  Select "Relative step No. by pointer".
- Online change to different files:
- The writing can be executed without selecting "Relative step No. by pointer".




Figure 6.76 Simultaneous online change from multiple GX Developers

(2) Operating procedure for performing online change to one file

Select [Tools] → [Options] → <Program common> tab in GX Developer.→
Set a pointer for online change beforehand.

(a) Setting “After conversion writing behavior” and “Step No. specification used in writing”

Set them as follows:

1) Select "Write during RUN (while PLC is running)" in "After conversion writing behavior".

2) Select “Absolute step No. (default)” or “Relative step No. by pointer” in “Step No. specification used in writing”.




Figure 6.77 Options screen

(b) Performing online change

Display the ladder including the specified pointer and write the changed ladder during RUN.

(3) Precautions

Precautions for online change from multiple GX Developers are the same as those for usual Write during RUN (☞ Section 6.12.3).

6.16 Watchdog Timer (WDT)

(1) Definition

This function serves as an CPU module internal timer to detect errors of CPU module hardware and sequence programs.

(2) Setting and resetting

(a) Setting

The watchdog timer setting can be changed in the PLC RAS setting of PLC parameter.
The default is set to 200ms.
The setting range is 10 to 2000ms (in increments of: 10ms).

(b) Reset

The CPU module resets the watchdog timer during END processing.

- The watchdog timer does not time up when the CPU module operates normally and the END/FEND instruction is executed within the setting value of watchdog timer.
- The watchdog timer times up when the scan time of the sequence program is extended and the END/FEND instruction could not be executed within the setting value of watchdog timer due to the hardware failure of the CPU module or execution of an interrupt program/fixed scan execution type program.

(3) When the watchdog timer times up

"WDT ERROR" is detected and the following status occurs:

1) The CPU module turns off all outputs.
2) The RUN LED on the front of the CPU module turns off and the ERR. LED starts flashing.
3) SM1 turns on and the error codes 5000 and 5001 are stored in SD0.

(4) Precautions

(a) Watchdog timer error

An error is observed within the range of 0 to 10ms.
Set a watchdog timer while considering such an error.

(b) Resetting a watchdog timer when a program is repeatedly executed between the FOR and NEXT instructions

The watchdog timer can be reset by executing the WDT instruction in the sequence program.
To avoid the time up of watchdog timer while a program is repeatedly executed between the FOR and NEXT instructions, reset the watchdog timer by the WDT instruction.




Figure 6.78 Resetting a watchdog timer when the program is executed between the FOR and NEXT instructions

(c) Scan time when using the WDT instruction

The scan time value is not reset even if the watchdog timer is reset in the sequence program.
The scan time is measured up to the END instruction.




Figure 6.79 Watchdog timer reset

Point

- A scan time is time required for the CPU module to operate the sequence program from step 0 and return to the step 0 in the sequence program with the same file name.
- The scan time depends on the execution status of the following:
  - Instructions used in the program
  - Interrupt program and fixed scan execution type program
    To keep the same scan time in every scan, use the constant scan function. (Section 6.2)

6.17 Self-diagnostic Function

(1) Definition

This function allows the CPU module to diagnose itself to check for errors.
This function aims to preventive measures and prevention of malfunction of the CPU module.

(2) Self-diagnostic timing

When an error occurs at power-on or during the RUN or STOP status of the CPU module, the error is detected and displayed by the self-diagnostic function, and the CPU module stops an operation.
Note that errors cannot be detected by the function depending on error status or an instruction executed.
When the operation is not stopped by the function, configure a safety circuit external to the programmable controller so that the entire system operates safely.

(3) Checking errors

(a) LED status

When the CPU module detects an error, the ERR. LED turns on.

(b) Storage location of error information and error check

When the CPU module detects an error, the special relays (SM0, SM1) turn on and the error information (error code) are stored in the special register (SD0).
When several errors are detected, the latest error code is stored in SD0.
Use the special relays and special register in a program as an interlock for the programmable controller and mechanical system.

(4) Checking error history

To check the latest error code, select [Diagnostics] → [PLC diagnostics] → "Error log" in GX Developer.
The error data history are backed up using a battery even after the programmable controller is powered off.

(5) CPU module operation at error detection

(a) Mode at error detection

When an error is detected by the self-diagnostic function, the CPU module enters either of the following modes.

1) Mode that stops CPU module operation

When an error is detected, the CPU module stops an operation and turns off all external outputs of the module set to "Clear" in "Error time output mode" in “Detailed setting” of the I/O assignment tab of the PLC parameter dialog box (Outputs (Y) in the device memory are held).
Note that the external outputs of the module set to "Hold" in "Error time output mode" are held (Outputs (Y) in the device memory are held).

2) Mode that continues CPU module operation

When an error is detected, the CPU module operates programs other than the one (instruction) where an error occurred.

(b) Errors whether to continue or stop an operation can be selected

Whether to continue or stop an operation can be selected in the following errors.

1) Errors whether to continue or stop an operation can be selected in the PLC RAS tab of the PLC parameter dialog box

- Computation error (including SFC program)
- Expanded command error (setting for future extension)
- Fuse blown
- Module verify error
- Intelligent module program execution error
- File access error
- Memory card operation error
- External power supply OFF (setting for future extension)

For example, when “Module verify error” is set to "Continue", an operation is continued from the I/O number before an error.
For details of errors, refer to “Self-diagnostics list”. (☞ (7) in this section)

2) Error whether to continue or stop an operation can be selected in “Detailed setting” in the I/O assignment tab of the PLC parameter dialog box

- Intelligent function module error

(6) Error check options

Whether to check the following errors or not can be selected in the PLC RAS tab of the PLC parameter dialog box (All the options are selected (executed) by default).

1) Carry out battery check
2) Carry out fuse blown check
3) Verify module
4) Check device range at indexing.
5) Diagnose redundant power supply system. Note6.9

Note6.9 Universal

When setting the diagnostic function of the redundant power supply system for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer. (☞ Appendix 2)

(7) Self-diagnostics list

The following table shows the self-diagnostics performed by the CPU module.
To check the error messages in the "Error message" column of Table6.29, select [Diagnostics] → [PLC diagnostics] of GX Developer.

Table6.29 Self-diagnostics list

Diagnostics		Error message	Diagnostic timing	CPU module status	LED status		Q00UJ CPU	Q00U CPU, Q01U CPU	Q02U CPU	QnUD(H) CPU	Built-in Ethernet port QCPU
					RUN	ERR.					
Hardware failure	CPU error	MAIN CPU DOWN	• Always	Stop	Off	Flashing	○	○	○	○	○
	END instruction not executed	END NOT EXECUTE	• Execution of the END instruction	Stop	Off	Flashing	○	○	○	○	○
	SFC program execution error	SFCP. END ERROR	• Execution of a SFC program	Stop	Off	Flashing	○	○	○	○	○
	RAM check	RAM ERROR	• Power-on/reset	Stop	Off	Flashing	○	○	○	○	○
	Operation circuit check	OPE.CIRCUIT ERR.	• Power-on/reset • Execution of the END instruction	Stop	Off	Flashing	○	○	○	○	○
	Fuse blown*1 *2	FUSE BREAK OFF	• Always	Stop/ continue	Off/on	Flashing/on	○	○	○	○	○
	I/O interrupt error	I/O INT. ERROR	• Occurrence of an interrupt	Stop	Off	Flashing	○	○	○	○	○
	LAN controller failure	LAN CTRL. DOWN	• Power-on/reset	Stop	Off	Flashing	○	○	○	○	○
	Intelligent function module error *1	SP.UNIT DOWN	• Power-on/reset • Execution of the FROM/TO instructions • Execution of the intelligent function module dedicated instruction • Execution of the END instruction	Stop/ continue	Off/on	Flashing/on	○	○	○	○	○
	Control bus error	CONTROL-BUS ERR.	• Power-on • Execution of END processing • Execution of the FROM/TO instructions • Execution of the intelligent function module dedicated instruction • Always	Stop	Off	Flashing	○	○	○	○	○
	Momentary power failure	AC/DC DOWN	• Always	Continue	On	Off	○	○	○	○	○
	Multiple CPU high speed bus error	MULTI-C.BUS ERR.	• Power-on/reset	Stop	Off	Flashing	×	×	×	○	○

○ : Self-diagnostics is performed. × : Self-diagnostics is not performed.

(To the next page)

Table6.29 Self-diagnostics list (continued)

Diagnostics		Error message	Diagnostic timing	CPU module status	LED status		Q00UJ CPU	Q00U CPU, Q01U CPU	Q02U CPU	QnUD(H) CPU	Built-in Ethernet port QCPU
					RUN	ERR.					
Handling error	Voltage drop of power supply for redundant base unit	SINGLE PS. DOWN	• Always	Continue	On	On	×	○	○ *5	○ *5	○
	Redundant power supply module failure	SINGLE PS. ERROR	• Always	Continue	On	On	×	○	○ *5	○ *5	○
	Module verification*1*2	UNIT VERIFY ERR.	• Execution of the END instruction	Stop/ continue	Off/on	Flashing/on	○	○	○	○	○
	Base assignment error	BASE LAY ERROR	• Power-on/reset	Stop	Off	Flashing	○	○	○	○	○
	Intelligent function module assignment error	SP.UNIT LAY ERR.	• Power-on/reset • Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
	Intelligent program execution error*1	SP.UNIT ERROR	• Execution of the FROM/TO instructions	Stop/ continue	Off/on	Flashing/on	○	○	○	○	○
	Intelligent function module version error	SP.UNIT VER.ERR	• Power-on/reset	Stop	Off	Flashing	○	○	○	○	○
	No parameter	MISSING PARA.	• Power-on/reset • Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
	Boot error	BOOT ERROR	• Power-on/reset	Stop	Off	Flashing	○	○	○	○	○
	Backup error	RESTORE ERROR	• Power-on/reset	Stop	Off	Flashing	○	○	○	○	○
	Memory card operation error*1	ICM.OPE. ERROR	• Mounting/removal of the memory card	Stop/ continue	Off/on	Flashing/on	×	×	○	○	○
	File setting error	FILE SET ERROR	• Power-on/reset • Writing to programmable controller	Stop	Off	Flashing	○	○	○	○	○
	File access error*1	FILE OPE. ERROR	• Execution of an instruction	Stop/ continue	Off/on	Flashing/on	○	○	○	○	○
	Instruction execution disabled	CANëT EXE.PRG.	• Power-on/reset • Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
Parameter error	Parameter setting check	PARAMETER ERROR	• Power-on/reset • Switching from STOP to RUN • Writing to programmable controller	Stop	Off	Flashing	○	○	○	○	○
	Link parameter error	LINK PARA.ERROR	• Power-on/reset • Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○

○ : Self-diagnostics is performed. × : Self-diagnostics is not performed.

(To the next page)

Table6.29 Self-diagnostics list (continued)

Diagnostics		Error message	Diagnostic timing	CPU module status	LED status		Q00UJ CPU	Q00U CPU, Q01U CPU	Q02U CPU	QnUD(H) CPU	Built-in Ethernet port QCPU
					RUN	ERR.					
SFC parameter error		SFC PARA.ERROR	• Switching from STOP to RUN • Writing to programmable controller	Stop	Off	Flashing	○	○	○	○	○
Intelligent function module parameter error		SP.PARA. ERROR	• Power-on/reset	Stop	Off	Flashing	○	○	○	○	○
Password error		REMOTE PASS.ERR	• Power-on/reset • Switching from STOP to RU	Stop	Off	Flashing	○	○	○	○	○
Instruction code check		INSTRUCT. CODE ERR	• Power-on/reset • Switching from STOP to RUN • Execution of an instruction	Stop	Off	Flashing	○	○	○	○	○
No END instruction		MISSING END INS.	• Power-on/reset • Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
Pointer setting error		CANëT SET(P)	• Power-on/reset • Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
		CANëT SET(I)	• Power-on/reset • Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
Program error	Operation error*1 *4	OPERATION ERROR	• Execution of an instruction	Stop/ continue	Off/on	Flashing/on	○	○	○	○	○
	FOR to NEXT instructions structure error	FOR NEXT ERROR	• Execution of an instruction	Stop	Off	Flashing	○	○	○	○	○
	CALL to RET instructions structure error	CANëT EXECUTE(P)	• Execution of an instruction	Stop	Off	Flashing	○	○	○	○	○
	Interrupt program error	CANëT EXECUTE(I)	• Execution of an instruction	Stop	Off	Flashing	○	○	○	○	○
	Instruction execution disabled	INST. FORMAT ERR.	• Execution of an instruction	Stop	Off	Flashing	○	○	○	○	○
	Dedicated instruction of multiple CPU high speed bus error	MULTI COM.ERROR	• Execution of an instruction	Stop	Off	Flashing	×	×	×	○	○
	SFC block configuration error	CANëT SET(BL)	• Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
	SFC step configuration error	CANëT SET(S)	• Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
	SFC execution error	SFC EXE. ERROR	• Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○

○ : Self-diagnostics is performed. × : Self-diagnostics is not performed

(To the next page)

Table6.29 Self-diagnostics list (continued)

Diagnostics		Error message	Diagnostic timing	CPU module status	LED status		Q00UJ CPU	Q00U CPU, Q01U CPU	Q02U CPU	QnUD(H) CPU	Built-in Ethernet port QCPU
					RUN	ERR.					
Program error	SFC syntax error	SFCP. FORMAT ERR.	• Switching from STOP to RUN	Stop	Off	Flashing	○	○	○	○	○
	SFC block execution error	BLOCK EXE.ERROR	• Execution of an instruction	Stop	Off	Flashing	○	○	○	○	○
	SFC step execution error	STEP EXE.ERROR	• Execution of an instruction	Stop	Off	Flashing	○	○	○	○	○
CPU error	Watchdog error supervision	WDT ERROR	• Always	Stop	Off	Flashing	○	○	○	○	○
	Program time-out	PRG.TIME OVER	• Always	Continue	On	On	○	○	○	○	○
Multiple CPU system s error	Another CPU major error	MULTI CPU DOWN	• Always • Power-on/reset	Stop	Off	Flashing	×	○	○	○	○
	Multiple CPU systems execution error	MULTI EXE.ERROR	• Power-on/reset	Stop	Off	Flashing	×	○	○	○	○
	Multiple CPU systems consistency error	CPU LAY. ERROR	• Power-on/reset	Stop	Off	Flashing	×	○	○	○	○
	Another CPU minor error	MULTI CPU ERROR	• Always	Continue	On	On	×	○	○	○	○
File diagnostic check		INCORRECT FILE	• Power-on/reset • Switching from STOP to RUN • Writing to programmable controller	Stop	Off	Off	○	○	○	○	○
Annunciator check		F****	• Execution of an instruction	Continue	On	USER LED turns on.	○	○	○	○	○

○ : Self-diagnostics is performed. × : Self-diagnostics is not performed

*1: The operating status can be changed to "Continue" with the parameter setting of GX Developer The default is set to "Stop".
*2: This option can be set "not checked" (set "checked" by default) with the parameter setting of GX Developer. Also, this option is not checked while SM251 is on.
*3: This option can be set "not checked" (set "checked" by default) with the parameter setting of GX Developer.
*4: This error includes an operation error when device range check is made at index modification.
*5: The CPU module having the serial number (first five digits) is "10042" or later can be diagnosed.

6.17.1 LEDs indicating errors

When an error occurs, the LEDs on the front of the CPU module turns on/flashes. (☞ Section 6.21)

6.17.2 Error clear

The CPU module can clear an error by a program if the error does not stop program operation.

(1) Procedures for error clear

Clear an error by the following procedures.

- Resolve the error cause.
- Store the code of the error to be cleared in the special register SD50.
- Turn off and then on the special relay SM50.
- The error is cleared.

(a) Procedures for error clear in case of multiple errors

When the latest error (error stored in the special register SD0) is cleared, error information stored in special relays and special registers (SM0, SM1, SM5, SM16, SD0 to SD26) are cleared and therefore information on errors that have not been cleared cannot be obtained from the special relays and spcial registers.

For errors that have not been cleared, obtain the past errors from the error history (☞ Section 6.18) and clear the errors.

(2) Status after error clear

When the CPU module is recovered by clearing an error, the special relay, special register, and LEDs affected by the error return to the status before the error.

If the same error occurs after clearing the error, it is logged in the error history again.

(3) Clear of annunciator

When multiple annunciators are detected, only the first detected "F"is cleared. (☞ Section 9.2.5)

Point

- When an error is cleared by storing the code of the error to be cleared in SD50, the last digit of the code number is ignored.

  Example When the error code 2410, 2411, or 2412 occurs, clearing the error by storing 2412 in SD50 also clears the error codes 2410 and 2411.

- If the CPU module is not an error cause, the error cannot be resolved by using the special relay (SM50) and special register (SD50).

  Example Since "SP. UNIT DOWN" indicates an error occurred to the Q bus, the error cannot be resolved by using the special relay (SM50) and special register (SD50).

  To resolve the error cause, refer to the following.

  ☞ QCPU User's Manual (Hardware Design, Maintenance and Inspecting)

6.18 Error History

This function stores an error detected by the self-diagnostic function and the detection time as an error history in a memory.
Select [Diagnostics] → [PLC diagnostics] of GX Developer to check the history.

Point

The detection time is based on the clock in the CPU module. Make sure to set the correct time before the first use of the CPU module. (☞ Section 6.5)

(1) Storage area

All stored logs are saved to the storage memory for error history of the CPU module.

Table6.30 Storage area for error history file

Storage area	Number of storable logs
CPU module built-in memory	Up to 100*1

*1: When the number of storable logs are exceeded, the latest error log is stored by deletion of the oldest error log.

(2) How to clear error history

To clear the storage memory for error history and error history file, select [Diagnostics] → [PLC diagnostics] in GX Developer and click the Clear log button.
This method clears all data stored in the storage memory for error history of the CPU module and error history file in a memory card.

6.19 System Protection

The CPU module has protection functions (system protection) to prevent programs being modified by a third party other than the designer with GX Developer or serial communication module.

Table6.31 System protection types

Protection target	File that can be protected	Description	Method	Valid timing	Reference
In units of memory cards*1	All files	Prohibits writing to a memory card.	Turn on the write protect switch of a memory card.	Always	-
In units of files	• Program • Device comment • Initial device value	• Changes the attribute for each file to either of the following. • Read/write (reading/ writing to programs) prohibitation • Write prohibitation (operations regarding writing such as writing to programs and tests)	Make setting in the Password registration screen.	Always	Section 6.19.1

*1: The Q00UJCPU, Q00UCPU, and Q01UCPU do not support the system protection in units of memory cards since they cannot use the memory card.

6.19.1 Password registration

This function prohibits reading and writing data such as a programs and device comments in the CPU module with GX Developer.

(1) Valid password range

The password can be registered with program, device comment, and initial device values files in the specified memory (program memory, standard ROM, and memory card).

(2) Operations that can be prohibited

The following two operations can be prohibited.

- Reading and writing a file
- Writing a file

When a password has been registered with a file, GX Developer cannot operate the file unless entered password does not match with the registered password.

(3) Setting method

Select [Online] → [Password setup] or click the Password setup button on the Write to PLC screen in GX Developer.




Figure 6.80 Password registration/change screen

(a) Target memory

Select a memory storing a file where a password is to be registered.

(b) Data type

Displays the type of a file stored in the target memory.

(c) Data name

Displays the name of a file stored in the target memory.

(d) Registration

Displays "*" when a password has been set to the target file.

(e) Password

Enter current password or a password to be registered.
The Registration Condition column can be set after setting a password.

(f) Registration Condition

1) Write protect

Writing to a password-protected file is prohibited (reading is allowed).

2) Read/Write protect

Reading and writing to a password-protected file is prohibited.

3) Clear

The set password is cleared (entering the current password is necessary).

(4) Precautions

(a) Password management

A password registered with a file cannot be read from the file.
Forgetting the registered password disables the following operations.

- Program memory or memory card: Format PLC memory
- Standard ROM: Batch-writing

Make sure to record the registered password and store the recording paper.

(b) Operations that overwrite a file independent of the password registration setting

The following operations overwrite a file in the target drive (program memory, standard ROM) independent of the password registration setting.

- Boot from a memory card
- Replacement of the CPU modules with a memory card (backup data restoration function)

6.19.2 Remote password

(1) Definition

This function prevents unauthorized remote access to the CPU module.
If a remote password has been set and the CPU module is remotely accessed, entering a remote password is required.

(2) Settable modules and the number of settable modules

Table6.32 shows the modules for which the remote password can be set and the number of settable modules.

Table6.32 Settable modules and the number of settable modules

Settable module	Number of settable modules
Ethernet module	4
Serial communication module	8
Modem interface module	
Built-in Ethernet port QCPU	1

Point

- The number of settable modules in the above table indicates the number of modules for which the remote password can be set, not the number of mountable modules in the system using the CPU module.
- For the number of mountable modules in the system, refer to the following.
  ☞ QCPU Userís Manual (Hardware Design, Maintenance and Inspection)
- For details of the remote password of each module, refer to the following.
  ☞ Manual for each module

(3) Flow from remote password setting to reflection of the password

Set a remote password (☞ (5) in this section) and then write it to the CPU module.
The remote password is transferred to the target module when the CPU module is powered off and then on or is reset. (☞ (2) in this section)




Figure 6.81 Outline of a remote password

(4) Remote password lock/unlock

Unlock the remote password of a serial communication module via a modem or the Ethernet module via Ethernet.
When entered remote password matches with the registered password, the module can access the CPU module.




Figure 6.82 Outline of locking/unlocking a remote password with an Ethernet module

(5) Procedures for setting/changing/clearing a remote password

(a) Setting a remote password

- In the project data list of GX Developer, select [Parameter] → [Remote pass].




Figure 6.83 Remote password settings screen

Table6.33 Setting items on the Remote password settings screen

Item		Description	Setting range/option
Password settings		Enter a remote password.	Four characters or less (alphanumeric characters, special symbols)
Password active module settings	Model name	Select a model name.	• QnUDE(H)CPU • QJ71E71 • QJ71C24/CMO
	Start X/Y	Set the start address of the module.	0000_H to $0FE0_H$
Detail		-	-
User connection No.		Select user connection No.	Connection 1 to Connection 16
System connection	Auto open UDP port	Select a valid port of the remote password.	-
	FTP transmission port (TCP/IP)		
	GX Developer transmission port (TCP/IP)		
	GX Developer transmission port (UDP/IP)		
	HTTP port		

- Connect GX Developer to the CPU module.
- Write a set remote password to the CPU module.
- In multiple CPU systems, write a remote password to the control CPU of the module to which the remote password is to be set.

Point

After setting a remote password, store the parameters to the valid drive (☞ Section 5.1.10).

(b) Changing a remote password

Change set password in the Remote password settings screen and write a new password to the CPU module.

(c) Clearing a remote password

- To delete set remote password, click the Clear button in the Remote password settings screen.
- Write a remote password with GX Developer.

6.20 System Display of CPU Module with GX Developer

When the CPU module is connected to GX Developer, this function can check the following items of the modules on the base unit in the System Monitor screen.

- Installed status
- Parameter status
- Module's Detailed Information
- Product information




Figure 6.84 System Monitor screen

(1) Installed status

The control CPU, model name, and the number of points of the modules on the selected base unit can be checked.

"Unmounting" is displayed in the field of a number of slot where a module is not mounted.

The model name of a module on a slot to which "Empty" is set in the I/O assignment tab of the PLC parameter dialog box is not displayed.

When using a redundant base unit, mounted status of the power supply module is also displayed.

Note6.10

(2) Parameter status

The I/O number, type, and the number of points of the module on each slot of the selected base unit can be displayed.

If the Parameter status displays "0" for an empty slot or assignment error, it indicates that the I/O assignment setting of the PLC parameter dialog box and the mounted status differs. Therefore, change the I/O assignment setting so that it may match with the mounted status.

When using a redundant base unit, mounted status of the power supply module is also displayed. Note6.10

Note6.10 Universal

Before monitoring the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer.(Appendix 2)

(3) Base

The status of the base unit and modules on the base unit can be checked.

When there is even one faulty module, the "Module" field color changes according to the status described at the bottom of the screen.

(4) Mode

The mode cannot be selected since modules cannot be replaced online.

(5) Diagnostics

Click this button to check an error and status of the selected module.

(6) Module's Detailed Information

Click this button to check the details of the selected module.

For details of the intelligent function module, refer to the manual for the intelligent function module used.

(7) Base Information

The "Overall Information" and "Base Information" can be checked.

(a) Overall Information

The number of base units and the number of modules on the base units can be checked.

(b) Base Information

The name, the number of slots, type, and the number of modules of the selected base unit can be checked.

(8) Product Inf. List

Individual information (Type, Series, Model name, Points, I/O No., Master PLC, Serial No., Ver., and Product No.) of the mounted CPU module, I/O modules, and intelligent function module can be checked.




Figure 6.85 Product Information List screen

(9) Detailed information of power supply module

This screen displays "ON/OFF status", "Error existence", and "Number of momentary power failures" of the power supply module.
This screen can be displayed when using the power supply module supporting a redundant base unit and this screen.





Figure 6.86 Detailed information of power supply module screen

Table6.34 Description of the Detailed information of power supply module screen

Item	Description
ON/OFF status	Displays the status of an input power supply to the redundant power supply module.
Error existence	Displays whether a failure (error) occurs in the redundant power supply module.
Number of momentary power failures	• When the redundant power supply module of redundant main base unit is selected Displays the number of momentary power failures of the redundant power supply module on the redundant main base unit (display range: 0 to 65535). • When the redundant power supply module of redundant extension base unit is selected Displays "-" and the number of momentary power failures is not counted.

Point

- In multiple CPU systems, the Detailed information of power supply module screen can be displayed:
  - when GX Developer is connected to CPU No. 1, or
  - when serial numbers (first five digits) of all CPU modules are "07032" or later.
- Double-clicking the area of power supply module in "Installed status" can also display the screen.



Double-clicking this area displays the Detailed information of power supply module screen.

Remark

For details of the System Monitor screen of GX Developer, refer to the following.

GX Developer Version 8 Operating Manual

6.21 LED Indication

Operating status of the CPU module can be checked by the LEDs on the front of the CPU module.
For details of LED indications, refer to the following.

☞ QCPU Userís Manual (Hardware Design, Maintenance and Inspection)




Figure 6.87 LEDs on the front of the CPU module

6.21.1 Methods for turning off the LEDs

(1) Methods

The LEDs can be turned off by the following operations (except for reset operation).

Table6.35 Methods for turing off the LEDs

Method for turning off the LED	Relevant LED			
	ERR.	USER	BAT.	BOOT
Execute the LEDR instruction after resolving the error.	○	○	○	×
After resolving the error, clear the error by the special relay SM50 and special register SD50*1 (operation continuation error only).	○	○	○	×
Turn off the LED by the special relay SM202 and special register SD202.*1	×	○	×	○

○ : Valid, × : Invalid

*1: Description of special relays and special registers

- SM50 : Clears an error of the error code stored in SD50 when the CPU module is powered off and then on.
- SD50 : Stores an code of an error to be ccleared.
  For details of error codes, refer to the following.
  ☞ QCPU Userís Manual (Hardware Design, Maintenance and Inspection)
- SM202 : Turns off the LED corresponding to each bit of SD202 when the CPU module is powered off and then on.
- SD202 : Set an LED to be turned off.




Figure 6.88 Bit structure of the special register SD202

Configure setting to turn off each LED as follows:

- Turning off both the Boot LED and USER LED: SD202 = 110_H
- Turning off only the BOOT LED: SD202 = 100_H
- Turning off only the USER LED: SD202 = 10_H

(2) Methods for not turning on the ERR. LED, USER LED, and BAT. LED

There is a priority in indications of the ERR.LED, USER LED, and BAT.LED. (☞ Section 6.21.2)
When an cause number of an LED is deleted in the priority, the LED will not turn on even if an error with the cause number occurs.

6.21.2 LED indication priority

This section describes a priority for error messages stored in the LED display data (SD220 to SD227) in case of an error.

(1) Displayed error messages and their priorities

In case of multiple errors, the error messages are displayed with the following conditions.
A stop error is always set to the LED display data (SD220 to SD227).
An operation continuation error is displayed according to the priority cause number described in this section.
The priority can be changed (set it to the special registers SD207 to SD209).
When errors having the same priority occur simultaneously, the error detected first is displayed.

The priority is determined with the special registers SD207 to SD209 as follows.




Figure 6.89 Special registers and bit structure ragarding a priority

(2) Priorities and cause numbers

The following table shows the description and priority of the cause numbers set to the special registers SD207 to SD209.

Table6.36 List of cause numbers and priorities

Priority	Cause number (hexadecimal)	Displayed error message	Remarks
1	1	• AC/DC DOWN	• Power-off
2	2	• UNIT VERIFY ERR. • FUSE BREAK OFF • SP.UNIT ERROR • SP.UNIT DOWN	• I/O module verification error • Fuse blown • Intelligent function module verification error
3	3	• OPERATION ERROR • SFCP OPE.ERROR • SFCP EXE.ERROR	• Operation error • SFC instruction operation error • SFC program execution error
4	4	• ICM.OPE.ERROR*1 • FILE OPE.ERROR	• Memory card operation error • File access error
		• FLASH ROM ERROR	• Flash ROM access count over error
5	5	• PRG.TIME OVER	• Constant scan setting time-out error
		• MULTI CPU ERROR*2	• Another CPU error in multiple CPU systems
6	6	-	—
7	7	• Annunciator	—
8	8	-	—
9	9	• BATTERY ERROR	—
10	A	-	—

*1: The Q00UJCPU, Q00UCPU, and Q01UCPU cannot display the error message.
*2: The Q00UJCPU cannot display the error message.

Point

- To remain the LED off even in case of an error, set the cause number setting area (each 4 bits) of SD207 to SD209 that stores the corresponding cause number to “0”.

  Example To remain the ERR. LED off even when a fuse blown error is detected, set the cause number setting area where the cause number “2" is stored to “0”.




Figure 6.90 Cause numbers stored in SD207 to SD209

  Because the cause number "2" is not set, the ERR.LED remains off even if a fuse blown is detected.
  In this case, even if another error with the cause number "2" (I/O module verification error or intelligent function module verification error) is detected, the ERR.LED remains off.

- If “0” is set to the cause number setting area (setting that does not turn on the LED), SM0 (Diagnostic errors) and SM1 (Self-diagnostic error) turn on, and the error code is stored to SD0 (Diagnostic errors).

6.22 Interrupt from Intelligent Function Module

The CPU module can execute an interrupt program (I ☐) by the interrupt request from the intelligent function module. For example, the serial communication module can receive data by an interrupt program when the following data communication functions are executed.

- Data reception during communication by nonprocedural protocol
- Data reception during communication by bidirectional protocol

Using an interrupt program enables a CPU module to receive data quickly.




Figure 6.91 Interrupt from a serial communication module

(1) Setting an interrupt from the intelligent function module

To execute an interrupt program by an interrupt from the intelligent function module, select "Interrupt pointer setting" in "Intelligent function module setting" of the PLC system tab in the PLC parameter dialog box.
Configure system setting at the intelligent function module is also required.
For execution of an interrupt program by an interrupt from the intelligent function module, refer to the following.

☞ Manual for the intelligent function module used

Remark

For the numbers of interrupt pointers available for an interrupt from the intelligent function module, refer to Section 9.11.

6.23 Serial Communication Function Note6.11

(1) Definition

This function communicates in the MC protocol[*1] by connecting the RS-232 interface of the CPU module, personal computer, and HMI by RS-232 cable.

This section describes the specifications, functions, and various settings of the function.

*1: The MC protocol is an abbreviation for the MELSEC communication protocol.
The MELSEC communication protocol is a communication method to access from an external device to the CPU module according to the communication procedure for the Q series programmable controller (such as a serial communication module, Ethernet module).
For the MC protocol, refer to the following.
☞ Q Corresponding MELSEC Communication Protocol Reference Manual




Figure 6.92 Communication with personal computer or HMI

Point

- A personal computer or HMI can communicate with a CPU module by the serial communication function only when the CPU module is connected to it.
  The CC-Link IE controller network, MELSECNET/H, Ethernet, or CC-Link cannot be communicated with another station.
- The serial communication function is not used for connection of GX Developer or GX Configurator with the CPU module.

Note6.11 Universal

When using the serial communication function for the Q02UCPU, check the versions of the CPU module and GX Developer. (☞ Appendix 2)
When using the Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, or Built-in Ethernet port QCPU, the serial communication function cannot be used.

(2) Specifications

(a) Transmission specifications

Table6.37 shows the transmission specifications of RS-232 for the serial communication function of the CPU module.

Check that the specifications of the personal computer and HMI match those of Table6.37 before using the function.

Table6.37 Transmission specifications of the serial communication function

Item	Default	Setting range
Communication method	Full-duplex communication	-
Synchronization method	Asynchronous method	-
Transmission speed*1	19.2kbps	9.6kbps, 19.2kbps, 38.4kbps, 57.6kbps, 115.2kbps
Data format	• Start bit: 1 • Data bit: 8 • Parity bit: Odd • Stop bit: 1	-
MC protocol format*2 (automatic detection)	• Format 4 (ASCII) • Format 5 (binary)	-
Frame*2	• QnA-compatible 3C frame • QnA-compatible 4C frame	-
Transmission control	DTR/DSR control	-
Sum check*1	Checked	Checked/not checked
Transmission wait time*1	No waiting time	No waiting time, 10ms to 150ms (in increments of 10ms)
RUN write setting*1	Prohibited (deselected)	Permit (checked), prohibited (deselected)
Overall cable distance	15m	-

*1: Can be set in the PLC parameter dialog box.

*2: Table6.38 shows the relationship between the MC protocol formats and frames.

Table6.38 Relationship between the MC protocol formats and frames


Function		Format 4	Format 5
Communication in ASCII code	QnA-compatible 3C frame	○	×
	QnA-compatible 4C frame	○	×
Communication in binary code	QnA-compatible 4C frame	×	○

○ : Available, × : Unavailable

(b) RS-232 connector specifications


Table6.39 shows the specifications of the RS-232 connector for the CPU module.

Table6.39 RS-232 connector specifications

Appearance	Pin number	Signal	Signal name
 Mini-DIN 6 pins (female)	1	RD(RXD)	Receive data
	2	SD(TXD)	Send data
	3	SG	Signal ground
	4	-	-
	5	DSR(DR)	Data setting ready
	6	DTR(ER)	Data terminal ready

(c) RS-232 cable

- The following RS-232 cable can be used for connecting the CPU module to the personal computer or HMI.
- QC30R2 (cable length: 3m)
- FMBKAZ1-*** (manufactured by Kuremo Electric Co., Ltd.)
- Cable with a Mini-DIN connector on one side and without connector on the other side
- *** indicates a cable length, which can be lengthened up to 15m in units of 0.1m.



Pin number	1	2	3	4	5	6	Metal shell
Signal	RD	SD	SG	-	DR	ER	
Wire core	Red	Black	Green/ white	-	Yellow	Brown	Shield

Figure 6.93 Effective length and signal layout of RS-232 cable

(3) Functions

Table6.40 shows the MC protocol commands that can be executed by the serial communication function.

Table6.40 MC protocol commands supported by the serial communication function

Function			Command	Processing	Number of processing points
Device memory	Batch read	In units of bits	0401(00 □ 1)	Reads bit devices in units of 1 point.	ASCII: 3584 points BIN: 7168 points
		In units of words	0401(00 □ 0)	Reads bit devices in units of 16 points.	480 words (7680 points)
				Reads word devices in units of 1 point.	480 points
	Batch write*1	In units of bits	1401(00 □ 1)	Writes bit devices in units of 1 point.	ASCII: 3584 points BIN: 7168 points
		In units of words	1401(00 □ 0)	Writes bit devices in units of 16 points.	480 words (7680 points)
				Writes word devices in units of 1 point.	480 points
	Random read	In units of words	0403(00 □ 0)	Reads bit devices in units of 16 points or 32 points by specifying the device or device number at random.	96 points
				Reads word devices in units of 1 point or 2 points by specifying the device or device number at random.	
	Test*1 (random write)	In units of bits	1402(00 □ 1)	Sets/resets bit devices in units of 1 point by specifying the device or device number at random.	94 points
		In units of words	1402(00 □ 0)	Sets/resets bit devices in units of 16 points or 32 points by specifying the device or device number at random.	*2
				Writes word devices in units of 1 point or 2 points by specifying the device or device number at random.	
	Monitor registration	In units of words	0801(00 □ 0)	Registers bit devices to be monitored in units of 16 points or 32 points.	96 points
				Registers word devices to be monitored in units of 1 point or 2 points.	96 points
	Monitor	In units of words	0802(00 □ 0)	Monitors devices registered for monitoring.	Number of monitor registration points

*1: When writing data while the CPU module is in the RUN status, set "RUN write setting" to "Permit".

*2: Set the number of processing points within the range of the following calculation formula.

(number of word access points) × 12 + (number of double word access points) × 14 ≦ 960

- One point of a bit device corresponds to 16 bits for word access or to 32 bits for double word access.
- One point of a word device corresponds to one word for word access or to two words for double word access.

(4) Accessible devices

Table6.41 shows accessible devices by the serial communication function.

Table6.41 Accessible devices by the serial communication function

Category	Device		Device code	Device number range*1 (default value		Write	Read
Internal system device	Function input		FX*2	000000 to 00000F	Hexadecimal	×	×
	Function output		FY*2	000000 to 00000F	Hexadecimal		
	Function register		FD	000000 to 000004	Decimal		
	Special relay		SM	000000 to 002047	Decimal	○	○
	Special register		SD	000000 to 002047	Decimal		
Internal user device	Input		X	000000 to 001FFF	Hexadecimal		
	Output		Y	000000 to 001FFF	Hexadecimal		
	Internal relay		M	000000 to 008191	Decimal		
	Latch relay		L	000000 to 008191	Decimal		
	Annunciator		F	000000 to 002047	Decimal		
	Edge relay		V	000000 to 002047	Decimal		
	Link relay		B	000000 to 001FFF	Hexadecimal		
	Data register		D	000000 to 012287	Decimal		
	Link register		W	000000 to 001FFF	Hexadecimal		
	Timer	Contact	TS	000000 to 002047	Decimal		
		Coil	TC				
		Current value	TN				
	Retentive timer	Contact	SS	000000 to 002047	Decimal		
		Coil	SC				
		Current value	SN				
	Counter	Contact	CS	000000 to 001023	Decimal		
		Coil	CC				
		Current value	CN				
	Link special relay		SB	000000 to 0007FF	Hexadecimal		
	Link special register		SW	000000 to 0007FF	Hexadecimal		
	Step relay		S	000000 to 008191	Decimal	×	
	Direct input		DX	000000 to 000FFF	Hexadecimal	○	
	Direct output		DY	000000 to 000FFF	Hexadecimal		
Index register	Index register		Z	000000 to 000019	Decimal		
File register*3	File register		R	000000 to 032767	Decimal		
			ZR	000000 to 3FD7FF	Hexadecimal		
Extended data register*3	Extended data register		D	000000 to 093183	Decimal		
Extended link register*3	Extended link register		W	000000 to 016BFF	Hexadecimal		

○ : Reading/writing are enabled. × : Writing is prohibited.

*1: After changing the number of device points of the CPU module with GX Developer, use the devices within the new device number range. Decimal and hexadecimal indicate whether a command specified for the MC protocol is decimal or hexadecimal.

*2: From 000005 to 00000F of FX and FY will be indefinite value.

*3: These registers are not supported by the Q00UJCPU.

(5) Setting of transmission specifications

Set Transmission speed, Sum check, Transmission wait time, and Run write setting of the serial communication function in the Serial tab of the PLC parameter dialog box.

- Select "Use serial communication" in communication with the personal computer or HMI.
- Set Transmission speed, Sum check, Transmission wait time, and Run write setting in the tab.




Figure 6.94 Serial tab

(6) Precautions

(a) Switching connection to GX Developer during communication with such as HMI

The CPU module can switch connection to GX Developer during communication with the personal computer or HMI with the serial communication function.

However, the personal computer or HMI in communication by the serial communication function results in a communication error.

For startup methods of the personal computer and HMI when they are reconnected to the CPU module, refer to the manual for used device.

(b) Transmission speed set in the Transfer Setup screen

When "Use serial communication" is selected, the transmission speed set in the Transfer setup screen of GX Developer is ignored.

Point

The data set in the "Serial" tab is valid when:

- the CPU module is powered on, or
- the CPU module is reset.

(c) Communication error

If any of the following status is met, responses are not returned and therefore communication cannot be made. Review the transmission frame.

1) The serial communication function is set not to be used.
2) Communication is made at different transmission speed and data format.
3) A frame to be sent has no correct starting end or terminal.
   - 3C frame format 4: ENQ/CR + LF
   - 4C frame format 4: ENQ/CR + LF
   - 4C frame format 5[*1]: DLE+STX/DLE + ETX

   *1: When "Sumcheck enable" is set, the sumcheck code is included.
4) The frame identification number of a frame to be sent is incorrect.
5) The number of transmission bytes is under the header part size.

(7) Error codes during communication with the serial communication function

Table6.42 shows the error codes, error description, and corrective actions sent from the CPU module to the external device when an error occurs during communication with the serial communication function.

Table6.42 Error codes sent from the CPU module to external device

Error code (hexadecimal)	Error item	Description	Corrective action
4000H to 4FFFH	-	Error detected by the CPU module (error occurred by other than the serial communication function)	Refer to the QCPU Userís Manual (Hardware Design, Maintenance and Inspection), and take corrective action.
7155H	Unregistered monitor error	A monitor request was given before monitor registration.	Give a monitor request after registering a device to be monitored.
7157H	Request target specification error	Other than the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU was selected as a request module and route.	Check that the transmission message address is Q00UJCPU, Q00UCPU, Q01UCPU, Q02UCPU, modify the setting and communicate again.
7164H	Request data error	The requested data or device specification method is wrong.	Check the sent message/requested data of the external device, correct it, and restart communication.
7167H	Disabled during RUN	A write command was specified while online change is disabled.	Enable the online change and restart communication.
7E40H	Command error	A subcommand or a command that does not exist is specified.	Check and correct the sent message of the external device and restart communication.
7E41H	Data length error	The number of points specified for random write/ read exceeds the number of points enabled for communication.	Check and correct the sent message of the external device and restart communication.
7E42H	Data count error	The requested number of points exceeds the range of the command.	Check and correct the sent message of the external device and restart communication.
7E43H	Device error	The device specified does not exist. The device specified cannot be specified by the corresponding command.	Check and correct the sent message of the external device and restart communication.
7E47H	Continuous request error	The next request was received before the response message was returned.	Do not give continuous requests from the external device. Match the monitoring time of timer 1 with the time-out time of the external device.
7F21H	Receive header section error	The command (frame) section specified is in error.	Check and correct the sent message of the external device and restart communication.
		The ASCII code received cannot be converted into binary.	
7F22H	Command error	The command or device specified does not exist.	Check and correct the sent message of the external device and restart communication.
7F23H	MC protocol message error	The data (such as ETX, CR+LF) specified after the character part does not exist or in error.	Check and correct the sent message of the external device and restart communication.
7F24H	Sumcheck error	The calculated sumcheck does not match the received sumcheck.	Review the sumcheck of external device.
7F67H	Overrun error	The next data was received before the CPU module completed receive processing.	Reduce the communication speed and restart communication. Check the CPU module for momentary power failure. (For the CPU module, use the special register SD53 to check.) When an momentary power failure occurs, remove its cause.
7F68H	Framing error	The stop bit setting does not match.	Match the setting of the CPU module with that of the external device.
7F69H	Parity error	The parity bit setting does not match.	Match the setting of the CPU module with that of the external device.

6.24 Service Processing

6.24.1 Service processing setting

(1) Definition

This function allows to set the time and the number of times of service processing performed at END processing by parameters.
This function also improves the response of communication with a peripheral and restrains the increase of scan time due to service processing.
This achieves the configuration of service processing environment optimum for the system.

Point

The service processing refers to communication service processing with a peripheral (such as GX Developer) and intelligent function modules. Link refresh processing such as CC-Link IE controller network module, MELSECNET/H module, and CC-Link Safety system master/local module are not included.

Using the COM instruction enables service processing during program execution of same performance with service processing at END processing. Therefore, the high-speed service processing response can be performed even if the scan time is long.

(2) Parameter setting

Set the parameters in the PLC system tab of the PLC parameter dialog box.




Figure 6.95 Parameter setting screen

To perform the service processing, select any of the parameter items in Table6.43.
The setting value of deselected parameter cannot be entered (default: Execute the process as the scan time proceeds. = 10%).

Table6.43 Parameter items

Item	Description	Setting range	Remarks
Execute the process as the scan time proceeds.	Set the percentage of service processing for one scan.	• Range: 1 to 99% • Unit: 1%	Default when selected =10%
Specify service process time.	Set the time of service processing for one scan.	• Range: 0.2ms to 1000ms • Unit: 0.1ms	Default when selected =0.2ms
Specify service process execution counts.	Set the number of service processing for one scan.	• Range: 1 to 10 times • Unit: 1 time	Default when selected =1 time
Execute it while waiting for constant scan setting.	Set whether to perform service processing during waiting time for constant scan setting.	-	Even when the waiting time is 0.2ms or less, the service processing time (0.2ms) will be added to the scan time at service processing execution.

(3) Operations for service processing setting

Operations for each service processing setting is described below.

(a) Operation when "Execute the process as the scan time proceeds." is selected

1) Operation when 10% is set




Figure 6.96 Operation when 10% is set

Point

If no request data for service processing exists, END processing speeds up by the request processing time. (The CPU module does not wait for requests.)

2) Operation for constant scan setting

The calculation of the service processing time is a calculation of the percentage of the time excluding the waiting time of the constant scan from the scan time, not a calculation of the percentage of the scan time.

Example Operation when 50% is set




Figure 6.97 Operation for constant scan setting

Point

When setting the constant scan, selecting "Execute it while waiting for constant scan setting." can perform the service processing efficiently. (☞ (3)(d) in this section)

(b) Operation when "Specify service process execution counts." is selected

1) Operation when 1 time is set




Figure 6.98 Operation when 1 time is set

2) Operation when 2 times is set




Figure 6.99 Operation when 2 times is set

Point

- When several devices are connected to one CPU module, each device requests service processing.
  When the CPU module receives requests from several devices simultaneously, a single END processing can accept several requests simultaneously if the service processing count is set to the number of connected devices. This improves response performance. (Note that the scan time increases by the service processing time.)
- If no request data exists when setting the service processing count, END processing speeds up by the request processing time. (The CPU module does not wait for requests.)

(c) Operation when "Specify service process time." is selected

1) Operation when 0.5ms is set




Figure 6.100 Operation when 0.5ms is set

2) Operation when 1ms is set




Figure 6.101 Operation when 1ms is set

Point

If no request data exists when setting the service processing time, END processing speeds up by the request processing time. (The CPU module does not wait for requests.)

(d) Operation when "Execute it while waiting for constant scan setting." is selected






Figure 6.102 Operation when "Execute it while waiting for constant scan setting." is selected

Point

- When setting the constant scan, selecting "Execute it while waiting for constant scan setting." can perform the service processing efficiently.
  - When "Execute it while waiting for constant scan setting." is selected



  - When "Execute the process as the scan time proceeds." is selected (50% is set.)



- Even when there is no waiting time, the service processing (0.2ms) is performed. Therefore, when the waiting time is less than 0.2ms, the constant scan time may be exceeded.

(4) Precautions

The following describes precautions when the service processing setting is configured.

1) For the following functions, scan time will be increased longer than the specified time during service processing even if the service processing time specification is set.
   - Online change
   - Change T/C setting
   - Local device monitor
   - Program memory backup
   - Writing to/reading from a file register (The scan time will be increased when the write or read size is large.)
   - Writing to/reading from the buffer memory of the intelligent function module (The scan time will be increased when the write or read size is large.)
   - Access to a network module
     a) Diagnostic functions (CC IE Control diagnostics, MELSECNET diagnostics, Ethernet diagnostics, CC-Link/ CC-Link/LT diagnostics)
     b) Monitor function (Module access device, Link direct device)
2) Note that the scan time will be increased much longer if the CPU module receives multiple requests simultaneously while the service processing count specification is set many.
3) When setting the service processing time much shorter than the scan time, the response performance of service processing is extremely reduced. Set the service processing time with considering the time-out time of a peripheral.
4) An error of -20 μs to +30 μs occurs between the actual processing time and the set service processing time.

6.25 Initial Device Value

(1) Definition

This function registers data used in a program to the device or the buffer memory of the intelligent function module without a program.

(2) Application

Using an initial device value can omit device data setting program by initial processing program.




Figure 6.103 Data setting by initial program

(3) Timing when initial device values are written to the specified device

The CPU module writes data in the specified initial device value file to the specified device or the buffer memory of the intelligent function module when the CPU module is powered off and then on, is reset, or is set to the STOP status and then the RUN status.




Figure 6.104 Flow of writing initial device value

(4) Devices that can be used*1

The following shows devices that can be used for initial device value.

- Current timer value (T)
- Current retentive timer value (ST)
- Current counter value (C)
- Data register (D)*2
- Special register (SD)
- Link register (W)*3
- Link special register (SW)
- File register (R)
- File register (ZR)
- Intelligent function module device (U□\G□)
- Link direct device (J□\W□, J□\SW□)

*1: For available ranges, refer to Section 9.1.
*2: The extended data register (D) is included.
*3: The extended link register (W) is included.

(5) Procedures and settings for using initial device values

To use initial device values, create initial device value data with GX Developer beforehand, and store the data as a initial device value file in the program memory, standard ROM, or memory card of the CPU module.

- Add an initial device value data to the project data list of GX Developer.
  The Device initialization range setting screen appears. Set the initial device value range.
  The number of settable points is up to 8000 points per range setting.
- Add device memory data in the project data list of GX Developer.
  The device memory screen appears. Set the initial device value data within the initial device value range set above.




Figure 6.105 Device initialization range setting screen and device memory screen

Point

When changing the setting on the Device initialization range setting screen, always execute "Device memory registration/ diversion".
For details of the "Device memory registration/diversion", refer to the following.

GX Developer Version 8 Operating Manual

- Select the name of a file where the initial device value data are stored in the PLC file tab of the PLC parameter dialog box.




Figure 6.106 PLC file tab

- Write the set initial device value and parameters to the CPU module.

(6) Precautions

(a) When initial device value and latch range are overlapped

In that case, initial device value takes priority. Therefore, the latch range data will be overwritten to the initial device value data after the CPU module is powered off and then on.

(b) Area disabling the initial device value setting when the CPU module is set from STOP to RUN

The initial device value are also reflected when the CPU module is set from STOP to RUN.

For an area where an initial device value is not to be set when the CPU module is set from STOP to RUN (data that are set when the CPU module is powered off and then on and changed by a program), the initial device value cannot be used.

Use an instruction such as the MOV instruction in the main routine program so that the initial device values will be set to the specified devices.

Use the TO instruction to write data to the buffer memory of the intelligent function module.

(c) Devices that require module synchronization setting

When setting the following devices in the Device initialization range setting screen, set "Module synchronization" in the PLC system tab of the PLC parameter dialog box.

If the setting is not configured, the initial device values may not be set to the target module properly.

- Intelligent function module device (U□\G□)
- Link direct device (J□\W□ , J□\SW□)

Remark

For details of the initial device value range setting, setting of the initial device value data, and writing of the initial device values to the CPU module, refer to the following.

☞ GX Developer Version 8 Operating Manual

6.26 Battery Life-prolonging Function

(1) Definition

This function extends the life of battery installed in the CPU module by restricting data to be held by the battery to clock data only.

This function initializes all data other than the clock data when the CPU module is powered off or is reset.

Table6.44 Initialization details

Data held by a battery		Description
Error history		The number of error history data is initialized to zero.
Latch device (L)		Cleared to zero.
Device in the latch range		Cleared to zero.
Standard RAM		Formatted (cleared to zero).
File register assigned to the standard RAM	Set "Use the same file name as the program."	A file is deleted.
	Set "Use the following file".	A file is deleted (A file is recreated at power-on or reset (Data is cleared to zero.).)

(2) Setting

Set the function in the I/O assignment tab of the PLC parameter dialog box.

1) Configure the I/O assignment setting.

2) Click the Switch setting button.

3) Enter 0001_H to the switch 3 of the slot where the CPU module is mounted (When entering the value to a slot in another station, the value is ignored).




Figure 6.107 Switch setting screen

(3) Battery life

For the life of battery installed in the CPU module when the battery life-prolonging function is used, refer to the following.

☞ QCPU User's Manual (Hardware Design, Maintenance and Inspection)

6.27 Memory Check Function

This function checks whether data in the memories of the CPU module are not changed due to such as excessive electric noise.
Since the CPU module automatically checks a memory, setting for enabling this function is unnecessary.
This function does not require processing time.

(1) Data to be checked

(a) Program

The program during execution is compared with the user program written to the program memory.
If they do not match, a stop error, “RAM ERROR” (error code: 1160) is detected.

(b) Parameter

The parameters are compared with the ones written to the parameter-valid drive.

(c) Device memory

If the devices cannot be read, a stop error, “RAM ERROR” (error code: 1161) is detected.

(2) Execution timing

1) Program: At program execution
2) Parameter:
   - When the CPU module is powered off and then on
   - When the CPU module is reset
   - When the CPU module is set from STOP to RUN after data are written to it
3) Device memory: When device data are read

6.28 Latch Data Backup to Standard ROM Function

(1) Definition

This function holds (backs up) latch data, such as device data and error history, to the standard ROM without using a battery when the system is stopped for a long period. This function helps to extend battery life.

Remark

When this function is performed, the battery life-prolonging function is enabled regardless of the parameter setting for the battery life-prolonging function.
Also, the battery life-prolonging function is switched to be disabled after backup data are restored.
The setting status of the battery life-prolonging function can be checked by SD119 (battery life-prolonging factor).
For details of the battery life-prolonging function, refer to Section 6.26.

(2) Data to be backed up

Table6.45 shows data to be backed up.

Table6.45 Data to be backed up

Data to be backed up	Description	Remarks
Device data	• Internal user device (M, L, B, F, V, T, ST, C, D, W) • Index register (Z)/standard device register (Z) • File register (R, ZR) • Extended data register (D)*1 • Extended link register (W)*1	The data of the file register, extended data register (D), and extended link register (W) are backed up only when the file register in the standard RAM is used
Error history	Error history data immediately before the latch data backup function to standard ROM function is performed	-
SFC program continuation start information	Information to start the SFC program continuously	-
Trace setting (Sampling trace file)	Trace condition settings and Trace data settings created by the sampling trace function.	Data cannot be backed up in the following cases. • Trace setting is made in a memory card. • Trace setting is not registered with the CPU module.

*1: The data are backed up only when the Universal model QCPU having the serial number (first five digits) is "10042" or later is used.

Point

When backing up the data in the file register, extended data register (D), and extended link register (W), pay attention to the following.

- The data are backed up only when the file register in the standard RAM is set to be used.
- Select "Transfer to Standard ROM at Latch data backup operation." on the PLC file tab of the PLC parameter dialog box.

Selecting this option starts backup.




Figure 6.108 PLC file tab

(3) File size for storing backup data

The system automatically creates storage file for backup data when the latch data backup function to standard ROM is performed.

Table6.46 shows the size of storage file.

Table6.46 Sizes of files to be stored

Data to be backed up		File size
Device data	Internal user device (M, L, B, F, V, T, ST, C, D, W) Index register (Z)/standard device register (Z)	110890 bytes*1 (When the default is set to the device assignment setting)*2
Error history		
SFC program continuation start information		
File register (R, ZR)*3, extended data register (D)*3, extended link register (W)*3		64 + 2 × Number of file register points
ÉgTrace setting (sampling trace file)*4		16 + Sampling trace file size

*1: The file size of the Q00UJCPU,Q00UCPU,Q01UCPU,and Q02UCPU are 87210 bytes.
*2: The size depends on the parameter setting.
*3: Storage files are created only when data in the file register, extended data register (D), and extended link register (W) are backed up.
*4: Storage files are created only when the trace registration has been made.

(4) Execution method

(a) Execution by contacts

1) Setting method

Set "Latch data backup operation valid contact" in the PLC system tab of the PLC parameter dialog box (Devices X, M, or B can be selected).




Figure 6.109 Setting screen of latch data backup start contact to standard ROM

2) Execution method

Backup starts at the rise of a contact (off → on).
After backup, the BAT.LED of the CPU module flashes (green), indicating that the CPU module is in the standby status ready to be powered off.

3) Precautions

a)Since data to be backed up is the data when a contact is on (END processing), the CPU module will not become the RUN status until the CPU module is powered on again or is reset after this operation.

b) Since the status of latch data backup start contact to the standard ROM is checked at execution of the END instruction, data are not backed up even if a contact is turned on → off → on, or off → on → off in one scan.

c) In the following cases, data are not backed up unless the latch data backup start contact to the standard ROM is turned off and then on again.

- The latch data backup start contact to the standard ROM is set to X, and the CPU module is powered off and then on or is reset after backup by turning off and then on the contact.
- The latch data backup start contact to the standard ROM is set to M or B, and data are backed up by turning off and then on the contact.

(b) Execution by remote operation

1) Execution method

Select [Online] → [Latch data backup operation] of GX Developer.
After backup, the BAT.LED of the CPU module flashes (green), indicating that the CPU module is in the standby status ready to be powered off.




Figure 6.110 Remote operation execution screen

Data to be backed up is the data at the execution of remote operation.

(5) Restoring backup data

The backup data is automatically restored by the following operations.

- At power-off → on of the CPU module
- At reset

Whether to restore data once after backup or per above operation is set by SM676 (Specification of restore repeated execution).

Table6.47 Status of SM676 and restoration operation

Status of SM676 at backup operation	Restoration operation
SM676 is off.	Data are restored once when the CPU module is powered off and then on or is reset after backup.
SM676 is on.	Data are restored whenever the CPU module is powered off and then on or is reset after backup. Data are repeatedly restored until the backup data are deleted or the latch data are backed up next time.

After backup data are restored, the BAT.LED on the CPU module turns on (green) for five seconds.

Point

If the number of device points configured in the parameter setting and the number of device points at the time of backup are different, "RESTORE ERROR" (error code: 2220) is detected when the backup data are restored, and data restoration is not normally completed.
(Data will be restored again when the CPU module is powered off and then on or is reset in the next time.)
Perform any of the following operations to normally complete restoring data.

- Return the status of data when the parameters are backed up.
- Delete the backup data.
- Backup data again.

(6) Deleting backup data

Select [Online] → [Latch data backup operation] of GX Developer (Set the CPU module to STOP since data cannot be deleted in the RUN status).
Also, information of special registers (SD671 to SD675) can be initialized (cleared to 0) by deleting the backup data.




Figure 6.111 Screen for deleting backup data

(7) Checking with special relays and special registers

The status of execution of latch data backup to the standard ROM or restoration operation can be checked by SM671, SM676, SD671 to SD679.

(8) Precautions

The following provides precautions for backing up latch data.

1) Do not power off or reset the CPU module during backup of latch data. If performed, "RESTORE ERROR" (error code: 2221) is detected, and backup data is not restored (The backup data are deleted).
2) Even if the backup data exists, the initial device value has a priority over the backup data when the initial device value is set.
   Therefore, the device where the initial device value setting is configured is overwritten by the device data of the initial device value after reflecting the backup data.
3) Even if the latch device or latch range setting is used, backup data has a priority. Therefore, even when data of latch device and latch range setting are changed after backup, it is overwritten by data backed up when the CPU module is powered off and then on or is reset.
4) Devices where local device range setting is configured are not backed up. They are initialized (cleared to 0) when the CPU module is powered off and then on or is reset.
5) When the number of writes to the standard ROM exceeds 100,000 times ("FLASH ROM ERROR" (error code: 1610) is detected), data may not be normally backed up.
6) Backup data cannot be deleted unless the data are deleted or the storage location memory (standard ROM) for the backup data is formatted.
7) The following operations cannot be performed during latch data backup. Perform them after the backup operation.
   If performed, an error is displayed on the GX Developer screen.
   - Format PLC memory (standard ROM only)
   - Latch data backup by remote operation
   - Online change (ladder mode, files, function block)
   - Write the program memory to ROM
   - Write to PLC (Flash ROM)

6.29 Writing/Reading Device Data to/from Standard ROM

(1) Definition

This function writes device data to the standard ROM.

Writing the fixed values for operation and operation results to the standard ROM can prevent losing data due to low battery. Also, timing of writing to the standard ROM can be set by an instruction.

(2) Execution method

Device data are written to the standard ROM by the SP.DEVST instruction.

The device data written to the standard ROM is read to the specified device by the S(P).DEVLD instruction.

(3) Devices that can be written to the standard ROM

Table6.48 shows the devices whose data can be written to the standard ROM.

Table6.48 Devices that can be written to the standard ROM and storage location


Device	Storage location
X,Y,M,L,B,F,V,T,ST,C,D*1,W*2,SM,SD,SB,SW,R,ZR	Standard ROM(device data storage location)

*1: The extended data register (D) is included.

*2: The extended link register (W) is included.

(4) Setting method

The area for storing the device data is set in the standard ROM by the PLC file tab of the PLC parameter dialog box.



Set a file size
(A file name is fixed to DEVSTORE).

Figure 6.112 Screen for setting a file for storing device data

Remark

For details of the instructions, refer to the following.

QCPU Programming Manual (Common Instructions)

6.30 CPU Module Change Function with Memory Card Note6.12

(1) Definition

This function backs up data in the CPU module to a memory card and restores the backup data to another CPU module.




Figure 6.113 CPU module change function with memory card

This function consists of the following two functions.

- Backup function to memory card: Section 6.30.1
- Backup data restoration function: Section 6.30.2

Note6.12 Universal

The Q00UJCPU, Q00UCPU, and Q01UCPU do not support the CPU module change function with memory card. When using the function for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, Q26UDHCPU, or Built-in Ethernet port QCPU, check the versions of the CPU module and GX Developer. (Appendix 2)

(2) Backup data file

After data are backed up, a backup data file "MEMBKUP0.QBP" is created in a memory card.
Only one backup data file can be stored to a memory card.
When data are backed up to a memory card containing a backup data file again, the stored backup data file is overwritten. When a memory card contains another file, a backup data file can be stored in the memory card without deleting the stored file.[*1] [*2]

*1: After restoration, if the parameters are stored in the memory card but not in the CPU module, the CPU module operates by the parameter settings in the memory card.
*2: When data are backed up to the Flash card, only a backup data file can be stored.

The backup data file can be deleted by "Delete PLC data" of GX Developer.

(3) Backup data

(a) Backup data selection

Table6.49 shows data to be backed up.

Table6.49 Data to be backed up

Backup data (drive)	Description	Backup selection by the user
Program memory (drive 0)	All data in the program memory (drive 0) [*1]	Selectable
Standard RAM (drive 3)	All data in the standard RAM (drive 3)	
Standard ROM (drive 4)	All data in the standard ROM (drive 4)	
Device data[*2]	Internal user device (M, L, B,F,V,T,ST,C,D,W)	Not selectable (Data are automatically backed up by the system.)
System data	Data managed by the system (such as error history)	

*1: Data in the program cache memory are backed up.
*2: Only the latch relay (L) and devices to which the latch range setting can be configured are backed up.

(b) Maximum backup data size

Table6.50 shows the maximum size of data that can be backed up.

Table6.50 Maximum size of data that can be backed up

Backup target data (drive)	Q02UCPU	Q03UD/ Q03UDE CPU	Q04UDH/ Q04UDEH CPU	Q06UDH/ Q06UDEH CPU	Q10UDH/ Q10UDEH CPU	Q13UDH/ Q13UDEH CPU	Q20UDH/ Q20UDEH CPU	Q26UDH/ Q26UDEH CPU
Program memory (drive 0)	80	142	182	262	422	542	822	1062
Standard RAM (drive 3)	128	193	257	769	1036	1036	1292	1292
Standard ROM (drive 4)	512	1036	1036	1036	2060	2060	4108	4108
Device data	128	128	128	128	128	128	128	128
System data	47	73	73	73	79	79	79	79
Total (maximum)	895	1572	1676	2268	3725	3845	6429	6669

(Unit: K byte)

The backup data size can be checked by the following methods.

- Execution screen of GX Developer (☞ Section 6.30.1(1)(b))
- SD698 and SD699(☞ CHAPTER 12)[*1]

*1: Can check the data size after backup starts.

6.30.1 Backup function to memory card

This function can save data in the CPU module to a memory card.
If a memory card is used in running system, data can be backed up by replacing the current memory card with the one for storing a backup data.

(1) Methods

(a) Method with contacts

1) Setting

To back up data with contacts, turn on the device set in the “PLC module change setting“ screen in the PLC system tab of the PLC parameter dialog box.




Figure 6.114 PLC module change setting screen

Table6.51 Setting items

Item	Description	Setting range	Default
Backup start setup contact*1	At the rise of the selected device among the items shown in the right column, backup is ready to start.	Available devices*2 • X (0 to 1FFF) • M (0 to 8191)*3 • B (0 to 1FFF)*3	-
Backup start contact	At the rise of the selected device among the items shown in the right column, backup enters execution status.		
Backup target data	Select data to be backed up stored in any of memories shown in right column.*4	• Program memory (drive 0) • Standard RAM (drive 3) • Standard ROM (drive 4)	All drives are backed up.
Format memory card before backup	Select whether to format a memory card before backup.	Formatted Not formatted	Not formatted
Title setting*5	Set a title appended to backup data stored in a memory card.	32 characters (16 in two-byte characters)	Set the title of the current time. (Example) If data are backed up at 12 p.m. on October 1, 2008, "200810011200" is set.

*1: The CPU module enters the STOP status at the rise of the backup start setup contact, the backup start contact cannot be turned on in the sequence program.
*2: The backup start setup contact and backup start contact cannot be set to the same device.
*3: This indicates the default number of points. The setting range when the internal user device is set to the maximum number of points (60K points) is M(0 to 61439) and B(0 to 0EFFF).
*4: If data to be backed up is deselected in "Backup target data", only device data and system data are backed up.
*5: The title is used for identifying backup data.
Settings for the title of the backup data stored in a memory card can be checked on the Delete PLC data screen of GX Developer.

2) Operating procedure

Turn on in the order of the backup start setup contact and the backup start contact. Data are not backed up when only the backup start contact is on.




Figure 6.115 Backup procedure using contacts

*1: Since the SM691 (Backup start preparation status flag) is on, data can be backed up again by turning off and then on the backup start contact.

3) Operation of contacts

Operations of the backup start setup contact, backup start contact, SM691 (Backup start preparation status flag), and SD690 (Backup status) at backup are shown in Figure 6.116.




Figure 6.116 Operation of contacts

If the backup start contact is turned on while the value in SD690 is 0_H (Before backup start) or 1_H (Backup start prepared), data are not backed up.

If the backup start contact is on before the value in SD690 becomes 2_H (Backup start preparation completed), turning off and then on the backup start contact again while the value in SD690 is 2_H (Backup start preparation completed) starts backup.

(b) Backup from GX Developer

Select [Online] → [PLC module change] → [Create backup data...].




Figure 6.117 Create backup data screen

For details of the operating procedure by the GX Developer wizard, refer to the following.

☞ GX Developer Version 8 Operating Manual

Point

Clicking the Confirm data size button on the screen shown in Figure 6.117 displays the size of backup data created at backup.
Data size can be checked by GX Developer connected to the CPU module.
This function is available regardless of the operating status of the CPU module (RUN, STOP, PAUSE) or mounting status of a memory card.

(2) Operations of backup to a memory card

(a) Mounting/removal of a memory card

In a system using a memory card, the memory card can be changed/removed after preparation for backup has been completed (Turning on SM609 (Memory card remove/insert enable flag) is unnecessary).
After preparation for backup has been completed, the CPU module turns off SM604 (Memory card in-use flag).

(b) Status of backup to a memory card

Table6.52 shows backup status.

Table6.52 Backup status

Status	Description	Value in SD690
Before backup start	Backup is not started.	0H
Backup start prepared	A memory card can be mounted/removed.	1H
Backup start preparation completed	Set data to be backed up.	2H
Backup in execution	Backup is in execution.	3H
Backup completed	Backup is normally completed.	4H
Backup error	Backup failed due to an error.	FFH




Figure 6.118 Flow of status change at backup

(c) Operations of special relays and special register*1

Figure 6.119 shows the operations of the SM609 (Memory card remove/insert enable flag), SM691 (Backup start preparation status flag), and SD690 (Backup status).




Figure 6.119 Special relays and special register at backup

*1: For details of the special relays and special register used for backup, refer to CHAPTER 12.
*2: This special relay is turned on/off by the system.

(d) Operating status of the CPU module

After END processing where the backup start setup request is accepted, the CPU module changes the operating status to STOP at backup. Therefore, data can be backed up regardless of the operating status. After backup, power off and then on the CPU module or reset the CPU module.(If the CPU module is not powered off and then on or is not reset but set the RESET/STOP/RUN switch to RUN, the CPU module remains in the STOP status).





Figure 6.120 Operating status of the CPU module at backup

*1: The status includes a stop error.

(3) LEDs indicating backup status

The LEDs on the front of the CPU module indicate backup status.

Table6.53 LEDs indicating backup status

Value stored in SD690	Backup status	LED indication
2H	Backup start preparation completed	MODE: Flash (green), BAT.: Flash (green)
3H	Backup in execution	The color changes at intervals of 800ms as follows. 
4H	Backup completed	MODE: Flash (green), BAT.: Flash (green), BOOT: Flash (green)
FFH	Backup error	MODE: Flash (green),USER: MODE: Flash (red), BAT.: Flash (green)

(4) Error cause of backup

When backup is not normally completed, an diagnostic error is not detected. In that case, the error cause is stored in SD689(Backup error factor) and the error response is returned to GX Developer.

Table6.54 Error cause of restoration

Value stored in SD689	Error response number	Error cause
100H	-	Restoration started while a memory card was not mounted.
200H	-	Size of data to be backed up exceeds the capacity of mounted memory card.
300H	-	Write protection has been set to the memory card.
400H	-	Writing to the memory card was not normally completed.
500H	-	Reading from a drive storing backup data was not normally completed (program memory read error).
503H	-	Reading from a drive storing backup data was not normally completed (standard RAM read error).
504H	-	Reading from a drive storing backup data was not normally completed (standard ROM read error).
510H	-	Reading from a drive storing backup data was not normally completed (system data read error).
600H*1	4335H*2	Backup preparation started while latch data were backed up to the standard ROM.
601H*1	410AH*2	Backup preparation started while data were written in the RUN status.
602H*1	4336H*2	Backup preparation started while a FTP client connected a FTP to the CPU module in FTP connection.
-	4082H*3, 4330H*4	Backup preparation or backup started while another backup was in execution.
-	4333H*2	Backup started while the CPU module was in "Before backup start" (SD690 = 0).

*1: Only when data are backed up with contacts
*2: Only when data are backed up from GX Developer
*3: Only when data area backed up from another boot source.
*4: Only when data area backed up from the same boot source.

(5) Functions that cannot be performed during backup

Table6.55 shows functions that cannot be performed during backup.

Table6.55 Functions that cannot be performed during backup

Category	Function	Category	Function
Drive operation	Format PLC memory	Trace	Sampling trace registration
	Write the program memory to ROM	Remote operation	Remote latch clear
	Program memory batch transfer	File operation	Write to PLC
	Arrange PLC memory		Delete PLC data
Online change	Online change (ladder mode)		Write PLC user data
	Online change (files)		Delete PLC user data
	Online change (multiple blocks)		Password registration
	Change TC setting		Latch data backup operation
Monitor	Monitor condition setup	FTP function	For all operations and commands
Debug	Executional conditioned device test		

(6) Precautions

(a) Do not perform the following operations during backup.

- Mounting/removal of a memory card
- Power-off of the CPU module
- Reset

(b) Even if booting parameters backed up with contacts for the Universal model QCPU having the serial number (first five digits) is "10101" or earlier, the system ignores the parameters.

In this case, even if the backup start setup contact or backup start contact set by the parameters is turned on, the operating status of the CPU module does not change (a diagnostic error is not detected).

(c) After backup is ready to start, the following functions stop (do not resume the operations even after the backup).

- Refresh of network modules
- Data link transfer
- Auto refresh of intelligent function modules
- Auto refresh of CPU shared memory

6.30.2 Backup data restoration function

This function restores data backed up to a memory card to the CPU module.

(1) Methods

(a) Restoration from GX Developer

Select [Online] → [PLC module change] → [Restore...].




Figure 6.121 Restore screen

After selecting "Execute" on the screen above and powering off and then on the CPU module or reset the CPU module, the restored data become valid.

(b) Automatic restoration

Select ”Auto restore at turn OFF → ON" in "PLC module change setting" in the PLC system tab of the PLC parameter dialog box. (☞ Section 6.30.1(1)(a))
After data are backed up and the CPU module is powered off and then on or is reset, restoration automatically starts.
Also, items shown in Table6.56 can be set by the option setting.

Table6.56 Option setting items

Option setting item	The CPU module is powered off and then on or is reset	
	First time	After the first time
Restore for the first time only *1 *2	Restored	Not restored (The CPU module operates the memory card as usual.)*3
Restore every time	Restored	Restored

*1: This setting is valid only when backup data are stored to the ATA card or SRAM card.
Note if the write protect switch of the SRAM card is set to be valid (write protection), the setting does not become valid and the data are restored even after the first time ("RESTORE ERROR" (error code: 2226) occurs).
*2: When using the FLASH card, restoration can be performed even after the first time.
*3: Restoration after the first time can be performed from GX Developer.

Data are restored at initial processing after the CPU module is powered off and then on or is reset.
After restoration, powering off and then on the CPU module or resetting the CPU module again is not required to change the operating status to the one set with the RUN/STOP/RESET switch.

If a memory card needs to be changed after restoration, turn on SM609 (Memory card remove/insert enable flag) and change the memory card after SM600 (Memory card usable flags) turns off.

(2) Operation for restoring backup data

Figure 6.122 shows operation for restoration.




Figure 6.122 Operation for restoration

A value indicating restoration status is stored in SD693 (Restoration status).

Table6.57 Status at restoration

Status	Description	Value stored in SD693
Before restoration start	Restoration is not performed.	0H
Restoration in execution	Restoration is in execution.	1H
Restoration completed	Restoration is normally completed.	2H
Restoration error	Restoration failed due to an error.	FFH

(3) Operation of special relay and special register*1

Figure 6.123 shows the operation of SM692 (Restoration complete flag) at restoration.





Figure 6.123 Operation of the special relay

*1: For details of special relays and special registers for restoration, refer to CHAPTER 12.

(4) LEDs indicating restoration status

The LEDs on the front of the CPU module indicate restoration status.

Table6.58 LEDs indicating restoration status

Value stored in SD693	Restoration status	LED indication
0H	Before restoration start	MODE: On (green)
1H	Restoration in execution	The color changes at intervals of 800ms as follows. 
2H	Restoration completed	• Restoration from GX Developer MODE: Flashing (orange), BAT.: Flashing (green), BOOT: Flashing (green) • Automatic restoration MODE:On (green)
FFH	Restoration error	• Restoration from GX Developer MODE:Flashing (orange), USER: Flashing (red),BAT.:Flashing (green) • Automatic restoration MODE:On (green), ERR: Flashing (red)

(5) Error cause of restoration

When restoration is not normally completed, an diagnostic error is not detected. In that case, the error cause is stored in SD692 (Restoration error factor) and the error response is returned to GX Developer.

Table6.59 Error cause of restoration

Value stored in SD692	Error response number	Error cause
800H	-	The CPU module where data are restored is different model with the one where the backup source data are stored.
801H	-	• Backup data files do not match. • Reading of backup data from a memory card was not normally completed.
810H	-	Writing of backup data to the restoration destination drive was not normally completed.
-	4335H*1	Restoration started while latch data were backed up to the standard ROM.
-	410AH*1	Restoration started while data were written in the RUN status.
-	4336H*1	Restoration started while a FTP client connected a FTP to the CPU module in FTP connection.
-	4330H*1	Restoration started while another restoration was in execution.
-	41FEH*1	Restoration started while a memory card was not mounted.

*1: Only when data are restored from GX Developer

When automatic restoration is not normally completed, “RESTORE ERROR” (error code: 2225 to 2227) is detected.

Table6.60 Error when automatic restoration is not normally completed

Error code	Error message	Error cause
2225	RESTORE ERROR	The CPU module where data are restored is different model with the one where the backup source data are stored.
2226		• Backup data file is corrupt (The contents of backup data file do not match with the check code). • Reading of backup data from a memory card was not normally completed. • The write protect switch of the SRAM card is valid (write protection), and therefore "Restore for the first time only" cannot be set to valid.
2227		Writing of backup data to the restoration destination drive was not normally completed.

Remark

For details of error codes, refer to the following.

☞ QCPU User's Manual (Hardware Design, Maintenance and Inspection)

(6) Functions that cannot be performed during restoration

Functions that cannot be performed during restoration are the same as the ones that cannot be performed during backup. (☞ Section 6.30.1(5))

(7) Precautions

(a) Do not perform the following operations during restoration.

- Mounting/removal of a memory card
- Power-off of the CPU module
- Reset

(b) Even if mounting a memory card storing backup data file to the Universal model QCPU having the serial number (first five digits) is "10101" or earlier and powering off and then on the CPU module or reset the CPU module, the system ignores the backup data file and starts operation (a diagnostic error is not detected).

(c) Do not use a memory card where the boot file setting parameter is stored. If used, data in the memory card are overwritten by the boot file setting even restoration is performed.

(d) If restoration is started from GX Developer, the following functions stop (do not resume the operations even after the restoration).

- Refresh of network modules
- Data link transfer
- Auto refresh of intelligent function modules
- Auto refresh of CPU shared memory

CHAPTER7 COMMUNICATIONS WITH INTELLIGENT FUNCTION MODULE

(1) Intelligent function module

The intelligent function module allows the CPU module to process analog quantity and high speed pulses that cannot be processed by the I/O modules.
For example, the analog-digital conversion module, one of the intelligent function modules, uses analog quantity by converting it into a digital value.

(2) Communication with intelligent function module

The intelligent function module is equipped with a memory (buffer memory) to store the data taken in from or output to external devices.
The CPU modules writes or reads data to or from the buffer memory of the intelligent function module.

7.1 Communications between CPU Module and Intelligent Function Module

The following table shows the communication methods between the CPU module and intelligent function modules and the communication timing.

Table7.1 Communication methods with intelligent function module and the communication timing

Communication methods with intelligent function module		Communication timing					Reference
		Power off → on	CPU module is reset	STOP → RUN*2	Instruction execution	END processing	
GX Configurator	Initial setting	○	○	○	-	-	Section 7.1.1
	Auto refresh setting	-	-	-	-	○	
Initial device value		○	○	○	-	-	Section 7.1.2
FROM or TO instruction*1		-	-	-	○	-	Section 7.1.3
Intelligent function module device*1		-	-	-	○	-	Section 7.1.4
Intelligent function module dedicated instruction*1		-	-	-	○	-	Section 7.1.5

○: Executed, -: Not executed

*1: Indicates the program that uses the intelligent function module device, FROM or TO instruction, or the intelligent function module dedicated instruction.
*2: The RUN/STOP/RESET switch is set from STOP → RUN (RUN LED flashes) → STOP → RUN.

Point

- Data, such as initial settings used for communications with intelligent function module, are stored in the CPU module. For the storage location, refer to Section 5.1.
- Power off and then on or reset the CPU module to make the initial setting configured in GX Configurator taken effect.

7.1.1 Initial setting and auto refresh setting by GX Configurator

The initial setting and auto refresh setting can be made by adding in GX Configurator that is supported by the intelligent function module to GX Developer.
After the initial and auto refresh settings, data can be read or written without creating a program for communications with intelligent function modules.

(1) Starting GX Configurator

Select [Tools] → [Intelligent function module utility] → [Start] in GX Developer.

(2) Setting in GX Configurator

An example of initial setting and auto refresh setting for the A/D conversion module Q64AD is used in this section.

(a) Initial setting

The initial setting for the Q64AD offers the following four types.

- A/D conversion enable/disable setting
- Sampling process/averaging process setting
- Time/number of times specifying
- Average time/average number of times setting

Make the initial settings of the Q64AD in the Initial setting screen in GX Configurator as shown in Figure 7.1.




Figure 7.1 Initial setting screen

The initial setting data set in this screen are stored into the intelligent function module parameters of the CPU module.

(b) Auto refresh setting

The CPU module devices for storing the following data can be set in the Auto refresh setting screen.

- Digital output of the Q64AD
- Maximum and minimum values of the Q64AD
- Error codes

Make auto refresh settings of the Q64AD in the Auto refresh setting screen in GX Configurator as shown in Figure 7.2.




Figure 7.2 Auto refresh setting screen

The auto refresh setting data set in this screen are stored into the intelligent function module parameters of the CPU module.

(3) Limitation on the number of parameter settings


Limitations are placed on the number of parameters (initial setting and auto refresh setting) set in GX Configurator.

When multiple intelligent function modules are mounted, make setting in GX Configurator so that the number of parameter settings for all intelligent function modules may not exceed the limitation shown in Table7.2.

Table7.2 Maximum number of parameters set in GX Configurator

CPU module	Maximum number of parameter settings	
	Initial setting	Auto refresh setting
Q00UJCPU, Q00UCPU, Q01UCPU	512	256
Q02UCPU	2048	1024
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	4096	2048

One line in the Auto refresh screen is counted as one parameter setting.



This one line is counted as one parameter setting.
Blanks are not counted.
Add the number of lines on this screen to those of other intelligent function modules.

Figure 7.3 Counting the number of parameter settings

Remark

For details of GX Configurator, refer to the manual for the intelligent function module used.

7.1.2 Initial setting by initial device value

(1) Initial device value

Using an initial device value (☞ Section 6.25) allows the initial setting of the intelligent function module without a program.
The set initial device values are written from the CPU module to the intelligent function module when the CPU module is powered off and then on, is reset, or set from STOP to RUN.

(2) Setting initial device values

Use GX Developer to set the following.

- Set the device data of the intelligent function module (☞ Section 9.5.1) used as the initial device value to the device memory.
- In the initial device value setting, specify the device range of the intelligent function module used as the initial device value.

7.1.3 Communications with the FROM and TO instructions

The FROM instruction stores data read from the buffer memory of the intelligent function module to the specified device.
The TO instruction writes data stored in the specified device to the buffer memory of the intelligent function module.

Remark

- For details of the FROM and TO instructions, refer to the following.
  ☞ QCPU Programming Manual (Common Instructions)

- For details of the buffer memory of the intelligent function module, refer to the following.
  ☞ Manual for the intelligent function module used

7.1.4 Communications using the intelligent function module device

(1) Intelligent function module device

The intelligent function module device (☞ Section 9.5.1) represents the buffer memory of the intelligent function module as one of the CPU module devices.
The data stored in the buffer memory of the intelligent function module can be treated by the sequence instruction as well as the device memory.
A programming example is given below for the case where "100" is written to the buffer memory of an address 0 of the intelligent function module whose I/O number is X/Y20 to X/Y2F.




Figure 7.4 Use of the intelligent function module device

(2) Difference from the FROM and TO instructions

The intelligent function module device processes data read from the intelligent function module with one instruction as the device can be treated as one of the CPU module devices.
A program example is given below for the case where data read from the intelligent function module are added and then the result is stored in D2.




Figure 7.5 Application example of the intelligent function module device

This reduces the number of steps in whole program.
The instruction processing time indicates the time required for instruction execution and accessing the intelligent function module.

Point

The intelligent function module device accesses the intelligent function module every time when an instruction is executed. When writing or reading buffer memory data using multiple intelligent function module devices in a sequence program, write or read the data with the FROM or TO instruction in one location of the program.




Figure 7.6 Writing using multiple intelligent function module devices




Figure 7.7 Writing using the TO instruction

7.1.5 Communications using the intelligent function module dedicated instruction

(1) Intelligent function module dedicated instruction

This instruction enables easy programming for the use of functions of the intelligent function module.

(a) Example with the serial communication module dedicated instruction (OUTPUT instruction)

The OUTPUT instruction allows communications with external device by nonprocedural protocol regardless of the buffer memory address of the serial communication module.

[Transmission by the OUTPUT instruction]




Figure 7.8 Communications with external devices using the OUTPUT instruction

(2) Processing of the intelligent function module dedicated instruction

Some of intelligent function module dedicated instructions can specify the completion device.

This completion device turns on for one scan when an instruction execution is completed.

When using multiple intelligent function module dedicated instructions to one intelligent function module, execute the dedicated instructions one by one after the completion device turns on.

(3) Precautions

(a) When the CPU module is set from RUN to STOP before the completion device turns on

When a intelligent function module dedicated instruction is executed and the CPU module is set from RUN to STOP before the completion device turns on, the completion device will not turn on until the CPU module is set to RUN and then finishes one scan.

(b) Available range

The intelligent function module dedicated instructions are not applicable to the intelligent function modules mounted on remote I/O stations of MELSECNET/H.

The instructions are applicable to the intelligent function modules mounted on the base unit or extension base units.

Remark

For intelligent function module dedicated instructions and completion devices, refer to the following.

☞ Manual for the intelligent function module used

CHAPTER8 PARAMETERS

This chapter describes the parameters required to be set for configuring a programmable controller system.

(1) Parameter types

The following parameters are provided for CPU module setting.

- PLC parameters (☞ Section 8.1)
  These parameters are set when a programmable controller is used.
- Network parameters (☞ Section 8.2)
  These parameters are set when a programmable controller module is used in combination with any of CC-Link IE controller network modules, MELSECNET/H modules, Ethernet modules, and CC-Link modules.
- Remote password (☞ Section 8.3)
  Parameters are set when the remote password function is used for an Ethernet module, serial communication module, modem interface module, or Built-in Ethernet port QCPU.

(2) Parameter setting method

Use GX Developer.

For the setting details, refer to the following.

☞ GX Developer Version 8 Operating Manual

Point

Grayed-out (unselectable) parameter settings in GX Developer are not available since the corresponding function is not supported.

Remark

Each parameter number shown in the tables in this chapter is stored in the special register (SD16 to SD26) when an error occurs in parameter setting.
Identify the parameter error location from the parameter number.

For the list of the special register (SD16 to SD26), refer to CHAPTER 12.
For the parameter updating procedure, refer to CHAPTER 11.

8.1 PLC Parameters

This section provides the list of PLC parameters and describes parameter details.

(1) PLC name

A label and a comment for the CPU module are set.

The settings will be displayed in the list for the find CPU function. Note8.1




Figure 8.1 PLC name

Table8.1 PLC name setting list

Item	Parameter No.	Description	Setting range	Default	Reference
Label	0000H	Set a label (name, application) for the CPU module.	Up to 10 characters	Blank	-
Comment	0001H	Set a comment for the CPU module label.	Up to 64 characters	Blank	-

Note8.1 Universal

The Universal model QCPUs other than the Built-in Ethernet port QCPU do not support the find CPU function.

(2) PLC system

Parameters required for use of the CPU module are set.




Figure 8.2 PLC system

Table8.2 PLC system setting list

Item		Parameter No.	Description	Setting range	Default	Reference
Timer limit setting	Low speed	1000H	Set the time limit for the low speed timer or high speed timer.	1ms to 1000ms (in increments of 1ms)	100ms	Section 9.2.10
	High speed			0.01ms to 100.0ms (in increments of 0.01ms)	10.0ms	Section 9.2.10
RUN-PAUSE contcts	RUN	1001H	Set the contacts that control RUN/ PAUSE of the CPU module. Setting of only the PAUSE contact is not allowed.	X0 to 1FFF	Blank	Section 6.6.1
	PAUSE					Section 6.6.2
Latch data backup operation valid contact		1014H	Set the valid contact device No. for backup of latch data to the standard ROM.	X, M, B	Blank	Section 6.28
Remote reset		1002H	Select whether to allow the remote reset from GX Developer.	Selected/deselected	Deselected	Section 6.6.3
Output mode at STOP to RUN		1003H	Set the status of the outputs (Y) when the operating status is switched from STOP to RUN.	Previous state, Recalculate (output is 1 scan later)	Previous state	Section 6.4
Intelligent function module setting (Interrupt pointer setting)		100AH	Assign the interrupt pointers (I50 to I255) and set the start I/O number and start SI number of each intelligent function module.	• Start I/O No. • Start SI No. • I50 to 255	Blank	Section 9.11
Module synchronization		100CH	Select whether to synchronize CPU module startup with intelligent function module startup.	Selected/deselected	Deselected	-

(To the next page)

Table8.2 PLC system setting list (continued)

Item		Parameter No.	Description	Setting range	Default	Reference
Common pointer No.		1005H	Set the start number of common pointers.	P0 to 4095	Blank	Section 9.10.2
Points occupied by empty slot		1007H	Set the number of points for empty slots on the main/extension base units.	0, 16, 32, 64, 128, 256, 512, or 1024 points	16 points	Section 3.2.2
System interrupt settings	Fixed scan interval (n: 28 to 31)	1008H	Set each execution interval for the interrupt pointers (I28 to I31).	0.5ms to 1000ms (in increments of 0.5ms)	• I28: 100.0ms • I29: 40.0ms • I30: 20.0ms • I31: 10.0ms	Section 9.11
Interrupt program/Fixed scan program setting		1008H	Enable or disable high speed execution of interrupt programs or fixed scan execution type programs.	Selected/deselected	Deselected	Section 2.2.3, 2.3.4
Service processing setting		1013H	Select any of the following options. • Execute the process as the scan time proceeds. • Specify service process time. • Specify service process execution counts. • Execute it while waiting for constant scan time setting.	• 1 to 99% (in increments of 1%) • 1 to 10 (in increments of 1 time) • 0.2 to 1000ms (in increments of 0.1ms) • Blank	Execute the process as the scan time proceeds.: 10%	Section 6.24.1
PLC module change setting (PLC module change setting)		1017H	Set items required when performing the CPU module change with memory card function.	• Backup start setup contact • Backup start contact • Backup target data • Title setting	Blank	Section 6.30

(3) PLC file

Parameters required for the files used in the CPU module are set.




Figure 8.3 PLC file

Table8.3 PLC file setting list

Item	Parameter No.	Description	Setting range	Default	Reference
File register*1	1100H	Set a file for the file register used in the program.	• Not used • Use the same file name as the program. • Use the following file.	Not used	Section 9.7
Transfer to Standard ROM at Latch data backup operation*1	1104H	Select whether to batch-transfer the data in the file register at the time of latch data backup to the standard ROM.	Checked/unchecked	Not selectable	Section 6.27
Comment file used in a command	1101H	Set a file for device comments used in the program.	• Not used • Use the same file name as the program. • Use the following file.	Not used	-
Initial Device value	1102H	Set a file for initial values of the devices used for the CPU module.	• Not used • Use the same file name as the program. • Use the following file.	Not used	Section 6.25
File for local device*1	1103H	Set a file for local devices used in the program.	• Not used • Use the following file.	Not used	Section 9.14.2
File use for SP.DEVST/S.DEVLD instruction	1105H	Set a device data file used for writing to or reading from the standard ROM.	• Not used • Use the following file.	Not used	Section 6.28

*1: Not available for the Q00UJCPU.

(4) PLC RAS

Parameters required for performing the RAS functions are set.




Figure 8.4 PLC RAS

Table8.4 PLC RAS setting list

Item		Parameter No.	Description	Setting range	Default	Reference
WDT (Watchdog timer) setting	WDT Setting	3000H	Set a watchdog timer value for the CPU module.	10ms to 2000ms (in increments of 10ms)	200ms	Section 6.16
	Initial execution monitoring time		Set a watchdog timer value in the case of using an initial execution type program.	10ms to 2000ms (in increments of 10ms)	Blank	Section 2.3.1
Operating mode when there is an error	Computation error	3002H	Set the operation mode of the CPU module when an error is detected.	Stop/Continue	Stop	Section 6.17
	Expanded command error*1					
	Fuse blown					
	Module verify error					
	Intelligent module program execution error					
	File access error					
	Memory card operation error*3					
	External power supply OFF*1					
Error check	Carry out battery check	3001H	Enable or disable detection of the specified error.	Selected/deselected	Deselected	Section 6.17
	Carry out fuse blown check					
	Verify module					
	Check device range at indexing.					
	Diagnose redundant power supply system.*2					
Constant scanning		3003H	Set a constant scan time value.	0.5ms to 2000ms (in increments of 0.5ms)	Blank	Section 6.2

*1: These items are provided for future expansion.
*2: When selecting this item for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer. (☞ Appendix 2)
*3: Not available for the Q00UJCPU, Q00UCPU, and Q01UCPU.

(5) Device

Number of points, latch range, and local device range are set for each device.




Figure 8.5 Device

Table8.5 Device setting list

Item	Parameter No.	Description	Setting range	Default	Reference
Device points[*1]	2000H	Set the number of device points that is appropriate to the system.	X (8K), Y (8K), and S (8K)[*3] are fixed. Setting is available within the range of 29K words in total, including the above fixed points (1.5K words). • One device: Up to 32K points • Total bit device points: Up to 64K points	• X: 8K • Y: 8K • M: 8K • L: 8K[*2] • B: 8K • F: 2K • SB: 2K • V: 2K • S: 8K[*3] • T: 2K • ST: 0K • C: 1K • D: 12K • W: 8K • SW: 2K	Section 9.1
Latch (1) start/end (Latch clear valid)[*2]	2001H	Set a latch range (start and end device numbers), which can be cleared by remote latch clear operation.	Setting is available for only one range for each of B, F, V, T, ST, C, D, and W devices.	Blank	Section 3.4, 6.3
Latch (2) start/end (Latch clear invalid)[*2]	2002H	Set a latch range (start and end device numbers), which cannot be cleared by remote latch clear operation.	Setting is available for only one range for each of L, B, F, V, T, ST, C, D, and W devices.	Blank	Section 3.4, 6.3
Local device start/end[*6]	2003H	Set a range (start and end device numbers), which is used for a local device.	Setting is available for only one range for each of M, V, T, ST, C, D, and Z devices.[*5]	Blank	Section 9.14.2

(To the next page)

Table8.5 Device setting list (continued)

Item		Parameter No.	Description	Setting range	Default	Reference
File register extended setting*6	Device points	2000H	Set points for the file register (ZR), extended data register (D), and extended link register (W).	Point assignment to the file register (ZR), extended data register (D), or extended link register (W). Assign part of the points of the file register to the extended data register and extended link register.	Blank	Section 9.1, 9.8
	Latch (1) start/end (Latch clear valid)	2004H	Set a latch range (start and end device numbers), which can be cleared by remote latch clear operation.	Each latch range for the file register (ZR), extended data register (D), or extended link register (W).	Blank	Section 3.4, 6.3
	Latch (2) start/end (Latch clear invalid)	2005H	Set a latch range (start and end device numbers), which cannot be cleared by remote latch clear operation.	Each latch range for the file register (ZR), extended data register (D), or extended link register (W).	Blank	Section 3.4, 6.3
	32 bit Indexing*4	2000H	Select Z or ZZ device for 32-bit indexing.	Z0 to Z18 (when using Z device)	Use Z	QCPU Programming Manual (Common Instructions)

*1: When changing the device points, new setting must not exceed the refresh ranges of network modules or the auto refresh ranges of intelligent function modules.
If a new device point setting exceeds the corresponding device range, the data may be written to another device or an error may occur.
*2: When a device latch range is set, the scan time increases.
When latching a device, consider the increase in the scan time. (☞ Section 10.1.2)
*3: The points for the step relay (S) can be changed to 0 if the serial number (first five digits) of the Universal model QCPU is "10042" or later.
*4: Available only when the serial number (first five digits) of the Universal model QCPU is "10042" or later.
*5: For the Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q13UDEHCPU, or Q26UDEHCPU, if the serial number (first five digits) is "10101" or earlier, the index register cannot be used as a local device. (☞ Section 9.14.2)
*6: Not available for the Q00UJCPU.

(6) Program

File names and execution types (execution conditions) are set for each program when two or more programs are written to the CPU module.




Figure 8.6 Program

Table8.6 Program setting list

Item	Parameter No.	Description	Setting range	Default	Reference
Program setting	7000H	When writing two or more programs to the CPU module, set a file name and execution type (execution condition) of each program. Also, set a fixed scan interval (execution interval of the fixed scan execution type program).	• Program name • Execute type (fixed scan interval when the fixed scan execution is selected) • File usability setting*1	Blank	Section 2.3

*1: Available for local devices only.

When using the file usability setting, check the versions of the CPU module and GX Developer. (☞ Appendix 2)
The setting is not available for the Q00UJCPU.

(7) Boot file

Parameters required for a boot from a memory card are set.




Figure 8.7 Boot file

Table8.7 Boot file setting list

Item		Parameter No.	Description	Setting range	Default	Reference
Boot option	Clear program memory	7000H	Select whether to clear the program memory at the time of boot.	Selected/deselected	Deselected	Section 5.1.8
Boot file setting			Set the type and data name of the boot file, and transfer source drive for boot operation.	Type, "Data name, and Transfer from (the transfer target drive (Transfer to) is automatically set in the program memory.)	Blank	

(8) SFC

The mode and conditions for starting an SFC program, and the output mode in the case of a block stop are set.




Figure 8.8 SFC

Table8.8 SFC setting list

Item	Parameter No.	Description	Setting range	Default	Reference
SFC program start mode	8002H	Set the mode and conditions for starring an SFC program, and also set the output mode in case a program block is stopped.	Refer to the QCPU (Q Mode)/ QnACPU Programming Manual (SFC).	Initial start	-
Start conditions	8003H			Autostart block 0	
Output mode when the block is stopped	8006H			Turn OFF	

(9) I/O assignment

The mounting status of each module in the system is set.




Figure 8.9 I/O assignment

Table8.9 I/O assignment setting list

Item		Parameter No.	Description	Setting range	Default	Reference
I/O Assignment	Type	0400H	Set the type of the mounted module.	• CPU No.2 to No.4: No.n/Empty (Set "CPU (Empty)" for the slot where no CPU module is mounted.) • Empty, Input, Hi input, Output, Intelli., I/O mix, or Interrupt	Blank	Section 4.2.2
	Model name		Set the model name of the mounted module. (Entered at user's discretion. Do not use the one for the CPU module.)	Up to 16 characters		
	Points		Set the number of points assigned to each slot.	0, 16, 32, 48, 64, 128, 256, 512, or 1024 points		
	Start XY		Set the start I/O number of each slot.	0H to FF0H		
Base setting	Base model name	0401H	Set the model name of the main base unit or extension base unit. (Entered at user's discretion. Do not use the one for the CPU module.)	Up to 16 characters	Blank	Section 4.1.2
	Power model name		Set the model name of the power supply module on the main base unit or extension base unit. (Entered at user's discretion. Do not use the one for the CPU module.)	Up to 16 characters		
	Extension cable		Set the extension cable name. (Entered at user's discretion. Do not use the one for the CPU module.)	Up to 16 characters		
	Slots		Set the number of slots of the main base unit or extension base unit. This setting must be done for all base units.	2, 3, 5, 8, 10, or 12		

(To the next page)

Table8.9 I/O assignment setting list (continued)

Item		Parameter No.	Description	Setting range	Default	Reference
Switch setting		0407H	Set various switches of an intelligent function module.	Refer to the manual for the intelligent function module used.	Blank	Section 6.10
Detailed setting	Error time output mode	0403H	Set whether to clear or hold the output in case of a stop error in the control CPU.	Clear/Hold	Clear	Section 6.8
	H/W error time PLC operarion mode	4004H	Set whether to stop or continue the operarion of the control CPU in case of a hardware failure of the intelligent function module.	Stop/Continue	Stop	Section 6.9
	I/O response time	0405H	Set a response time for the input module, high-speed input module, I/O combined module, or interrupt module.	• Input or I/O mix: 1ms, 5ms, 10ms, 20ms, or 70ms • Hi input or Interrupt: 0.1ms, 0.2ms, 0.4ms, 0.6ms, or 1ms	• Input or I/O mix: 10ms • Hi input or Interrupt: 0.2ms	Section 6.7
	Control PLC	0406H	Set the control CPU for the input/output modules and intelligent function module.	No.1, No.2, No.3, or No.4	No.1	QCPU User's Manual (Multiple CPU System)

(10) Serial Note8.2

The transmission speed, sum check, transmission wait time, and RUN write setting for using the serial communication function of the CPU module are set.




Figure 8.10 Serial

Table8.10 Serial setting list

Item	Parameter No.	Description	Setting range	Default	Reference
Use serial communication	100EH	Select the item when using the serial communication function.	Selected/deselected	Deselected	Section 6.23
Transmission speed		Set a transmission speed for data communication with the external device.	9.6kbps, 19.2kbps, 38.4kbps, 57.6kbps, 115.2kbps	19.2kbps	
Sum check		Set whether to add a sum check code to a message sent or received when using the serial communication function, according to the specifications of the external device.	Selected/deselected	Selected	
Transmission wait time		Set a period of waiting time on the Basic model QCPU side in case the CPU module cannot receive data immediately after the external device sends data.	No waiting time/10ms to 150ms (in increments of 10ms)	No waiting time	
RUN write setting		Enable or disable writing of data from the external device to the running CPU module.	Selected/deselected	Deselected	

Note8.2 Universal

When using the serial communication function for the Q02UCPU, check the versions of the CPU module and GX Developer. (Appendix 2)

The Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, and Built-in Ethernet port QCPU do not support the serial communication function.

(11) Acknowledge XY assignment

The parameters set in the I/O assignment, Ethernet/CC IE/MELSECNET setting, and CC-Link setting can be confirmed.




Figure 8.11 Acknowledge XY assignment

Table8.11 Acknowledge X/Y assignment list

Item	Parameter No.	Description	Setting range	Default	Reference
X/Y assignment	-	The data set in the I/O assignment, Ethernet/CC IE/ MELSECNET setting, and CC-Link setting can be checked.	-	-	-

(12) Multiple CPU settings Note8.3

Parameters required for configuring a multiple CPU system are set.




Figure 8.12 Multiple CPU settings

Table8.12 Multiple CPU setting list

Item	Parameter No.	Description	Setting range	Default	Reference
No. of PLC	0E00H	Set the number of CPU modules used in a multiple CPU system.	1 to 4	1	QCPU User's Manual (Multiple CPU System)
Host CPU number*1	E00CH	Set a CPU number for which the multiple CPU setting parameters are set. (Set the number of the connected CPU module.)	PLC No.1 to No.4	Blank	
Operating mode	0E01H	Select the multiple CPU system operation to be performed in case a stop error occurs in any of CPU No.2 to No.4. When CPU No.1 results in a stop error, the multiple CPU system stops. (Fixed)	Selected/ deselected	All items selected	
Multiple CPU synchronous startup setting*1	E00BH	Enable or disable synchronous startup of the CPU modules on the multiple CPU system.	Mp.1 to No.4	All items selected	

(To the next page)

Note8.3 Universal

The Q00UJCPU cannot be used in multiple CPU systems.

Table8.12 Multiple CPU setting list (continued)

Item			Parameter No.	Description	Setting range	Default	Reference
Online module change*1			E006H	Enable or disable the online module change in the multiple CPU system. (When enabled, the CPU module cannot read the I/O data outside the specified group.)	Selected/deselected	Deselected	QQCPU Userís Manual (Multiple CPU System)
I/O sharing when using Multiple CPUs		All CPUs can read all inputs	0E04H	Select whether to read the input data of the input modules or intelligent function modules controlled by another CPU.	Selected/deselected	Deselected	
		All CPUs can read all outputs		Select whether to read the output data of the output modules controlled by another CPU.	Selected/deselected	Deselected	
Multiple CPU high speed transmission area setting*1	CPU specific send range		E008H	Set the size of the multiple CPU high-speed transmission area that is assigned to each CPU module of the multiple CPU system.	Simple setting: 0 to 12K (in increments of 1K points) Advanced setting: 0 to 16K (in increments of 0.5K points)	3K points	
	Auto refresh setting	Refresh setting	E009H E00AH	Set an area range for data communication performed with the auto refresh function in the user area of the multiple CPU high-speed transmission area.	Available devices*2: X, Y, M, L, B, D, W, R, ZR, SM, SD, SB, and SW	-	
Communication area setting (refresh setting)			E002H E003H	In the multiple CPU system, data are transferred by auto refresh among respective CPU modules. Set the devices to be written or read and their points.	[Set starting devices for each CPU] Selected/deselected	Deselected	
					[CPU specific send range] 0 to 2048 points (in increments of 2 points) per CPU Up to 8K points (8192 points) per system	Blank	
					[PLC side device] B, M, Y, D, W, R, or ZR Occupies the device of the points set for the send range and starting from the specified device number. • One point in the send range equals 16 points in B, M, or Y. • One point in the send range equals one point in D, W, R, or ZR.		

*1: Not available for the Q00UCPU, Q01UCPU, and Q02UCPU.
*2: SM, SD, SB, and SW are valid only when they are selected as send devices.

(13) Built-in Ethernet port Note8.4

Parameters required for use of the built-in Ethernet port are set.




Figure 8.13 Built-in Ethernet port

Table8.13 Built-in Ethernet port setting list

Item	Parameter No.	Description	Setting range	Default	Reference
IP address	1016H	• IP address: Enter the IP address of the QnUDE(H)CPU. • Subnet mask pattern: Enter the subnet mask pattern when using a router. • Default router IP address: Enter the IP address of the router.	• IP address: 0.0.0.1 to 223.255.255.254 (00000001_H to $0DFFFFFE_H$) • Subnet mask pattern: Blank or 192.0.0.0 to 255.255.255.252 ($0C0000000_H$ to $0FFFFFFC_H$) • Default router IP address: Blank or 0.0.0.1 to 223.255.255.254 (00000001_H to $0DFFFFFE_H$)	• IP address: 192.168.3.39 • Subnet mask pattern: Blank • Default router IP address: Blank	QnUCPU Userís Manual(Communication via Built-in Ethernet Port)
Communication data code		Select the code for MC protocol communication.	Binary code/ASCII code	Binary code	

(To the next page)

Note8.4 Universal

The Universal model QCPUs other than the Built-in Ethernet port QCPU are not equipped with any Ethernet port.

Table8.13 Built-in Ethernet port setting list (continued)

Item	Parameter No.	Description	Setting range	Default	Reference
Open settings	1016_H	Set data when using MC protocol or socket communication.	-	Blank	QnUCPU Userís Manual (Communication via Built-in Ethernet Port)
FTP settings		Set data when using the file transfer function (FTP).	-	Blank	
Time settings		Set data when using the time setting function.	-	Blank	
Enable online change (FTP, MC protocol)		Enable or disable writing data in devices or files to the running CPU module when MC protocol or FTP is used.	Selected/deselected	Deselected	
Disable direct connection to MELSOFT		Enable or disable direct connection to MELSOFT. To enhance the security with the remote password setting, check it to disable it.	Selected/deselected	Deselected	
Do not respond to search for CPU (Built-in Ethernet port) on network		Checking this box disables response to the find CPU function of the MELSOFT connection. To enhance the security, check it to disable this.	Selected/deselected	Deselected	

8.2 Network Parameters

This section provides the list of network parameters and describes parameter details.

■ Symbols, M and N, used in the "Parameter No." column
M and N in "Parameter No." in this section denote the following:

- N: Indicates the module number.
- M: Indicates the network type.

Table8.14 For CC-Link IE controller network and MELSECNET/H (☞ (1), (2) in this section)

M	Network type
1H	CC IE Control (Control station), MELSECNET/H mode (Control station), MELSECNET/H Extended mode (Control station), MELSECNET/10 mode (Control station)
2H	CC IE Control (Normal station), MELSECNET/H mode (Normal station), MELSECNET/H Extended mode (Normal station), MELSECNET/10 mode (Normal station)
5H	MELSECNET/H (Remote master)
AH	MELSECNET/H (Standby station)
BH	MELSECNET/H mode multiplexed remote I/O network master station
DH	MELSECNET/H mode multiplexed remote I/O network sub-master station (when no parameter is set)
EH	MELSECNET/H mode multiplexed remote I/O network sub-master station (when parameters are set)

Table8.15 For CC-Link setting (☞ (4) in this section)

M	Network type
0H	Master station
1H	Local station
2H	Standby master station

(1) CC-Link IE controller network setting

Network parameters for the CC-Link IE controller network are set.




Figure 8.14 Setting the number of Ethernet/CC IE/MELSECNET cards (CC-Link IE controller network setting)

Table8.16 CC-Link IE controller network setting list

Item	Parameter No.	Description	Setting range	Default	Reference
Number of modules on CC-Link IE controller network	A000H	Set network parameters for the CC-Link IE controller network.	Refer to the manual for the CC-Link IE controller network.	-	-
Starting I/O No.	ANM0H				
Network No.					
Total stations					
Station No.					
Group No.	0AmnH				
Mode	ANM0H				
Refresh parameters	ANM1H				
Common parameters	ANM2H				
Station inherent parameters	ANM3H				
Interlink transmission parameters	A002H				
Routing parameters	5003H				

(2) MELSECNET/H setting

Network parameters for MELSECNET/H are set.




Figure 8.15 Setting the number of Ethernet/CC IE/MELSECNET cards (MELSECNET/H setting)

Table8.17 MELSECNET/H setting list

Item	Parameter No.	Description	Setting range	Default	Reference
Number of modules on MELSECNET/H	5000H	Set MELSECNET/H network parameters.	Refer to the manual for the Q series-compatible MELSECNET/H.	-	-
Starting I/O No.	5NM0H				
Network No.					
Total stations					
Group No.	05mnH				
Mode	5NM0H				
Refresh parameters	5NM1H				
Common parameters	5NM2H				
Station inherent parameters	5NM3H				
Common parameters 2	5NMAH				
Station inherent parameters 2	5NMBH				
Interrupt settings					
Valid module during other station access	5001H				
Interlink transmission parameters	5002H				
Routing parameters	5003H				

(3) Ethernet setting

Network parameters for Ethernet are set.




Figure 8.16 Setting the number of Ethernet/CC IE/MELSECNET cards (Ethernet setting)

Table8.18 Ethernet setting list

Item	Parameter No.	Description	Setting range	Default	Reference
Number of modules on Ethernet	9000H	Set Ethernet network parameters.	Refer to the manual for the Q series-compatible Ethernet.	-	-
Starting I/ONo.	9N00H				
Network No.					
Group No.					
Station No.					
Operational settings					
Initial settings	9N01H				
Open settings	9N02H				
Router relay parameter	9N03H				
Station No.<->IP information	9N05H				
FTP Parameters	9N06H				
E-mail settings	9N07H				
News setting	9N08H				
Interrupt settings	9N09H				
Valid module during other station access	5001H				
Routing parameter	9N04H				

(4) CC-Link setting

Parameters for CC-Link are set.




Figure 8.17 Setting the CC-Link list

Table8.19 CC-Link setting list

Item	Parameter No.	Description	Setting range	Default	Reference
Number of modules	C000H	Set CC-Link parameters.	Refer to the manual for CC-Link.	-	-
Type					
Start I/O No.	CNM2H				
Operational setting					
All connect count					
Remote input (RX)	CNM1H				
Remote output (RY)					
Remote register (RWr)					
Remote register (RWw)					
Ver.2 Remote input (RX)					
Ver.2 Remote output (RY)					
Ver.2 Remote register (RWr)					
Ver.2 Remote register (RWw)					
Special relay (SB)	CNM2H				
Special register (SW)					
Retry count					
Automatic reconnection station count					
Standby master station No.					
PLC down select					
Scan mode setting					
Delay information setting					
Station information setting					
Remote device station initial setting					
Interrupt setting					

8.3 Remote Password

This section provides the list of parameters for use of remote password and describes parameter details.




Figure 8.18 Remote password settings dialog box

A remote password is set for an Ethernet module, serial communication module, modem interface module, or Built-in Ethernet port QCPU.

Table8.20 Remote password setting list

Item		Parameter No.	Description	Setting range	Default	Reference
Password settings		-	Enter a remote password.	Four characters or less (alphanumeric characters, special symbols)	-	• QnUDE(H)CPU: QnUCPU User's Manual (Communication via Built-in Ethernet Port) • QJ71E71: Ethernet module manual • QJ71C24: Serial communication module manual • QJ71CMO: Modem interface module manual
Password active module settings	Model name	-	Select a model name of the module for which the remote password set to the CPU module is checked.	• QnUDE(H)CPU • QJ71E71 • QJ71C24/CMO	-	
	Start XY	-	Set the start address of the module for which the remote password is checked.	0000_H to $0FE0_H$	-	
Detail		-	Set details of the remote password for the QJ71E71.	-	-	
User connection No.		-	Select user connection No.	Connection 1 to Connection 16	-	
System connection		-	Select a valid port of the remote password for system connection.	Specify a valid port of the remote password. • Auto open UDP port • FTP transmission port (TCP/IP) • GX Developer transmission port (TCP/IP) • GX Developer transmission port (UDP/IP), Dedicated instruction, CC IE Control, MNET/10(H) relay transmission port. • HTTP port	-	

CHAPTER9 DEVICES

This chapter describes the devices that can be used in the CPU module.

9.1 Device List

Table 9.1 lists the names and data ranges of the devices that can be used in the CPU module.

Table9.1 Device list

Classification	Type	Device name	Default			Parameter-set range	Reference
			Points	Range			
Internal user device	Bit device	Input	8192	X0 to X1FFF	Hexadecimal	Can be changed within 29K words *3	Section 9.2.1
		Output	8192	Y0 to Y1FFF	Hexadecimal		Section 9.2.2
		Internal relay	8192	M0 to M8191	Decimal		Section 9.2.3
		Latch relay	8192	L0 to L8191	Decimal		Section 9.2.4
		Annunciator	2048	F0 to F2047	Decimal		Section 9.2.5
		Edge relay	2048	V0 to V2047	Decimal		Section 9.2.6
		Step relay	8192	S0 to S511/block	Decimal		Section 9.2.9
		Link relay	8192	B0 to B1FFF	Hexadecimal		Section 9.2.7
		Link special relay	2048	SB0 to SB7FF	Hexadecimal		Section 9.2.8
	Word device	Timer*1	2048	T0 to T2047	Decimal		Section 9.2.10
		Retentive timer*1	0	(ST0 to ST2047)	Decimal		
		Counter*1	1024	C0 to C1023	Decimal		Section 9.2.11
		Data register	12288	D0 to D12287	Decimal		Section 9.2.12
		Link register	8192	W0 to W1FFF	Hexadecimal		Section 9.2.13
		Link special register	2048	SW0 to SW7FF	Hexadecimal		Section 9.2.14
Internal system device	Bit device	Function input	16	FX0 to FXF	Hexadecimal	Cannot be changed	Section 9.3.1
		Function output	16	FY0 to FYF	Hexadecimal		Section 9.3.1
		Special relay	2048	SM0 to SM2047	Decimal		Section 9.3.2
	Word device	Function register	5	FD0 to FD4	Decimal		Section 9.3.1
		Special register	2048	SD0 to SD2047	Decimal		Section 9.3.2
Link direct device	Bit device	Link input	8192	Jn\X0 to Jn\X1FFF	Hexadecimal	Cannot be changed	Section 9.4
		Link output	8192	Jn\Y0 to Jn\Y1FFF	Hexadecimal		
		Link relay	16384	Jn\B0 to Jn\B3FFF	Hexadecimal		
		Link special relay	512	Jn\SB0 to Jn\SB1FF	Hexadecimal		
	Word device	Link register	16384	Jn\W0 to Jn\W3FFF	Hexadecimal		
		Link special register	512	Jn\SW0 to Jn\SW1FF	Hexadecimal		
Module access device	Word device	Intelligent function module device	65536	Un\G0 to Un\G65535*2	Decimal	Cannot be changed	Section 9.5
		Cyclic transmission area device *4	14336	U3En\G10000 to U3En\G24335	Decimal	Can be changed	
Index register or standard device register	Word device	Index register or standard device register	20	Z0 to Z19	Decimal	Cannot be changed	Section 9.6

(To the next page)

Table9.1 Device list (continued)

Classification	Type	Device name	Default			Parameter-set range	Reference
			Points	Range			
File register *7	Word device	File register	0	-	-	0 to 4086K points *6	Section 9.7
Extended data register *7	Word device	Extended data register	0	-	-		Section 9.8
Extended link register *7	Word device	Extended link register	0	-	-		Section 9.8
Nesting	-	Nesting	15	N0 to N14	Decimal	Cannot be changed	Section 9.9
Pointer	-	Pointer	4096 *8	P0 to P4095 *9	Decimal	Cannot be changed	Section 9.10
		Interrupt pointer	256 *10	I0 to I255 *11	Decimal		Section 9.11
Other	Bit device	SFC block device	320 *10	BL0 to BL319 *12	Decimal	Cannot be changed	Section 9.12
	-	Network No. specification device	255	J1 to J255	Decimal		Section 9.12.1
		I/O No. specification device	-	U0 to UFF, U3E0 to U3E3E3 *13	Hexadecimal		Section 9.12.3
		Macro instruction argument device	-	VD0 to VD □	Hexadecimal		Section 9.12.4
Constant	-	Decimal constant	K-2147483648 to K2147483647				Section 9.13.1
		Hexadecimal constant	H0 to HFFFFFFFF				Section 9.13.2
		Real number constant	Single-precision floating-point data: E ± 1.17549435 − 38 to E ± 3.40282347 + 38				Section 9.13.3
			Double-precision floating-point data*5: E ± 2.2250738585072014 − 308 to E ± 1.7976931348623157 + 308				Section 9.13.3
		Character string constant	"ABC", "123"				Section 9.13.4

*1: For the timer, retentive timer, and counter, a bit device is used for contacts and coils, and a word device is used for a present value.
*2: The number of points that can be actually used varies depending on the intelligent function module.
For the number of buffer memory points, refer to the manual for the intelligent function module used.
*3: Can be changed in the Device tab of the PLC parameter dialog box (except the input, output, and step relay). The points for the step relay can be changed to 0 if the serial number (first five digits) of the Universal model QCPU is "10042" or later. (☞ Section 9.2)
*4: Available only in multiple CPU systems.
*5: Up to 15 digits can be entered in GX Developer.
*6: Indicates the total number of points for the file register, extended data register (D), and extended link register (W).
*7: Not available for the Q00UJCPU.
*8: "512 points" for the Q00UJCPU, Q00UCPU, and Q01UCPU.
*9: "P0 to P511" for the Q00UJCPU, Q00UCPU, and Q01UCPU.
*10: "128 points" for the Q00UJCPU, Q00UCPU, and Q01UCPU.
*11: "I0 to I127" for the Q00UJCPU, Q00UCPU, and Q01UCPU.
*12: "BL0 to BL127" for the Q00UJCPU, Q00UCPU, and Q01UCPU.
*13: "U0 to UF" for the Q00UJCPU, "U0 to U3F" or "U3E0 to U3E3E2" for the Q00UCPU and Q01UCPU, and "U0 to U7F" or "U3E0 to U3E3E2" for the Q02UCPU.

9.2 Internal User Device

(1) Definition

Internal user devices can be used for various user applications.

(2) Points for internal user devices

The default values can be changed in the Device tab of the PLC parameter dialog box.

However, the points for the input (X), output (Y), and step relay (S) Note9.1 cannot be changed.




Figure 9.1 Device tab of the PLC parameter dialog box

When changing device points, note the following.

- Set each device in increments of 16 points.
- Up to 32K or 60K points can be set for each device. Note9.2
- Up to 29K words can be set for total internal user devices.
- One point set for the timer, retentive timer, or counter must be regarded as two points (one for coil and one for contact).

Note9.1 Universal

The points for the step relay (S) can be changed to 0 if the serial number (first five digits) of the Universal model QCPU is "10042" or later. (☞ Section 9.2.9)

Note9.2 Universal

Up to 60K points can be set for each of the internal relay and link relay, if the serial number (first five digits) of the Universal model QCPU is "10042" or later.

Point

- When changing device points, the following refresh ranges must not exceed the corresponding device ranges.
  - Refresh range of network module
  - Auto refresh range of intelligent function module

  If device points are set exceeding the corresponding device range, data may be written to any other device or an error may occur.

- The total number of points for the internal relay, latch relay, annunciator, edge relay, link relay, link special relay, step relay, timer, retentive timer, and counter must be set within the following range.
  - Serial number (first five digits) of the Universal model QCPU is "10041" or earlier: Up to 64K points
  - Serial number (first five digits) of the Universal model QCPU is "10042" or later: Not limited (Up to 29 words for internal user devices)

(3) Memory size

Set the internal user devices so that the following condition is satisfied.

(Bit device size) + (Timer, retentive timer, and counter sizes) + (Word device size) ≦ 29K words

(a) Bit device

For bit devices, 16 points are calculated as one word.

$$\text{(Bit device size)} = \frac{(X+Y+M+L+B+F+SB+V+S)}{16} \text{ Words}$$

(b) Timer (T), retentive timer (ST), and counter (C)

For the timer (T), retentive timer (ST), and counter (C), 16 points are calculated as 18 words.

$$\text{(Timer, retentive timer, or counter size)} = \frac{(T+ST+C)}{16} \times 18 \text{ Words}$$

(c) Word device

For the data register (D), link register (W), and link special register (SW), 16 points are calculated as 16 words.

$$\text{(Word device size)} = \frac{(D+W+SW)}{16} \times 16 \text{ Words}$$

Point

If the points for the internal user devices have been changed, the following files created with the previous parameters can no longer be used.

- Sequence program files
- SFC program files
- ST program files

In such a case, read the above program files out from the CPU module to GX Developer, and then write them back again to the CPU module.

(4) Device point assignment example

Table9.2 shows a device point assignment example.

Table9.2 uses the same format as the device point assignment sheet shown in Appendix 4.

Table9.2 Device point assignment example

Device name	Symbol	Numeric notation	Number of device point *2		Restriction check			
			Points	Range	Size (words)*3		Points (bits)*2	
Input relay*1	X	Hexadecimal	8K (8192)	X0000 to X1FFF	/16	512	× 1	8192
Output relay*1	Y	Hexadecimal	8K (8192)	Y0000 to Y1FFF	/16	512	× 1	8192
Internal relay	M	Decimal	16K (16384)	M0 to M16383	/16	1024	× 1	16384
Latch relay	L	Decimal	4K (4096)	L0 to L4095	/16	256	× 1	4096
Link relay	B	Hexadecimal	4K (4096)	B0000 to B0FFF	/16	256	× 1	4096
Annunciator	F	Decimal	1K (1024)	F0 to F1023	/16	64	× 1	1024
Link special relay	SB	Hexadecimal	2K (2048)	SB0000 to SB07FF	/16	128	× 1	2048
Edge relay	V	Decimal	1K (1024)	V0 to V1023	/16	64	× 1	1024
Step relay*1	S	Decimal	8K (8192)	S0 to S8191	/16	512	× 1	8192
Timer	T	Decimal	2K (2048)	T0 to T2047	$\times \frac{18}{16}$	2304	× 2	4096
Retentive timer	ST	Decimal	2K (2048)	ST0 to ST2047	$\times \frac{18}{16}$	2304	× 2	4096
Counter	C	Decimal	1K (1024)	C0 to C1023	$\times \frac{18}{16}$	1152	× 2	2048
Data register	D	Decimal	14K (14336)	D0 to D14335	× 1	14336	-	
Link register	W	Hexadecimal	4K (4096)	W0000 to W4095	× 1	4096	-	
Link special register	SW	Hexadecimal	2K (2048)	SW0000 to SW07FF	× 1	2048	-	
Total						29568 (29696 or less)		63488 (65536 or less)

*1: The points are fixed for the system. (Cannot be changed)
The points for the step relay (S) can be changed to 0 if the Universal model QCPU whose serial number (first five digits) is "10042" or later.

*2: Up to 32K points can be set for each device.
However, up to 60K points can be set for each device of the internal relay and link relay if the Universal model QCPU whose serial number (first five digits) is "10042" or later,

*3: Enter the values multiplied (or divided) by the number shown in the Size (words) column.

9.2.1 Input (X)

(1) Definition

The input (X) is used to send commands or data to the CPU module from external devices such as push-button switches, selector switches, limit switches, and digital switches.




Figure 9.2 Commands from external devices to a CPU module

(2) Concept of input (X)

One input point is assumed to be a virtual relay Xn in the CPU module.
Programs use the normally open or closed contact of Xn.




Figure 9.3 Concept of input (X)

(3) Allowable number of normally open or closed contacts

There are no restrictions on the number of normally open or closed contacts of Xn used in a program, as long as the program capacity is not exceeded.




Figure 9.4 Input (X) used in a program

Point

- When debugging a program, the input (X) can be set to on or off by the following:
  - Device test in GX Developer
  - OUT Xn instruction




Figure 9.5 Input (X) on/off with the OUT Xn instruction

- The input (X) can also be used for the following.
  - Refresh target device (CPU module side) of RX in CC-Link
  - Refresh target device (CPU module side) of CC-Link IE controller network or MELSECNET/H

9.2.2 Output (Y)

(1) Definition

The output (Y) is used to output control results on programs to external devices such as signal lamps, digital displays, electromagnetic switches (contactors), or solenoids.

Data can be output to the outside like using a normally open contact.




Figure 9.6 Output from a CPU module to external devices

(2) Allowable number of normally open or closed contacts

There are no restrictions on the number of normally open or closed contacts of Yn used in a program, as long as the program capacity is not exceeded.




Figure 9.7 Output (Y) used in a program

(3) Using the output (Y) as the internal relay (M)

The output (Y) corresponding to the slots for input modules or empty slots can be utilized as the internal relay (M).




Figure 9.8 Using as the internal relay

9.2.3 Internal relay (M)

(1) Definition

The internal relay (M) is a device for auxiliary relays used in the CPU module.
All of the internal relay are set to off in the following cases:

- When the CPU module is powered off and then on
- When the CPU module is reset
- When latch clear is executed (☞ Section 6.3)

(2) Latch (data retention during power failure)

The internal relay cannot be latched.

(3) Allowable number of normally open or closed contacts

There are no restrictions on the number of normally open or closed contacts used in a program, as long as the program capacity is not exceeded.




Figure 9.9 Internal relay (M) used in a program

(4) Method for external output

The output (Y) is used to output sequence program operation results to external devices.

Point

Use the latch relay (L) when latch (data retention during power failure) is required.
(☞ Section 9.2.4)

9.2.4 Latch relay (L)

(1) Definition

The latch relay (L) is a device for auxiliary relays that can be latched inside the CPU module.
Latch relay data are retained by batteries in the CPU module during power failure.
Operation results (on/off information) immediately before the following will be also retained.

- Powering off and then on the CPU module
- Resetting the CPU module

(2) Latch relay clear

The latch relay is turned off by the latch clear operation. (☞ Section 3.7)
However, the latch relay set in "Latch (2) start/end" in the Device tab of the PLC parameter dialog box cannot be turned off even by the remote latch clear function.

(3) Allowable number of normally open or closed contacts

There are no restrictions on the number of normally open or closed contacts used in a program, as long as the program capacity is not exceeded.




Figure 9.10 Latch relay

Point

Scan time is prolonged when the latch relay (L) is used. Reducing the points of latch relay (L) can reduce the prolonging scan time. (☞ Section 10.1.2)

(4) Method for external output

The output (Y) is used to output sequence program operation results to external devices.

Point

- If latch is not required, use the internal relay (M). (☞ Section 9.2.3)
- The latch clear invalid area is set in the Device setting of PLC parameter. (☞ Section 6.3)

9.2.5 Annunciator (F)

(1) Definition

The annunciator (F) is an internal relay which can be effectively used in fault detection programs for user-created system.

(2) Special relay and special register after annunciator ON

When the annunciator is turned on, the special relay (SM62) is set to on, and the numbers and quantity of the annunciator numbers are stored in the special register (SD62 to SD79).

• Special relay	: SM62	• • •	Turns on even if only one of the annunciator number areas is turned on.
• Special register	: SD62	• • •	Stores the number of the annunciator that was turned on first.
	SD63	• • •	Stores the quantity of the annunciator number areas that are on.
	SD64 to SD79	• • •	Stores annunciator numbers in the order of turning on. (The same annunciator number is stored in SD62 and SD64.)

The annunciator number stored in SD62 is also registered in the error history area.

(3) Applications of the annunciator

Using the annunciator in a fault detection program allows check for a system fault and identification of the fault (annunciator number) by monitoring the special register (SD62 to SD79) when the special relay (SM62) turns on.

Example In this program, when annunciator (F5) is turned on, the corresponding annunciator number is output to the outside.




Figure 9.11 Detecting and saving the annunciator ON

(4) Allowable number of normally open or closed contacts

There are no restrictions on the number of normally open or closed contacts used in a program, as long as the program capacity is not exceeded.

(5) Turning on the annunciator and processing

(a) Turning on the annunciator

The following instructions can be used.

1) SET F□ instruction

The SET F□ instruction can be used to turn on the annunciator only on the leading edge (off to on) of an input condition.

Even if the input condition turns off, the annunciator is held on.

Using many annunciator numbers can shorten scan time more than using the OUT F□ instruction.

2) OUT F□ instruction

The OUT F□ instruction can be also used to turn on or off the annunciator. However, since the processing is performed for every scan, the scan time is longer than the case of using the SET F□ instruction.

In addition, execution of the RST F□, LEDR, or BKRST instruction is required after the annunciator is turned off with the OUT F□ instruction.

Therefore, use of the SET F□ instruction is recommended.

Point

If the annunciator is turned on with any instruction other than SET F□ and OUT F□ (for example, the MOV instruction), the same operation as the internal relay (M) is performed.
The ON information is not stored in SM62, and annunciator numbers are not stored in SD62 and SD64 to SD79.

(b) Processing after annunciator on

1) Data stored in the special register (SD62 to SD79)

- Turned-on annunciator numbers are stored in SD64 to SD79 in order.
- The annunciator number in SD64 is stored in SD62.
- SD63 value is incremented by "1".




Figure 9.12 Processing after annunciator ON

2) Processing on the CPU

The USER LED on the front side turns on (red).

3) On/off setting for the LED

Whether to turn on the USER.LED or not when the annunciator is turned on can be set in the LED indication setting. (☞ Section 6.21.2).

(6) Turning off the annunciator and processing

(a) Turning off the annunciator

The following instructions can be used.

1) RST F□ instruction

This is used to turn off the annunciator number that was turned on with the SET F□ instruction.

2) LEDR instruction

This is used to turn off the annunciator number stored in SD62 and SD64.

3) BKRST instruction

This is used to turn off all of the annunciator numbers within the specified range.


4) OUT F□ instruction

One annunciator number can be turned on or off with the same instruction.

However, even if an annunciator number is turned off with the OUT F□ instruction, the off processing described in (6)(b) in this section is not performed.

If the annunciator is turned off with the OUT F□ instruction, execution of the RST F□, LEDR, or BKRST instruction is required.

- Turning off annunciator 5 (F5)



- Turning off all of the turned-on annunciator numbers




Figure 9.13 Example of turning off the annunciator

Remark

For details of each instruction, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

(b) Processing after annunciator off

1) Data stored in the special register (SD62 to SD79) after execution of the LEDR instruction

- The annunciator number in SD64 is deleted, and the other annunciator numbers in the register addressed SD65 and after are shifted accordingly.
- The annunciator number in SD64 is stored into SD62.
- SD63 value is decremented by "1".
- If the SD63 value is changed to "0", SM62 is turned off.




Figure 9.14 Processing after annunciator OFF (when the LEDR instruction executed)

2) Data stored in the special register (SD62 to SD79) when the annunciator is turned off with the RST F□ or BKRST instruction

- The annunciator number specified with the RST or BKRST instruction is deleted, and the other annunciator numbers in the register addressed SD65 and after are shifted accordingly.
- If the existing annunciator number in SD64 is turned off, a new annunciator number stored in SD64 will be stored in SD62.
- SD63 value is decremented by "1".
- If the SD63 value is changed to "0", SM62 is turned off.




Figure 9.15 Processing after annunciator OFF (when the REST F□ instruction is executed)

3) LED indication

When all of the annunciator numbers in SD64 to SD79 turn off, the LED that was turned on by turn-on of the annunciator will turn off. (☞ (5)(b) in this section)

Point

If the LEDR instruction is executed while the annunciator is on and at the same time the operation continuation error that has higher priority (☞ Section 6.21.1) than the annunciator has occurred, the LEDR instruction clears the higher priority error. Because of this, the annunciator is not turned off by execution of the LEDR instruction.
To turn off the annunciator with the LEDR instruction, remove the error whose priority is higher than that of the annunciator.

9.2.6 Edge relay (V)

(1) Definition

The edge relay (V) is a device in which the on/off information from the beginning of the ladder block.
Contacts only can be used. (Coils cannot be used).





Figure 9.16 Edge relay

(2) Applications of the edge relay

The edge relay can be utilized to detect the leading edge (off to on) in programs configured using index modification.



*1: The on/off information for X0Z1 is stored in the V0Z1 edge relay.
For example, the on/off information of X0 is stored in V0, and that of X1 is stored in V1.




Figure 9.17 Application example and timing chart of the edge relay

(3) Precautions

The edge relay of the same number cannot be set only once in a program.

9.2.7 Link relay (B)

(1) Definition

The link relay (B) is a relay on the CPU module side, and it is used for refreshing the link relay (LB) data of another module such as a MELECNET/H network module to the CPU module or refreshing the CPU module data to the link relay (LB) of the MELECNET/H network module.




Figure 9.18 Link refresh

(2) Allowable number of normally open or closed contacts

There are no restrictions on the number of normally open or closed contacts used in a program, as long as the program capacity is not exceeded.




Figure 9.19 Link relay

(3) Using the link relay in the network system

Network parameters must be set.

The link relay range areas that is not set by network parameters (not used for a network system such as a MELSECNET/H network) can be used as the internal relay or latch relay.

- Link relay range where no latch is performed••••••Internal relay
- Link relay range where latch is performed••••••••••Latch relay

Point

- Although the points for the link relay in a CC-Link IE controller network module is 32768, the default for the link relay in the CPU module is 8192 points.
- Although the points for the link relay in a MELSECNET/H network module is 16384, the default for the link relay in the CPU module is 8192 points.

To use the link relay exceeding the above points, change the link relay points in the Device tab of the PLC parameter dialog box.

Remark

For network parameters, refer to the following.

☞ Reference manual for each network module

9.2.8 Link special relay (SB)

(1) Definition

The Link special relay (SB) is a relay that indicates various communication status and detected errors of intelligent function modules such as CC-Link IE controller modules or MELSECNET/H network modules.
Each of this device area is turned on or off according to a factor occurred during data link.
The communication status and errors on the network can be confirmed by monitoring the link special relay (SB).

(2) Number of link special relay points

The points for the link special relay in the CPU module is 2048. (SB0 to SB7FF).
However, the points can be changed in the Device tab of the PLC parameter dialog box. (☞ Section 9.1)
To an intelligent function module that has a link special relay, such as a CC-Link IE controller module or MELSECNET/H network module, 512 points are assigned.
Assigning the link special relay as shown in Figure 9.20 allows refresh of the CC-Link link special relay (SB) to the link special relay (SB) of the CPU module.




Figure 9.20 Points of the link special relay

Remark

For details of the link special relay, refer to the manual for an intelligent function module that has the link special relay.

9.2.9 Step relay (S)

This device is provided for SFC programs.

Point

Because the step relay is a device exclusively used for SFC programs, it cannot be used as an internal relay in the sequence program.
If used, an SFC error will occur, and the system may go down.

Remark

For use of the step relay, refer to the following.
☞ QCPU (Q Mode)/QnACPU Programming Manual (SFC)

9.2.10 Timer (T)

(1) Definition

Time counting starts when a coil is turned on, and it times out and the contact turns on when the current value reaches the set value.
The timer is of an incremental type.

(2) Timer types

Timers are mainly classified into the following two types.

1) Timer of which value is set to 0 when the coil is turned off.
2) Retentive timer that holds the current value even if the coil is turned off.

Also, low-speed and high-speed timers are included in timer 1), and low-speed and high-speed retentive timers are included in timer 2).




Figure 9.21 Timer types

(3) Specification of the timer

The same device is used for the low- and high-speed timers, and the type is determined according to the instruction used.

Example For the OUT T0 instruction, the low-speed timer is specified, and for the OUTH T0 instruction, the high-speed timer is specified.

The same device is used for the low- and high-speed retentive timers, and the type is determined according to the instruction used.

Example For the OUT ST0 instruction, the low-speed retentive timer is specified, and for the OUTH ST0 instruction, the high-speed retentive timer is specified.


(4) Low-speed timer

(a) Definition

This type of timer measures time in increments of 1 to 1000ms.

The timer starts time measurement when its coil is turned on, and when it times out, the contact is turned on. If the timer's coil is turned off, the current value is changed to "0" and the contact is turned off.

[Ladder example]



[Timing chart]




Figure 9.22 Ladder example and timing chart of a low-speed timer

(b) time increment setting

The time increment is set in the PLC system tab of the PLC parameter dialog box.

The default is 100ms, and it can be changed in increments of 1ms.


(5) High-speed timer

(a) Definition

This type of timer measures time in increments of 0.01 to 100ms.

The timer starts time measurement when its coil is turned on, and when it times out, the contact is turned on. If the timer's coil is turned off, the current value is changed to "0" and the contact is turned off.

[Ladder example]



[Timing chart]




Figure 9.23 Ladder example and timing chart of a high-speed timer

(b) Time increment setting

The time increment is set in the PLC system tab of the PLC parameter dialog box.

The default is 10.0ms, and it can be changed in increments of 0.01ms.

(6) Retentive timer

(a) Definition

This timer measures the period of time during which the coil is on.

The timer starts time measurement when its coil is turned on, and when it times out, the contact is turned on. Even if the timer's coil is turned off, the current value and the on/off status of the contact are retained.

When the coil is turned on again, the measurement restarts from the retained current value.

(b) Retentive timer clear

The current value and the contact off status can be cleared with the RST ST□ instruction.




Figure 9.24 Ladder example and timing chart of a retentive timer

(c) Time increment setting

The time increment is set in the same manner as the corresponding low- or high-speed timer.

- Low-speed retentive timer: Low-speed timer
- High-speed retentive timer: High-speed timer

Point


To use a retentive timer, set the points for it in the Device tab of the PLC parameter dialog box.

(7) Timer processing and accuracy

(a) Processing

When the OUT T□ or OUT ST□ instruction is executed, the on/off switching of the timer coil, current value update, and on/off switching of the contact are performed.
In the END processing, the current timer value is not updated and the contact is not turned on/off.

[Ladder example]



[Processing at execution of OUT T0 instruction]





Figure 9.25 Processing at execution of the OUT T0 instruction

(b) Accuracy

The value obtained by the END instruction is added to the current value when the OUT T□ or OUT ST□ instruction is executed.

The current value is not updated while the timer coil is off even if the OUT T□ or OUT ST□ instruction is executed.

[Ladder example]



[Current value update timing]




Figure 9.26 Timer accuracy (in the case of 10ms)

Accuracy of the timer response that is from reading input (X) to output the data is up to "2-scan time + timer limit setting".

(8) Precautions for using timers

(a) Use of the same timer

Do not use the OUT T□ instruction that describes the same timer more than once within one scan.

If this occurs, the current timer value will be updated by each OUT T□ instruction execution, resulting in incorrect time measurement.




Figure 9.27 When the same timer is used

(b) When the timer is not executed in every scan

While a coil of a timer (for example. T1) is on, do not make the OUT T1 instruction jumped to any other part with another instruction such as CJ.

If jump of the OUT T□ instruction has occurred, the current timer value is not updated.

Also, if a timer exists in a subroutine program, execute a subroutine call including the OUT T1 instruction once in each scan while the coil of the timer (for example, T1) is on.

Failure to do so will not update the current timer value.

(c) Programs that cannot use timers

Timers cannot be used in interrupt programs and fixed scan execution programs.

(d) When the set value is 0

The contact turns on when the OUT T□ instruction is executed.

(e) When the set value is changed after time-out


Even if the set value is changed to a larger value after time-out of the timer, the timer remains timed-out and does not start the operation.

(f) When using multiple timers

When using multiple timers to update the respective current values at execution of each OUT T□ instruction, pay attention to the ladder sequence.

For example, to create an on/off ladder using two timers, refer to examples shown in Figure 9.28.

[Correct ladder example]



[Incorrect ladder example]




Figure 9.28 On/off ladder using two timers

9.2.11 Counter (C)

(1) Definition

The counter (C) is a device that counts the number of rises for input conditions in sequence programs. When the count value matches the set value, the counting stops and its contact is turned on.
The counter is of an incremental type.

(2) Counter types

Counters are mainly classified into the following two types.

- Counter that counts the number of rises for input conditions in sequence programs
- Interrupt counter that counts the number of interrupts occurred

(3) Counting

(a) When the OUT C□ instruction is executed

The coil of the counter is turned on/off, the current value is updated (the count value + 1), and the contact is turned on.
In the END processing, the current counter value is not updated and the contact is not turned on.




Figure 9.29 Execution and processing of the OUT C□ instruction

(b) Current value update (count value + 1)

The current value is updated (count value + 1) at the leading edge (OFF → ON) of the OUT C□ instruction.

The current value is not updated while the coil is off, or when it remains on or turns off from on by the OUT C□ instruction.




Figure 9.30 Current value update timing

(c) Resetting the counter

The current counter value is not cleared even if the OUT C□ instruction is turned off.

To clear the current value and to turn off the contact of the counter, use the RST C□ instruction.

At the time of execution of the RST C□ instruction, the counter value is cleared, and the contact is also turned off.

[Ladder example]



[Counter reset timing]




Figure 9.31 Resetting the counter

1) Precautions for resetting the counter

Execution of the RST C□ instruction also turns off the coil of C□.

If the execution condition for the OUT C□ instruction is still ON after execution of the RST C□ instruction, turn on the coil of C□ at execution of the OUT C□ instruction and update the current value (count value + 1).




Figure 9.32 Counter resetting ladder example

In the above ladder example, when M0 turns on from off, the coil of C0 turns on, updating the current value.

When C0 reaches the preset value finally, the contact of C0 turns on, and execution of the RST C0 instruction clears the current value of C0. At this time, the coil of C0 also turns off.

If M0 is still on in the next scan, the current value is updated since the coil of C0 turns on from off at execution of the OUT C0 instruction. (The current value is changed to 1.)




Figure 9.33 Current value update timing

To prevent the above, it is recommended to add a normally closed contact of the OUT C0 instruction execution to the condition for the RST C0 instruction execution so that the coil of C0 does not turn off while the execution condition (M0) of the OUT C0 instruction is on.




Figure 9.34 Counter resetting ladder example (recommended)

(d) Maximum counting speed

The counter can count only when the on/off time of the input condition is longer than the execution interval of the corresponding OUT C□ instruction.

The maximum counting speed is calculated by the following expression:

$$\text{Maximum counting speed (Cmax)} = \frac{n}{100} \times \frac{1}{T} \text{[times/s]}$$

n: Duty (%) *1

T: Execution interval of the OUT C□ instruction (sec)

*1: Duty (n) is the ON-OFF time ratio of count input signal, and is expressed as a percentage value.

When T1 ≧ T2, $n = \frac{T2}{T1+T2} \times 100\%$

When T1 < T2, $n = \frac{T1}{T1+T2} \times 100\%$




Figure 9.35 Duty ratio

Point

The maximum counting speed can be increased by placing multiple counters within one scan.

At this time, use the direct access input (DX□)(☞ Section 3.8.2) for the counter input signal.




Figure 9.36 Ladder example for increasing the maximum counting speed

(4) Precautions

(a) When counting processing is suspended

If an interrupt occurs during execution of the processing shown below, counting is suspended until the execution of each processing is completed.

- Each instruction on the sequence program
- Interrupt program
- Fixed scan execution type program

Upon completion of the processing, the counting restarts.

However, if the same interrupt occurs again during each processing, these interrupts are counted as once.

9.2.12 Data register (D)

(1) Definition

The data register (D) is a memory in which numeric data (-32768 to 32767, or 0000H to FFFFH) can be stored.

(2) Bit structure of the data register

(a) Bit structure and read/write unit

One point of the data register consists of 16 bits, and data can be read or written in units of 16 bits.




Figure 9.37 Bit structure of the data register

Point

Data register data are handled as signed data.
In the case of the hexadecimal notation, 0000H to FFFFH can be stored. However, because the most significant bit represents a sign bit, decimal values that can be specified are -32768 to 32767.

(b) When using a 32-bit instruction for the data register

For a 32-bit instruction, two consecutive points of the data register (D_n and D_{n+1}) are the target of the processing.

The lower 16 bits correspond to the data register number (Dn) specified in the sequence program, and the higher 16 bits correspond to the specified data register number + 1.

Example When D12 is specified in the DMOV instruction, D12 represents the lower 16 bits and D13 represents the higher 16 bits.




Figure 9.38 Data transfer with a 32-bit instruction and storage location

Data of -2147483648 to 2147483647 or 0H to FFFFFFFFH can be stored in a two-point area of the data register. (The most significant bit in a 32-bit structure is a sign bit.)

(3) Retention of stored data

The data stored in the data register are held until other different data are stored.
Note that the stored data are initialized when the CPU module is powered off or reset.

9.2.13 Link register (W)

(1) Definition

The link register (W) is a memory in the CPU module, which is refreshed with link register (LW) data of an intelligent function module such as a MELSECNET/H network module.




Figure 9.39 Link refresh

In the link register, numeric data (-32768 to 32767, or 0000H to FFFFH) are stored.

(2) Bit structure of the link register

(a) Bit structure and read/write unit

One point of the link register consists of 16 bits, and data can be read or written in units of 16 bits.




Figure 9.40 Bit structure of the link register

Point

- Link register data are handled as signed data.
  In the case of the hexadecimal notation, 0000H to FFFFH can be stored. However, because the most significant bit represents a sign bit, decimal values that can be specified are -32768 to 32767.

- The area range in the link register, which is not used for a MELSECNET/H network module, can be used as a data register.

(b) When using a 32-bit instruction for the link register

For a 32-bit instruction, two consecutive points of the data register (Wn and Wn+1) are the target of the processing.

The lower 16 bits correspond to the link register number (Wn) specified in the sequence program, and the higher 16 bits correspond to the specified link register number + 1.

Example When W12 is specified in the DMOV instruction, W12 represents the lower 16 bits and D13 represents the higher 16 bits.




Figure 9.41 Data transfer with a 32-bit instruction and storage location

Data of -2147483648 to 2147483647 or 0H to FFFFFFFFH can be stored in a two-point area of the link register. (The most significant bit in a 32-bit structure is a sign bit.)

(3) Retention of stored data

The data stored in the link register are held until other different data are stored.

Note that the stored data are initialized when the CPU module is powered off or reset.

Point

- Although the number of points for the link register in a CC-Link IE controller network module is 131072 points, the default value for the link register in the CPU module is 8192 points.
- Although the number of points for the link register of a MELSECNET/H network module is 16384 points, the default value for the link register in the CPU module is 8192 points.

To use the link register exceeding the above points, change the link register points in the Device tab of the PLC parameter dialog box in GX Developer or use a file register.

(4) Using the link register in a network system

Network parameters must be set.

The area range that is not set by network parameters can be used as a data register.

Remark

For the network parameters, refer to the following.

Reference manual for each network module

9.2.14 Link special register (SW)

(1) Definition

The link special register (SW) is used to store communication status data and error data of intelligent function modules, such as CC-Link IE controller network modules and MELSECNET/H network modules.
Because the data link information is stored as numeric data, error locations and causes can be checked by monitoring the link special register.

(2) Number of link special register points

The points for the link special register in the CPU module are 2048 (SW0 to SW7FF).
However, the number of points can be changed in the Device tab of the PLC parameter dialog box.
(☞ Section 9.1)
The points for an intelligent function module such as a CC-Link IE controller network module or a MELSECNET/H network module are 512.
By assigning it as shown in Figure 9.42, data of the link special register (SW) in a CC-Link module can be also refreshed to the link special register (SW) in the CPU module.




Figure 9.42 Points of the link special register

Remark

For details of the link special register, refer to the manual for each intelligent function module that has the link special register.

9.3 Internal System Devices

Internal system devices are provided for system operations.
The allocations and sizes of internal system devices are fixed, and cannot be changed by the user.

9.3.1 Function devices (FX, FY, FD)

(1) Definition

Function devices are used in subroutine programs with argument passing.
Data are read or written between such subroutine programs and calling programs, using function devices.

Example When FX0, FY1, and FD2 are used in a subroutine program, and if X0, M0, and D0 are specified with a subroutine program call instruction, on/off data of X0 and FY1 are passed to FX0 and M0 respectively, and D0 data are passed to FD2.




Figure 9.43 Application example of function devices

(2) Applications of function devices

Because a device in each calling program can be determined by using a function device for subroutine programs, the same subroutine program can be used without considering other calling programs.

(3) Types of function devices

The following three types of function devices are available.

- Function input (FX)
- Function output (FY)
- Function register (FD)

(a) Function input (FX)

- The function input is used to pass on/off data to a subroutine program.
- Bit data specified by a subroutine call instruction with argument passing are fetched into a subroutine program and they are used for operations.
- All bit devices for the CPU module can be used.

(b) Function output (FY)

- The function output is used for passing an operation result (on/off data) in a subroutine program to a calling program.
- An operation result is stored in the device specified in the subroutine program with argument passing.
- All bit devices except for input devices of the CPU module (X and DX) can be used.

(c) Function register (FD)

- The function register is used for data writing or reading between a subroutine program and a calling program.
- The CPU module auto-detects the input or output conditions of the function register.
  Source data are input data of the subroutine program.
  Destination data are output data from the subroutine program.
- The function register of one point can occupy up to four words.
  Note that, however, the number of words used differs depending on the instruction in the subroutine program.

1) A one-word instruction uses one word only.




Figure 9.44 When the function register of one point occupies one word

2) two-word instruction uses two words.




Figure 9.45 When the function register of one point occupies two words

3) At a destination using 32-bit multiplication or division, four words are used.




Figure 9.46 When the function register of one point occupies four words

- Word devices of the CPU module can be used.

Point

In subroutine programs with argument passing, do not use any devices that are used by the function register.
If this occurs, function register values will not be normally passed to the calling program.




Figure 9.47 Ladder example in which use of devices is not allowed in a subroutine program with argument passing

Remark

For use of function devices, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

9.3.2 Special relay (SM)

(1) Definition

The special relay (SM) is an internal relay of which details are specified inside the programmable controller, and the CPU module status data are stored in this special relay.

(2) Special relay classifications

Table9.3 shows special relay classifications.

Table9.3 Special relay classification list

Classification	Special relay
Diagnostics information	SM0 to SM199
Serial communication function	SM100 to SM115 *1
System information	SM200 to SM399
System clocks and counters	SM400 to SM499
Scan information, I/O refresh	SM500 to SM599
Drive information	SM600 to SM699
Instruction related	SM700 to SM799
Debugging	SM800 to SM899
Latch area	SM900 to SM999
A → QnA conversion compatibility	SM1000 to SM1299 *2 *3
Redundant power supply module information	SM1780 to SM1799*3

*1: Available only for the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU. (☞ Section 6.23)

*2: Valid only when "Use special relay/special register from SM/SD1000" is selected in the PLC system tab of the PLC parameter dialog box.

*3: Applicability differs depending on the CPU module version. (☞ Appendix 2)

Remark

For details of the special relay, refer to CHAPTER 12.

9.3.3 Special register (SD)

(1) Definition

The special register (SD) is an internal relay of which details are specified inside the programmable controller, and the CPU module status data (such as error diagnostics or system information) are stored in this special register.

(2) Special register classifications

Table9.4 shows special register classifications.

Table9.4 Special register classification list

Classification	Special register
Diagnostics information	SD0 to SD199
Serial communication function	SD100 to SD111 *1
System information	SD200 to SD399
System clocks and counters	SD400 to SD499
Scan information	SD500 to SD599
Drive information	SD600 to SD699
Instruction related	SD700 to SD799
Debugging	SD800 to SD899
Latch area	SD900 to SD929
Fuse blown module	SD1300 to SD1399
Check of I/O modules	SD1400 to SD1499
A → QnA conversion compatibility	SD1000 to SD1299 *2 *3
Redundant power supply module information	SD1780 to SD1799 *3

*1: Available only for the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU. (☞ Section 6.23)

*2: Valid only when "Use special relay/special register from SM/SD1000" is selected in the PLC system tab of the PLC parameter dialog box.

*3: Applicability differs depending on the CPU module version. (☞ Appendix 2)

Remark

For details of the special register, refer to CHAPTER 12.

(1) Definition

The link direct device is a device for direct access to the link device in a CC-Link IE controller network module or MELSECNET/H network module.

The CPU module can directly write data to or read data from the link device in a CC-Link IE controller network module or MELSECNET/H network module using sequence programs regardless of link refresh.

(2) Specification method and application example

(a) Specification method

Specify a network number and a device number.




Figure 9.48 Specification method

(b) Application example

For link register 10 (W10) of network number 2, "J2\W10" must be used.




Figure 9.49 Application example

For a bit device (X, Y, B, or SB), the digit must be specified.

Example J1\K1X0, J10\K4B0

(3) Specification range

A link device that is not set in the Network parameter dialog box can be specified.

(a) Writing

- The write range must be within the link device send range that is set by common parameters on Network parameter setting dialog box, and it must be outside the refresh range set by network refresh parameters.




Figure 9.50 Write range of a link direct device

- Although writing can be done to a refresh range portion (specified by refresh parameters) within the link device range, the link module's link device data will be overwritten when a refresh occurs.
  When writing data by using a link direct device, write the same data to the relevant devices on the CPU module side, which are set by refresh parameters.
  [Refresh parameter settings]
  1) Network number: 1
  2) CPU module (W0 to W3F) ↔ Network module (LW0 to LW3F)




Figure 9.51 Writing to the link device set within the refresh range

- If data are written to another station's write range using a link direct device, the data will be overwritten with other data that are received from the corresponding station.

(b) Reading

The link device ranges of network modules can be read.

Point

Writing or reading data by using a link direct device is allowed for only one network module that is on the same network.
If two or more network modules are mounted on the same network, a network module with the lowest slot number is the target of writing or reading by the link direct device.
For example, if network modules set as station numbers 1 and 2 are mounted on network number 1 as shown in Figure 9.52, station number 2 is the target of the link direct device.




Figure 9.52 When two or more network module are mounted on the same network

(4) Differences between link direct devices and link refresh

Table9.5 Differences between link direct devices and link refresh

Item		Link direct device	Link refresh
Description on programs	Link relay	J□\K4B0 or higher	B0 or higher
	Link register	J□\W0 or higher	W0 or higher
	Link special relay	J□\K4SB0 or higher	SB0 or higher
	Link special register	J□\SW0 or higher	SW0 or higher
Number of steps		2 steps	1 step
Range of network module access		J□\□0 to J□\□3FFF	Range specified by refresh parameters
Guaranteed access data integrity		Word (16-bit) units	

Remark

For network parameters, common parameters, and network refresh parameters, refer to the following.

- Details:
  ☞ Network manual for each network module
- Setting method:
  ☞ GX Developer Version 8 Operating Manual

9.5 Module Access Devices

9.5.1 Intelligent function module device (U□\G□)

(1) Definition

The intelligent function module device allows direct access from the CPU module to the buffer memories of the intelligent function modules which are mounted on the main and extension base units.

(2) Specification method and application example

(a) Specification method

Specify the I/O number and buffer memory address of the intelligent function module.




Figure 9.53 Specification method

(b) Application example

When the Q64AD analog-digital converter module is mounted in the position of I/O number 020 (X/Y020 to X/Y02F), to store digital output values of CH.1 to CH.4 into D0 to D3 accordingly, specify the device as shown in Figure 9.53.




Figure 9.54 Application example

Point

If the intelligent function module device is used, device comments can be attached to the buffer memory.

GX Developer Version 8 Operating Manual

(3) Processing speed

The processing speed of the intelligent function module device is as follows:

- The processing speed of writing or reading using the intelligent function module device is slightly higher compared with the case of using the FROM or TO instruction.

  Example "MOV U2\G11 D0"

- When reading from the buffer memory of an intelligent function module and another processing with one instruction, totalize the processing speed of the FROM or TO instruction and the other instruction.

  Example "+ U2\G11 D0 D10"

Point

Instead of using the intelligent function module device in the sequence program twice or more to write or read buffer memory data, using the FROM or TO instruction once in one place can increase the processing speed.




Figure 9.55 Writing data using the intelligent function module device multiple times




Figure 9.56 Writing data using the TO instruction once in the program

Remark

1. For buffer memory addresses and applications, refer to the manual for each intelligent function module/special function module.

2. For the FROM and TO instructions, refer to the following.
   ☞ QCPU Programming Manual (Common Instructions)

9.5.2 Cyclic transmission area device (U3En\G□)

(1) Definition

The cyclic transmission area device is used to access the CPU shared memory of each CPU module in a multiple CPU system.

(2) Features

- The transfer speed is higher than the case of using the write (S.TO or TO) or read (FROM) instruction to the CPU shared memory, resulting in reduced programing steps.
- Using the cyclic transmission area device allows bit manipulation.
- By setting device comments for the cyclic transmission area device, program readability is increased.
- Because information on the CPU shared memory can be directly specified as an argument of the instruction, no interlock device is required.

(3) Specification method

Specify the I/O number of the CPU module and the CPU shared memory address.




Figure 9.57 Specification method

Remark

For details of the cyclic transmission area device, refer to the following.

☞ QCPU User's Manual (Multiple CPU System)

9.6 Index Register (Z)/Standard Device Resister (Z)

9.6.1 Index register (Z)

(1) Definition

The index register is used for indirect specification (index modification) in sequence programs.
Index modification uses one point of the index register.




Figure 9.58 Index register

The index register has 20 points (Z0 to Z19).

(2) Bit structure of the index register

(a) Bit structure and read/write unit

One point of the index register consists of 16 bits, and data can be read or written in units of 16 bits.




Figure 9.59 Bit structure of the index register

Point

Index register data are handled as signed data.
In the case of the hexadecimal notation, 0000H to FFFFH can be stored. However, because the most significant bit represents a sign bit, decimal values that can be specified are -32768 to 32767.

(b) When using the index register for a 32-bit instruction

The processing target is Zn and Zn+1.
The lower 16 bits correspond to the specified index register number (Zn), and the higher 16 bits correspond to the specified index register number + 1.

Example When Z2 is specified in the DMOV instruction, Z2 represents the lower 16 bits and Z3 represents the higher 16 bits. (The most significant bit in a 32-bit structure is a sign bit.)




Figure 9.60 Data transfer with a 32-bit instruction and storage location

(3) When using 32-bit index modification

For the file register (ZR), extended data register (D), extended link register (W) using the serial number access method, 32-bit index modification using two points of the index register is available.
The following two kinds of methods can be used to specify the index register.

- Specify the range used for 32-bit index modification.
- Specify the 32-bit index modification using "ZZ". Note9.3

Remark

For details and precautions of index modification using the index register, refer to the following.
QCPU Programming Manual (Common Instructions)

Note9.3 Universal

When specifying the 32-bit index modification using "ZZ" for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Developer.
(Appendix 2)

9.6.2 Standard device register (Z)

(1) Definition

By using the index register between register operations, operations can be executed at a higher speed.
The index register used in this case is called the standard device resister.

(2) Device number

Since the standard device register is the same device as the index register, pay attention not to use the same device number when using the index modification.

Remark

For operation processing and processing time of the standard device register, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

9.6.3 Switching from the scan execution type program to the interrupt/fixed scan execution type program

The CPU module performs the following when switching from the scan execution type program to the interrupt/fixed scan execution type program.

- Saving and restoring the index register data
- Saving and restoring block numbers of the file register

(1) Setting for saving and restoration

Saving and restoration setting can be enabled in the PLC system tab of the PLC parameter dialog box.
To disable writing to the index register in the interrupt/fixed scan execution type program, select "High speed execution" in the Interrupt program/Fixed scan program setting area.
If this setting is enabled, the program will switch faster than before.




Figure 9.61 Interrupt/fixed scan program setting

(2) Processing of the index register

(a) When "High-speed execution" is not selected

1) When switching from the scan execution type program to the interrupt/fixed scan execution type program

The CPU module saves index register values in the scan execution type program, and passes them to the interrupt/fixed scan execution type program.

2) When switching from the interrupt/fixed scan execution type program to the scan execution type program

The CPU module restores the saved index register values.




Figure 9.62 Saving and restoring index register data (when "High speed execution" is not selected)

*1: The Z0 value is changed to 3 in the interrupt program.

Point

To pass index register values from the interrupt/fixed scan execution type program to the scan execution type program, use word devices.

(b) When "High-speed execution" is selected

1) When switching from the scan execution type program to the interrupt/fixed scan execution type program

The CPU module does not save/restore any index register values.

2) When switching from the interrupt/fixed scan execution type program to the scan execution type program

If data are written to the index register by the interrupt/fixed scan execution type program, the values of the index register used in the scan execution type program will be corrupted.




Figure 9.63 Saving and restoring index register data (when "High speed execution" is selected)

*1: The Z0 value is changed to 3 in the interrupt program.

When writing data to the index register by the interrupt/fixed scan execution type program, use the ZPUSH or ZPOP instruction to save and restore the data.




Figure 9.64 Writing data to the index register in the interrupt/fixed scan execution type program

(3) Processing of file register's block numbers

(a) When switching from the scan execution type program to the interrupt/fixed scan execution type program

The CPU module saves the file register block numbers in the scan execution type program, and passes them to the interrupt/fixed scan execution type program.

(b) When switching from the interrupt/fixed scan execution type program to the scan execution type program

The CPU module restores the saved block numbers of the file register.




Figure 9.65 Saving and restoring file register's block numbers

9.7 File Register (R) Note9.4

(1) Definition

The file register (R) is a device provided for extending the data register.
The file register can be used at the same processing speed as the data register.




Figure 9.66 Writing to the file register

(2) Bit structure od the file register

(a) Bit structure and read/write unit

One point of the file register consists of 16 bits, and data can be read or written in units of 16 bits.




Figure 9.67 Bit structure of the file register

(b) When using a 32-bit instruction for the file register

The processing target is R_n and R_{n+1}.
The lower 16 bits correspond to the file register number (Rn) specified in the sequence program, and the higher 16 bits correspond to the specified file register number + 1.
For example, when R2 is specified in the DMOV instruction, R2 represents the lower 16 bits and R3 represents the higher 16 bits.




Figure 9.68 Data transfer with a 32-bit instruction and storage location

Data of -2147483648 to 2147483647 or 0H to FFFFFFFFH can be stored in a two-point area of the file register.
(The most significant bit in a 32-bit structure is a sign bit.)

Note9.4 Universal
The Q00UJCPU does not have the file register.

(3) Clearing the file register

The file register contents are backed up by the battery built in the CPU module, and they are held if the CPU module is powered off or reset.
(Not initialized even if the latch is cleared.*1)

*1: The latch range of the file register can be set in the Device tab of the PLC parameter dialog box. (☞ Section 6.3)

To initialize the file register contents, perform the data clear operation in the sequence program or GX Developer.

(a) When clearing by the sequence program



Figure 9.69 Example of clearing the file register R0 to R999

(b) When clearing by GX Developer

Select [Online] → [Clear PLC memory] in GX Developer and clear the data by selecting "Clear all file registers".

9.7.1 File register data storage location

There are the following three kinds of memory media for storing file register data.

- Standard RAM
- SRAM card
- Flash card

9.7.2 File register size

(1) When using the standard RAM

The table below shows the maximum points of file register data that can be stored in the standard RAM.
Note that, however, if the standard RAM is used for an application other than file registers, available points are decreased. (☞ Section 5.1.10)

Table9.6 File register size

CPU module	Points
Q00UCPU, Q01UCPU, Q02UCPU	64K
Q03UDCPU, Q03UDECPU	96K
Q04UDHCPU, Q04UDEHCPU	128K
Q06UDHCPU, Q06UDEHCPU	384K
Q10UDHCPU, Q10UDEHCPU, Q13UDHCPU, Q13UDEHCPU	512K
Q20UDHCPU, Q20UDEHCPU, Q26UDHCPU, Q26UDEHCPU	640K

(2) When using an SRAM card

Up to 4086K points can be stored in one file.
Since one block consists of 32K words, up to 128 blocks can be stored.

Note that the number of points or blocks that can be added depends on the size of the programs and device comments stored in the memory card.

(3) When using a Flash card

Up to 2039K points can be stored in one file.
Since one block consists of 32K words, up to 64 blocks can be stored.

Note that the number of points or blocks that can be added depends on the memory card capacity and the size of the programs and device comments stored in the memory card.

Remark

For the memory cards available for the CPU module, refer to Section 5.1.1.

9.7.3 Differences in available accesses by storage memory

Accesses available for the file register vary for each memory.

Table9.7 Differences in accesses available for the file register

Access		Standard RAM	SRAM card	Flash card
Program writing		○	○	×
Program reading		○	○	○
Writing device memory to programmable controller		○	○	×
Reading device memory from programmable controller		○	○	○
Data modification	Online test operation from GX Developer	○	○	×
	Writing to programmable controller by GX Developer	○	○	×
	Writing to programmable controller by GX Developer (flash ROM)	×	×	○
	Batch write by a serial communication module	○	○	×
	Device data writing from GOT1000 series	○	○	×
	Random write command from GOT1000 series	○	○	×

9.7.4 Registration procedure for the file register

To use a file register, register the file of the file register to the CPU module in the following steps.




Figure 9.70 Registration procedure for the file register

(1) Setting the file register

In the PLC file tab of the PLC parameter dialog box, specify the standard RAM or a memory card to use the file register in the sequence program.




Figure 9.71 File register setting

(a) Not used

Select this in the following cases.

- When not using any file register
- When specifying a file register used in the sequence program (the QDRSET instruction is used for specification.)

(b) Use the same file name as the program.

Select this when executing the file register with the same file name as the sequence program.

1) When the program is changed

The file name of the file register is automatically changed to the same name as the program.
This feature is useful if the file register is exclusively used for one program as a local device.

Example When each of file registers A to C has the same name with the corresponding one of the program A to C, the operation is as described below.

- During execution of program A: Accessing file register A
- During execution of program B: Accessing file register B
- During execution of program C: Accessing file register C




Figure 9.72 When the program is changed

2) Point setting for file registers

Select [Online] → [Write to PLC] in GX Developer and set the number of file register points.

Point

With some instructions, file registers set for respective programs cannot be specified.
For details, refer to the pages describing devices available for each instruction in the following manual.
☞ QCPU Programming Manual (Common Instructions)

(c) Use the following file.

Select this when one file register is to be shared by all execution programs.
Specify "Corresponding memory", "File name", and "Capacity" and write these parameters to the CPU module to create a file for the file register.
If the capacity is not specified, note the following.

- When the specified file register file is stored in the specified drive, the file is used. (The capacity is the same as that of the stored file register file.)
- If the file register file with the specified file name is not found on the specified drive, "PARAMETER ERROR" (error code: 3002) will occur.
- For use of an ATA card, "Memory card (ROM) cannot be selected for "Corresponding memory".
  (File register data cannot be stored in ATA cards.)
  Selecting "Memory card (ROM)"for "Corresponding memory" and writing the settings to the CPU module will result in "PARAMETER ERROR" (error code: 3002).

(2) File register setting

In a new device memory window, set data for the specified file register.




Figure 9.73 Device memory window

(a) Devices

Setting Rn (R0 in the case shown above)and clicking the Display button will display the file register list.

(b) Data setting

Enter data that are set for the file register.

This step is not needed when you specify only the capacity of file register.

(3) Registering the file register file to the CPU module

When either of the following is selected in the PLC file tab of the PLC parameter dialog box, the file register file must be registered to the CPU module.

- Not used. (when specifying a file register used in the sequence program) (☞ (1)(a) in this section)
- Use the same name with the program. (☞ (1)(b) in this section)

File register files can be registered to the CPU module by selecting [Online] → [Write to PLC] in GX Developer.




Figure 9.74 File register file registration

(a) Target memory

Select the Standard RAM, Memory card (RAM), or Memory card (ROM) from this list box.
When using the same file name as that of the program, register the file register to the memory specified in the PLC File tab of the PLC parameter dialog box.

(b) Selecting a file register file

By selecting a memory for the file register, file names of the set file registers are displayed. Select a file register file.

(c) Setting the size and file name

Set the size of the file register and a file name of the file register file to be written to the CPU module (PLC-side file name).

1) File register size of the CPU module

The file register size can be set in increments of one point.
Note that each file size is ensured in units of 256 points.
Even if a file register is not specified from ZR0, the created file will have an assignment from ZR0 to the last number.
For example, if the write range of a file register is specified to be ZR1000 to ZR1791, the created file register file will have an assignment from ZR0 to ZR1791.
However, because the data in ZR0 to ZR999 are unreliable, specify the file register from ZR0.
The size of the file register is checked in the units of 1K points. Therefore, the file register size must be specified from R0 in the units of 1K points.

(d) Writing to the CPU module

The file register file of the specified points is registered to the specified memory of the CPU module.

9.7.5 Specification methods of the file register

(1) Block switching method

The file register points used are divided and specified in units of 32K points (R0 to R32767).
If multiple blocks are used, the desired block is specified with the block number in the RSET instruction.
Each block has a specification range of R0 to R32767.




Figure 9.75 Block switching method

(2) Serial number access method

A file register whose size is exceeding 32K points can be specified using consecutive device numbers.
Multiple blocks of a file register can be used as a continuous file register.
This kind of device is expressed as "ZR".




Figure 9.76 Serial number access method

Point

The block numbers and ZR device points that can be specified vary depending on the following.

- Storage location of the file register (☞ Section 9.7.1)
- File register size (☞ Section 9.7.2)

9.7.6 Precautions for using the file register

(1) No registration or use of an invalid file register number

(a) When the file of the file register has not been registered

Writing to or reading from the file register will result in "OPERATION ERROR" (error code: 4101).

(b) When writing to or reading from the file register exceeding the registered size (points)

"OPERATION ERROR" (error code: 4101) will occur.

(2) File register size check

When writing to or reading from the file register, check the file register size so that data can be written or read within the size (points) set for the CPU module.

(a) Checking the file register size

The file register size can be checked in the File register capacity area (SD647). *1
The file register size data in units of 1K points is stored in this SD647.

*1: If a file register file is switched to another, the size of the currently selected file register file is stored in SD647.

Point

The remainder after dividing the file register size by 1K points is discarded.
To ensure an accurate "range of use" check, specify the file register setting in units of 1K points (1024 points).

(b) Checking timing

- In a program using any file register, check the file register size at step 0.
- After execution of the file register file switching instruction (QDRSET), check the file register size.
- Before executing the file register block switching instruction (RSET), confirm that space of 1K points or more can be ensured after the switching.


(File register size) > [32K points × (Switching block No) + {1K points]

(c) File register size checking procedure

- Check the file register size used for each sequence program.
- Check the total file register size set in SD647 on the sequence program to see if there are sufficient number of points to be used or not.


[Program example 1]

The file register range of use is checked at the beginning of each program.



[Program example 2]

The file register range of use is checked after execution of the QDRSET instruction.



[Program example 3]

When a block is switched to another:




Figure 9.77 Program examples of file register checking

(3) Deleting a file register file

To delete an unnecessary file register file, select [Online] → [Delete PLC data] in GX Developer.

9.8 Extended Data Register (D) and Extended Link Register (W) Note9.5

(1) Definition

The extended data register (D) and extended link register (W) are devices for using the large-capacity file register (ZR) area as an extended area of the data register (D) and link register (W). These devices can be programmed as the data register (D) and link register (W) together with the file register (ZR) area.




Figure 9.78 Operation of the extended data register (D) and extended link register (W)

Note9.5 Universal

For the Q00UJCPU, the extended data register (D) and extended link register (W) cannot be used.
For using them for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, Q26UDHCPU, and Built-in Ethernet port QCPU, check the version of GX Developer. (Appendix 2)

(2) Device numbers

Device numbers for the extended data register (D) and extended link register (W) can be assigned consecutively after those for the internal user devices, data register (D) and link register (W).

Point

- Even though device numbers are consecutively assigned, there is no physical area contiguity between the data register (D) (internal user device) and the extended data register (D), and between the link register (W) (internal user device) and the extended link register (W).
  To use them as one contiguous area, set the points for the data register (D) and link register (W) (internal user device) to "0" in the Device tab of the PLC parameter dialog box, and use only the extended data register (D) and extended link register (W).

- When using the file register (ZR), extended data register (D) and extended link register (W) with the auto refresh setting enabled in GX Configurator, the points set in the File register extended setting in the Device tab of the PLC parameter dialog box must not be exceeded.

(3) Setting method

Since the extended data register (D) and extended link register (W) use the file register area, data must be set for both the file register setting and the device setting.

(a) File register setting

Select "Use the following file." in the PLC file tab of the PLC parameter dialog box, and enter data in the boxes indicated in Figure 9.79.

The "Use the same file name as the program." option is not selectable.




Figure 9.79 Dialog box for file register point setting

Table9.8 File register setting item list

Item	Corresponding memory		File name	Capacity *1	Remarks
"Use the following file"	Memory card (RAM) *4		Any name	1 to 4086K points *2	-
	Memory card (ROM) *4		Any name	1 to 2039K points *3	Read only
	Standard RAM	Q00UCPU, Q01UCPU, Q02UCPU	Any name	1 to 64K points	-
		Q03UDCPU, Q03UDECPU		1 to 96K points	
		Q04UDHCPU, Q04UDEHCPU		1 to 128K points	
		Q06UDHCPU, Q06UDEHCPU		1 to 384K points	
		Q10UDHCPU, Q10UDEHCPU, Q13UDHCPU, Q13UDEHCPU		1 to 512K points	
		Q20UDHCPU, Q20UDEHCPU, Q26UDHCPU, Q26UDEHCPU		1 to 640K points	

*1: The total points of the file register (ZR), extended data register (D), and extended link register (W).
*2: This is the maximum number of points when an SRAM card (8M bytes) is used.
*3: This is the maximum number of points when a Flash card (4M bytes) is used.
*4: For the Q00UCPU and Q01UCPU, no memory card can be used.

(b) Device setting

Set each number of points for the file register (ZR), extended data register (D), and extended link register (W) in the File register extended setting in the Device tab of the PLC parameter dialog box.
Assign a part of the points set for the file register (ZR) in the PLC file tab to the extended data register (D) and extended link register (W).

If data are to be latched, specify the latch range.

- Latch (2) of the file register (ZR)
- Latch (1) and (2) of the extended data register (D)
- Latch (1) and (2) of the extended link register (W)




Figure 9.80 File register extended setting

Once the points for the extended data register (D) and extended link register (W) is set, areas for these devices are reserved in the file register file.




Figure 9.81 Areas for the extended data register (D) and extended link register (W)

(4) Checking the points by the special register

The points for each of the file register (ZR), extended data register (D), and extended link register (W) can be checked in the following special register areas.

- SD306, SD307: File register (ZR)
- SD308, SD309: Extended data register (D)
- SD310, SD311: Extended link register (W)

(5) Precautions

For use of the extended data register (D) and extended link register (W), pay attention to the following.

1) When the extended data register (D) and extended link register (W) are specified, the values of the following items will be the same as those for the file register (ZR).
   - Number of program steps
   - Instruction processing time
   - Processing time of auto refresh with network modules
   - Processing time of auto refresh with intelligent function modules
   - Processing time of auto refresh between CPU shared memories
2) The file register size cannot be changed in the RUN status.
3) The file register cannot be switched to another using the QDRSET instruction. ("OPERATION ERROR" (error code: 4100))
4) Set the refresh ranges for the following auto refresh properly so that each refresh range does not cross over the boundary between the internal user device and the extended data register (D) or extended link register (W).
   - Auto refresh with network modules
   - Auto refresh with intelligent function modules
   - Auto refresh between CPU shared memories
5) Set the following properly so that each specification does not cross over the boundary between the internal user device and the extended data register (D) or extended link register (W).
   - Index modification
   - Indirect specification
   - Specification for instructions that use block data *1

*1: Block data means the following:
- •Data used in instructions, such as FMOV, BMOV, and BK+, which treat more than one word for operation.
- •Control data, composed of two or more words, which are specified in instructions, such as SP.FWRITE and SP.FREAD.
- •Data in a 32-bit or greater format (binary 32 bits, real number, indirect address of a device)

Remark

For details on the index modification and indirect specification with the extended data register (D) and extended link register (W), refer to the following.

☞ QCPU Programming Manual (Common Instructions)

6) To access the extended data register (D) or extended link register (W) from a module that does not support the use of these devices, device numbers need to be specified with those of the file register (ZR). Calculation formulas for obtaining device numbers of the file register (ZR) to be specified to access the extended data register (D) and extended link register (W) and calculation examples are described below.

Table9.9 Calculation formulas for obtaining device numbers of the file register (ZR) to be specified to access the extended data register (D) and extended link register (W) *1

Item	Calculation formula
Device number of the file register (ZR) used to access the extended data register (D)	$ED_{ZN} = ZR_C + (ED_N - D_C)$
Device number of the file register (ZR) used to access the extended link register (W)	$EW_{ZN} = ZR_C + ED_C + (EW_N - W_C)$

*1: Variables in the table indicate the following:

- ZR_C: Points of the file register (ZR)
- ED_{ZN}: Device number of the file register (ZR) used to access the extended data register (D)
- ED_N: Access target device number of the extended data register (D)
- D_C: Points of the data register (D)
- ED_C: Points of the extended data register (D)
- EW_{ZN}: Device number of the file register (ZR) used to access the extended link register (W)
- EW_N: Access target device number of the extended link register (W) (hexadecimal)
- W_C: Points of the link register (W)

[Calculation example]

- D_C: Points of the data register (D) ••• 12288 points
- W_C: Points of the link register (W) ••• 8192 points
- ZR_C: Points of the file register (ZR) ••• 2048 points
- ED_C: Points of the extended data register (D) ••• 2048 points

1) Device number of the file register (ZR) used to access D13000
$ED_{ZN} = 2048 + (13000-12288) = 2760$

2) Device number of the file register (ZR) used to access W2100
$EW_{ZN} = 2048 + 2048 + (2100_H - 8192) = 2048 + 2048 + (8448 - 8192) = 4352$




Figure 9.82 Access to the extended data register (D) and extended link register (W)

9.9 Nesting (N)

(1) Definition

Nesting (N) is a device used in the master control instructions (MC and MCR instructions) to program operation conditions in a nesting structure.

(2) Specification method using master control instructions

The master control instruction opens or closes a common ladder gate to switch the ladder of a sequence program efficiently.

Specify the nesting (N) in ascending order (in order of N0 to N14), starting from the outside of the nesting structure.




Figure 9.83 Programming example using the nesting

Remark

For use of the nesting, refer to the following.

☞ QCPU Programming Manual (Common Instructions)

9.10 Pointer (P)

(1) Definition

The pointer (P) is a device used in jump instructions (CJ, SCJ, or JMP) or subroutine call instructions (such as CALL).

(2) Applications

Pointers can be used in the following applications.

- Specification of the jump destination in a jump instruction (CJ, SCJ, or JMP) and a label (start address of the jump destination)
- Specification of the call destination of a subroutine call instruction (CALL or CALLP) and a label (start address of the subroutine program)




Figure 9.84 Program using a pointer

(3) Pointer types

There are the following two different pointer types.

- Local pointer (☞ Section 9.10.1):
  The pointer used independently in each program
- Common pointer (☞ Section 9.10.2):
  The pointer that can be called in all running programs by the subroutine call instruction.

(4) Number of available pointer points

The number of points available for the pointer is 4096.

Remark

For the jump instructions and subroutine call instructions, refer to the following.
☞ QCPU Programming Manual (Common Instructions)

9.10.1 Local pointer

(1) Definition

The local pointer is a pointer that can be used independently in jump instructions and subroutine call instructions in each program.

The same pointer number can be used in respective programs.




Figure 9.85 Using the same pointer in respective programs (local pointer)

(2) Number of local pointer points

The local pointer can be divided for use of all the programs stored in the program memory.

The local pointer number ranges from P0 to the highest number of the local pointer in use. (The CPU module's system computes the number of points used.)

Even if only P99 is used in a program, for example, the number of points used will be 100, which is from P0 to P99.

For using the local pointer for several programs, use the pointers in ascending order starting from P0 in each program.

Example The total is 600 points when the pointer is used as shown below.




Figure 9.86 Concept of the local pointer points

(3) Precautions for using the local pointer

(a) Program where the local pointer is described

A jump from another program is not allowed.
jump instructions and sub-routine CALL instructions.
Use the ECALL instruction from another program when calling a subroutine program in a program file that contains any local pointer.

(b) Total number of local pointer points

If the total number of pointers (in all programs) exceeds 4096 points, a "Pointer configuration error" (error code: 4020) occurs.

9.10.2 Common pointer

(1) Definition

The common pointer is used to call subroutine programs from all programs that are being executed.




Figure 9.87 Calling pointers in another program (common pointer)

(2) Common pointer range

In the PLC system tab of the PLC parameter dialog box, set the start number for the common pointer.
The common pointer range is from the specified pointer number to P4095.
However, the pointer number that can be entered here is a number higher than the total points used for the local pointer.




Figure 9.88 Dialog box for setting the common pointer

If a total of 400 points are used in three programs (100 points in each of Program A and Program B, and 200 points in Program C), for example, P400 and higher numbers can be set for the common pointer.

(3) Precautions

1) The same pointer number cannot be used as a label.
Doing so will result in a "Pointer configuration error" (error code: 4021).

2) If the total number of the local pointer points used in several programs exceeds the start number of the common pointer, a "Pointer configuration error (error code: 4020) will occur.




Figure 9.89 Concept of the common pointer range

Point

The jump instructions are not capable of executing a jump to the common pointer in other programs.
Use the common pointer with subroutine call instructions only.

9.11 Interrupt Pointer(I)

(1) Definition

The interrupt pointer (I) is used as a label at the start of an interrupt program, and can be used in any programs.




Figure 9.90 Interrupt pointer

(2) Number of available points

The number of points available for the interrupt pointer is 256 (I0 to I255).

(3) Interrupt factors

Interrupt factors are listed in Table9.10.

Table9.10 Classification of interrupt factors

Interrupt factor	Interrupt pointer No.	Description
Interrupt by an interrupt module *1	I0 to I15	Interrupt input from an interrupt module
Interrupt by the internal timer	I28 to I31	Fixed scan interrupt by the internal timer of the CPU module
Multiple CPU synchronous interrupt *2	I45	Fixed scan interrupt to execute synchronized control with the operation cycle of a motion controller
Intelligent function module interrupt	I50 to I255	Interrupt from an intelligent function module *3

*1: For available interrupt modules, refer to the following.
☞ QCPU User's Manual (Hardware Design, Maintenance and Inspection)

*2: Applicable when using the Universal model QCPU and motion controller that support the multiple CPU high speed transmission.

*3: This module can be a serial communication module, MELSECNET/H module, Ethernet module, or high-speed counter module. For details, refer to the manual for each module.

Point

To use the intelligent function module interrupt (☞ Section 6.22), the intelligent function module setting (interrupt pointer setting) is required in the "PLC system" tab of the PLC parameter dialog box.

9.11.1 List of interrupt pointer numbers and interrupt factors

The list of interrupt pointer numbers and interrupt factors are shown below.

Table9.11 List of interrupt pointer numbers and interrupt factors

I No.	Interrupt factor		Priority	I No.	Interrupt factor		Priority
I0	Interrupt by interrupt module (QI60)	1st point	6	I32 to I44	-	N/A	-
I1		2nd point	7				
I2		3rd point	8				
I3		4th point	9				
I4		5th point	10				
I5		6th point	11				
I6		7th point	12				
I7		8th point	13				
I8		9th point	14				
I9		10th point	15				
I10		11th point	16				
I11		12th point	17				
I12		13th point	18				
I13		14th point	19				
I14		15th point	20	I45 *2 *5	Multiple CPU synchronous interrupt	0.88ms	1
I15		16th point	21				
I16 to I27	-	N/A	-	I46 to I49	-	N/A	-
I28 *5	Interrupt by internal timer *1	100ms	5	I50 to I255	Intelligent function module interrupt *3 *5/ Interrupt by interrupt module (QI60)	Specify the intelligent function module or interrupt module (QI60) with a parameter.	22 to 227
I29 *5		40ms	4				
I30 *5		20ms	3				
I31 *5		10ms	2				

*1: The time-limit value of the internal timer is set by default.
In the PLC system tab of the PLC parameter dialog box, the value can be changed within the range of 0.5ms to 1000ms in increments of 0.5ms.

*2: This is available for multiple CPU system configuration.

*3: To use the intelligent function module interrupt, the intelligent function module setting (interrupt pointer setting) is required in the PLC system tab of the PLC parameter dialog box. (For interrupt from an intelligent function module, refer to Section 6.22.

*4: I50 has the highest priority (priority 22), and I255 has the lowest priority (priority 227).

*5: When an interrupt occurs, even if no interrupt pointer exists on the program, CANíT EXECUTE(I) (error code: 4220) does not occur.

9.12 Other Devices

9.12.1 SFC block device (BL)

The SFC block is used to check that the specified block in the SFC program is activated.

Remark

For use of the SFC block device, refer to the following.

☞ QCPU (Q Mode)/QnACPU Programming Manual (SFC)

9.12.2 Network No. specification device (J)

(1) Definition

The network No. specification device is used to specify the network number in the link dedicated instructions.

(2) Specification method

In the link dedicated instruction, this device is specified as shown in Figure 9.91.




Figure 9.91 How to use the network No. specification device

Remark

For details of the link dedicated instructions, refer to the following.

☞ Reference manual for each network module

9.12.3 I/O No. specification device (U)

(1) Definition

The I/O No. specification device is used to specify I/O numbers in the intelligent function module dedicated instructions.

(2) Specification method

In the intelligent function module dedicated instruction, this device is specified as shown in Figure 9.92.




Figure 9.92 How to use the I/O No. specification device

Remark

For details of the intelligent function module dedicated instructions, refer to the following.

☞ Manual for the intelligent function module used

9.12.4 Macro instruction argument device (VD)

(1) Definition

The macro instruction argument device (VD) is used with ladders registered as macros.

When a VD□ setting is specified, the value is converted to the specified device when the macro instruction is executed.

(2) Specification method

Among the devices used in the ladders registered as macros in GX Developer, specify a device used for VD.
When using macro instructions in the sequence program, specify devices that correspond to the macro instruction argument devices used in the macro registration ladders in ascending order.




Figure 9.93 Macro instruction argument device specification

Point

- With the macro instruction argument device, VD0 to VD9 can be used in one macro registration ladder.
- The GX Developer read mode provides an option to view a program in macro instruction format.
  To change the display, select [View] → [Display macro instruction format].




Figure 9.94 Setting for macro instruction display

9.13 Constants

9.13.1 Decimal constant (K)

(1) Definition

The decimal constant (K) is used to specify decimal data in sequence programs.

Specify it as K⬚ (example: K1234) in sequence programs.

In the CPU module, data are stored in binary (BIN). (☞ Section 2.4.1)

(2) Specification range

The specification ranges for decimal constants are as follows:

- When using word data (16-bit data) ••••••••••••••••••••••••••••••••K-32768 to K32767
- When using 2-word data (32-bit data)••••••••••••••••••••••••••••••K-2147483648 to K2147483647

Point

The most significant bit represents a sign bit.

9.13.2 Hexadecimal constant (H)

(1) Definition

The hexadecimal constant (H) is a device for specifying hexadecimal or BCD data in sequence programs.
(For BCD data, each digit of a hexadeciml number is specified with 0 to 9.)

In sequence programs, specify it as H⬚ (example: H1234). (☞ Section 2.4.2)

(2) Specification range

The specification ranges for hexadecimal constants are as follows:

- When using word data (16-bit data) ••• H0 to HFFFF (For BCD data, H0 to H9999)
- When using 2-word data (32-bit data) ••• H0 to HFFFFFFFF (For BCD data, H0 to H99999999)

9.13.3 Real number (E)

(1) Definition

The real number (E) is a device used to specify real numbers in sequence programs.

In sequence programs, specify it as E□ (example: E1.234). (☞ Section 2.4.4)



Figure 9.95 Real number specification

(2) Specification range

(a) Real number setting range

- For single-precision floating-point data

  $-2^{128} < \text{Device} \leqq -2^{-126}, 0, 2^{-126} \leqq \text{Device} < 2^{128}$
- For double-precision floating-point data

  $-2^{1024} < \text{Device} \leqq -2^{-1022}, 0, 2^{-1022} \leqq \text{Device} < 2^{1024}$

(b) When an overflow or underflow has occurred

Table9.12 shows the operation of the CPU module when an overflow or underflow has occurred during arithmetic operation.

Table9.12 When an overflow or underflow has occurred

Overflow	Underflow
OPERATION ERROR (error code: 4141)	Turned to 0 without any error

(c) When a special value[*1] is input

If operation is performed with input data that contains a special value, "OPERATION ERROR" (error code: 4140) occurs.

*1: The special values are -0, unnormalized numbers, nonnumeric characters, and $\pm\infty$.

(3) Specification method

Real numbers can be specified in sequence programs by the following expressions.

- Normal expression ••• A numeric value can be specified as it is.

  Example 10.2345 can be specified as E10.2345.
- Exponential expression ••• A numeric value is specified by (Value) $\times 10^n$.

  Example 1234 is specified as E1.234 + 3.[*1]

*1: + 3 represents 10^3 in E1.234 + 3.

9.13.4 Character string (" ")

(1) Definition

The character string is a device used to specify a character string in sequence program.
Characters enclosed in quotation marks (example: "ABCD1234") are specified.

(2) Available characters

All ASCII code characters can be used in character strings.
The CPU module distinguishes between upper and lower case characters.

(3) Number of specified characters

A string from the specified character to the NUL code (00H) is one unit.
Note that, however, up to 32 characters can be specified for an instruction using a character string, such as $MOV.

9.14 Convenient Usage of Devices

When multiple programs are executed in the CPU module, each program can be executed independently by specifying an internal user device as a local device.
Devices of the CPU module are classified into the following two types:

- Global device that can be shared by multiple programs that are being executed.
- Local device that is used independently for each program.

9.14.1 Global device

Programs being executed in the CPU module can share the global device.
Global device data are stored in the device memory of the CPU module, and can be shared by all programs.




Figure 9.96 Using a global device

Point

- All of the devices that have not been set as local devices (Section 9.14.2) are global devices.
- For execution of multiple programs, the range to be shared by all programs and the range to be used independently by each program (Section 9.14.2) must be specified in advance.




Figure 9.97 Range specification for a device

9.14.2 Local device Note9.6

The local device is a device that can be used independently for each program.
Using local devices allows programming of multiple independently-executed programs without considering other programs.
Note that local device data can be stored in the standard RAM and a memory card (SRAM) only.




Figure 9.98 Using local devices

Note9.6 Universal

For the Q00UJCPU, local devices cannot be used.

(1) Devices that can be used as local devices

The following devices can be used as local devices.

- Internal relay (M)
- Edge relay (V)
- Timer (T, ST)
- Counter (C)
- Data register (D)
- Index register (Z) Note9.7

(2) Saving and restoring a local device file

When some programs use a local device, respective local device file data in the standard RAM or a memory card (SRAM) are exchanged with the device memory data of the CPU module after execution of each program.
For this reason, the scan time increases by the time spent for data exchange.




Figure 9.99 Saving and restoring local device files

Remark

1. There are some instructions for which a local device cannot be specified.
   For details, refer to the pages describing devices available for each instruction in the following manual.
   ☞ QCPU Programming Manual (Common Instructions)

2. For the concept of the number of words used for the local devices, refer to Section 9.2.

Note9.7 Universal

When using the index register as a local device for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, Q26UDHCPU, and Built-in Ethernet port QCPU, check the versions of the CPU module and GX Developer. (☞ Appendix 2)

(3) Local device setting

(a) Setting the local device range

In the Device tab of the PLC parameter dialog box, set the range that is used as a local device.




Figure 9.100 Device

Note that the local device range is common to all programs, and cannot be changed for each program.
For example, if a local device range is specified as M0 to M100, this range setting applies to all programs that use the local device.




Figure 9.101 Local device range

Point

- The 32-bit index modification range must not overlap with the local device setting range of the index register. If overlapped, 32-bit index modification values will be written over the local device values.

- When CPU module parameters which contains local device setting of the index register are read out from the GX Developer that does not support the setting, all of the index register data will be read out as global device data.

(b) Setting the drive and file name

After setting the local device range, set a memory for storing the local device file and a file name in the PLC file tab of the PLC parameter dialog box.




Figure 9.102 PLC file

(c) Writing the setting data

Write the data set in (a) and (b) to the CPU module.

Select [Online] → [Write to PLC] in GX Developer.




Figure 9.103 Device memory writing

Point

- If the size setting of the local device in the standard RAM is changed with a sampling trace file stored in the standard RAM, the sampling trace file is cleared.
  To save the trace results in your personal computer, perform the following operations.
  1) Click the Trace result PLC read button on the Sampling trace dialog box to read the trace result into the personal computer. (☞ Section 6.14(5)(e))
  2) Click the Trace result button to display the trace result.
  3) Click the Create CSV file button to store the trace results in CSV format.

- All of the devices that have not been set as local devices are global devices.

(4) Setting of whether to use a local device (for each program) Note9.8

Use of the local device can be set for each program, and this function can reduce the scan time.
Also, since the area for saving and restoring data is not required for the programs not using a local device, the local device file size can be reduced.




Figure 9.104 Save area configuration of a local device file

Note9.8 Universal

For setting a local device for each program in the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, and Q26UDHCPU, check the versions of the CPU module and GX Developer. (☞ Appendix 2)

(a) Setting method

In addition to the setting in (3) in this section, set the following.

Select the File usability setting button in the Program tab of the PLC parameter dialog box, and specify the programs that use the local device.




Figure 9.105 File usability setting dialog box

(b) Precautions

1) Change of the local device

Do not change or refer to the local device in a program for which the local device is set to "Not used".

Even if the local device is changed in such a program, the changed data will not be held.

2) Conditions for creating a local device file

Creation of a local device file depends on the PLC parameter settings.

Table9.13 shows the conditions for creating a local device file.

Table9.13 Conditions for creating a local device file

PLC parameter setting			File creation	Error detection
PLC file setting	Device setting*1	File usability setting		
Set	Set	Use PLC file setting	○	-
		Not used	○	-
	Not set	Use PLC file setting	×	-
		Not used	×	-
Not set	Set	Use PLC file setting	×	PARAMETER ERROR (error code: 3000)
		Not used	×	-
	Not set	Use PLC file setting	×	-
		Not used	×	-

○ : Created, × : Not created

*1: Indicates the local device range setting in the Device tab.

(5) Using the local device corresponding to the file where a subroutine program is stored

When executing a subroutine program, you can utilize the local device corresponding to the file where the subroutine program is stored.

Use of the relevant local device is set by ON/OFF of SM776.

Table9.14 Local device switching by ON/OFF of the special relay (SM776)

SM776	Operation
OFF	Perform operations with the local device that corresponds to the source file of the subroutine program.
ON	Perform operations with the local device that corresponds to the file where the subroutine program is stored.

(a) When SM776 is off




Figure 9.106 When SM776 is off

(b) When SM776 is on




Figure 9.107 When SM776 is on

(c) Precautions

- When SM776 is on, local device data are read out when a subroutine program is called, and the data are saved after execution of the RET instruction.
  Because of this, the scan time is increased if one subroutine program is executed with SM776 set to on.
- The on/off status of SM776 is set for each CPU module.
  It cannot be set for each file.
- If the on/off status of SM776 is changed during sequence program execution, control is implemented according to the information after the change.

Remark

For details of SM776, refer to CHAPTER 12.

(6) When executing an interrupt/fixed scan execution type program

When executing an interrupt/fixed scan execution type program, you can utilize the local device corresponding to the file where the program is stored.

Use of the relevant local device is set by ON/OFF of SM777. *1

*1: The index register set as the local device uses the local device area for the program executed before the interrupt/fixed scan execution type program, regardless of the on/off status of SM777.

Table9.15 Local device switching by ON/OFF of the special relay (SM777)

SM777	Operation
OFF	Perform operations with the local device that corresponds to the program executed before the interrupt/fixed scan execution type program.
ON	Perform operations with the local device that corresponds to the program file where the interrupt/fixed scan execution type program is stored.

(a) When SM777 is off




Figure 9.108 When SM777 is off

(b) When SM777 is on




Figure 9.109 When SM777 is on

(c) Precautions

- When SM777 is on, local device data are read out before execution of an interrupt/fixed scan execution type program, and the data are saved after execution of the IRET instruction.
  Because of this, the scan time is increased if one interrupt/fixed scan execution type program is executed with SM777 set to on.
- The on/off status of SM777 is set for each CPU module.
  It cannot be set for each file.
- If the on/off status of SM777 is changed during sequence program execution, control is implemented according to the information after the change.

Remark

For details of SM777, refer to CHAPTER 12.

(7) Clearing local device data

Local device data is cleared by either of the following:

- When the CPU module is powered off and then on or is reset
- When the CPU module status is changed from STOP to RUN

Local device data cannot be cleared from GX Developer.

CHAPTER10 CPU MODULE PROCESSING TIME

This chapter describes the CPU module processing time.

10.1 Scan Time

This section describes the scan time structures and CPU module processing time.

10.1.1 Scan time structure

A CPU module sequentially performs the following processing in the RUN status.

Scan time is the time required for all processing and executions to be performed.




Figure 10.1 Scan time structure

*1: End of a program indicates the timing when the END, GOEND, FEND, or STOP instruction is executed.

(1) How to check scan time

The CPU module measures current, minimum, and maximum values of the scan time.
The scan time can be checked by monitoring the special register (SD520, SD521, and SD524 to SD527).
Accuracy of each stored scan time is ± 0.1ms.




Figure 10.2 Scan time storage location

Example If the stored values in SD520 and SD521 are 3 and 400 respectively, the scan time is 3.4ms.

10.1.2 Time required for each processing included in scan time

This section describes how to calculate the processing and execution time described in Section 10.1.1.

(1) I/O refresh time

The I/O refresh time is time required for refreshing I/O data to/from the following modules mounted on the main base unit and extension base units.

- Input module
- Output module
- Intelligent function module

■ Calculation method

Use the following expression to calculate the I/O refresh time.

(I/O refresh time) = (number of input points/16) × N1 + (number of output points/16) × N2

For N1 and N2, refer to Table10.1.

Table10.1 I/O refresh time

CPU module	Q3□B, Q3□SB, Q3□RB, Q3□DB		Q5□B, Q6□B, Q6□RB	
	N1	N2	N1	N2
Q00UJCPU, Q00UCPU, Q01UCPU	1.8 μs	1.0 μs	2.6 μs	1.9 μs
Q02UCPU	1.5 μs	1.1 μs	2.4 μs	1.9 μs
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	1.5 μs	1.0 μs	2.3 μs	1.8 μs

(2) Instruction execution time in END processing

This is the processing time of the DUTY instruction in END processing.
The user timing clock (SM420 to 424 and SM430 to SM434) specified with the DUTY instruction is turned on/off during the END processing.

Table10.2 Instruction execution time in END processing

CPU module	Processing time in END processing	
	When set to 1	When set to 5
Q00UJCPU, Q00UCPU, Q01UCPU	0.0120ms	0.0140ms
Q02UCPU	0.0050ms	0.0550ms
Q03UDCPU, Q03UDECPU	0.0043ms	0.0046ms
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.0041ms	0.0045ms

(3) Instruction execution time

The instruction execution time is the time required for all instructions used in the program to be executed.

Remark

For the processing time required for each instruction, refer to the following.
☞ QCPU Programming Manual (Common Instructions)

(a) Overhead time at execution of interrupt and fixed scan execution type programs

When calculating instruction execution time, add the overhead time given in the following table to the instruction execution time, which is described in (3).

Two kinds of overhead time (pre-start and program-end) need to be added to interrupt programs.

Table10.3 Pre-start overhead time for interrupt programs

CPU module	Fixed scan interrupt (I28 to I31)		Multiple CPU synchronous interrupt (I45)		Interrupt*1 (I0 to I15) from QI60 or interrupt (I50 to I127) from the intelligent function module	
	Without high-speed start	With high-speed start	Without high-speed start	With high-speed start	Without high-speed start	With high-speed start
Q00UJCPU, Q00UCPU, Q01UCPU	55 μs	35 μs	---	---	76 μs	55 μs
Q02UCPU	48 μs	17 μs	---	---	60 μs	31 μs
Q03UDCPU, Q03UDECPU	47 μs	17 μs	46 μs	16 μs	54 μs	22 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	46 μs	16 μs	44 μs	14 μs	52 μs	22 μs

*1: Indicates the value when the QI60 is mounted on the slot 0 of the main base unit.

Table10.4 Program-end overhead time for interrupt programs

CPU module	Without high-speed start	With high-speed start
Q00UJCPU, Q00UCPU, Q01UCPU	28 μs	15 μs
Q02UCPU	26 μs	7 μs
Q03UDCPU, Q03UDECPU	26 μs	7 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	26 μs	7 μs

Table10.5 Overhead time for fixed scan execution type programs

CPU module	Without high-speed start	With high-speed start
Q00UJCPU, Q00UCPU, Q01UCPU	92 μs	60 μs
Q02UCPU	73 μs	25 μs
Q03UDCPU, Q03UDECPU	73 μs	24 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	72 μs	23 μs

1) Overhead time when local devices in the interrupt program are enabled

When SM777 (Enable/disable local device in interrupt program) is turned on, the time given in Table10.6 and Table10.7 will be added to the overhead time given in Table10.3 and Table10.4.

Each n, N1, N2, and N3 in the table indicates the following:

- n: Number of local device points (unit: K words)
- N1: Number of devices that specified a local device
- N2: Number of word device points that specified a local device
- N3: Number of bit device points that specified a local device

Table10.6 When a local device file in the standard RAM is used

CPU module	Additional time to the pre-start overhead time for interrupt programs (Table10.3)	Additional time to the program-end overhead time for interrupt programs (Table10.4)
Q00UCPU, Q01UCPU	(13.2 × N1) + (0.22 × (N2 + (N3 ÷ 16))) + 210 μs	(8 × N1) + (0.23 × (N2 + (N3 ÷ 16))) + 30 μs
Q02UCPU	(13.2 × N1) + (0.22 × (N2 + (N3 ÷ 16))) + 210 μs	(8 × N1) + (0.22 × (N2 + (N3 ÷ 16))) + 30 μs
Q03UDCPU, Q03UDECPU	(8 × N1) + (0.22 × (N2 + (N3 ÷ 16))) + 80 μs	(8 × N1) + (0.22 × (N2 + (N3 ÷ 16))) + 20 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	(8 × N1) + (0.10 × (N2 + (N3 ÷ 16))) + 80 μs	(8 × N1) + (0.10 × (N2 + (N3 ÷ 16))) + 20 μs

Table10.7 When a local device file in a SRAM card is used

CPU module	Additional time to the pre-start overhead time for interrupt programs (Table 10.3)	Additional time to the program-end overhead time for interrupt programs (Table 10.4)
Q02UCPU	(16 × N1) + (0.43 × (N2 + (N3 ÷ 16))) + 260 μs	(16 × N1) + (0.43 × (N2 + (N3 ÷ 16))) + 60 μs
Q03UDCPU, Q03UDECPU	(12 × N1) + (0.43 × (N2 + (N3 ÷ 16))) + 100 μs	(12 × N1) + (0.43 × (N2 + (N3 ÷ 16))) + 20 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	(12 × N1) + (0.40 × (N2 + (N3 ÷ 16))) + 100 μs	(12 × N1) + (0.40 × (N2 + (N3 ÷ 16))) + 20 μs

(4) Module refresh time

Module refresh time is the total time required for the CPU module to refresh data with CC-Link IE controller network, MELSECNET/H, and CC-Link modules.

(a) Refresh via CC-Link IE controller network

This is the time required for refreshing data between link devices in a CC-Link IE controller network module and devices in the CPU module.

(b) Refresh via MELSECNET/H

This is the time required for refreshing data between link devices in a MELSECNET/H network module and devices in the CPU module.

(c) Auto refresh via CC-Link

This is the time required for refreshing data between a CC-Link system master/local module and CPU module.

Remark

For each refresh time, refer to the following.

☞ Reference manual of each network module

(d) Auto refresh with an intelligent function module

This is the time required for refreshing data between the buffer memory of an intelligent function module and devices in the CPU module.
Use intelligent function module utility package (GX Configurator) for auto refresh settings.

■ Calculation method

Use the following expression to calculate the auto refresh time with an intelligent function module.

(Refresh time) = KN1 + KN2 × (number of refresh points)

For KN1 and KN2, use the values given in Table10.8 and Table10.9.

Table10.8 When an intelligent function module is mounted on the main base unit

CPU module	KN1	KN2
Q00UJCPU, Q00UCPU, Q01UCPU	96.3 μs	6.7 μs
Q02UCPU	23 μs	6 μs
Q03UDCPU, Q03UDECPU	6 μs	5 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	4 μs	5 μs

Table10.9 When an intelligent function module is mounted on the extension base unit

CPU module	KN1	KN2
Q00UJCPU	79.7 μs	8.9 μs
Q00UCPU, Q01UCPU	79.7 μs	8.1 μs
Q02UCPU	45 μs	7.0 μs
Q03UDCPU, Q03UDECPU	7 μs	6.0 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	5 μs	6 μs

Example When the number of auto refresh points for the analog-digital converter module (Q64AD) is 4 points (when the module is mounted on the Q26UDHCPU main base unit)

0.029 (ms) = 0.005 + 0.006 × 4

(5) Function execution time in END processing

This is the time required for updating calender or clearing error in END processing.

(a) Calendar update processing time

When the clock data set request (SM210 changes from off to on) or the clock data read request (SM213 turns on) is issued, the processing time for changing or reading the clock data is required in END processing.

Table10.10 Calendar update processing time

CPU module	Processing time in END processing	
	When the clock data set request is issued	When the clock data read request is issued
Q00UJCPU, Q00UCPU, Q01UCPU	0.040ms	0.019ms
Q02UCPU	0.040ms	0.019ms
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.011ms	0.004ms

(b) Error clear processing time

Upon the rising edge (changes from off to on) of SM50 (Error reset), the processing time for clearing the continuation error stored in SD50 is required.

Table10.11 Error clear processing time

CPU module	Processing time in END processing	
	When the error is cleared (the one detected by the annunciator)	When the error is cleared
Q00UJCPU, Q00UCPU, Q01UCPU	0.185ms	0.185ms
Q02UCPU	0.180ms	0.175ms
Q03UDCPU, Q03UDECPU	0.068ms	0.062ms
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.065ms	0.062ms

(6) Device data latch processing time

When the latch range is set in the Device tab of the PLC parameter dialog box[*1 *2 *3], the processing time shown in Table10.12 is required.

Each N1, N2, and N3 in the table indicates the following:

- N1: Number of devices specified to be latched (Count the latch range (1) and the latch range (2) as different devices.)
- N2: Number of bit device points specified to be latched
- N3: Number of word device points specified to be latched

Table10.12 Processing time when the latch range is set

CPU module	Processing time
Q00UJCPU, Q00UCPU, Q01UCPU	(4.4 × N1) + (0.12 × (N2 ÷ 16 + N3)) μs
Q02UCPU	(4.0 × N1) + (0.12 × (N2 ÷ 16 + N3)) μs
Q03UDCPU, Q03UDECPU	(3.0 × N1) + (0.12 × (N2 ÷ 16 + N3)) μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	(3.0 × N1) + (0.05 × (N2 ÷ 16 + N3)) μs

*1: When setting the latch range of the timer (T), retentive timer (ST), and counter (C), one point for word device and two points for bit device are occupied per point.
*2: The case where the points are set for the latch relay (L) is included.
*3: The scan time will not increase if the latch range is set for the file register (R, ZR), extended data register (D), or extended link register (W).

Point

To shorten the scan time, minimize the number of latch points.
The number of latch points can be reduced by performing the following.

- Move data to be latched to the file register.
- Store device data that is updated less frequently to the standard ROM with the SP.DEVST instruction. (The device data stored in the standard ROM can be read with the S(P).DEVLD instruction.)

QCPU Programming Manual (Common Instructions)

(7) Service processing time

Service processing is the communication processing with GX Developer and external devices. When monitoring device data, reading programs, and setting monitor conditions in GX Developer, the processing time shown in Table10.13 or Table10.14 is required.

Table10.13 Processing time to monitor device data and read programs

CPU module	Processing time*1	
	Monitoring device data (Data register: 32 points)	Reading programs (10K step)
Q00UJCPU, Q00UCPU, Q01UCPU	1.60ms	3.70ms
Q02UCPU	1.00ms	1.55ms
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.35ms	0.95ms

*1: The time in the table is for the case where the service processing count is set to one.

Table10.14 Processing time to set monitor conditions

CPU module	Processing time	
	Specified step match	Specified device match
Q02UCPU	0.03ms	0.04ms
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.01ms	0.03ms

(8) Common processing time

The CPU module performs common processing by the system. The common processing time shown in Table10.15 is required.

Table10.15 Common processing time

CPU module	Processing time
Q00UJCPU, Q00UCPU, Q01UCPU	0.25ms
Q02UCPU	0.17ms
Q03UDCPU	0.12ms
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU	0.09ms
Q03UDECPU	0.21ms
Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.17ms

(9) Multiple CPU high speed transmission processing time

This is the processing time required for data transmission between the CPU modules when the multiple CPU high speed transmission function is used.

For the multiple CPU high speed transmission processing time, refer to the following.

☞ QCPU User's Manual (Multiple CPU System)

10.1.3 Factors that increase the scan time

When executing any of the functions or operations described in this section, add the given processing time to the time value calculated in Section 10.1.2.

(1) Sampling trace

When the sampling trace function (☞ Section 6.14) is executed, the processing time shown in Table10.16 is required.

Table10.16 Processing time (when 50 points of the internal relay (for bit device) and 50 points of the data register (for word device) are set as sampling trace data)

	CPU module	Processing time
Standard RAM	Q00UCPU, Q01UCPU	0.12ms
	Q02UCPU	0.09ms
	Q03UDCPU, Q03UDECPU	0.07ms
	Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.06ms
SRAM card	Q02UCPU	0.16ms
	Q03UDCPU, Q03UDECPU	0.08ms
	Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.06ms

(2) Use of local devices

When local devices are used, the processing time shown in Table10.17 is required.

Each n, N1, N2, and N3 in the table indicates the following:

- n: Number of programs using a local device*1
- N1: Number of devices that specified a local device
- N2: Number of word device points that specified a local device
- N3: Number of bit device points that specified a local device

Table10.17 Processing time (when local devices are used)

	CPU module	Processing time
Standard RAM	Q00UCPU, Q01UCPU	((12.5 × N1) + (0.24 × (N2 + (N3 ÷ 16))) + 170) × n μs
	Q02UCPU	((12 × N1) + (0.22 × (N2 + (N3 ÷ 16))) + 140) × n μs
	Q03UDCPU, Q03UDECPU	((8 × N1) + (0.22 × (N2 + (N3 ÷ 16))) + 50) × n μs
	Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	((8 × N1) + (0.10 × (N2 + (N3 ÷ 16))) + 50) × n μs
SRAM card	Q02UCPU	((16 × N1) + (0.43 × (N2 + (N3 ÷ 16))) + 160) × n μs
	Q03UDCPU, Q03UDECPU	((12 × N1) + (0.43 × (N2 + (N3 ÷ 16))) + 60) × n μs
	Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	((12 × N1) + (0.40 × (N2 + (N3 ÷ 16))) + 60) × n μs

*1: If the serial number (first five digits) of the Universal model QCPU is "10011" or earlier, "n" indicates the number of executed programs.

(a) When local devices in a subroutine program are enabled

When SM776 (Enable/disable local device at CALL) is turned on, the processing time shown in Table10.18 or Table10.19 is required for each subroutine call.

Each n, N1, N2, and N3 in the table indicates the following:

- n: Number of local device points (unit: K words)
- N1: Number of devices that specified a local device
- N2: Number of word device points that specified a local device
- N3: Number of bit device points that specified a local device

Table10.18 Processing time (when a local device file in the standard RAM is used)

CPU module	Processing time when a subroutine program in the same file is called	Processing time when a subroutine program in a different file is called
Q00UCPU, Q01UCPU	0.00 μs	(24 × N1) + (0.73 × (N2 + (N3 ÷ 16))) + 280 μs
Q02UCPU	0.00 μs	(24 × N1) + (0.44 × (N2 + (N3 ÷ 16))) + 280 μs
Q03UDCPU, Q03UDECPU	0.00 μs	(16 × N1) + (0.44 × (N2 + (N3 ÷ 6))) + 100 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.00 μs	(16 × N1) + (0.20 × (N2 + (N3 ÷ 16))) + 100 μs

Table10.19 Processing time (when a local device file in a SRAM card is used)

CPU module	Processing time when a subroutine program in the same file is called	Processing time when a subroutine program in a different file is called
Q02UCPU	0.00 μs	(32 × N1) + (0.86 × (N2 + (N3 ÷ 16))) + 320 μs
Q03UDCPU, Q03UDECPU	0.00 μs	(24 × N1) + (0.86 × (N2 + (N3 ÷ 16))) + 120 μs
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.00 μs	(24 × N1) + (0.80 × (N2 + (N3 ÷ 16))) + 120 μs

(3) Execution of multiple programs

When multiple programs are executed, the processing time shown in Table10.20 is required for each program.

Table10.20 Processing time for each program (when multiple programs are executed)

CPU module	Processing time
Q00UJCPU, Q00UCPU, Q01UCPU	0.053 × n[*1] ms
Q02UCPU	0.04 × n[*1] ms
Q03UDCPU, Q03UDECPU	0.02 × n[*1] ms
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.02 × n[*1] ms

*1: "n" indicates the number of program files.

(4) Removal and insertion of a memory card

When a memory card is removed or inserted, the processing time shown inTable10.21 is required only for one scan where a memory card is removed or inserted.

Table10.21 Processing time (when a memory card is removed or inserted)

CPU module	Processing time	
	When a memory card is inserted	When a memory card is removed
Q02UCPU	0.7ms	0.2ms
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.6ms	0.1ms

(5) Use of the file register

When “Use the same file name as the program.” is selected in the PLC file tab of the PLC parameter dialog box, the processing time shown in Table10.22 is required.

When “Use the following file.” is selected, the scan time will not be increased.

Table10.22 Processing time (when the file register is used)

	CPU module	Processing time
Standard RAM	Q00UCPU, Q01UCPU	0.135ms
	Q02UCPU	0.082ms
	Q03UDCPU, Q03UDECPU	0.043ms
	Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.041ms
SRAM card	Q02UCPU	0.11 × n[*1] ms
	Q03UDCPU, Q03UDECPU	0.06 × n[*1] ms
	Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	0.06 × n[*1] ms

*1: "n" indicates the number of program files.

(6) Online change

When data is written to the running CPU module, the processing time described below is required.

(a) Online change (ladder mode)

When a program in the running CPU module is changed in ladder mode, the processing time shown in Table10.23 is required.*1

*1: The time in the table is for the case where the service processing count is set to one.

Table10.23 Proceccing time (online change (ladder mode))

CPU module	Processing time	
	The reserved area for online change is not changed.	The reserved area for online change is re-set.
Q00UJCPU, Q00UCPU, Q01UCPU	Up to 2.1ms	Up to 2.1ms
Q02UCPU	Up to 1.3ms	Up to 1.3ms
Q03UDCPU, Q03UDECPU	Up to 1.0ms	Up to 1.0ms
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	Up to 0.7ms	Up to 0.7ms

(b) Online change (files)

When a file is written to the running CPU module, the processing time shown in Table10.24 is required. *1

*1: The time in the table is for the case where the service processing count is set to one.

Table10.24 Processing time (online change (files))

CPU module	Processing time	
	Scan time = 2ms	Scan time = 20ms
Q00UJCPU	Up to 4.00ms	Up to 6.20ms
Q00UCPU	Up to 3.50ms	Up to 5.80ms
Q01UCPU	Up to 3.50ms	Up to 5.60ms
Q02UCPU	Up to 4.80ms	Up to 4.80ms
Q03UDCPU, Q03UDECPU	Up to 3.75ms	Up to 3.75ms
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	Up to 3.70ms	Up to 3.70ms

(7) Non-group output status read

In multiple CPU systems, the scan time increases when “All CPUs can read all outputs” is selected in the Multiple CPU settings screen of the PLC parameter dialog box.

The scan time increases when this parameter is set.




Figure 10.3 Multiple CPU settings screen

(8) Scan time measurement

When the scan time is measured by GX Developer, the processing time shown in Table10.25 is required (☞ Section 6.13.3)

Table10.25 Processing time (when the scan time is measured)

CPU module	Processing time
Q00UJCPU, Q00UCPU, Q01UCPU	179.5 + 5.8 × number of branch instructions μs*1
Q02UCPU	40.0 + 3.0 × number of branch instructions μs*1
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	40.0 + 1.5 × number of branch instructions μs*1

*1: The number of the branch instructions is a total of the following instructions, which are executed during the scan time measurement.

- Pointer branch instruction : CJ, SCJ, JMP
- Subroutine program call instruction: CALL(P), FCALL(P), ECALL(P), EFCALL(P), XCALL(P), RET

(9) Batch transfer of data to the program memory

When data in the program cache memory is batch-transferred to the program memory by GX Developer, the processing time shown in Table10.26 is required.*1

*1: The time in the table is for the case where the service processing count is set to one.

Table10.26 Processing time (when data is batch-transferred to the program memory)

CPU module	Processing time	
	Scan time = 2ms	Scan time = 20ms
Q00UJCPU, Q00UCPU, Q01UCPU	1.90ms	4.90ms
Q02UCPU	1.55ms	4.50ms
Q03UDCPU, Q03UDECPU	1.10ms	3.65ms
Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	1.05ms	3.65ms

(10) Diagnostics of the redundant power supply system

When the "Diagnose redundant power supply system." is selected on the PLC RAS tab of the PLC parameter dialog box, the processing time shown in Table10.27 is required.

Table10.27 Processing time (when the diagnostics for the redundant power supply system is enabled)

CPU module	Processing time	
	With a power supply module failure*1	Without a power supply module failure*1
Q00UCPU	125 μs	165 μs
Q01UCPU	125 μs	135 μs
Q02UCPU	90 μs	90 μs
Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q10UDHCPU, Q13UDHCPU, Q20UDHCPU, Q26UDHCPU, Q03UDECPU, Q04UDEHCPU, Q06UDEHCPU, Q10UDEHCPU, Q13UDEHCPU, Q20UDEHCPU, Q26UDEHCPU	43 μs	52 μs

*1: A power supply module failure indicates any of the following.

- The redundant power supply module has failed.
- Power for the redundant power supply module is turned off.
- The redundant power supply module is not mounted.

CHAPTER11 PROCEDURES FOR WRITING PROGRAM TO CPU MODULE

This chapter describes procedures for writing a program created by GX Developer to the CPU module.

Remark

For procedures for starting the CPU module, refer to the following.
☞ QCPU User's Manual (Hardware Design, Maintenance and Inspection)

11.1 Items to be Considered for Creating Programs

To create a program, the number of device points, size, and file name of the program must be predetermined.

(1) Program size

Check whether the total size of programs and parameters are within the program size executable in the CPU module used. (☞ Section 5.3.3)
Table11.1 provides the program size executable in each CPU module.

Table11.1 Program size

CPU module	Program size
Q00UJCPU, Q00UCPU	10K steps (40K bytes)
Q01UCPU	15K steps (60K bytes)
Q02UCPU	20K steps (80K bytes)
Q03UDCPU, Q03UDECPU	30K steps (120K bytes)
Q04UDHCPU, Q04UDEHCPU	40K steps (160K bytes)
Q06UDHCPU, Q06UDEHCPU	60K steps (240K bytes)
Q10UDHCPU, Q10UDEHCPU	100K steps (400K bytes)
Q13UDHCPU, Q13UDEHCPU	130K steps (520K bytes)
Q20UDHCPU, Q20UDEHCPU	200K steps (800K bytes)
Q26UDHCPU, Q26UDEHCPU	260K steps (1040K bytes)

Whether parameters are stored to the program memory, standard ROM, or memory card can be set.
If the program size above is required for only programs, store the parameters in the standard ROM or memory card.

(2) Determining a unit for structuring the programs

When creating multiple programs, determine a unit (process/function) for structuring the programs.

(3) Setting the execution conditions for programs to be created

When executing multiple programs, set their execution conditions to each program. (☞ Section 2.3)
Without the setting, the programs cannot be executed.

(4) Setting the applications of devices and the number of device points

Consider the applications of devices and the number of device points used in the program.

(☞ CHAPTER 9)

(5) Setting the initial device value

Set data necessary as an initial value to the device memory and the buffer memory of the intelligent function module. (☞ Section 6.25)

(6) Setting boot operation

When storing a program to the memory card, execute the program after boot operation.


For boot operation, make the setting in the Boot file tab of the PLC parameter dialog box.

(☞ Section 5.1.8, Section 5.1.10)

11.2 Hardware Check

This section describes a procedure for checking hardware before writing a created program.

In the following procedure, ▭ indicates an operation on the CPU module side.






Figure 11.1 Hardware check flowchart


Remark

For installation and mounting procedures of the CPU module, refer to the following.
☞ QCPU User's Manual (Hardware Design, Maintenance and Inspection)

11.3 Procedure for Writing One Program

This section describes a procedure for writing a program to the program memory. (☞ Section 5.1.2) Follow the procedure below and then the procedure provided in Section 11.5 before storing the program in the memory card for boot operation.

In the following procedure, ▭ indicates an operation on the CPU module side.






Figure 11.2 Flowchart for writing one program

*1: When storing the file register and initial device value to the standard RAM or memory card (except the Flash card), format the memory used.

*2: Write each data in the memory as shown below:

- •Program:Program memory
- •Parameter:Memory set in the parameter-valid drive
- •Initial device value:Memory set in the PLC file tab of the PLC parameter dialog box

Point


When the Universal model QCPU No.1 is the control CPU in the MELSECNET/H system, the Universal model QCPU can communicate with the Universal model QCPU where MISSING PARA. has been detected via the MELSECNET/H (for the network number 1 only).


11.4 Procedure for Writing Multiple Programs


This section describes a procedure for writing multiple programs to the program memory. (☞ Section 5.1.2)

Follow the procedure below and then the procedure provided in Section 11.5 before storing the programs in the memory card for boot operation.

In the following procedure, ▭ indicates an operation on the CPU module side.




1)
Set local devices?
NO
YES
Set the local device range in the Device tab of the PLC parameter dialog box.
Section 9.14.1
Set a file name for the local devices in the PLC file tab of the PLC parameter dialog box.
Section 9.14.1
Use the common pointers?
NO
YES
Set the start pointer number in the PLC system tab of the PLC parameter dialog box.
Section 9.10
Set the names and execution conditions of programs to be executed in the Program tab of the PLC parameter dialog box.
Section 2.3
Connect the personal computer to which GX Developer is installed to the CPU module.
Set the RUN/STOP/RESET switch to STOP and power on the CPU module (the ERR. LED turns on).
Select [Online] → [Format PLC memory] in GX Developer and format the program memory.
*1
Select [Online] → [Write to PLC] → "Program memory/Device memory" for "Target memory" in GX Developer and write the parameters and created programs.
*2
Write to PLC screen
Power off the programmable controller and then on or reset the CPU module.
Set the RUN/STOP/RESET switch to RUN to change the CPU module in the RUN status.
3)



☞ QCPU User's Manual
(Hardware Design, Maintenance and Inspection)

Figure 11.3 Flowchart for writing multiple programs

*1: When storing the file register and initial device value to the standard RAM or memory card (except the Flash card), format the memory used.

*2: Write each data in the memory as shown below:

- •Program:Program memory
- •Parameter:Memory set in the parameter-valid drive
- •Initial device value:Memory set in the PLC file tab of the PLC parameter dialog box

Point

When the Universal model QCPU No.1 is the control CPU in the MELSECNET/H system, the Universal model QCPU can communicate with the Universal model QCPU where MISSING PARA. has been detected via the MELSECNET/H (for the network number 1 only).

11.5 Procedure for Boot Operation

This section describes a procedure for boot operation.

In the following procedure, ▭ indicates an operation on the CPU module side.




Figure 11.4 Flowchart for boot operation

CHAPTER12 SPECIAL RELAY LIST AND SPECIAL REGISTER LIST

12.1 SPECIAL RELAY LIST

Special relays, SM, are internal relays whose applications are fixed in the Programmable Controller.

For this reason, they cannot be used by sequence programs in the same way as the normal internal relays.

However, they can be turned ON or OFF as needed in order to control the CPU module.

The heading descriptions in the following special relay lists are shown in 3.1.

Table12.1 Explanation of special relay list

Item	Function of Item
Number	• Indicates special relay number
Name	• Indicates name of special relay
Meaning	• Indicates contents of special relay
Explanation	• Discusses contents of special relay in more detail
Set by (When set)	• Indicates whether the relay is set by the system or user, and, if it is set by the system, when setting is performed. <Set by> S : Set by system U : Set by user (sequence programs or test operations from GX Developer) S/U : Set by both system and user <When set> Indicated only for registers set by system Each END : Set during each END processing Initial : Set only during initial processing (when power supply is turned ON, or when going from STOP to RUN) Status change : Set only when there is a change in status Error : Set when error occurs Instruction execution : Set when instruction is executed Request : Set only when there is a user request (through SM, etc.) System switching : Set when system switching is executed.
Corresponding ACPU M9□□□	• Indicates the corresponding special relay (M9□□□) of the ACPU. (When the contents are changed, the special relay is represented M9□□□ format change. Incompatible with the Q00J/Q00/Q01 and QnPRH.) • New indicates the special relay newly added to the Q series CPU module.
Corresponding CPU	Indicates the corresponding CPU module type name. QCPU : Indicates all the Q series CPU modules. Q00J/Q00/Q01 : Indicates the Basic model QCPU. Qn(H) : Indicates the High Performance model QCPU. QnPH : Indicates the Process CPU. QnPRH : Indicates the Redundant CPU. QnU : Indicates the Universal model QCPU Each CPU module model name: Indicates the relevant specific CPU module. (Example: Q02U)

For details on the following items, refer to the following manuals:

- Networks → Manual of the corresponding network module
- SFC → QCPU(Q mode)/QnACPU Programming Manual (SFC)

Point

Do not change the values of special relays set by the system with user program or device test operations.
Doing so may result in system downtime or communication fault.

(1) Diagnostic Information

Table12.2 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM0	Diagnostic errors	OFF : No error ON : Error	• Turns ON if an error occurs as a result of diagnosis. (Includes when an annunciator is ON, and when an error is detected with CHK instruction) • Remains ON even if the condition is restored to normal thereafter.	S (Error)	New	Qn(H) QnPH QnPRH
			• Turns ON if an error occurs as a result of diagnosis. (Includes when an annunciator is ON) • Remains ON even if the condition is restored to normal thereafter.	S (Error)	New	Q00J/Q00/Q01 QnU
SM1	Self-diagnostic error	OFF : No self-diagnosis errors ON : Self-diagnosis	• Turns ON if an error occurs as a result of diagnosis. (Does not include when an annunciator is ON or when an error is detected by the CHK instruction) • Remains ON even if the condition is restored to normal thereafter.	S (Error)	M9008	Qn(H) QnPH QnPRH
			• Turns ON if an error occurs as a result of diagnosis. (Does not include when an annunciator is ON) • Remains ON even if the condition is restored to normal thereafter.	S (Error)	New	Q00J/Q00/Q01 QnU
SM5	Error common information	OFF : No error common information ON : Error common information	• When SM0 is ON, turns ON if there is error common information	S (Error)	New	QCPU
SM16	Error individual information	OFF : No error individual information ON : Error individual information	• When SM0 is ON, turns ON if there is error individual information	S (Error)	New	
SM50	Error reset	OFF → ON: Error reset	• Conducts error reset operation	U	New	
SM51	Battery low latch	OFF : Normal ON : Battery low	• Turns ON if battery voltage at CPU module or memory card drops below rated value. • Remains ON even if the battery voltage returns to normal thereafter. • Synchronizes with the BAT. LED.	S (Error)	M9007	Qn(H) QnPH QnPRH QnU
			• Turns ON if battery voltage at CPU module drops below rated value. • Remains ON even if the battery voltage returns to normal thereafter. • Synchronous with ERR. LED	S (Error)	New	Q00J/Q00/Q01
SM52	Battery low	OFF : Normal ON : Battery low	• Same as SM51, but turns OFF subsequently when battery voltage returns to normal.	S (Error)	M9006	QCPU
SM53	AC/DC DOWN detection	OFF : AC/DC DOWN not detected ON : AC/DC DOWN detected	• Turns ON if an instantaneous power failure of within 20ms occurs during use of the AC power supply module. Reset when the power supply is switched OFF, then ON.	S (Error)	M9005	
			• Turns ON if an instantaneous power failure of within 10ms occurs during use of the DC power supply module. Reset when the power supply is switched OFF, then ON.			

Table12.2 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM56	Operation error	OFF : Normal ON : Operation error	• ON when operation error is generated • Remains ON if the condition is restored to normal thereafter.	S (Error)	M9011	QCPU
SM60	Blown fuse detection	OFF : Normal ON : Module with blown fuse	• Turns ON if there is at least one output module whose fuse has blown. • Remains ON if the condition is restored to normal thereafter. • Blown fuse status is checked even for remote I/O station output modules.	S (Error)	M9000	
SM61	I/O module verify error	OFF : Normal ON : Error	• Turns ON if the I/O module differs from the status registered at power on. • Remains ON if the condition is restored to normal thereafter. • I/O module verification is also conducted for remote I/O station modules.	S (Error)	M9002	
SM62	Annunciator detection	OFF : Not detected ON : Detected	• Goes ON if even one annunciator (F) goes ON.	S (Instruction execution)	M9009	
SM80	CHK detection	OFF : Not detected ON : Detected	• Goes ON if error is detected by CHK instruction. • Remains ON if the condition is restored to normal thereafter.	S (Instruction execution)	New	Qn(H) QnPH QnPRH
SM90	Startup of monitoring timer for step transition (Enabled only when SFC program exists)	OFF : Not started(monitoring timer reset) ON : Started(monitoring timer started)	Corresponds to SD90	U	M9108	Qn(H) QnPH QnPRH
SM91			Corresponds to SD91		M9109	
SM92			Corresponds to SD92		M9110	
SM93			Corresponds to SD93		M9111	
SM94			Corresponds to SD94		M9112	
SM95			Corresponds to SD95		M9113	
SM96			Corresponds to SD96		M9114	
SM97			Corresponds to SD97		New	
SM98			Corresponds to SD98		New	
SM99			Corresponds to SD99		New	
			• Goes ON when measurement of step transition monitoring timer is commenced. • Resets step transition monitoring timer when it goes OFF.			
SM100	Serial communication function using flag	OFF : Serial communication function is not used. ON : Serial communication function is used.	• Stores the setting of whether the serial communication function is used or not in the serial communication setting parameter	S (Power-ON or reset)	New	Q00/Q01 Q00UJ Q00U Q01U Q02U*7
SM101	Communication protocol status flag	OFF : GX Developer ON : MC protocol communication device	• Stores whether the device that is communicating via the RS-232 interface is GX Developer or MC protocol communication device	S (RS232 communication)		
SM110	Protocol error	OFF : Normal ON : Abnormal	• Turns ON when an abnormal protocol was used to make communication in the serial communication function. • Remains ON if the condition is restored to normal thereafter	S (Error)		
SM111	Communication status	OFF : Normal ON : Abnormal	• Turns ON when the mode used to make communication was different from the setting in the serial communication function. • Remains ON if the condition is restored to normal thereafter.	S (Error)		
SM112	Error information clear	ON : Cleared	• Turns ON when the error codes stored in SM110, SM111, SD110 and SD111 are cleared. (Activated when turned from OFF to ON)	U		
SM113	Overrun error	OFF : Normal ON : Abnormal	• Turns ON when an overrun error occurred in the serial communication error.	S (Error)		
SM114	Parity error	OFF : Normal ON : Abnormal	• Turns ON when a parity error occurred in the serial communication error.	S (Error)		
SM115	Framing error	OFF : Normal ON : Abnormal	• Turns ON when a framing error occurred in the serial communication error.	S (Error)		
SM165	Program memory batch transfer execution status	OFF : Completed ON : Not being executed or Not completed	• Turns ON when the data is written to the program cache memory. • Turns OFF when the program memory batch transfer is completed. • Remains ON if the program memory batch transfer is not executed after the data is written to the program cache memory.	S (When status changed)	New	QnU*6

*6: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10012" or later.
- Q13UDHCPU, Q26UDHCPU

*7: The module whose first 5 digits of serial No. is "10102" or later.

(2) System information

Table12.3 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM202	LED OFF command	OFF → ON : LED OFF	• When this relay goes from OFF to ON, the LEDs corresponding to the individual bits at SD202 go off	U	New	Qn(H) QnPH QnPRH QnU
SM203	STOP contact	STOP status	• Goes ON at STOP status	S (Status change)	M9042	QCPU
SM204	PAUSE contact	PAUSE status	• Goes ON at PAUSE status	S (Status change)	M9041	
SM206	PAUSE enable coil	OFF : PAUSE disabled ON : PAUSE enabled	• PAUSE status is entered if this relay is ON when the PAUSE contact goes ON	U	M9040	
SM210	Clock data set request	OFF : Ignored ON : Set request	• When this relay goes from OFF to ON and after END instruction execution of subsequent scan, clock data stored in SD210 to SD213 are written to the CPU module.	U	M9025	
SM211	Clock data error	OFF : No error ON : Error	• ON when error is generated in clock data (SD210 to SD213) value, and OFF if no error is detected.	S (Request)	M9026	
SM213	Clock data read request	OFF : Ignored ON : Read request	• When this relay is ON, clock data is read to SD210 to SD213 as BCD values.	U	M9028	
SM220	CPU No.1 preparation completed	OFF : CPU No.1 preparation uncompleted ON : CPU No.1 preparation completed	Turned ON when access can be made to the CPU module No.1 from the other CPU module at power-on or reset operation. SM220 is used as interlock for accessing the CPU module No.1 when the multiple CPU synchronous setting is asynchronous.	S (When status changed)	New	QnU
SM221	CPU No.2 preparation completed	OFF : CPU No.2 preparation uncompleted ON : CPU No.2 preparation completed	Turned ON when access can be made to the CPU module No.2 from the other CPU module at power-on or reset operation. SM221 is used as interlock for accessing the CPU module No.2 when the multiple CPU synchronous setting is asynchronous.			QnU*8
SM222	CPU No.3 preparation completed	OFF : CPU No.3 preparation uncompleted ON : CPU No.3 preparation completed	Turned ON when access can be made to the CPU module No.3 from the other CPU module at power-on or reset operation. SM222 is used as interlock for accessing the CPU module No.3 when the multiple CPU synchronous setting is asynchronous.			
SM223	CPU No.4 preparation completed	OFF : CPU No.4 preparation uncompleted ON : CPU No.4 preparation completed	Turned ON when access can be made to the CPU module No.4 from the other CPU module at power-on or reset operation. SM223 is used as interlock for accessing the CPU module No.4 when the multiple CPU synchronous setting is asynchronous.			QnU*5
SM235	Online module change flag	OFF : Online module change is not in progress ON : Online module change in progress	• Turns on during online module change. (for host CPU)	S (During online module change)	New	QnPH
SM236	Online module change complete flag	OFF : Online module change incomplete ON : Online module change complete	• Turns ON for one scan after online module change is complete. • This contact point can only be used by the scan program. (for host CPU)	S (When online module change is complete)	New	
SM237	Device range check inhibit flag	OFF : Device range checked ON : Device range not checked	• Selects whether to check a device range during execution of the BMOV, FMOV or DFMOV instruction (only when the conditions for subset processing are established).	U	New	QnU*6

*5: The Universal model QCPU except the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU.
*6: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10012" or later.
- Q13UDHCPU, Q26UDHCPU

*8: The Universal model QCPU except the Q00UJCPU.

Table12.3 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM240	No. 1 CPU reset flag	OFF : No. 1 CPU reset cancel ON : No. 1 CPU resetting	• Goes OFF when reset of the No. 1 CPU is canceled. • Comes ON when the No. 1 CPU is resetting (including the case where the CPU module is removed from the base). The other CPUs are also put in reset status.	S (Status change)	New	Q00/Q01*1 Qn(H)*1 QnPH QnU*8
SM241	No. 2 CPU reset flag	OFF : No. 2 CPU reset cancel ON : No. 2 CPU resetting	• Goes OFF when reset of the No. 2 CPU is canceled. • Comes ON when the No. 2 CPU is resetting (including the case where the CPU module is removed from the base). The other CPUs result in "MULTI CPU DOWN" (error code: 7000).			
SM242	No. 3 CPU reset flag	OFF : No. 3 CPU reset cancel ON : No. 3 CPU resetting	• Goes OFF when reset of the No. 3 CPU is canceled. • Comes ON when the No. 3 CPU is resetting (including the case where the CPU module is removed from the base). The other CPUs result in "MULTI CPU DOWN" (error code: 7000).			
SM243	No. 4 CPU reset flag	OFF : No. 4 CPU reset cancel ON : No. 4 CPU resetting	• Goes OFF when reset of the No. 4 CPU is canceled. • Comes ON when the No. 4 CPU is resetting (including the case where the CPU module is removed from the base). The other CPUs result in "MULTI CPU DOWN" (error code: 7000).			Qn(H)*1 QnPH QnU*5
SM244	No. 1 CPU error flag	OFF : No. 1 CPU normal ON : No. 1 CPU during stop error	• Goes OFF when the No. 1 CPU is normal (including a continuation error). • Comes ON when the No. 1 CPU is during a stop error.			Q00/Q01*1 Qn(H)*1 QnPH QnU*8
SM245	No. 2 CPU error flag	OFF : No. 2 CPU normal ON : No. 2 CPU during stop error	• Goes OFF when the No. 2 CPU is normal (including a continuation error). • Comes ON when the No. 2 CPU is during a stop error.			
SM246	No. 3 CPU error flag	OFF : No. 3 CPU normal ON : No. 3 CPU during stop error	• Goes OFF when the No. 3 CPU is normal (including a continuation error). • Comes ON when the No. 3 CPU is during a stop error.			
SM247	No. 4 CPU error flag	OFF : No. 4 CPU normal ON : No. 4 CPU during stop error	• Goes OFF when the No. 4 CPU is normal (including a continuation error). • Comes ON when the No. 4 CPU is during a stop error	S (Status change)	New	Qn(H)*1 QnPH QnU*5
SM250	Max. loaded I/O read	OFF : Ignored ON : Read	• When this relay goes from OFF to ON, maximum loaded I/O number is read to SD250.	U	New	Qn(H) QnPH QnPRH
SM254	All stations refresh command	OFF : Refresh arrival station ON : Refresh all stations	• Effective for the batch refresh (also effective for the low speed cyclic) • Designate whether to receive arrival stations only or to receive all slave stations in the MELSECNET/H.	U	New	
			• Designate whether to receive arrival stations only or to receive all slave stations in the CC-Link IE controller network .			Qn(H)*2 QnPH*6 QnPRH*6
			• Effective for the batch refresh (also effective for the low speed cyclic) • Specify whether to receive only arrival station or all stations in the MELSECNET/H or CC-Link IE controller network.			QnU

*1: This applies to the CPU of function version B or later.
*2: The module whose first 5 digits of serial No. is "09012" or later.
*5: The Universal model QCPU except the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU.
*6: The module whose first 5 digits of serial No. is "10042" or later.
*8: The Universal model QCPU except the Q00UJCPU.

Table12.3 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM255	MELSECNET/10, MELSECNET/H module 1 information	OFF : Operative network ON : Standby network	• Goes ON for standby network(If no designation has been made concerning active or standby, active is assumed.)	S (Initial)	New	Qn(H) QnPH QnPRH
SM256		OFF : Reads ON : Does not read	• For refresh from link to CPU module (B, W, etc.) indicate whether to read from the link module.	U	New	
SM257		OFF : Writes ON : Does not write	• For refresh from CPU module to link (B, W, etc.), designate whether to write to the link module.	U	New	
SM260	MELSECNET/10, MELSECNET/H module 2 information	OFF : Operative network ON : Standby network	• Goes ON for standby network (If no designation has been made concerning active or standby, active is assumed.)	S (Initial)	New	
SM261		OFF : Reads ON : Does not read	• For refresh from link to CPU module (B, W, etc.) indicate whether to read from the link module.	U	New	
SM262		OFF : Writes ON : Does not write	• For refresh from CPU module to link (B, W, etc.), designate whether to write to the link module.	U	New	
SM265	MELSECNET/10, MELSECNET/H module 3 information	OFF : Operative network ON : Standby network	• Goes ON for standby network (If no designation has been made concerning active or standby, active is assumed.)	S (Initial)	New	
SM266		OFF : Reads ON : Does not read	• For refresh from link to CPU module (B, W, etc.) indicate whether to read from the link module.	U	New	
SM267		OFF : Writes ON : Does not write	• For refresh from CPU module to link (B, W, etc.), designate whether to write to the link module.	U	New	
SM270	MELSECNET/10, MELSECNET/H module 4 information	OFF : Operative network ON : Standby network	• Goes ON for standby network (If no designation has been made concerning active or standby, active is assumed.)	S (Initial)	New	
SM271		OFF : Reads ON : Does not read	• For refresh from link to CPU module (B, W, etc.) indicate whether to read from the link module.	U	New	
SM272		OFF : Writes ON : Does not write	• For refresh from CPU module to link (B, W, etc.), designate whether to write to the link module.	U	New	
SM280	CC-Link error	OFF : Normal ON : Error	• Goes ON when a CC-Link error is detected in any of the installed CC-Link module. Goes OFF when normal operation is restored.	S (Status change)	New	
SM315	Communication reserved time delay enable/disable flag	OFF : Without delay ON : With delay	• This flag is enabled when the time reserved for communication processing is set in SD315. • Turns ON to delay the END processing by the time set in SD315 in order to perform communication processing. (The scan time increases by the period set in SD315.) • Turns OFF to perform the END processing without a delay of the time set in SD315 when there is no communication processing. (Defaults to OFF)	U	New	Q00J/Q00/Q01
SM320	Presence/absence of SFC program	OFF : SFC program absent ON : SFC program present	• Turns ON when an SFC program is registered. • OFF when an SFC program is not registered.	S (Initial)	M9100	Q00J/Q00/Q01*1 Qn(H) QnPH QnPRH QnU
SM321	Start/stop SFC program	OFF : SFC program not executed (stop) ON : SFC program executed (start)	• Initial value is set at the same value as SM320. (Goes ON automatically if SFC program is present.) • Turn this relay from ON to OFF to stop program execution. • Turn this relay from OFF to ON to resume program execution.	S (Initial)/U	M9101form at change	

*1: This applies to the CPU of function version B or later.

Table12.3 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM322	SFC program start status	OFF : Initial start ON : Resume start	• The SFC program starting mode in the SFC setting of the PLC parameter dialog box is set as the initial value. AT initial start: OFF At continued start: ON	S (Initial)/U	M9102form at change	Q00J/Q00/Q01*1 Qn(H) QnPH QnPRH QnU
SM323	Presence/absence of continuous transition for entire block	OFF : Continuous transition not effective ON : Continuous transition effective	Set the presence/absence of continuous transition for the block where "Continuous transition bit" of the SFC data device has not been set.	U	M9103	
SM324	Continuous transition prevention flag	OFF : When transition is executed ON : When no transition	• OFF during operation in the continuous transition mode or during continuous transition, and ON when continuous transition is not executed. • Always ON during operation in the no continuous transition mode.	S (Instruction execution)	M9104	
				S (Status change)	New	
SM325	Output mode at block stop	OFF : OFF ON : Preserves	Select whether the coil outputs of the active steps are held or not at the time of a block stop. • As the initial value, the output mode at a block stop in the parameter is OFF when the coil outputs are OFF, and ON when the coil outputs are held. • All coil outputs go OFF when this relay is OFF. • Coil outputs are preserved when this relay is ON.	S (Initial)/U	M9196	
SM326	SFC device clear mode	OFF : Clear device ON : Preserves device	Selects the device status when the stopped CPU is run after the sequence program or SFC program has been modified when the SFC program exists.	U	New	
SM327	Output during end step execution	OFF : Hold step output turned OFF (cleared) ON : Hold step output held	Select the device status at the time of switching from STOP to program write to RUN.(All devices except the step relay)	S (Initial)/U	New	Qn(H) QnPH QnPRH QnU
				U		Q00J/Q00/Q01*1
SM328	Clear processing mode when end step is reached	OFF : Clear processing is performed. ON : Clear processing is not performed.	Select whether clear processing will be performed or not if active steps other than the ones being held exist in the block when the end step is reached.? • When this relay turns OFF, all active steps are forcibly terminated to terminate the block. • When this relay is ON, the execution of the block is continued as-is. • If active steps other than the ones being held do not exist when the end step is reached, the steps being held are terminated to terminate the block.	U	New	Q00J/Q00/Q01*1 QnU
SM330	Operation mode for low speed execution type program	OFF : Asynchronous mode ON : Synchronous mode	Select whether the low speed execution type program will be executed in the asynchronous mode or in the synchronous mode. • Asynchronous mode (this relay is turned OFF.) Mode in which the operation of the low speed execution type program is performed continuously within the excess time. • Synchronous mode (this relay is turned ON.) Mode in which the operation of the low speed execution type program is not performed continuously and operation is performed from the next scan if there is excess time.	U	New	Qn(H) QnPH
SM331	Normal SFC program execution status	OFF : Not executed ON : Being executed	• Indicates whether the normal SFC program is being executed or not. • Used as an SFC control instruction execution interlock.	S (Status change)	New	Qn(H)*3 QnPH*4 QnPRH
SM332	Program execution management SFC program execution status	OFF : Not executed ON : Being executed	• Indicates whether the program execution management SFC program is being executed or not. • Used as an SFC control instruction execution interlock.			
SM390	Access execution flag	ON indicates completion of intelligent function module access	• The status of the intelligent function module access instruction executed immediately before is stored. (This data is overwritten when the intelligent function module access instruction is executed again.) • Used by the user in a program as a completion bit.	S (Status change)	New	Qn(H) QnPH QnPRH
SM391	GINT instruction execution completion flag	OFF : Not executed ON : Execution completed	Indicates execution status of the S(P).GINT instruction. • Turned OFF before the instruction is executed. • Turned ON after the instruction is completed.	S (Instruction execution)	New	QnU




*1: This applies to the CPU of function version B or later.
*3: The module whose first 5 digits of serial No. is "04122" or later.
*4: The module whose first 5 digits of serial No. is "07032" or later.

(3) System clocks/counters

Table12.4 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM400	Always ON	ON OFF	• Normally is ON	S (Every END processing)	M9036	QCPU
SM401	Always OFF	ON OFF	• Normally is OFF	S (Every END processing)	M9037	
SM402	After RUN, ON for 1 scan only	ON OFF 1 scan	• After RUN, ON for 1 scan only. • This connection can be used for scan execution type programs only. • When an initial execution type program is used, this relay turns OFF at the END processing of the scan execution type program in the first scan after RUN. ON OFF Initial execution type program / 1 scan of scan execution type program	S (Every END processing)	M9038	Qn(H) QnPH QnPRH QnU
			• After RUN, ON for 1 scan only.	S (Every END processing)	New	Q00J/Q00/Q01
SM403	After RUN, OFF for 1 scan only	ON OFF 1 scan	• After RUN, OFF for 1 scan only. • This connection can be used for scan execution type programs only. • When an initial execution type program is used, this relay turns OFF at the END processing of the scan execution type program in the first scan after RUN. ON OFF Initial execution type program / 1 scan of scan execution type program	S (Every END processing)	M9039	Qn(H) QnPH QnPRH QnU
			• After RUN, OFF for 1 scan only.	S (Every END processing)	New	Q00J/Q00/Q01
SM404	Low speed execution type programON for 1 scan only after RUN	ON OFF 1 scan	• After RUN, ON for 1 scan only. • This connection can be used for low speed execution type programs only.	S (Every END processing)	New	Qn(H) QnPH
SM405	Low speed execution type programAfter RUN, OFF for 1 scan only	ON OFF 1 scan	• After RUN, OFF for 1 scan only. • This connection can be used for low speed execution type programs only.	S (Every END processing)	New	
SM409	0.01 second clock	0.005s 0.005s	• Repeatedly changes between ON and OFF at 5-ms interval. • When Programmable Controller power supply is turned ON or a CPU module reset is performed, goes from OFF to start. (Note that the ON-OFF status changes when the designated time has elapsed during the execution of the program.)	S (Status change)	New	Qn(H) QnPH QnPRH QnU
SM410	0.1 second clock	0.05s 0.05s	• Repeatedly changes between ON and OFF at each designated time interval. • When Programmable Controller power supply is turned ON or a CPU module reset is performed, goes from OFF to start. (Note that the ON-OFF status changes when the designated time has elapsed during the execution of the program.)	S (Status change)	M9030	QCPU
SM411	0.2 second clock	0.1s 0.1s			M9031	
SM412	1 second clock	0.5s 0.5s			M9032	
SM413	2 second clock	1s 1s			M9033	
SM414	2n second clock	ns ns	• This relay alternates between ON and OFF at intervals of the time (unit: s) specified in SD414. • When Programmable Controller power supply is turned ON or a CPU module reset is performed, goes from OFF to start. (Note that the ON-OFF status changes when the designated time has elapsed during the execution of the program.)	S (Status change)	M9034form at change	

Table12.4 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU M9□□□	Corresponding CPU
SM415	2n (ms) clock		• This relay alternates between ON and OFF at intervals of the time (unit: ms) specified in SD415. • When Programmable Controller power supply is turned ON or a CPU module reset is performed, goes from OFF to start. (Note that the ON-OFF status changes when the designated time has elapsed during the execution of the program.)	S (Status change)	New	Qn(H) QnPH QnPRH QnU
SM420	User timing clock No.0		• Relay repeats ON/OFF switching at fixed scan intervals. • When Programmable Controller power supply is turned ON or a CPU module reset is performed, goes from OFF to start. (For the redundant CPU, however, this relay is always OFF after system switching.) • The ON/OFF intervals are set with the DUTY instruction  n1: ON scan interval n2: OFF scan interval	S (Every END processing)	M9020	QCPU
SM421	User timing clock No.1				M9021	
SM422	User timing clock No.2				M9022	
SM423	User timing clock No.3				M9023	
SM424	User timing clock No.4				M9024	
SM430	User timing clock No.5		• For use with SM420 to SM424 low speed programs	S (Every END processing)	New	Qn(H) QnPH
SM431	User timing clock No.6					
SM432	User timing clock No.7					
SM433	User timing clock No.8					
SM434	User timing clock No.9					

(4) Scan information

Table12.5 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU M9□□□	Corresponding CPU
SM510	Low speed program execution flag	OFF : Completed or not executed ON : Execution under way.	• Goes ON when low speed execution type program is executed.	S (Every END processing)	New	Qn(H) QnPH
SM551	Reads module service interval	OFF : Ignored ON : Read	• When this relay goes from OFF to ON, the module service interval designated by SD550 is read to SD551 to SD552.	U	New	Qn(H) QnPH QnPRH

(5) I/O refresh

Table12.6 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU M9□□□	Corresponding CPU
SM580	Program to program I/O refresh	OFF : Not refreshed ON : Refreshed	• When this special relay is turned ON, I/O refresh is performed after execution of the first program, and the next program is then executed. When a sequence program and an SFC program are to be executed, the sequence program is executed, I/O refresh is performed, and the SFC program is then executed.	U	New	Q00J/Q00/Q01*1

*1: This applies to the CPU of function version B or later.

(6) Memory cards

Table12.7 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM600	Memory card usable flags	OFF : Unusable ON : Use enabled	• ON when memory card is ready for use by user	S (Status change)	New	Qn(H) QnPH QnPRH QnU*1
SM601	Memory card protect flag	OFF : No protect ON : Protect	• Goes ON when memory card protect switch is ON	S (Status change)	New	
SM602	Drive 1 flag	OFF : No drive 1 ON : Drive 1 present	• Turns ON when the mounted memory card is RAM	S (Status change)	New	
SM603	Drive 2 flag	OFF : No drive 2 ON : Drive 2 present	• Turns ON when the mounted memory card is ROM	S (Status change)	New	
SM604	Memory card in-use flag	OFF : Not used ON : In use	• Goes ON when memory card is in use	S (Status change)	New	
SM605	Memory card remove/ insert prohibit flag	OFF : Remove/insert enabled ON : Remove/insert prohibited	• Goes ON when memory card cannot be inserted or removed	U	New	
SM609	Memory card remove/ insert enable flag	OFF : Remove/insert prohibited ON : Remove/insert enabled	• Turned ON by user to enable the removal/insertion of memory card. • Turned OFF by the system after the memory card is removed. • This contact can be used only when SM604 and SM605 are OFF.	S/U	New	
SM620	Drive 3/4 usable flags	OFF : Unusable ON : Use enabled	• Always ON	S (Initial)	New	QCPU
SM622	Drive 3 flag	OFF : No drive 3 ON : Drive 3 present	• Always ON	S (Initial)	New	Q00J/Q00/Q01 Qn(H) QnPH QnPRH QnU*2
SM623	Drive 4 flag	OFF : No drive 4 ON : Drive 4 present	• Always ON	S (Initial)	New	QCPU
SM624	Drive 3/4 in-use flag	OFF : Not used ON : In use	• Goes ON when the file within Drive 3 (standard RAM) or Drive 4 (standard ROM) is used.	S (Status change)	New	Qn(H) QnPH QnPRH QnU
SM640	File register use	OFF : File register not used ON : File register in use	• Goes ON when file register is in use	S (Status change)	New	Q00J/Q00/Q01 Qn(H) QnPH QnPRH QnU*2

*1: The Universal model QCPU except the Q00UJCPU, Q00UCPU, and Q01UCPU.
*2: The Universal model QCPU except the Q00UJCPU.

Table12.7 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM650	Comment use	OFF : File register not used ON : File register in use	• Goes ON when comment file is in use	S (Status change)	New	Qn(H) QnPH QnPRH QnU
SM660	Boot operation	OFF : Internal memory execution ON : Boot operation in progress	• Goes ON while boot operation is in process • Goes OFF if boot designation switch is OFF	S (Status change)	New	Qn(H) QnPH QnPRH
		OFF : Program memory execution ON : Boot operation in progress	• Goes ON while boot operation is in process	S (Status change)	New	Q00J/Q00/Q01 QnU*1
SM671	Latch data backup to standard ROM completion flag	OFF : Not completed ON : Completed	• Turned ON when latch data backup to the standard ROM is completed. • Time when the latch data backup to the standard ROM was performed is stored in SD672 or later.	S (Status change)	New	QnU
SM672	Memory card file register access range flag	OFF : Within access range ON : Outside access range	• Goes ON when access is made to area outside the range of file register of memory card(Set within END processing.) • Reset at user program	S/U	New	Qn(H) QnPH QnPRH
SM675	Error completion of latch data backup to standard ROM	OFF : No Error ON : Error	• Turned ON when data cannot be backuped to the standard ROM by the latch data backup normally. • Turned OFF when data is backuped to the standard ROM by the latch data backup normally.	S	New	QnU
SM676	Specification of restration repeated execution	OFF : Not specified ON : Specified	• If latch data backup is performed when SM676 is ON, restore the data every time turning ON from OFF the power supply from the next power-on. • Delete the backuped latch data, or restore the data every time turning ON from OFF the power supply until the latch data backup operation will be executed again.	U	New	
SM680	Program memory write error	OFF : Write error ON : Write not executed/ normal	• Turns ON if a write error is detected at writing to program memory (flash ROM). Turns OFF by the write direction.	S (At write)	New	
SM681	Program memory writing flag	OFF : During writing ON : Write not executed	• Turns ON when writing to the program memory (flash ROM) is in progress, and turns OFF when writing is completed.	S (At write)	New	
SM682	Program memory overwrite count error flag	OFF : Overwrite count is 100,000 or more ON : Overwrite count is less than 100,000	• Turns ON when the overwrite count of program memory (flash ROM) reaches 100,000.	S (At write)	New	
SM685	Standard ROM write error	OFF : Write error ON : Write not executed/ normal	• Turns ON when write error is detected at writing to standard ROM (flash ROM). • Turns OFF by the write direction.	S (At write)	New	
SM686	Standard ROM writing flag	OFF : During overwriting ON : Overwrite not executed	• Turns ON when writing to the standard ROM (flash ROM) is in progress, and turns OFF when writing is completed.	S (At write)	New	
SM687	Standard ROM overwrite count error flag	OFF : Overwrite count is 100,000 or more ON : Overwrite count is less than 100,000	• Turns ON when the overwrite count of standard ROM (flash ROM) reaches 100,000. (It is necessary to change CPU module.)	S (At write)	New	
SM691	Backup start preparation status flag	OFF : Backup start preparation not completed ON : Backup start preparation completed	Turns on when the backup start preparation is completed.	S (Status change)	New	QnU*3
SM692	Restoration complete flag	OFF : Restoration not completed ON : Restoration completed	Turns on when restoration of the backup data in the memory card is completed.	S (Status change)	New	

*1: The Universal model QCPU except the Q00UJCPU, Q00UCPU, and Q01UCPU.
*3: The modules whose serial number (first five digits) is "10102" or later are the relevant models. (Except the Q00UJCPU, Q00UCPU, and Q01UCPU)

(7) Instruction-Related Special Relays

Table12.8 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU M9□□□	Corresponding CPU
SM700	Carry flag	OFF : Carry OFF ON : Carry ON	• Carry flag used in application instruction	S (Instruction execution)	M9012	QCPU
SM701	Number of output characters selection	Switching the number of output characters and the output pattern	• Used for the PR, PRC, BINDA, DBINDA, BINHA, DBINHA, BCDDA, DBCDDA, or COMRD instruction	U	M9049	Qn(H) QnPH QnPRH QnU
SM702	Search method	OFF : Search next ON : 2-part search	• Designates method to be used by search instruction. • Data must be arranged for 2-part search.	U	New	QCPU
SM703	Sort order	OFF : Ascending order ON : Descending order	• The sort instruction is used to designate whether data should be sorted in ascending order or in descending order.	U	New	
SM704	Block comparison	OFF : Non-match found ON : All match	• Goes ON when all data conditions have been met for the BKCMP instruction.	S (Instruction execution)	New	
			• Goes ON when all data conditions have been met for the DBKCMP instruction.	S (Instruction execution)	New	QnU*2
SM709	DT/TM instruction improper data detection flag	OFF : Improper data not detected ON : Improper data detected	Turns on when the data to be compared by the DT or TM instruction is not recognized as date data or time data, or the device (3 words) to be compared exceeds the specified device range.	S (Instruction execution) or U	New	
SM710	CHK instruction priority ranking flag	OFF : Conditions priority ON : Pattern priority	• Remains as originally set when OFF. • CHK priorities updated when ON.	S (Instruction execution)	New	Qn(H) QnPH QnPRH
SM715	EI flag	OFF : During DI ON : During EI	• ON when EI instruction is being executed.	S (Instruction execution)	New	QCPU
SM716	Block comparison (Except an interrupt program)	OFF : Mismatch found ON : No mismatch	Turns on when all data conditions are confirmed that they are met by the DBKCMP instruction. (Initial execution type program, scan execution type program, stand-by type program executed from initial execution type program or scan execution type program)	S (Instruction execution)	New	QnU*2
SM717	Block comparison (Interrupt program)	OFF : Mismatch found ON : No mismatch	Turns on when all data conditions are confirmed that they are met by the DBKCMP instruction. (Interrupt program, fixed scan execution type program, stand-by type program executed from interrupt program or fixed scan execution type program)			
SM718	Block comparison (Interrupt program (I45))	OFF : Mismatch found ON : No mismatch	Turns on when all data conditions are confirmed that they are met by the DBKCMP instruction. (Interrupt program (I45) or Stand-by type program executed from interrupt program (I45))			QnU*3
SM720	Comment read completion flag	OFF : Comment read not completed ON : Comment read completed	• Turns on only during one scan when the processing of the COMRD or PRC instruction is completed.	S (Status change)	New	Qn(H) QnPH
			• Turns on only during one scan when the processing of the COMRD instruction is completed.			QnPRH QnU
SM721	File being accessed	OFF : File not accessed ON : File being accessed	• Switches ON while a file is being accessed by the SP. FWRITE, SP. FREAD, COMRD, PRC, or LEDC instruction.	S (Status change)	New	Qn(H) QnPH
			• Switches ON while a file is being accessed by the SP. FWRITE, SP. FREAD, COMRD or LEDC instruction.			Qn(H) QnPH QnPRH
			• Switches ON while a file is being accessed by the SP. FWRITE, SP. FREAD, COMRD or SP.DEVST instruction.			QnU
			• Turns ON while the ATA card or standard ROM is being accessed.			QnU*1
SM722	BIN/DBIN instruction error disabling flag	OFF : Error detection performed ON : Error detection not performed	• Turned ON when "OPERATION ERROR" is suppressed for BIN or DBIN instruction.	U	New	QCPU

*1: The module whose first 5 digits of serial No. is "09042" or later.
*2: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

*3: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UCPU, Q01UCPU

Table12.8 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM734	XCALL instruction execution condition designation	OFF : Not executed by execution condition risen ON : Executed by execution condition risen	• During OFF, XCALL instructions will not be executed even if execution condition is risen. • During ON, XCALL instructions will be executed when execution condition is risen.	U	New	Qn(H)*1
SM735	SFC comment readout instruction in execution flag	OFF : SFC comment readout instruction is inactivated. ON : SFC comment readout instruction is activating.	• Turns on the instructions, (S(P).SFCSCOMR) to read the SFC step comments and (S(P). SFCTCOMR) to read the SFC transition condition comments.	S (status change)	New	Qn(H)*2 QnPH*3 QnPRH*3
SM738	MSG instruction reception flag	OFF : Instruction not executed ON : Instruction execution	• Goes ON when MSG instruction is executed	S (Instruction execution)	New	Qn(H) QnPRH
SM750	Scaling instruction search method setting	OFF : Search next ON : 2-part search	Determines a search method when the scaling instruction is executed.	U	New	QnU*8
SM774	PID bumpless processing (for complete derivative)	OFF : Matched ON : Not matched	• Specifies whether to match the set value (SV) with the process value (PV) or not in the manual mode.	U	New	Q00J/Q00/Q01*4 Qn(H) QnPRH QnU
SM775	Selection of refresh processing during COM/CCOM instruction execution	OFF : Performs link refresh ON : Performs no link refresh	• Select whether link refresh processing will be performed or not when only communication with the CPU module is made at the execution of the COM instruction.	U	New	Q00J/Q00/Q01 Qn(H) QnPH
		OFF : Performs refresh processes other than an I/O refresh ON : Performs refresh set by SD778	• Select whether to perform refresh processes other than an I/O refresh set by SD778 when the COM or CCOM instruction is executed.	U	New	Q00J/Q00/Q01*4 Qn(H)*5 QnPH*3 QnPRH QnU
SM776	Enable/disable local device at CALL	OFF : Local device disabled ON : Local device enabled	• Set whether the local device of the subroutine program called at execution of the CALL instruction is valid or invalid.	U	New	Qn(H) QnPH QnPRH QnU*9
SM777	Enable/disable local device in interrupt program	OFF : Local device disabled ON : Local device enabled	• Set whether the local device at execution of the interrupt program is valid or invalid.	U	New	
SM794	PID bumpless processing(for incomplete derivative)	OFF : Matched ON : Not matched	• Specifies whether to match the set value (SV) with the process value (PV) or not in the manual mode.	U	New	Q00J/Q00/Q01*4 Qn(H)*6 QnPRH QnU

*1: The module whose first 5 digits of serial No. is "06082" or later.
*2: The module whose first 5 digits of serial No. is "07012" or later.
*3: The module whose first 5 digits of serial No. is "07032" or later.
*4: This applies to the CPU module of function version B or later.
*5: The module whose first 5 digits of serial No. is "04012" or later.
*6: The module whose first 5 digits of serial No. is "05032" or later.
*8: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

*9: The Universal model QCPU except the Q00UJCPU.

Table12.8 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM796	Block information using multiple CPU high-speed transmission dedicated instruction (for CPU No.1)	OFF : Block is secured ON : Block set by SD796 cannot be secured	• Turns ON when the number of the remaining blocks of the dedicated instruction transmission area used for the multiple CPU high-speed transmission dedicated instruction(target CPU= CPU No.1) is less than the number of blocks specified by SD796. Turns ON at instruction execution. Turns OFF when the empty area exists at END processing.	S (When instruction/END processing executed)	New	QnU*7
SM797	Block information using multiple CPU high-speed transmission dedicated instruction (for CPU No.2)	OFF : Block is secured ON : Block set by SD797 cannot be secured	• Turns ON when the number of the remaining blocks of the dedicated instruction transmission area used for the multiple CPU high-speed transmission dedicated instruction (target CPU= CPU No.2) is less than the number of blocks specified by SD797. Turns ON at instruction execution. Turns OFF when the empty area exists at END processing.	S (When instruction/END processing executed)	New	
SM798	Block information using multiple CPU high-speed transmission dedicated instruction (for CPU No.3)	OFF : Block is secured ON : Block set by SD798 cannot be secured	• Turns ON when the number of the remaining blocks of the dedicated instruction transmission area used for the multiple CPU high-speed transmission dedicated instruction (target CPU= CPU No.3) is less than the number of blocks specified by SD798. Turns ON at instruction execution. Turns OFF when the empty area exists at END processing.	S (When instruction/END processing executed)	New	
SM799	Block information using multiple CPU high-speed transmission dedicated instruction (for CPU No.4)	OFF : Block is secured ON : Block set by SD799 cannot be secured	• Turns ON when the number of the remaining blocks of the dedicated instruction transmission area used for the multiple CPU high-speed transmission dedicated instruction(target CPU= CPU No.4) is less than the number of blocks specified by SD799. Turns ON at instruction execution. Turns OFF when the empty area exists at END processing.	S (When instruction/END processing executed)	New	

*7: The Universal model QCPU except the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU.

(8) Debug

Table12.9 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM800	Trace preparation	OFF : Not ready ON : Ready	• Switches ON when the trace preparation is completed	S (Status change)	New	Qn(H) QnPH QnPRH QnU*1
SM801	Trace start	OFF : Suspend ON : Start	• Trace is started when this relay switches ON. • Trace is suspended when this relay switches OFF. (All related special Ms switches OFF.)	U	M9047	
SM802	Trace execution in progress	OFF : Suspend ON : Start	• Switches ON during execution of trace.	S (Status change)	M9046	
SM803	Trace trigger	OFF→ON: Start	• Trace is triggered when this relay switches from OFF to ON. (Identical to TRACE instruction execution status)	U	M9044	
SM804	After trace trigger	OFF : Not after trigger ON : After trigger	• Switches ON after trace is triggered.	S (Status change)	New	
SM805	Trace completed	OFF : Not completed ON : End	• Switches ON at completion of trace	S (Status change)	M9043	
SM826	Trace error	OFF : Normal ON : Errors	• Switches ON if error occurs during execution of trace	S (Status change)	New	
SM829	Forced registration specification of trace setting	ON : Forced registration enabled OFF : Forced registration disabled	• Even when the trace condition or the trigger condition is established, the sampling trace setting can be set to the CPU module by turning SM829 ON and registering the sampling trace setting by GX Developer.	U	New	QnU*1

*1: The Universal model QCPU except the Q00UJCPU.

(9) A to Q conversion correspondences

Special relays SM1000 to SM1255 are the relays which correspond to ACPU special relays M9000 to M9255 after A to Q conversion.
(However, the Basic model QCPU and Redundant CPU do not support the A to Q conversion.)
These special relays are all set by the system, and cannot be set by the user program.
To turn them ON/OFF by the user program, change the special relays in the program into those of QCPU.
However, some of SM1084 and SM1200 to SM1255 (corresponding to M9084 and M9200 to M9255 before conversion) can be turned ON/OFF by the user program, if they could be turned ON/OFF by the user program before conversion.For details on the ACPU special relays, see the user's manuals for the individual CPUs, and MELSECNET or MELSECNET/B Data Link System Reference Manuals

Point

Check "Use special relay/special register from SM/SD1000" for "A-PLC" on the PLC system tab of PLC parameter in GX Developer when the converted special relays are used with the High Performance model QCPU, Process CPU, and Universal model QCPU.
When not using the converted special relays, uncheck "Use special relay/special register from SM/SD1000" to save the time taken for processing special relays.

Remark

The following are additional explanations about the Special Relay for Modification column.

① When a special relay for modification is provided, the device number should be changed to the provided QCPU special relay.

② When — is provided, the converted special relay can be used for the device number.






③ When × is provided, the device number does not work with QCPU.

Table12.10 Special relay

ACPU Special Relay	Special Relay after Conversion	Special Relay for Modification	Name	Meaning	Details	Corresponding CPU
M9000	SM1000	–	Fuse blown	OFF : Normal ON : Module with blown fuse	• Turned on when there is one or more output modules of which fuse has been blown. • Remains ON if the condition is restored to normal thereafter. • Output modules of remote I/O stations are also checked fore fuse condition.	Qn(H) QnPH QnU*1
M9002	SM1002	–	I/O module verify error	OFF : Normal ON : Error	• Turned on if the status of I/O module is different form entered status when power is turned on. • Remains ON if the condition is restored to normal thereafter. • I/O module verification is done also to remote I/O station modules. • Reset is enabled only when special registers SD1116 to SD1123 are reset.	


*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

Table12.11 Special relay

ACPU Special Relay	Special Relay after Conversion	Special Relay for Modification	Name	Meaning	Details	Corresponding CPU
M9005	SM1005	–	AC DOWN detection	OFF : AC DOWN not detected ON : AC DOWN detected	• Turns ON if an instantaneous power failure of within 20ms occurs during use of the AC power supply module. • Reset when the power supply is switched OFF, then ON. • Turns ON if an instantaneous power failure of within 10ms occurs during use of the DC power supply module. • Reset when the power supply is switched OFF, then ON.	Qn(H) QnPH QnU*1
M9006	SM1006	–	Battery low	OFF : Normal ON : Battery low	• Turns ON when the battery voltage drops to or below the specified. • Turns OFF when the battery voltage returns to normal thereafter.	
M9007	SM1007	–	Battery low latch	OFF : Normal ON : Battery low	• Turns ON when the battery voltage drops to or below the specified. • Remains ON if the battery voltage returns to normal thereafter.	
M9008	SM1008	SM1	Self-diagnosis error	OFF : No error ON : Error	• Turned on when error is found as a result of self-diagnosis.	
M9009	SM1009	SM62	Annunciator detection	OFF : No F number detected ON : F number detected	• Turned on when OUT F of SET F instruction is executed. • Switched off when SD1124 data is cleared to zero.	
M9011	SM1011	SM56	Operation error flag	OFF : No error ON : Error	• Turned on when operation error occurs during execution of application instruction. • Remains ON if the condition is restored to normal thereafter.	
M9012	SM1012	SM700	Carry flag	OFF : Carry OFF ON : Carry ON	• Carry flag used in application instruction.	Qn(H) QnPH
M9016	SM1016	×	Data memory clear flag	OFF : Ignored ON : Output claered	• Clears the data memory including the latch range (other than special relays and special registers) in remote run mode from computer, etc. when SM1016 is on.	
M9017	SM1017	×	Data memory clear flag	OFF : Ignored ON : Output claered	• Clears the unlatched data memory (other than special relays and special registers) in remote run mode from computer, etc. when SM1017 is on.	
M9020	SM1020	–	User timing clock No.0		• Relay which repeats on/off at intervals of predetermined scan. • When power is turned on or reset is per-formed, the clock starts with off. Set the intervals of on/off by DUTY instruction.  n1: ON scan interval n2: OFF scan interval * : If DUTY instruction, which specified from SM 1020 to SM 1024 of User timing clock in programs other than a program for a Universal model QCPU, changes the programmable controller to the Universal model QCPU, the special relays SM 420 to 424 will be replaced. (Universal model QCPUs cannot specify the special relays from SM 1020 to SM1024.)	Qn(H) QnPH QnU*1
M9021	SM1021	–	User timing clock No.1			
M9022	SM1022	–	User timing clock No.2			
M9023	SM1023	–	User timing clock No.3			
M9024	SM1024	–	User timing clock No.4			
M9025	SM1025	–	Clock data set request	OFF : Ignored ON : Set request present used	• Writes the clock data stored in SD1025 to SD1028 to the CPU module after the END instruction is executed in the scan in which SM1025 turned from OFF to ON.	
M9026	SM1026	–	Clock data error	OFF : No error ON : Error	• Switched on by clock data (SD1025 to SD1028) error	
M9028	SM1028	–	Clock data read request	OFF : Ignored ON : Read request	• Reads clock data to SD1025 to SD1028 in BCD when SD1028 is on.	
M9029	SM1029	×	Batch processing of data communications requests	OFF : Batch processing not conducted ON : Batch processing conducted	• The SM1029 relay is turned on using a sequence program to process all data communication requests accepted during one scan in the END processing of that scan. • The batch processing of the data communication requests can be turned on and off during running. • The default is OFF (processed one at a time for each END processing in the order in which data communication requests are accepted).	Qn(H) QnPH
M9030	SM1030	–	0.1 second clock		• 0.1 second, 0.2 second, 1 second and 2 second, clocks are generated. • Not turned on or off per scan but turned on and off even during scan if corresponding time has elapsed. • Starts with off when Programmable Controller power supply is turned on or CPU module reset is performed.	Qn(H) QnPH QnU*1
M9031	SM1031	–	0.2 second clock			
M9032	SM1032	–	1 second clock			
M9033	SM1033	–	2 second clock			

*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

Table12.11 Special relay

ACPU Special Relay	Special Relay after Conversion	Special Relay for Modification	Name	Meaning	Details	Corresponding CPU
M9034	SM1034	–	2n minute clock(1 minute clock)*2		• Alternates between ON and OFF according to the seconds specified at SD414. (Default: n = 30) • Not turned on or off per scan but turned on and off even during scan if corresponding time has elapsed. • Starts with off when Programmable Controller power supply is turned on or CPU module reset is performed.	Qn(H) QnPH QnU*1
M9036	SM1036	–	Always ON		• Used as dummy contacts of initialization and application instruction in sequence program. • SM1038 and SM1037 are turned on and off without regard to position of key switch on CPU module front. SM1038 and SM1039 are under the same condition as RUN status except when the key switch is at STOP position, and turned off and on. Switched off if the key switch is in STOP position. SM1038 is on for one scan only and SM1039 is off for one scan only if the key switch is not in STOP position.	
M9037	SM1037	–	Always OFF			
M9038	SM1038	–	ON for 1 scan only after RUN			
M9039	SM1039	–	RUN flag(After RUN, OFF for 1 scan only)			
M9040	SM1040	SM206	PAUSE enable coil	OFF : PAUSE disabled ON : PAUSE enabled	• When RUN key switch is at PAUSE position or pause contact has turned on and if SM1040 is on, PAUSE mode is set and SM1041 is turned on.	Qn(H) QnPH
M9041	SM1041	SM204	PAUSE status contact	OFF : PAUSE not in effect ON : PAUSE in effect		Qn(H) QnPH QnU*1
M9042	SM1042	SM203	STOP status contact	OFF : STOP not in effect ON : STOP in effect	• Switched on when the RUN key switch or RUN/STOP switch is in STOP position.	
M9043	SM1043	SM805	Sampling trace completed	OFF : Sampling trace in progress ON : Sampling trace completed	• Turned on upon completion of sampling trace performed the number of times preset by parameter after STRA instruction is executed. Reset when STRAR instruction is executed.	
M9044	SM1044	SM803	Sampling trace	OFF → ON Same as STRA instruction execution ON → OFF Same as STRAR instruction execution	• Turning on/off SM1044 can execute STRA/STRAR instruction. (SM1044 is forcibly turned on/off by a peripheral device.) When switched from OFF to ON: STRA instruction When switched from ON to OFF: STRAR instruction The value stored in SD1044 is used as the condition for the sampling trace. At scanning, at time → Time (10 ms unit)	Qn(H) QnPH
M9045	SM1045	×	Watchdog timer (WDT) reset	OFF : Does not reset WDT ON : Resets WDT	• The SM1045 relay is turned on to reset the WDT when the ZCOM instruction and data communication request batch processing are executed (used when the scan time exceeds 200 ms).	
M9046	SM1046	SM802	Sampling trace	OFF : Trace not in progress ON : Trace in progress	• Switched on during sampling trace.	Qn(H) QnPH QnU*1
M9047	SM1047	SM801	Sampling trace preparations	OFF : Sampling trace suspended ON : Sampling trace started	• Sampling trace is not executed unless SM1047 is turned ON. Sampling trace is suspended when SM1047 goes OFF.	Qn(H) QnPH
M9049	SM1049	SM701	Switching the number of output characters	OFF : Output until NULL code encountered ON : 16 characters output	• When SM1049 is OFF, characters up to NULL (00_H) code are output. • When SM1049 is ON, ASCII codes of 16 characters are output.	
M9051	SM1051	×	CHG instruction execution disable	OFF : Enabled ON : Disable	• Switched ON to disable the CHG instruction. • Switched ON when program transfer is requested. Automatically switched OFF when transfer is complete.	
M9052	SM1052	×	SEG instruction switch	OFF : 7SEG segment display ON : I/O partial refresh	• When SM1052 is ON, the SEG instruction is executed as an I/O partial refresh instruction. When SM1052 is OFF, the SEG instruction is executed as a 7-SEG display instruction.	

*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

*2: minute clock indicates the name of the special relay (M9034) of the ACPU.

Table12.11 Special relay

ACPU Special Relay	Special Relay after Conversion	Special Relay for Modification	Name	Meaning	Details	Corresponding CPU
M9056	SM1056	×	Main side P, I set request	OFF : Other than when P, I set being requested ON : P, I set being requested	• Provides P, I set request after transfer of the other program (for example subprogram when main program is being run) is complete during run. Automatically switched off when P, I setting is complete.	Qn(H) QnPH
M9057	SM1057	×	Sub side P, I set request	OFF : Other than when P, I set being requested ON : P, I set being requested		
M9058	SM1058	×	Main side P, I set completion	Momentarily ON at P, I set completion	• Turned ON once when the P, I set has been completed, and then turned OFF again.	
M9059	SM1059	×	Sub program P, I set completion	Momentarily ON at P, I set completion		
M9060	SM1060	×	Sub program 2 P, I set request	OFF : Other than when P, I set being requested ON : P, I set being requested	• Provides P, I set request after transfer of the other program (for example subprogram when main program is being run) is complete during run. Automatically switched off when P, I setting is complete.	
M9061	SM1061	×	Sub program 3 P, I set request	OFF : Other than when P, I set being requested ON : P, I set being requested		
M9070	SM1070	×	A8UPU/ A8PUJrequired search time*3	OFF : Read time not shortened ON : Read time shortened	• Turned ON to shorten the search time in the A8UPU/ A8PUJ. (In this case, the scan time is extended by 10 %.)	
M9084	SM1084	×	Error check	OFF : Error check executed ON : No error check	It is set whether the error checks below are performed or not when the END instruction is processed (to set the END instruction processing time). • Check for fuse blown. • Check of battery • Collation check of I/O module	
M9091	SM1091	×	Operation error details flag	OFF : No error ON : Error	• Turns ON when the detail factor of the operation error is stored into SD1091. • Remains ON if the condition is restored to normal thereafter.	
M9100	SM1100	SM320	Presence/absence of SFC program	OFF : SFC programs not used ON : SFC programs used	• Turned on if the SFC program is registered. • Turned off if the SFC program is not registered.	
M9101	SM1101	SM321	Start/stop SFC program	OFF : SFC programs stop ON : SFC programs start	• The value in SM1100 is set as the initial value. (The relay automatically turns ON when the SFC program is present.) • When this relay turns from ON to OFF, execution of the SFC program stops. • When this relay turns from OFF to ON, execution of the SFC program resumes.	
M9102	SM1102	SM322	SFC program start status	OFF : Initial start ON : Resume start	• The SFC program start mode in the SFC setting of the PLC parameter dialog box is set as the initial value. At initial start: OFF At continue start: ON	

*3: The A8UPU/A8PUJ is not available for the QCPU/QnACPU.

Table12.11 Special relay

ACPU Special Relay	Special Relay after Conversion	Special Relay for Modification	Name	Meaning	Details	Corresponding CPU
M9103	SM1103	SM323	Presence/absence of continuous transition	OFF : Continuous transition not effective ON : Continuous transition effective	• Set whether continuous transition will be performed for the block where the "continuous transition bit" of the SFC information device is not set.	Qn(H) QnPH
M9104	SM1104	SM324	Continuous transition suspension flag	OFF : When transition is completed ON : When no transition	• OFF during operation in the continuous transition mode or during continuous transition, and ON when continuous transition is not executed. • Always ON during operation in the no continuous transition mode.	
M9108	SM1108	SM90	Step transition monitoring timer start (equivalent of SD90)	OFF : Monitoring timer reset ON : Monitoring timer reset start	• Turns ON when the measurement of the step transition monitoring timer is started. Turning this relay OFF resets the step transition monitoring timer.	
M9109	SM1109	SM91	Step transition monitoring timer start (equivalent of SD91)			
M9110	SM1110	SM92	Step transition monitoring timer start (equivalent of SD92)			
M9111	SM1111	SM93	Step transition monitoring timer start (equivalent of SD93)			
M9112	SM1112	SM94	Step transition monitoring timer start (equivalent of SD94)			
M9113	SM1113	SM95	Step transition monitoring timer start (equivalent of SD95)			
M9114	SM1114	SM96	Step transition monitoring timer start (equivalent of SD96)			
M9196	SM1196	SM325	Operation output at block stop	OFF : Coil output OFF ON : Coil output ON	• Selects the operation output when block stop is executed. ON : Retains the ON/OFF status of the coil being used by using operation output of the step being executed at block stop. OFF : All coil outputs are turned off. (Operation output by the SET instruction is retained regardless of the ON/OFF status of SM1196.)	
M9197	SM1197	×	Switch between blown fuse and I/O verify error display	SM1197 / SM1198 / I/O numbers to be displayed OFF / OFF / X/Y0 to 7F0 ON / OFF / X/Y800 to FF0 OFF / ON / X/Y1000 to 17F0 ON / ON / X/Y1800 to 1FF0	Switches I/O numbers in the fuse blow module storage registers (SD1100 to SD1107) and I/O module verify error storage registers (SD1116 to SD1123) according to the combination of ON/OFF of the SM1197 and SM1198.	
M9198	SM1198	×				
M9199	SM1199	×	Data recovery of online sampling trace/status latch	OFF : Data recovery disabled ON : Data recovery enabled	• Recovers the setting data stored in the CPU module at restart when sampling trace/status latch is executed. • SM1199 should be ON to execute again. (Unnecessary when writing the data again from peripheral devices.)	

(10) QCPU with built-in Ethernet port

Table12.12 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM1270	Time setting function (SNTP client) execution	OFF : No time setting function (SNTP client) execution ON : Time setting function (SNTP client) execution	Set this to ON when executing the time setting function (SNTP client). (Only when the time setting function is in "Use" with the time setting parameter.)	U	New	QnU*1
SM1273	Remote password mismatch count clear	OFF : Normal ON : Clear	To clear the acumulated numeber (SD979 to 999) of mismatched remote passwords, the setting SM1273 is executed.	U	New	

* 1: This applies to the Built-in Ethernet port QCPU.

(11) Process control instructions

Table12.13 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU M9□□□	Corresponding CPU
SM1500	Hold mode	OFF : No-hold ON : Hold	• Specifies whether or not to hold the output value when a range over occurs for the S.IN instruction range check.	U	New	QnPH QnPRH
SM1501	Hold mode	OFF : No-hold ON : Hold	• Specifies whether or not the output value is held when a range over occurs for the S.OUT instruction range check.	U	New	

(12) For redundant systems (Host system CPU information *1)

SM1510 to SM1599 are only valid for redundant systems.

All off for standalone systems.

Table12.14 Special relay

<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corresponding ACPU M9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SM1510</td><td>Operation mode</td><td>OFF : Redundant system backup mode, stand-alone system
ON : Redundant system separate mode</td><td>• Turns on when the operating mode is redundant system separate.</td><td>S (Each END)</td><td>New</td><td rowspan="6">QnPRH</td></tr>
<tr><td>SM1511</td><td>System A identification flag</td><td colspan="2">• Distinguishes between system A and system B.
• The flag status does not change even if the tracking cable is disconnected.
<table><tr><th></th><th>System A</th><th>System B</th><th>When TRK. CABLE ERR. (error code: 6210) occurs (Unknown)</th></tr><tr><td>SM1511</td><td>ON</td><td>OFF</td><td>OFF</td></tr><tr><td>SM1512</td><td>OFF</td><td>ON</td><td>OFF</td></tr></table></td><td rowspan="2">S (Initial)</td><td rowspan="2">New</td></tr>
<tr><td>SM1512</td><td>System B identification flag</td></tr>
<tr><td>SM1513</td><td>Debug mode status flag</td><td>OFF : Not in debug mode
ON : Debug mode</td><td>• Turns on when the redundant system operating mode is set to debug mode.</td><td>S (Initial)</td><td>New</td></tr>
<tr><td>SM1515</td><td>Control system judgment flag</td><td colspan="2">• Indicates operation system status.
• The flag status does not change even if the tracking cable is disconnected.
<table><tr><th></th><th>Control system</th><th>Standby system</th><th>When TRK. CABLE ERR. (error code: 6210) occurs (Unknown)</th></tr><tr><td>SM1515</td><td>ON</td><td>OFF</td><td>OFF</td></tr><tr><td>SM1516</td><td>OFF</td><td>ON</td><td>OFF</td></tr></table></td><td rowspan="2">S (Status change)</td><td rowspan="2">New</td></tr>
<tr><td>SM1516</td><td>Standby system judgment flag</td></tr>
</table>

*1: The information of the host CPU module is stored.

Table12.13 Special relay


Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM1517	CPU module startup status	OFF : Power supply on startup ON : Operation system switch start up	• Turns on when the CPU module is started up by the system switching (switching from the standby system to the control system). Remains OFF when the standby system is switched to the control system by a power-ON startup.	S (Status change)	New	
SM1518	Standby system to control system switching status flag		• Turns ON once switch between standby system to control system, (ON for 1 scan only) occurs. • This status flag can only be used for scan execution type programs.	S (Each END)	New	
SM1519	Previous Control System Identification Flag		• On the last operation Control System was System B,if power supply is supplied, or reset is released on both SYSTEM together,After RUN, ON for 1 scan only by System A side.	S (Each END)	New	
SM1520	Data tracking transfer trigger specification	OFF : No trigger ON : Trigger	SM1520 Block 1 SM1521 Block 2 SM1522 Block 3 SM1523 Block 4 SM1524 Block 5 SM1525 Block 6 SM1526 Block 7 SM1527 Block 8 SM1528 Block 9 SM1529 Block 10 SM1530 Block 11 SM1531 Block 12 SM1532 Block 13 SM1533 Block 14 SM1534 Block 15 SM1535 Block 16 SM1536 Block 17 SM1537 Block 18 SM1538 Block 19 SM1539 Block 20 SM1540 Block 21 SM1541 Block 22 SM1542 Block 23 SM1543 Block 24 SM1544 Block 25 SM1545 Block 26 SM1546 Block 27 SM1547 Block 28 SM1548 Block 29 • When data is transferred based on the tracking setting of the redundant parameter dialog box, the target block is specified as trigger. • When "Auto Tracking block No.1" is enabled in the tracking setting, SM1520 is turned ON by the system at power ON/ STOP to RUN. In other cases, SM1520 to SM1583 are turned ON by the user.	S (initial)/U	New	QnPRH
SM1521						
SM1522						
SM1523						
SM1524						
SM1525						
SM1526						
SM1527						
SM1528						
SM1529						
SM1530						
SM1531						
SM1532						
SM1533						
SM1534						
SM1535						
SM1536						
SM1537						
SM1538						
SM1539						
SM1540						
SM1541						
SM1542						
SM1543						
SM1544						
SM1545						
SM1546						
SM1547						
SM1548						

Table12.13 Special relay

Number	Name	Meaning	Explanation			Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM1549	Data tracking transfer trigger specification	OFF : No trigger ON : Trigger	SM1549	Block 30	• When data is transferred based on the tracking setting of the redundant parameter dialog box, the target block is specified as trigger. • When "Auto tracking block No. 1" is enabled in the tracking setting, SM1520 is turned ON by the system at power ON/ STOP to RUN. In other cases, SM1520 to SM1583 are turned ON by the user.	S (initial)/U	New	QnPRH
SM1550			SM1550	Block 31				
SM1551			SM1551	Block 32				
SM1552			SM1552	Block 33				
SM1553			SM1553	Block 34				
SM1554			SM1554	Block 35				
SM1555			SM1555	Block 36				
SM1556			SM1556	Block 37				
SM1557			SM1557	Block 38				
SM1558			SM1558	Block 39				
SM1559			SM1559	Block 40				
SM1560			SM1560	Block 41				
SM1561			SM1561	Block 42				
SM1562			SM1562	Block 43				
SM1563			SM1563	Block 44				
SM1564			SM1564	Block 45				
SM1565			SM1565	Block 46				
SM1566			SM1566	Block 47				
SM1567			SM1567	Block 48				
SM1568			SM1568	Block 49				
SM1569			SM1569	Block 50				
SM1570			SM1570	Block 51				
SM1571			SM1571	Block 52				
SM1572			SM1572	Block 53				
SM1573			SM1573	Block 54				
SM1574			SM1574	Block 55				
SM1575			SM1575	Block 56				
SM1576			SM1576	Block 57				
SM1577			SM1577	Block 58				
SM1578			SM1578	Block 59				
SM1579			SM1579	Block 60				
SM1580			SM1580	Block 61				
SM1581			SM1581	Block 62				
SM1582			SM1582	Block 63				
SM1583			SM1583	Block 64				
SM1590	System switching enable/disable flag from network module	OFF : System switching request issuing module absent ON : System switching request issuing module present	• Turns ON when a system switching request is issued from the network module. The module No. that issued system switching can be checked by SD1590. • Turns OFF when all bits of SD1590 are OFF.			S (Each END)	New	
SM1591	Standby system error detection disable flag at system switching	ON : Error is not detected by new standby system at system switching OFF : Error is detected by new standby system at system switching	This flag is used to determine if the new standby station detects 6210:STANDBY during system switching. This applies to the following switching methods: • System switching from GX Developer • System switching using dedicated instruction • System switching by the intelligent function module			U	New	
SM1592	Enable/disable user system switching	OFF : Disable user system switching ON : Enable user system switching	• This flag enables system switching by the user from GX Developer or by dedicated instruction. (SP.CONTSW).			U	New	

Table12.13 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM1593	Setting to access extension base unit of standby system CPU	OFF : Error ON : Ignored	Sets the operation for the case accessing buffer memory of the intelligent function module mounted on the extension base unit from the standby system CPU in separate mode. OFF : "OPERATION ERROR" (error code: 4112) will be returned when accessing buffer memory of the intelligent function module on the extension base unit from the standby system CPU. ON : No processing is performed when accessing buffer memory of intelligent function module on the extension base unit from the standby system CPU.	U	New	QnPRH*2
SM1595	Memory copy to other system start flag	OFF : Start memory copy ON : No memory copy initiated	• When SM1595 is turned from OFF to ON, memory copy from control system to standby system starts. Note that when SM1595 is turned from OFF to ON, memory copy does not start if the I/O No. of the copy destination (standby system CPU module: 3D1H) is not stored in SD1595.			QnPRH
SM1596	Memory copy to other system status flag	OFF : Memory copy not executed ON : Memory copy executed	• Turns on while memory is copied to other system. • Turns off when memory copy execution has completed.	S (Starting to copy/finish)		
SM1597	Memory copy to other system completion flag	OFF : Memory copy not completed ON : Memory copy completed	• Turns on once the memory copying to the other system has completed.	S (finish)/U	New	
SM1598	Copy contents of standard ROM during memory copy	OFF : Copy standard ROM data ON : Standard ROM data is not copied	• If set to on by user, the standard ROM data is not copied to the other system while memory copy is executing.	U		

*2: The module whose first 5 digits of serial No. is "09012" or later.

(13) For redundant system (Other system CPU information *1)

SM1600 to SM1650 only valid for the CPU redundant system backup mode, so they cannot be refreshed during the separate mode.

Either the backup mode or the separate mode is valid for the SM4651 to SM1699.

SM1600 to SM1699 are all turned off for stand-alone system.

Table12.14 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding Host SM□□ *2	Corresponding CPU
SM1600	Other system error flag	OFF : No error ON : Error	• Turns on when an error occurs during redundant system. Error check (Turns on single bit of SD1600.) • Is off when no errors are present	S (Each END)	–	QnPRH
SM1610	Other system diagnostics error	OFF : No error ON : Error	• Turns on when a diagnostics error occurs. (Includes error detection when annunciator is ON, and by CHK instruction) • Corresponds to status of SM0 at other system	S (Each END)	SM0	QnPRH
SM1611	Other systems self diagnostics error.	OFF : No self diagnostics error occurred ON : Self diagnostics error occurred	• Turns on when a self diagnostics error occurs. (Does not include error detection when annunciator is ON, and by CHK instruction) • Corresponds to status of SM1 at other system	S (Each END)	SM1	
SM1615	Other system common error information	OFF : No common error information present ON : Common error information present	• Turns on when there is common error information at other system • Corresponds to status of SM5 at other system	S (Each END)	SM5	
SM1626	Error individual information for other systems	OFF : No individual error information present ON : Individual error information present	• Turns on when there is individual error information at other system • Corresponds to status of SM16 at other system	S (Each END)	SM16	
SM1649	Standby system cancel error flag	OFF to ON: Cancels error of standby system	By turning this relay from OFF to ON, the continue error that occurred in the standby system CPU module can be canceled. Use SD1649 to specify the error code of the error to be canceled.	U	–	

*1 Stores other system CPU diagnostic information and system information.

*2 This shows the special relay(SM☐ ☐) for the host system CPU.

(14) For redundant system (tracking)

Either the backup mode or the second mode is valid for SM1700 to SM1799.

All is turned off for stand-alone system.

Table12.15 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM1700	Transfer trigger completion flag	OFF : Transfer not completed ON : Transfer completed	• Turns on for one scan, once transfer of block 1 to block 64 is completed.	S (status change)	New	QnPRH
SM1709	Manual system switching disable/ enable setting during online program change redundant tracking	ON : Manual system switching enabled (Disable canceled) OFF : Manual system switching disabled	(1) Turning this relay from OFF to ON enables manual system switching during online program change redundant tracking. After the manual system switching disable status is canceled, the system automatically turns off SM1709. (2) System switching due to any of the following conditions is executed even during online program change redundant tracking, regardless of the status of this relay. •Power off, reset, hardware failure, CPU stop error (3) In either of the following statuses, the system switching disable status can also be canceled by this relay. •Multiple-block online program change redundant tracking execution status •File batch online program change redundant tracking execution status	S (When executed)/U		
SM1710	Transfer tracking data during online program change enable flag	OFF : No device tracking ON : Transfer device memory	(1) Set whether the tracking of the following data will be executed or not during online program change redundant tracking. •Device memory (Including SM/SD that will automatically execute tracking) •PIDINIT information, S.PIDINIT information, SFC information (2) SM1710 can be also used to set whether tracking will be executed or not while online change of multiple program blocks or batch of files is being performed to ensure consistency of both systems. (3) This SM is also transferred form control system CPU module to standby system CPU module by tracking data.	U		

Table12.15 Special relay

Number	Name	Meaning	Explanation			Set by (When Set)	Corres-ponding ACPU M9□□□	Corresponding CPU
SM1712	Transfer trigger completion flag	OFF : Transfer uncompleted ON : Transfer completed	SM1712	Block 1	Turns ON only during one scan when the transmission of the corresponding block is completed.	S (status change)	New	QnPRH
SM1713			SM1713	Block 2				
SM1714			SM1714	Block 3				
SM1715			SM1715	Block 4				
SM1716			SM1716	Block 5				
SM1717			SM1717	Block 6				
SM1718			SM1718	Block 7				
SM1719			SM1719	Block 8				
SM1720			SM1720	Block 9				
SM1721			SM1721	Block 10				
SM1722			SM1722	Block 11				
SM1723			SM1723	Block 12				
SM1724			SM1724	Block 13				
SM1725			SM1725	Block 14				
SM1726			SM1726	Block 15				
SM1727			SM1727	Block 16				
SM1728			SM1728	Block 17				
SM1729			SM1729	Block 18				
SM1730			SM1730	Block 19				
SM1731			SM1731	Block 20				
SM1732			SM1732	Block 21				
SM1733			SM1733	Block 22				
SM1734			SM1734	Block 23				
SM1735			SM1735	Block 24				
SM1736			SM1736	Block 25				
SM1737			SM1737	Block 26				
SM1738			SM1738	Block 27				
SM1739			SM1739	Block 28				
SM1740			SM1740	Block 29				
SM1741			SM1741	Block 30				
SM1742			SM1742	Block 31				
SM1743			SM1743	Block 32				
SM1744			SM1744	Block 33				
SM1745			SM1745	Block 34				
SM1746			SM1746	Block 35				
SM1747			SM1747	Block 36				
SM1748			SM1748	Block 37				
SM1749			SM1749	Block 38				
SM1750			SM1750	Block 39				
SM1751			SM1751	Block 40				
SM1752			SM1752	Block 41				
SM1753			SM1753	Block 42				
SM1754			SM1754	Block 43				
SM1755			SM1755	Block 44				
SM1756			SM1756	Block 45				
SM1757			SM1757	Block 46				
SM1758			SM1758	Block 47				
SM1759			SM1759	Block 48				

Table12.15 Special relay

Number	Name	Meaning	Explanation			Set by (When Set)	Corresponding ACPU M9□□□	Corresponding CPU
SM1760	Transfer trigger completion flag	OFF : Transmission uncompleted ON : Transmission end	SM1760	Block 49	Turns ON only during one scan when the transmission of the corresponding block is completed.	S (status change)	New	QnPRH
SM1761			SM1761	Block 50				
SM1762			SM1762	Block 51				
SM1763			SM1763	Block 52				
SM1764			SM1764	Block 53				
SM1765			SM1765	Block 54				
SM1766			SM1766	Block 55				
SM1767			SM1767	Block 56				
SM1768			SM1768	Block 57				
SM1769			SM1769	Block 58				
SM1770			SM1770	Block 59				
SM1771			SM1771	Block 60				
SM1772			SM1772	Block 61				
SM1773			SM1773	Block 62				
SM1774			SM1774	Block 63				
SM1775			SM1775	Block 64				

(15) Redundant power supply module information

Table12.16 Special relay

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU M9□□□	Corresponding CPU
SM1780	Power supply off detection flag	OFF : No redundant power supply module with input power OFF detected ON : Redundant power supply module with input power OFF detected	• Turns ON when one or more redundant power supply modules with input power OFF are detected. • Turns on if any of SD1780 bits is on. • Turns off if all bits of SD1780 are off. • Turns OFF when the main base unit is not the redundant main base unit (Q38RB). • When the multiple CPU system is configured, the flags are stored only to the CPU No.1.	S (Each END)	New	Qn(H)*2 QnPH*2 QnPRH QnU*3
SM1781	Power supply failure detection flag	OFF : No faulty redundant power supply module detected ON : Faulty redundant power supply module detected	• Turns ON when one or more faulty redundant power supply modules are detected. • Turns on if any of SD1781 bits is on. • Turns off if all bits of SD1781 are off. • Turns OFF when the main base unit is not the redundant main base unit (Q38RB). • When the multiple CPU system is configured, the flags are stored only to the CPU No.1.	S (Each END)		
SM1782	Momentary power failure detection flag for power supply 1 *1	OFF : No momentary power failure detected ON : Momentary power failure detected	• Turns ON when a momentary power failure of the input power supply to the power supply 1 or 2 is detected one or more times. After turning ON, remains ON even if the power supply recovers from the momentary power failure. • Turns OFF the flag (SM1782, SM1783) of the power supply 1/2 when the CPU module starts. • When the input power to one of the redundant power supply modules turns OFF the corresponding flag turns OFF. • Turns OFF when the main base unit is not the redundant main base unit (Q38RB). • When the multiple CPU system is configured, the flags are stored only to the CPU No.1.	S (Each END)		
SM1783	Momentary power failure detection flag for power supply 2 *1					

*1: The "power supply 1" indicates the redundant power supply module mounted on the POWER 1 slot of the redundant base unit (Q38RB/Q68RB/Q65WRB).
The "power supply 2" indicates the redundant power supply module mounted on the POWER 2 slot of the redundant base unit (Q38RB/Q68RB/Q65WRB).
*2: The module whose first 5 digits of serial No. is "04012" or later.
However, for the multiple CPU system configuration, this applies to all CPU modules whose first 5 digits of serial No. are "07032" or later.
*3: The module whose first 5 digits of serial No. is "10042" or later.

12.2 SPECIAL REGISTER LIST

The special registers, SD, are internal registers with fixed applications in the Programmable Controller.

For this reason, it is not possible to use these registers in sequence programs in the same way that normal registers are used.

However, data can be written as needed in order to control the CPU modules.

Data stored in the special registers are stored as BIN values if no special designation has been made to the contrary.

The heading descriptions in the following special register lists are shown in 4.1.

Table12.17 Descriptions of the special register lists headings

Item	Function of Item
Number	• Indicates special register number
Name	• Indicates name of special register
Meaning	• Indicates contents of special register
Explanation	• Discusses contents of special register in more detail
Set by (When set)	• Indicates whether the relay is set by the system or user, and, if it is set by the system, when setting is performed. <Set by> S : Set by system U : Set by user (sequence programs or test operations from GX Developer) S/U : Set by both system and user <When set> Indicated only for registers set by system Each END : Set during each END processing Initial : Set only during initial processing (when power supply is turned ON, or when going from STOP to RUN) Status change : Set only when there is a change in status Error : Set when error occurs Instruction execution : Set when instruction is executed Request : Set only when there is a user request (through SM, etc.) System switching : Set when system switching is executed.
Corresponding ACPU M9□□□	• Indicates corresponding special register in ACPU (When the contents are changed, the special register is represented D9□ □ □ format change. Incompatible with the Q00J/Q00/Q01 and QnPRH.) • New indicates the special register newly added to the Q series CPU module.
Corresponding CPU	Indicates the relevant CPU module. QCPU : Indicates all the Q series CPU modules. Q00J/Q00/Q01 : Indicates the Basic model QCPU. Qn(H) : Indicates the High Performance model QCPU. QnPH : Indicates the Process CPU. QnPRH : Indicates the Redundant CPU. QnU : Indicates the Universal model QCPU Each CPU type name : Can be applied only to the specific CPU. (e.g. Q02U)

For details on the following items, refer to the following manuals:

- Networks → Manual of the corresponding network module
- SFC → QCPU(Q mode)/QnACPU Programming Manual (SFC)

Point

Do not change the values of special relays set by the system with user program or device test operations.
Doing so may result in system downtime or communication fault.

(1) Diagnostic Information

Table12.18 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD0	Diagnostic errors	Diagnosis error code	• Error codes for errors found by diagnosis are stored as BIN data. • Contents identical to latest fault history information.	S (Error)	D9008 format change	QCPU
SD1	Clock time for diagnosis error occurrence	Clock time for diagnosis error occurrence	• Year (last two digits) and month that SD0 data was updated is stored as BCD 2-digit code. b15 to b8 b7 to b0 Year (0 to 99) | Month (1 to 12) (Example) October, 1995 9510H	S (Error)	New	
SD2			• The day and hour that SD0 was updated is stored as BCD 2-digit code. b15 to b8 b7 to b0 Day (1 to 31) | Hour (0 to 23) (Example) 10 a.m. on 25th 2510H			
SD3			• The minute and second that SD0 data was updated is stored as BCD 2-digit code. b15 to b8 b7 to b0 Minutes (0 to 59) | Seconds (0 to 59) (Example) 35 min. 48 sec. 3548H			
SD4	Error information categories	Error information category code	Category codes which help indicate what type of information is being stored in the common information areas (SD5 through SD15) and the individual information areas (SD16 through SD26) are stored here. The category code for judging the error information type is stored. b15 to b8 b7 to b0 Individual information category codes | Common information category codes • The common information category codes store the following codes: 0 : No error 1: Unit/module No./ CPU No./Base No.* 2: File name/Drive name 3: Time (value set) 4: Program error location 5: System switching cause (for Redundant CPU only) 6: Reason(s) for tracking capacity excess error (specific to Redundant CPU) 7: Base No./Power supply No. (The first 5 digits of serial number 10072 or higer are chosen for Universal model QCPU.) 8: Tracking transmission data classification (specific to Redundant CPU) *: For a multiple CPU system that consists of the Basic model QCPU, High Performance model QCPU, Process CPU, Universal model QCPU the module number or CPU number is stored depending on the error that occurred. (Refer to the corresponding error code for which number has been stored.) CPU No. 1: 1, CPU No. 2: 2, CPU No. 3: 3, CPU No. 4: 4 • The individual information category codes store the following codes: 0: No error 1: (Empty) 2: File name/Drive name 3: Time (value actually measured) 4: Program error location 5: Parameter number 6: Annunciator number 7: CHK instruction failure No. (except for the Basic model QCPU and the Universal model QCPU) 8: Reason(s) for system switching failure (specific to Redundant CPU) 12: File diagnostic information (specific to the Universal model QCPU) 13: Parameter No./CPU No. (specific to the Universal model QCPU)	S (Error)	New	

Table12.18 Special register

<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SD5
SD6
SD7
SD8
SD9
SD10
SD11
SD12
SD13
SD14
SD15</td><td>Error common information</td><td>Error common information</td><td>
• Common information corresponding to the error codes (SD0) is stored here.
• The following ten types of information are stored here:
• The error common information type can be judged by the "common information category code" in SD4. (The values of the "common information category code" stored in SD4 correspond to following 1) to 8).)
1) Slot No.
<table>
<tr><th>Number</th><th>Meaning</th></tr>
<tr><td>SD5</td><td>Slot No./CPU No./Base No.*1, *2, *3, *4</td></tr>
<tr><td>SD6</td><td>I/O No.*5</td></tr>
<tr><td>SD7
SD8
SD9
SD10
SD11
SD12
SD13
SD14
SD15</td><td>(Empty)</td></tr>
</table>
*1: For a multiple CPU system that consists of the Basic model QCPU, High Performance model QCPU, Process CPU, Universal model QCPU, the slot number or CPU number is stored depending on the error that occurred.
Slot 0 in the multiple CPU system is the one on the slot on the right of the rightmost CPU module.
(Refer to the corresponding error code for which number has been stored.)
No. 1 CPU: 1, No. 2 CPU: 2, No. 3 CPU: 3, No. 4 CPU: 4
*2: If a fuse blown or I/O verify error occurred in the module loaded in the MELSECNET/H remote I/O station, the network number is stored into the upper 8 bits and the station number into the lower 8 bits.
Use the I/O No. to check the module where the fuse blown or I/O verify error occurred.
*3: 255 is stored into SD5 of the Basic model QCPU when an instruction, etc. has been executed for the module later than the one on the last slot where a module can be mounted.
*4: Definitions of base No. and slot No.
<Base No.>
Value used to identify the base unit on which the CPU module has been mounted. The following shows the definition of the base No.
<table>
<tr><th>Base No.</th><th>Definition</th></tr>
<tr><td>0</td><td>Indicates the main base unit mounted with the CPU module.</td></tr>
<tr><td>1 to 7</td><td>Indicates the extension base unit. The stage number setting made by the stage number setting connector on the extension base unit is the base No.
When stage number setting is extension 1: Base No. = 1
when stage number setting is extension 7: Base No. = 7</td></tr>
</table>
<Slot No.>
Value used to identify the slot of each base unit and the module mounted on that slot.
•The I/O slot 0 (slot on the right side of the CPU slot) of the main base unit is defined as the slot of "Slot No. = 0".
•The slot Nos. are consecutively assigned to the slots of the base units in order of the main base unit and extension base units 1 to 7.
•When the number of base unit slots has been set in the I/O assignment setting of the PLC parameter dialog box, the slot Nos. are assigned for only the number of set slots.
*5: When 0FFFF_H is stored into SD6 (I/O No.), the I/O No. cannot be identified due to overlapping I/O No., etc. in the I/O assignment setting of the PLC parameter dialog box. Therefore, identify the error location using SD5.
2) File name/Drive name
<table>
<tr><th>Number</th><th colspan="2">Meaning</th></tr>
<tr><td>SD5</td><td colspan="2">Drive</td></tr>
<tr><td>SD6
SD7
SD8
SD9</td><td colspan="2">File name
(ASCII code: 8 characters)</td></tr>
<tr><td>SD10</td><td>Extension *6</td><td>2E_H(.)</td></tr>
<tr><td>SD11</td><td colspan="2">(ASCII code: 3 characters)</td></tr>
<tr><td>SD12
SD13
SD14
SD15</td><td colspan="2">(Empty)</td></tr>
</table>
(Example) File name = ABCDEFGH. IJK
<table>
<tr><th colspan="2">b15 to b8 b7 to b0</th></tr>
<tr><td>42_H(B)</td><td>41_H(A)</td></tr>
<tr><td>44_H(D)</td><td>43_H(C)</td></tr>
<tr><td>46_H(F)</td><td>45_H(E)</td></tr>
<tr><td>48_H(H)</td><td>47_H(G)</td></tr>
<tr><td>49_H(I)</td><td>2E_H(.)</td></tr>
<tr><td>4B_H(K)</td><td>4A_H(J)</td></tr>
</table>
</td><td>S (Error)</td><td>New</td><td>QCPU</td></tr>
</table>

Table12.18 Special register


<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by
(When Set)</th><th>Corres-
ponding
ACPU
D9□□□</th><th>Corresponding
CPU</th></tr>
<tr><td>SD5</td><td rowspan="15">Error common information</td><td rowspan="15">Error common information</td><td rowspan="15">3) Time (value set)
<table><tr><th>Number</th><th>Meaning</th></tr><tr><td>SD5</td><td>Time : 1μs units (0 to 999μs)</td></tr><tr><td>SD6</td><td>Time : 1ms units (0 to 65535ms)</td></tr><tr><td>SD7</td><td rowspan="9">(Empty)</td></tr><tr><td>SD8</td></tr><tr><td>SD9</td></tr><tr><td>SD10</td></tr><tr><td>SD11</td></tr><tr><td>SD12</td></tr><tr><td>SD13</td></tr><tr><td>SD14</td></tr><tr><td>SD15</td></tr></table>4) Program error location
<table><tr><th>Number</th><th colspan="2">Meaning</th></tr><tr><td>SD5</td><td colspan="2" rowspan="4">File name
(ASCII code: 8 characters)</td></tr><tr><td>SD6</td></tr><tr><td>SD7</td></tr><tr><td>SD8</td></tr><tr><td>SD9</td><td>Extension ∗6</td><td>2EH(.)</td></tr><tr><td>SD10</td><td colspan="2">(ASCII code: 3 characters)</td></tr><tr><td>SD11</td><td colspan="2">Pattern ∗7</td></tr><tr><td>SD12</td><td colspan="2">Block No.</td></tr><tr><td>SD13</td><td colspan="2">Step No./transition condition</td></tr><tr><td>SD14</td><td colspan="2">Sequence step No. (L)</td></tr><tr><td>SD15</td><td colspan="2">Sequence step No. (H)</td></tr></table>*7 : Contents of pattern data
 
</td><td rowspan="15">S (Error)</td><td rowspan="15">New</td><td rowspan="15">QCPU</td></tr>
<tr><td>SD6</td></tr>
<tr><td>SD7</td></tr>
<tr><td>SD8</td></tr>
<tr><td>SD9</td></tr>
<tr><td>SD10</td></tr>
<tr><td>SD11</td></tr>
<tr><td>SD12</td></tr>
<tr><td>SD13</td></tr>
<tr><td>SD14</td></tr>
<tr><td>SD15</td></tr>
</table>

Table12.18 Special register

<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SD5
SD6
SD7
SD8
SD9
SD10
SD11
SD12</td><td>Error common information</td><td>Error common information</td><td>5) Reason(s) for system switching
<table><tr><th>Number</th><th>Meaning</th></tr><tr><td>SD5</td><td>System switching condition *13</td></tr><tr><td>SD6</td><td>Control system switching instruction argument</td></tr><tr><td>SD7
SD8
SD9
SD10
SD11
SD12
SD13
SD14
SD15</td><td>(Empty)</td></tr></table>*13: Details of reason(s) for system switching
0 : No system switching condition (default)
1 : Power-OFF, reset, hardware failure, watchdog timer error
2 : Stop error (except watchdog timer error)
3 : System switching request by network module
16 : Control system switching instruction
17 : Control system switching request from GX Developer
6) Reason(s) for tracking capacity excess error
The block No. when the data amount that can be tracked (100k) is exceeded is indicated by the bit pattern of the corresponding special relay.
<table><tr><th></th><th>b15</th><th>b14</th><th>b13</th><th>b12</th><th>b11</th><th>b10</th><th>b9</th><th>b8</th><th>b7</th><th>b6</th><th>b5</th><th>b4</th><th>b3</th><th>b2</th><th>b1</th><th>b0</th></tr><tr><td>SD5</td><td>1 (SM1535) (Block16)</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>1 (SM1528) (Block9)</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>1 (SM1520) (Block1)</td></tr><tr><td>SD6</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td></tr><tr><td>SD7</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td></tr><tr><td>SD8</td><td>1 (SM1583) (Block64)</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>1 (SM1568) (Block49)</td></tr><tr><td>SD9</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td></tr><tr><td>SD15</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td></tr></table></td><td>S (Error)</td><td>New</td><td>QnPRH</td></tr>
<tr><td>SD13
SD14
SD15</td><td></td><td></td><td>7) Power supply No.
<table><tr><th>Number</th><th>Meaning</th></tr><tr><td>SD5</td><td>Base No.</td></tr><tr><td>SD6</td><td>Power supply No.</td></tr><tr><td>SD7
SD8
SD9
SD10
SD11
SD12
SD13
SD14
SD15</td><td>(Empty)</td></tr></table>1: Power supply 1 fault
2: Power supply 2 fault
"Power supply module 1": Redundant power supply module mounted on POWER 1 slot of redundant base unit (Q38RB, Q68RB, Q65WRB)
"Power supply module 2": Redundant power supply module mounted on POWER 2 slot of redundant base unit (Q38RB, Q68RB, Q65WRB)</td><td>S (Error)</td><td>New</td><td>Qn(H)*1
QnPH*1
QnPRH
QnU*2</td></tr>
</table>


*1: The module whose first 5 digits of serial No. is "07032" or later.

*2: The module whose first 5 digits of serial No. is "10042" or later.

Table12.18 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD5	Error common information	Error common information	8) Tracking transmission data classification Stores the data classification during tracking. Number: SD5 — Meaning: Data type *15 SD6 to SD15: (Empty) *15: Details of data classification b15: 0: Not sent, 1: Being sent b14 to b6: 0 b5: Device data b4: Signal flow b3: PIDINIT/S. PIDINIT instruction data b2: SFC execution data b1: System switching request b0: Operation mode change request System data	S (Error)	New	QnPRH
SD6						
SD7						
SD8						
SD9						
SD10						
SD11						
SD12						
SD13						
SD14						
SD15						

Table12.18 Special register

<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SD16
SD17
SD18
SD19
SD20
SD21
SD22
SD23
SD24
SD25
SD26</td><td>Error individual information</td><td>Error individual information</td><td>
• Individual information corresponding to error codes (SD0) is stored here.
• There are the following eight different types of information are stored.
• The error individual information type can be judged by the "individual information category code" in SD4. (The values of the "individual information category code" stored in SD4 correspond to following 1) to 8), 12), and 13).)
1) (Empty)
2) File name/Drive name
<table>
<tr><th>Number</th><th colspan="2">Meaning</th></tr>
<tr><td>SD16</td><td colspan="2">Drive</td></tr>
<tr><td>SD17
SD18
SD19
SD20</td><td colspan="2">File name
(ASCII code: 8 characters)</td></tr>
<tr><td>SD21</td><td>Extension *6</td><td>2EH(.)</td></tr>
<tr><td>SD22</td><td colspan="2">(ASCII code: 3 characters)</td></tr>
<tr><td>SD23
SD24
SD25
SD26</td><td colspan="2">(Empty)</td></tr>
</table>
(Example) File name = ABCDEFGH. IJK
<table>
<tr><td>b15 to b8</td><td>b7 to b0</td></tr>
<tr><td>42H(B)</td><td>41H(A)</td></tr>
<tr><td>44H(D)</td><td>43H(C)</td></tr>
<tr><td>46H(F)</td><td>45H(E)</td></tr>
<tr><td>48H(H)</td><td>47H(G)</td></tr>
<tr><td>49H(I)</td><td>2EH(.)</td></tr>
<tr><td>4BH(K)</td><td>4AH(J)</td></tr>
</table>
3) Time (value actually measured)
<table>
<tr><th>Number</th><th>Meaning</th></tr>
<tr><td>SD16</td><td>Time : 1μs units (0 to 999μs)</td></tr>
<tr><td>SD17</td><td>Time : 1ms units (0 to 65535ms)</td></tr>
<tr><td>SD18
SD19
SD20
SD21
SD22
SD23
SD24
SD25
SD26</td><td>(Empty)</td></tr>
</table>
4) Program error location
<table>
<tr><th>Number</th><th colspan="2">Meaning</th></tr>
<tr><td>SD16
SD17
SD18
SD19</td><td colspan="2">File name
(ASCII code: 8 characters)</td></tr>
<tr><td>SD20</td><td>Extension *6</td><td>2EH(.)</td></tr>
<tr><td>SD21</td><td colspan="2">(ASCII code: 3 characters)</td></tr>
<tr><td>SD22</td><td colspan="2">Pattern *7</td></tr>
<tr><td>SD23</td><td colspan="2">Block No.</td></tr>
<tr><td>SD24</td><td colspan="2">Step No./transition No.</td></tr>
<tr><td>SD25</td><td colspan="2">Sequence step No. (L)</td></tr>
<tr><td>SD26</td><td colspan="2">Sequence step No. (H)</td></tr>
</table>
*7 : Contents of pattern data


5) Parameter No. 6) Annunciator number / 7) CHK instruction malfunction number
<table>
<tr><th>Number</th><th>Meaning</th></tr>
<tr><td>SD16</td><td>Parameter No. *16</td></tr>
<tr><td>SD17
SD18
SD19
SD20
SD21
SD22
SD23
SD24
SD25
SD26</td><td>(Empty)</td></tr>
</table>
<table>
<tr><th>Number</th><th>Meaning</th></tr>
<tr><td>SD16</td><td>No.</td></tr>
<tr><td>SD17
SD18
SD19
SD20
SD21
SD22
SD23
SD24
SD25
SD26</td><td>(Empty)</td></tr>
</table>
*16: For details of the parameter No., refer to the User's Manual (Function Explanation, Program Fundamentals) of the CPU module used.
</td><td>S (Error)</td><td>New</td><td>QCPU</td></tr>
</table>

*6 : Extensions are shown below.

Table12.19 Extension name

SDn	SDn+1		Extension	File Type
Higher 8 bits	Lower 8 bits	Higher 8 bits	Name	
51H	50H	41H	QPA	Parameters
51H	50H	47H	QPG	• Sequence program • SFC program
51H	43H	44H	QCD	Device comment
51H	44H	49H	QDI	Initial device value
51H	44H	52H	QDR	File register
51H	44H	4CH	QDL	Local device (Other than the Basic model QCPU)
51H	54H	44H	QTD	Sampling trace data (Other than the Basic model QCPU)
51H	46H	44H	QFD	Breakdown history data (Other than the Basic model QCPU and the Universal model QCPU)
51H	53H	54H	QST	SP.DEVST/S.DEVLD instruction file (For Universal model QCPU only)

Table12.18 Special register

<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td rowspan="2">SD26</td><td rowspan="2">Error individual information</td><td rowspan="2">Error individual information</td><td>8) Reason(s) for system switching failure
<table><tr><th>Number</th><th>Meaning</th></tr><tr><td>SD16</td><td>System switching prohibition condition *14</td></tr><tr><td>SD17</td><td rowspan="10">(Empty)</td></tr><tr><td>SD18</td></tr><tr><td>SD19</td></tr><tr><td>SD20</td></tr><tr><td>SD21</td></tr><tr><td>SD22</td></tr><tr><td>SD23</td></tr><tr><td>SD24</td></tr><tr><td>SD25</td></tr><tr><td>SD26</td></tr></table>*14: Details of reason(s) for system switching failure
0 : Normal switching completion (default)
1 : Tracking cable fault (cable removal, cable fault, internal circuit fault, hardware fault)
2 : Hardware failure, power OFF, reset or watchdog timer error occurring in standby system
3 : Hardware failure, power OFF, reset or watchdog timer error occurring in control system
4 : Preparing for tracking
5 : Time limit exceeded
6 : Standby system is in stop error (except watchdog timer error)
7 : Operation differs between two systems (in backup mode only)
8 : During memory copy from control system to standby system
9 : Online program change
10 : Error detected by network module of standby system
11 : System switching being executed
12 : Online module change in progress</td><td rowspan="2">S (Error)</td><td rowspan="2">New</td><td>QnPRH</td></tr>
<tr><td>12) File diagnostic information
<table><tr><td>SD16</td><td>Failuer information (H)</td><td>drive No.(L)</td></tr><tr><td>SD17
SD18
SD19
SD20</td><td colspan="2">File name
(ASCII: 8 characters)</td></tr><tr><td>SD21</td><td>EXtension *6</td><td>2EH(.)</td></tr><tr><td>SD22</td><td colspan="2">(ASCII; 3 characters)</td></tr><tr><td>SD23
SD24</td><td colspan="2">Failure information 2
(CRC value that is read)</td></tr><tr><td>SD25
SD26</td><td colspan="2">Failure information 3
(CRC value that is calculated)</td></tr></table>13) Parameter No./CPU No.
<table><tr><th>Number</th><th>Meaning</th></tr><tr><td>SD16</td><td>Parameter No.*16</td></tr><tr><td>SD17</td><td>CPU No. (1 to 4)</td></tr><tr><td>SD18</td><td rowspan="10">(Empty)</td></tr><tr><td>SD19</td></tr><tr><td>SD20</td></tr><tr><td>SD21</td></tr><tr><td>SD22</td></tr><tr><td>SD23</td></tr><tr><td>SD24</td></tr><tr><td>SD25</td></tr><tr><td>SD26</td></tr></table></td><td>QnU</td></tr>
</table>

Table12.18 Special register






Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD50	Error reset	Error number that performs error reset	• Stores error number that performs error reset	U	New	QCPU
SD51	Battery low latch	Bit pattern indicating where battery voltage drop occurred	• All corresponding bits go 1(ON) when battery voltage drops. • Subsequently, these remain 1(ON) even after battery voltage has been returned to normal.  ∗1: This does not apply to Basic model QCPU. • In the alarm, data can be held within the time specified for battery low. • The error indicates the complete discharge of the battery.	S (Error)	New	
SD52	Battery low	Bit pattern indicating where battery voltage drop occurred	• Same configuration as SD51 above • After the alarm is detected (ON), the alarm turns OFF by error detection (ON). (For the Universal model QCPU only) • Turns to 0 (OFF) when the battery voltage returns to normal thereafter.	S (Error)	New	
SD53	AC/DC DOWN detection	Number of times for AC/DC DOWN detection	• Every time the input voltage falls to or below 85% (AC power)/65% (DC power) of the rating during operation of the CPU module, the value is incremented by 1 and stored in BIN code. • The counter repeats increment and decrement of the value ; 0 → 32767 → -32768 → 0	S (Error)	D9005	
SD60	Number of module with blown fuse	Number of module with blown fuse	• Value stored here is the lowest station I/O number of the module with the blown fuse.	S (Error)	D9000	
SD61	I/O module verify error number	I/O module verify error module number	• The lowest I/O number of the module where the I/O module verification number took place.	S (Error)	D9002	

Table12.18 Special register

<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SD62</td><td>Annunciator number</td><td>Annunciator number</td><td>• The first annunciator number (F number) to be detected is stored here.</td><td>S (Instruction execution)</td><td>D9009</td><td rowspan="18">QCPU</td></tr>
<tr><td>SD63</td><td>Number of annunciators</td><td>Number of annunciators</td><td>• Stores the number of annunciators searched.</td><td>S (Instruction execution)</td><td>D9124</td></tr>
<tr><td>SD64</td><td rowspan="16">Table of detected annunciator numbers</td><td rowspan="16">Annunciator detection number</td><td rowspan="16">When F goes ON due to OUT F or SET F instruction, the F numbers which go progressively ON from SD64 through SD79 are registered.
The F numbers turned OFF by RST F instruction are deleted from SD64 - SD79, and the F numbers stored after the deleted F numbers are shifted to the preceding registers.
Execution of the LEDR instruction shifts the contents of SD64 to SD79 up by one.
After 16 annunciators have been detected, detection of the 17th will not be stored from SD64 through SD79.
 
</td><td rowspan="16">S (Instruction execution)</td><td>D9125</td></tr>
<tr><td>SD65</td><td>D9126</td></tr>
<tr><td>SD66</td><td>D9127</td></tr>
<tr><td>SD67</td><td>D9128</td></tr>
<tr><td>SD68</td><td>D9129</td></tr>
<tr><td>SD69</td><td>D9130</td></tr>
<tr><td>SD70</td><td>D9131</td></tr>
<tr><td>SD71</td><td>D9132</td></tr>
<tr><td>SD72</td><td>New</td></tr>
<tr><td>SD73</td><td>New</td></tr>
<tr><td>SD74</td><td>New</td></tr>
<tr><td>SD75</td><td>New</td></tr>
<tr><td>SD76</td><td>New</td></tr>
<tr><td>SD77</td><td>New</td></tr>
<tr><td>SD78</td><td>New</td></tr>
<tr><td>SD79</td><td>New</td></tr>
<tr><td>SD80</td><td>CHK number</td><td>CHK number</td><td colspan="2">• Error codes detected by the CHK instruction are stored as BCD code.</td><td>S (Instruction execution)</td><td>New</td><td rowspan="11">Qn(H)
QnPH
QnPRH</td></tr>
<tr><td>SD90</td><td rowspan="10">Step transition monitoring timer setting value (Enabled only when SFC program exists)</td><td rowspan="10">F number for timer set value and time over error</td><td>Corresponds to SM90</td><td rowspan="10">• Set the annunciator number (F number) that will be turned ON when the step transition monitoring timer setting or monitoring timeout occurs.
 

• Turning ON any of SM90 to SM99 during an active step starts the timer, and if the transition condition next to the corresponding step is not met within the timer time limit, the set annunciator (F) turns ON.</td><td rowspan="10">U</td><td>D9108</td></tr>
<tr><td>SD91</td><td>Corresponds to SM91</td><td>D9109</td></tr>
<tr><td>SD92</td><td>Corresponds to SM92</td><td>D9110</td></tr>
<tr><td>SD93</td><td>Corresponds to SM93</td><td>D9111</td></tr>
<tr><td>SD94</td><td>Corresponds to SM94</td><td>D9112</td></tr>
<tr><td>SD95</td><td>Corresponds to SM95</td><td>D9113</td></tr>
<tr><td>SD96</td><td>Corresponds to SM96</td><td>D9114</td></tr>
<tr><td>SD97</td><td>Corresponds to SM97</td><td>New</td></tr>
<tr><td>SD98</td><td>Corresponds to SM98</td><td>New</td></tr>
<tr><td>SD99</td><td>Corresponds to SM99</td><td>New</td></tr>
</table>



Table12.18 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD100	Transmission speed storage area	Stores the transmission speed specified in the serial communication setting.	96 : 9.6kbps, 192 : 19.2kbps, 384 : 38.4kbps, 576 : 57.6kbps, 1152 : 115.2kbps	S (Power-ON or reset)	New	Q00/Q01 Q00UJ Q00U Q01U Q02U*4
SD101	Communication setting storage area	Stores the communication setting specified in the serial communication setting.	 * : Since the data is used by the system, it is undefined.	S (Power-ON or reset)	New	
SD102	Transmission wait time storage area	Stores the transmission wait time specifed in the serial communication setting.	0 : No waiting time 10 to 150 : Waiting time (unit: ms) Defaults to 0.	S (Power-ON or reset)	New	
SD105	CH1 transmission speed setting (RS-232)	Stores the preset transmission speed when GX Developer is used.	96 : 9600bps, 192 : 19.2kbps, 384 : 38.4kbps, 576 : 57.6kbps, 1152 : 115.2kbps *: Other than RS-232 connection holds the data at RS-232 connection. (When disconnected, the default value is 1152.)	S	New	Qn(H) QnPH QnPRH QnU*3
SD110	Data sending result storage area	Stores the data sending result when the serial communication function is used.	Stores the error code at the timeout sending data.	S (Error)	New	Q00/Q01 Q00UJ Q00U Q01U Q02U*4
SD111	Data receiving result storage area	Stores the data receiving result when the serial communication function is used.	Stores the error code at the time of receiving data.	S (Error)		
SD118	Amount of battery consumption	Amount of battery consumption	Displays the current amount of battery consumption. The value range:1 to 2(Q00UJCPU, Q00UCPU, Q01UCPU, Q02UCPU, Q03UD(E)CPU, Q04UD(E)HCPU) 1 to 3(Q06UD(E)HCPU) 1 to 4(Q10UD(E)HCPU, Q20UD(E)HCPU, Q13UD(E)HCPU, Q26UD(E)HCPU)	S (Status change)	New	QnU*4
SD119	Battery life-prolonging factor	Battery life-prolonging factor	Stores the factor which makes the battery life-prolonging function valid. When SD119 is other than 0, the battery life-prolonging function is valid. 	S (Status change)	New	QnU

*3: This applies to Universal model QCPUs except for the Built-in Ethernet port QCPU.

*4: The module whose first 5 digits of serial No. is "10102" or later.

Table12.18 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD130 SD131 SD132 SD133 SD134 SD135 SD136 SD137	Fuse blown module	Bit pattern in units of 16 points, indicating the modules whose fuses have blown 0: No blown fuse 1: Blown fuse present	• The numbers of output modules whose fuses have blown are input as a bit pattern (in units of 16 points). (If the module numbers are set by parameter, the parameter-set numbers are stored.)  • Not cleared even if the blown fuse is replaced with a new one. This flag is cleared by error resetting operation	S (Error)	New	Q00J/Q00/Q01
SD150 SD151 SD152 SD153 SD154 SD155 SD156 SD157	I/O module verify error	Bit pattern, in units of 16 points, indicating the modules with verify errors. 0: No I/O verify errors 1: I/O verify error present	• When I/O modules, of which data are different from those entered at power-ON, have been detected, the I/O module numbers (in units of 16 points) are entered in bit pattern. (Preset I/O module numbers set in parmeters when parameter setting has been performed.)  • Not cleared even if the blown fuse is replaced with a new one. This flag is cleared by error resetting operation.			

(2) System information

Table12.20 Special register






Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD200	Status of switch	Status of CPU switch	• The CPU switch status is stored in the following format:  1): CPU switch status — 0: RUN 1: STOP 2: L.CLR 2): Memory card switch — Always OFF 3): DIP switch — b8 through b12 correspond to SW1 through SW5 of system setting switch 1. 0: OFF, 1: ON. b13 through b15 are empty.	S (Every END processing)	New	Qn(H) QnPH QnPRH
			• The CPU switch status is stored in the following format:  1): CPU switch status — 0: RUN 1: STOP 2): Memory card switch — Always OFF	S (Every END processing)	New	Q00J/Q00/Q01
			• The CPU switch status is stored in the following format:  1): CPU switch status — 0: RUN 1: STOP 2): Memory card switch — Always OFF	S (when RUN/ STOP/RESET switch changed)	New	QnU
SD201	LED status	Status of CPU-LED	• The following bit patterns store the status of the LEDs on the CPU module: • 0 is off, 1 is on, and 2 is flicker.  1): RUN 5): BOOT 2): ERR. 6): Empty Mode bit pattern 3): USER 7): Empty 0: OFF 1: Green 4): BAT. 8): MODE 2: Orange (The Basic model QCPU does not include 3) to 8).)	S (Status change)	New	Q00J/Q00/Q01 Qn(H) QnPH QnPRH
			• The following bit patterns store the status of the LEDs on the CPU module: • 0 is off, 1 is on, and 2 is flicker.  1): RUN 5): BOOT 2): ERROR 6): Empty 3): USER 7): Empty 4): BAT. 8): MODE (The Q00UJCPU, Q00UCPU, and Q01UCPU do not include 5).)	S (Status change)	New	QnU

Table12.20 Special register




Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD202	LED off command	Bit pattern of LED that is turned off	• Specify the LEDs to be turned off using this register, and turn SM202 from OFF to ON to turn off the specified LEDs. USER and BOOT can be specified as the LEDs to be turned off. • Specify the LEDs to be turned off in the following bit pattern. (Turned off at 1, not be turned off at 0.)  (The Q00UJCPU, Q00UCPU, and Q01UCPU cannot specify the BOOT LED.)	U	New	Qn(H) QnPH QnPRH QnU
SD203	Operating status of CPU	Operating status of CPU	• The CPU operating status is stored as indicated in the following figure:  1): Operating status of CPU — 0: RUN; 1: STEP-RUN (For the QnACPU only); 2: STOP; 3: PAUSE 2): STOP/PAUSE cause — 0: Instruction in remote operation program from RUN/STOP switch ("RUN/STOP/RESET switch" for Basic model QCPU); 1: Remote contact; 2: Remote operation from GX Developer/serial communication, etc.; 3: Internal program instruction Note: Priority is earliest first — 4: Error	S (Every END processing)	D9015 format change	QCPU
SD204	LED display color	CPU-LED display color	• The LED display color of the LED status shown in SD201 1) to 8).  (The Q00UJCPU, Q00UCPU, and Q01UCPU do not include 5).)	S (status change)	New	QnU

Table12.20 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD207	LED display priority ranking	Priorities 1 to 4	• When error is generated, the LED display (flicker) is made according to the error number setting priorities. (The Basic model QCPU supports only the annunciator (error item No. 7). • The Universal model QCPU sets execution/non-execution of LED display of the error corresponding to the each priority ranking when the error occurs. • The setting areas for priorities are as follows: b15 to b12 b11 to b8 b7 to b4 b3 to b0 SD207: Priority 4 | Priority 3 | Priority 2 | Priority 1 SD208: Priority 8 | Priority 7 | Priority 6 | Priority 5 SD209: Priority 11 | Priority 10 | Priority 9 (Priority 11 is valid when Redundant CPU is used.) Default Value SD207 = 4321H(0000H for Basic model QCPU) SD208 = 8765H(0700H for Basic model QCPU) (0765H for Redundant CPU) SD209 = 00A9H(0000H for Basic model QCPU) (0B09H for Redundant CPU) • No display is made if "0" is set. • In case of the Basic model QCPU, the ERR. LED turns ON when the annunciator turns ON, if "7" has been set to either of priorities 1 to 11. • In case of the Basic model QCPU, the ERR. LED does not turn ON when the annumciator turns ON, if "7" has not been set to either of priorities 1 to 11. However, even if "0" has been set, information concerning CPU module operation stop (including parameter settings) errors will be indicated by the LEDs without conditions.	U	D9038	Q00J/ Q00/Q01*9 Qn(H) QnPH QnPRH QnU
SD208		Priorities 5 to 8			D9039 format change	
SD209		Priorities 9 to 11			New	
SD210	Clock data	Clock data (year, month)	• The year (last two digits) and month are stored as BCD code as shown below: b15 to b12 b11 to b8 b7 to b4 b3 to b0 Example: July, 1993 9307H Year Month	S (Request)/U	D9025	QCPU
SD211	Clock data	Clock data (day, hour)	• The day and hour are stored as BCD code as shown below: b15 to b12 b11 to b8 b7 to b4 b3 to b0 Example: 31st, 10 a.m. 3110H Day Hour		D9026	
SD212	Clock data	Clock data (minute, second)	• The minutes and seconds (after the hour) are stored as BCD code as shown below: b15 to b12 b11 to b8 b7 to b4 b3 to b0 Example: 35 min, 48 s 3548H Minute Second		D9027	

*9: Function version is B or later.

Table12.20 Special register









<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SD213</td><td>Clock data</td><td>Clock data (higher digits of year, day of week)</td><td>• The year (first two digits) and the day of the week are stored as BCD code as shown below.
  </td><td>S (Request)/U</td><td>D9028</td><td rowspan="10">QCPU</td></tr>
<tr><td>SD220</td><td rowspan="8">LED display data</td><td rowspan="8">LED display data</td><td rowspan="8">• LED display ASCII data (16 characters) stored here.
(On the Basic model QCPU, the registers store the message (16 characters of ASCII data) at error occurrence (including annunciator ON).
<table><tr><th></th><th>b15 to b8</th><th>b7 to b0</th></tr><tr><td>SD220</td><td>15th character from the right</td><td>16th character from the right</td></tr><tr><td>SD221</td><td>13th character from the right</td><td>14th character from the right</td></tr><tr><td>SD222</td><td>11th character from the right</td><td>12th character from the right</td></tr><tr><td>SD223</td><td>9th character from the right</td><td>10th character from the right</td></tr><tr><td>SD224</td><td>7th character from the right</td><td>8th character from the right</td></tr><tr><td>SD225</td><td>5th character from the right</td><td>6th character from the right</td></tr><tr><td>SD226</td><td>3rd character from the right</td><td>4th character from the right</td></tr><tr><td>SD227</td><td>1st character from the right</td><td>2nd character from the right</td></tr></table>• The LED display device data at the time of CHK is not stored in the Basic model QCPU and the Universal model QCPU.</td><td rowspan="8">S (When changed)</td><td rowspan="8">New</td></tr>
<tr><td>SD221</td></tr>
<tr><td>SD222</td></tr>
<tr><td>SD223</td></tr>
<tr><td>SD224</td></tr>
<tr><td>SD225</td></tr>
<tr><td>SD226</td></tr>
<tr><td>SD227</td></tr>
<tr><td>SD235</td><td>Module to which online module change is being performed</td><td>The header I/O number of the module to which online module change is being performed /10H</td><td>• 10H is added to the value of the header I/O number of which the online module change is being performed.</td><td>S (During online module change)</td><td>New</td><td>QnPH
QnPRH</td></tr>
<tr><td>SD240</td><td>Base mode</td><td>0: Automatic mode
1: Detail mode</td><td>• Stores the base mode.</td><td>S (Initial)</td><td>New</td><td rowspan="2">QCPU</td></tr>
<tr><td>SD241</td><td>Extension stage number</td><td>0: Main base only
1 to 7: Extension stage number</td><td>• Stores the maximum number of the extension bases being installed.</td><td>S (Initial)</td><td>New</td></tr>
</table>

Table12.20 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD242	A/Q base differentiation	Base type differentiation 0: QA**B is installed (A mode) 1: Q**B is installed (Q mode)		S (Initial)	New	Qn(H) QnPH QnPRH
	Installed Q base presence/ absence	Base type differentiation 0: Base not installed 1: Q**B is installed		S (Initial)	New	Q00J/Q00/Q01
	Installed Q base presence/ absence	Base type differentiation 0: Base not installed 1: Q**B is installed	 • The bits from the third extension stage to the seventh extension stage are fixed to "0" in the Q00UJCPU. • The bits from the fifth extension stage to the seventh extension stage are fixed to "0" in the Q00UCPU, Q01UCPU, and Q02UCPU.	S (Initial)	New	QnU
SD243 SD244	No. of base slots	No. of base slots	 • As shown above, each area stores the number of slots being installed. • The bits from the third extension stage to the seventh extension stage are fixed to "0" in the Q00UJCPU. • The bits from the fifth extension stage to the seventh extension stage are fixed to "0" in the Q00UCPU, Q01UCPU, and Q02UCPU.	S (Initial)	New	Qn(H) QnPH QnPRH QnU
SD243 SD244	No. of base slots (Operation status)	No. of base slots	 • As shown above, each area stores the number of slots being installed. (Number of set slots when parameter setting has been made)	S (Initial)	New	Q00J/Q00/Q01
SD245 SD246	No. of base slots (Mounting status)	No. of base slots	 • As shown above, each area stores the number of module-mounted slots of the base unit (actual number of slots of the installed base unit).	S (Initial)		Q00J/Q00/Q01*9
SD250	Loaded maximum I/O	Loaded maximum I/O No.	• When SM250 goes from OFF to ON, the upper 2 digits of the final I/O number plus 1 of the modules loaded are stored as BIN values.	S (Request END)	New	Qn(H) QnPH QnPRH
			• The upper 2 digits of the final I/O number plus 1 of the modules loaded are stored as BIN values.	S (Initial)	New	Q00J/Q00/Q01 QnU


*9: Function version is B or later.

Table12.20 Special register

Number	Name	Meaning		Explanation	Set by (When Set)	Corresponding ACPU D9□□□	Corresponding CPU
SD254	MELSECNET/10. MELSECNET/H information	Number of modules installed		• Indicates the number of mounted MELSECNET/10 modules or MELSECNET/H modules.	S (Initial)	New	QCPU
SD255		Information from 1st module	I/O No.	• Indicates I/O number of mounted MELSECNET/10 module or MELSECNET/H module			
SD256			Network No.	• Indicates network No. of mounted MELSECNET/10 module or MELSECNET/H module			
SD257			Group number	• Indicates group No. of mounted MELSECNET/10 module or MELSECNET/H module			
SD258			Station No.	• Indicates station No. of mounted MELSECNET/10 module or MELSECNET/H module			
SD259			Standby informa-tion	• In the case of standby stations, the module number of the standby station is stored. (1 to 4)			Qn(H) QnPH QnPRH QnU*10
SD260 to SD264		Information from 2nd module		• Configuration is identical to that for the first module.			
SD265 to SD269		Information from 3rd module		• Configuration is identical to that for the first module.			Qn(H) QnPH QnPRH QnU*11
SD270 to SD274		Information from 4th module		• Configuration is identical to that for the first module.			
SD280	CC-Link error	Error detection status		1) When Xn0 of the mounted CC-Link module turns ON, the bit of the corresponding station turns to 1 (ON). 2) When either Xn1 or XnF of the mounted CC-Link module turns OFF, the bit of the corresponding station turns to 1 (ON). 3) Turns to 1 (ON) when communication between the mounted CC-Link module and CPU module cannot be made.  The above module Nos. n are in order of the head I/O numbers. (However, the one where parameter setting has not been made is not counted.)	S (Error)	New	Qn(H) QnPH QnPRH

*10: The Universal model QCPU except the Q00UJCPU, Q00UCPU, and Q01UCPU.
*11: The Universal model QCPU except the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU.

Table12.20 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD281	CC-Link error	Error detection status	1) When Xn0 of the mounted CC-Link module turns ON, the bit of the corresponding station turns to 1 (ON). 2) When either Xn1 or XnF of the mounted CC-Link module turns OFF, the bit of the corresponding station turns to 1 (ON). 3) Turns to 1 (ON) when communication between the mounted CC-Link module and CPU module cannot be made.  The above module Nos. n are in order of the head I/O numbers. (However, the one where parameter setting has not been made is not counted.)	S (Error)	New	Qn(H)*14 QnPH*14 QnPRH*15
SD286	Device assignment	Points assigned to M (for extension)	• The number of points assigned to M is stored with 32 bits. • Even if the points assigned to M are 32k points or less, the points are stored.	S (Initial)	New	QnU*16
SD287						
SD288		Points assigned to B (for extension)	• The number of points assigned to B is stored with 32 bits. • Even if the points assigned to B are 32k points or less, the points are stored.			
SD289						
SD290	Device assignment (Same as parameter contents)	Number of points assigned for X	• Stores the number of points currently set for X devices	S (Initial)	New	QCPU
SD291		Number of points assigned for Y	• Stores the number of points currently set for Y devices			
SD292		Number of points assigned for M	• Stores the number of points currently set for M devices			
SD293		Number of points assigned for L	• Stores the number of points currently set for L devices			
SD294		Number of points assigned for B	• Stores the number of points currently set for B devices			
SD295		Number of points assigned for F	• Stores the number of points currently set for F devices			
SD296		Number of points assigned for SB	• Stores the number of points currently set for SB devices			
SD297	Device assignment (Same as parameter contents)	Number of points assigned for V	• Stores the number of points currently set for V devices	S (Initial)	New	
SD298		Number of points assigned for S	• Stores the number of points currently set for S devices			
SD299		Number of points assigned for T	• Stores the number of points currently set for T device			
SD300		Number of points assigned for ST	• Stores the number of points currently set for ST devices			
SD301		Number of points assigned for C	• Stores the number of points currently set for C devices			
SD302		Number of points assigned for D	• Stores the number of points currently set for D devices			
SD303		Number of points assigned for W	• Stores the number of points currently set for W devices			
SD304		Number of points assigned for SW	• Stores the number of points currently set for SW devices			

*14: The module whose first 5 digits of serial No. is "08032" or later.
*15: The module whose first 5 digits of serial No. is "09012" or later.
*16: The module whose first 5 digits of serial No. is "10042" or later.

Table12.20 Special register

Number	Name	Meaning		Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD305	Device assignment (Index register)	16 bit modification Number of points assigned for Z		• Stores the number of points of index register (Z) to be modified in the range of 16 bits. (The assignment is set by the ZR device index modification setting parameter.)	S (Initial)	New	QnU
SD306	Device assignment (Same as parameter contents)	Number of points assigned for ZR (for extension)		• Stores the number of ZR device points (except the number of points of extended data register (D) and extended link register (W)). The number of assignment points of ZR device is stored into this SD only when 1k point or more is set to the extended data register (D) and extended link register (W).	S (Initial)	New	QnU*17
SD307							
SD308	Device assignment (assignment including the number of points set to the extended data register (D) and extended link register (W))	Number of points assigned for D (for inside + for extension)		• Stores the total number of points of the extended data register (D) and data register in internal device memory area (stores the value in 32-bit binary).			
SD309							
SD310		Number of points assigned for W (for inside + for extension)		• Stores the total number of points of the extended link register (W) and link register in internal device memory area (stores the value in 32-bit binary).			
SD311							
SD315	Time reserved for communication processing	Time reserved for communication processing		• Reserves the designated time for communication processing with GX Developer or other units. • The greater the value is designated, the shorter the response time for communication with other devices (GX Developer, serial communication units) becomes. • If the designated value is out of the range above, it is processed that no setting is made. • Setting range: 1 to 100 ms • Note that the scan time becomes longer by the designated time.	U	New	Q00J/Q00/Q01 Qn(H) QnPH QnPRH
SD340	Ethernet information	No. of modules installed		• Indicates the number of mounted Ethernet module.	S (Initial)	New	QCPU
SD341		Information of 1st module	I/O No.	• Indicates I/O No. of mounted Ethernet module			
SD342			Network No.	• Indicates network No. of mounted Ethernet module			
SD343			Group No.	• Indicates group No. of mounted Ethernet module			
SD344			Station No.	• Indicates station No. of mounted Ethernet module			
SD345 to SD346			Empty	• Empty (With QCPU, the Ethernet module IP address of the 1st module is stored in buffer memory.)			Qn(H) QnPH QnPRH QnU*10
SD347			Empty	• Empty (With QCPU, the Ethernet module error code of the 1st module is read with the ERRRD instruction.)			
SD348 to SD354	Ethernet information	Information from 2nd module		• Configuration is identical to that for the first module.	S (Initial)	New	Qn(H) QnPH QnPRH QnU*11
SD355 to SD361		Information from 3rd module		• Configuration is identical to that for the first module.			
SD362 to SD368		Information from 4th module		• Configuration is identical to that for the first module.			

*10: The Universal model QCPU except the Q00UJCPU, Q00UCPU, and Q01UCPU.
*11: The Universal model QCPU except the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU.
*17: The Universal model QCPU except the Q00UJCPU.

Table12.20 Special register




Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD380	Ethernet instruction reception status	Instruction reception status of 1st module	 ON: Received (Channel is being used.) OFF: Not received (Channel is not used.)	S (Instruction execution)	New	QnPRH
SD381	Ethernet instruction reception status	Instruction reception status of 2nd module	• Configuration is identical to that for the first module.			
SD382		Instruction reception status of 3rd module	• Configuration is identical to that for the first module.			
SD383		Instruction reception status of 4th module	• Configuration is identical to that for the first module.			

Table12.20 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD393	Multiple CPU system information	Number of multiple CPUs	• The number of CPU modules that comprise the multiple CPU system is stored. (1 to 3, Empty also included)	S (Initial)	New	Q00/Q01*9 QnU
SD394		CPU mounting information	• The CPU module types of No. 1 CPU to 3 and whether the CPU modules are mounted or not are stored. 			Q00/Q01*9
SD395		Multiple CPU number	• In a multiple CPU system configuration, the CPU number of the host CPU is stored. CPU No. 1: 1, CPU No. 2: 2, CPU No. 3: 3, CPU No. 4: 4	S (Initial)	New	Q00/Q01*9 Qn(H)*9 QnPH QnU
SD396		No. 1 CPU operation status	The operation information of each CPU No. is stored. (The information on the number of multiple CPUs indicated in SD393 is stored.) 	S (END processing error)	New	Q00/Q01*9 QnU*17
SD397		No. 2 CPU operation status				
SD398		No. 3 CPU operation status				
SD399		No. 4 CPU operation statu				QnU*11

*9: Function version is B or later.
*11: The Universal model QCPU except the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU.
*17: The Universal model QCPU except the Q00UJCPU.

(3) System clocks/counters

Table12.21 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD412	1 second counter	Number of counts in 1-second units	• Following programmable controller CPU module RUN, 1 is added each second • Count repeats from 0 to 32767 to -32768 to 0	S (Status change)	D9022	QCPU
SD414	2n second clock setting	2n second clock units	• Stores value n of 2n second clock (Default is 30) • Setting can be made between 1 and 32767	U	New	
SD415	2nms clock setting	2nms clock units	• Stores value n of 2nms clock (Default is 30) • Setting can be made between 1 and 32767	U	New	Qn(H) QnPH QnPRH QnU
SD420	Scan counter	Number of counts in each scan	• Incremented by 1 for each scan execution after the CPU module is set to RUN. (Not counted by the scan in an initial execution type program.) • Count repeats from 0 to 32767 to -32768 to 0	S (Every END processing)	New	
			• Incremented by 1 for each scan execution after the CPU module is set to RUN. • Count repeats from 0 to 32767 to -32768 to 0	S (Every END processing)	New	Q00J/Q00/Q01
SD430	Low speed scan counter	Number of counts in each scan	• Incremented by 1 for each scan execution after the CPU module is set to RUN. • Count repeats from 0 to 32767 to -32768 to 0 • Used only for low speed execution type programs	S (Every END processing)	New	Qn(H) QnPH

(4) Scan information

Table12.22 Special register


Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD500	Execution program No.	Program No. in execution	• Program number of program currently being executed is stored as BIN value.	S (Status change)	New	Qn(H) QnPH QnPRH QnU
SD510	Low speed excution type program No.	Low speed execution type program No. in execution	• Program number of low speed excution type program No. currently being executed is stored as BIN value. • Enabled only when SM510 is ON.	S (Every END processing)	New	Qn(H) QnPH
SD520	Current scan time	Current scan time (in 1 ms units)	• The current scan time is stored into SD520 and SD521. (Measurement is made in 100 μs units. (For the Universal model QCPU, in 1μs units.)) SD520: Stores the ms place. (Storage range: 0 to 65535) SD521: Stores the μs place. (Storage range: 0 to 900 (For the Universal model QCPU, storage range is 0 to 999)) (Example) When the current scan time is 23.6ms, the following values are stored. SD520 = 23 SD521 = 600	S (Every END processing)	D9018 format change	QCPU
SD521		Current scan time (in 100 μs units)		S (Every END processing)	New	
SD522	Initial scan time	Initial scan time (in 1 ms units)	• Stores the scan time of an initial execution type program into SD522 and SD523. (Measurement is made in 100 μs units. (For the Universal model QCPU, in 1μs units.)) SD522: Stores the ms place. (Storage range: 0 to 65535) SD523: Stores the μs place. (Storage range: 0 to 900 (For the Universal model QCPU, storage range is 0 to 999))	S (First END processing)	New	Qn(H) QnPH QnPRH QnU
SD523		Initial scan time (in 100 μs units)				
SD524	Minimum scan time	Minimum scan time (in 1 ms units)	• Stores the minimum value of the scan time except that of an initial execution type program into SD524 and SD525. (Measurement is made in 100 μs units. (For the Universal model QCPU, in 1μs units.)) SD524: Stores the ms place. (Storage range: 0 to 65535) SD525: Stores the μs place. (Storage range: 0 to 900 (For the Universal model QCPU, storage range is 0 to 999))	S (Every END processing)	D9017 format change	
SD525		Minimum scan time (in 100 μs units)		S (Every END processing)	New	
SD526	Maximum scan time	Maximum scan time (in 1 ms units)	• Stores the maximum value of the scan time except that of an initial execution type program into SD526 and SD527. (Measurement is made in 100 μs units. (For the Universal model QCPU, in 1μs units.)) SD526: Stores the ms place. (Storage range: 0 to 65535) SD527: Stores the μs place. (Storage range: 0 to 900 (For the Universal model QCPU, storage range is 0 to 999))	S (Every END processing)	D9019 format change	
SD527		Maximum scan time (in 100 μs units)			New	
SD528	Current scan time for low speed execution type programs	Current scan time (in 1 ms units)	• Stores the current scan time of a low speed execution type program into SD528 and SD529. (Measurement is made in 100 μs units.) SD528: Stores the ms place. (Storage range: 0 to 65535) SD529: Stores the μs place. (Storage range: 0 to 900)	S (Every END processing)	New	Qn(H) QnPH
SD529		Current scan time (in 100 μs units)				
SD532	Minimum scan time for low speed execution type programs	Minimum scan time (in 1 ms units)	• Stores the minimum value of the scan time of a low speed execution type program into SD532 and SD533. (Measurement is made in 100 μs units.) SD532: Stores the ms place. (Storage range: 0 to 65535) SD533: Stores the μs place. (Storage range: 0 to 900)	S (Every END processing)	New	
SD533		Minimum scan time (in 100 μs units)				
SD534	Maximum scan time for low speed execution type programs	Maximum scan time (in 1 ms units)	• Stores the maximum value of the scan time except that of the first scan of a low speed execution type program into SD534 and SD535. (Measurement is made in 100 μs units.) SD534: Stores the ms place. (Storage range: 0 to 65535) SD535: Stores the μs place. (Storage range: 0 to 900)	S (Every END processing)	New	
SD535		Maximum scan time (in 100 μs units)				
SD540	END processing time	END processing time (in 1 ms units)	• Stores the time from the end of a scan execution type program to the start of the next scan into SD540 and SD541. (Measurement is made in 100 μs units.(For the Universal model QCPU, in 1μs units.)) SD540: Stores the ms place. (Storage range: 0 to 65535) SD541: Stores the μs place. (Storage range: 0 to 900) (Storage range: 0 to 900 (For the Universal model QCPU, storage range is 0 to 999))	S (Every END processing)	New	Qn(H) QnPH QnPRH QnU
SD541		END processing time (in 100 μs units)				

Table12.22 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU D9□□□	Corresponding CPU
SD524	Minimum scan time	Minimum scan time (in 1 ms units)	• Stores the minimum value of the scan time into SD524 and SD525. (Measurement is made in 100 μs units.) SD524: Stores the ms place. (Storage range: 0 to 65535) SD525: Stores the μs place. (Storage range: 0 to 900)	S (Every END processing)	New	Q00J/Q00/Q01
SD525		Minimum scan time (in 100 μs units)				
SD526	Maximum scan time	Maximum scan time (in 1 ms units)	• Stores the maximum value of the scan time into SD526 and SD527. (Measurement is made in 100 μs units.) SD526: Stores the ms place. (Storage range: 0 to 65535) SD527: Stores the μs place. (Storage range: 0 to 900)	S (Every END processing)		
SD527		Maximum scan time (in 100 μs units)				
SD540	END processing time	END processing time (in 1 ms units)	• Stores the time from when the scan program ends until the next scan starts into SD540 and SD541. (Measurement is made in 100 μs units.) SD540: Stores the ms place. (Storage range: 0 to 65535) SD541: Stores the μs place. (Storage range: 0 to 900)	S (Every END processing)	New	
SD541		END processing time (in 100 μs units)				
SD542	Constant scan wait time	Constant scan wait time (in 1 ms units)	• Stores the wait time for constant scan setting into SD542 and SD543. (Measurement is made in 100 μs units. (For the Universal model QCPU, in 1μs units.)) SD542: Stores the ms place. (Storage range: 0 to 65535) SD543: Stores the μs place. (Storage range: 0 to 900 (For the Universal model QCPU, storage range is 0 to 999))	S (Every END processing)	New	QCPU
SD543		Constant scan wait time (in 100 μs units)				
SD544	Cumulative execution time for low speed execution type programs	Cumulative execution time for low speed execution type programs (in 1 ms units)	• Stores the cumulative execution time of a low speed execution type program into SD544 and SD545. (Measurement is made in 100 μs units.) SD544: Stores the ms place. (Storage range: 0 to 65535) SD545: Stores the μs place. (Storage range: 0 to 900) • Cleared to 0 after the end of one low speed scan.	S (Every END processing)	New	Qn(H) QnPH
SD545		Cumulative execution time for low speed execution type programs (in 100 μs units)				
SD546	Execution time for low speed execution type programs	Execution time for low speed execution type programs (in 1 ms units)	• Stores the execution time of a low speed execution type program during one scan into SD546 and SD547. (Measurement is made in 100 μs units.) SD546: Stores the ms place. (Storage range: 0 to 65535) SD547: Stores the μs place. (Storage range: 0 to 900) • Stored every scan.	S (Every END processing)	New	
SD547		Execution time for low speed execution type programs (in 100 μs units)				
SD548	Scan execution type program execution time	Scan execution type program execution time (in 1 ms units)	• Stores the execution time of a scan execution type program during one scan into SD548 and SD549. (Measurement is made in 100 μs units.) SD548: Stores the ms place. (Storage range: 0 to 65535) SD549: Stores the μs place. (Storage range: 0 to 900) • Stored every scan.	S (Every END processing)	New	Qn(H) QnPH QnPRH
SD549		Scan execution type program execution time (in 100 μs units)				
SD548	Scan program execution time	Scan program execution time (in 1 ms units)	• Stores the execution time of a scan program during one scan into SD548 and SD549. (Measurement is made in 100 μs units. (For the Universal model QCPU, in 1μs units.)) SD548: Stores the ms place. (Storage range: 0 to 65535) SD549: Stores the μs place. (Storage range: 0 to 900 (For the Universal model QCPU, storage range is 0 to 999)) • Stored every scan.	S (Every END processing)	New	Q00J/Q00/Q01 QnU
SD549		Scan program execution time (in 100 μs units)				
SD550	Service interval measurement module	Unit/module No.	• Sets I/O number for module that measures service interval.	U	New	Qn(H) QnPH QnPRH
SD551	Service interval time	Module service interval (in 1 ms units)	• Stores the service interval for the module specified in SD550 into SD551 and SD552 when SM551 is turned ON. (Measurement is made in 100 μs units.) SD551: Stores the ms place. (Storage range: 0 to 65535) SD552: Stores the μs place. (Storage range: 0 to 900)	S (Request)	New	
SD552		Module service interval (in 100 μs units)				

(5) Memory card




Table12.23 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD600	Memory card typs	Memory card typs	• Indicates the type of the memory card installed.  (The bits for the drive 1 (RAM) type and drive 2 (ROM) type are fixed to "0" in the Q00UJCPU, Q00UCPU, and Q01UCPU.)	S (Initial and card removal)	New	Qn(H) QnPH QnPRH QnU
SD602	Drive 1 (Memory card RAM) capacity	Drive 1 capacity	• Drive 1 capacity is stored in 1 k byte units. • (Empty capacity after format is stored.)	S (Initial and card removal)	New	Qn(H) QnPH QnPRH QnU*2
SD603	Drive 2 (Memory card ROM) capacity	Drive 2 capacity	• Drive 2 capacity is stored in 1 k byte units.*1	S (Initial and card removal)	New	
SD604	Memory card use conditions	Memory card use conditions	• The use conditions for memory card are stored as bit patterns . (In use when ON) • The significance of these bit patterns is indicated below: b0 : Boot operation (QBT) b1 : Parameters (QPA) b2 : Device comments (QCD) b3 : Device initial value (QDI) b4 : File register R (QDR) b5 : Sampling trace (QTD) b6 : Not used b7 : Not used b8 : Not used b9 : CPU fault history (QFD) b10 : Not used b11 : Local device (QDL) b12 : Not used b13 : Not used b14 : Not used b15 : Not used	S (Status change)	New	Qn(H) QnPH QnPRH
	Memory card use conditions	Memory card use conditions	• The use conditions for memory card are stored as bit patterns . (In use when ON) • The significance of these bit patterns is indicated below: b0 : Boot operation (QBT)*1 b1 : Parameters (QPA) b2 : Device comments (QCD) b3 : Device initial value (QDI)*2 b4 : File register R (QDR) b5 : Sampling trace (QTD) b6 : Not used b7 : Backup data (QBP)*3 b8 : Not used b9 : Not used b10 : Not used b11 : Local device (QDL) b12 : Not used b13 : Not used b14 : Not used b15 : Not used *1: Turned ON at boot start and OFF at boot completion. *2: Turned ON when reflection of device initial value is started and OFF when reflection of device initial value is completed. *3: The module whose first 5 digits of serial No. is "10102" or later.	S (Status change)	New	QnU*2

*1: When the Q2MEM-8MBA is used, value stored in the special register SD603 differs depending on the combination of the serial number of the High Performance model QCPU and the manufacture control number of the ATA card.
For details, refer to QCPU User's Manual (Hardware Design, Maintenance and Inspection).

*2: The Universal model QCPU except the Q00UJCPU, Q00UCPU, and Q01UCPU.

Table12.23 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD620	Drive 3/4 typs	Drive 3/4 typs	• Indicates the drive 3/4 type.  (The bits for the drive 3 (standard RAM) type is fixed to "0" in the Q00UJCPU.)	S (Initial)	New	Qn(H) QnPH QnPRH QnU
			• Indicates the drive 3/4 type. 	S (Initial)	New	Q00J/Q00/Q01
SD622	Drive 3 (Standard RAM) capacity	Drive 3 capacity	• Drive 3 capacity is stored in 1 k byte units. (Empty capacity after format is stored.)	S (Initial)	New	Qn(H) QnPH QnPRH QnU
			• Drive 3 capacity is stored in 1k byte units.	S (Initial)	New	Q00J/Q00/Q01
SD623	Drive 4 (Standard ROM) capacity	Drive 4 capacity	• Drive 4 capacity is stored in 1 k byte units. (Empty capacity after format is stored.)	S (Initial)	New	Qn(H) QnPH QnPRH QnU
			• Drive 4 capacity is stored in 1k byte units.	S (Initial)	New	Q00J/Q00/Q01
SD624	Drive 3/4 use conditions	Drive 3/4 use conditions	• The conditions for usage for drive 3/4 are stored as bit patterns. (In use when ON) • The significance of these bit patterns is indicated below: b0 : Boot operation (QBT) b1 : Parameters (QPA) b2 : Device comments (QCD) b3 : Device initial value (QDI) b4 : File register (QDR) b5 : Sampling trace (QTD) b6 : Not used b7 : Not used b8 : Not used b9 : CPU fault history (QFD) b10 : SFC trace (QTS) b11 : Local device (QDL) b12 : Not used b13 : Not used b14 : Not used b15 : Not used	S (Status change)	New	Qn(H) QnPH QnPRH
	Drive 3/4 use conditions	Drive 3/4 use conditions	• The conditions for usage for drive 3/4 are stored as bit patterns. (In use when ON) • The significance of these bit patterns is indicated below: b0 : Not used b1 : Parameters (QPA) b2 : Device comments (QCD) b3 : Device initial value (QDI)*1 b4 : File register (QDR) b5 : Sampling trace (QTD) b6 : Not used b7 : Not used b8 : Not used b9 : Not used b10 : Not used b11 : Local device (QDL) b12 : Not used b13 : Not used b14 : Not used b15 : Not used *1: Turned ON at boot start and OFF at boot completion.	S (Status change)	New	QnU
SD624	Drive 3/4 use conditions	Drive 3/4 use conditions	• The conditions for usage for drive 3/4 are stored as bit patterns. 	S (Status change)	New	Q00J/Q00/Q01
SD640	File register drive	Drive number:	• Stores drive number being used by file register	S (Status change) *10	New	Q00J/Q00/Q01 Qn(H) QnPH QnPRH QnU*3

*3: The Universal model QCPU except the Q00UJCPU.

*10: On the Basic model QCPU, data is set at STOP to RUN or RSET instruction execution after parameter execution.

Table12.23 Special register





<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SD641
SD642
SD643
SD644
SD645
SD646</td><td>File register file name</td><td>File register file name</td><td>• Stores file register file name (with extension) selected at parameters or by use of QDRSET instruction as ASCII code.
<table><tr><th></th><th>b15 to b8</th><th>b7 to b0</th></tr><tr><td>SD641</td><td>2nd character</td><td>1st character</td></tr><tr><td>SD642</td><td>4th character</td><td>3rd character</td></tr><tr><td>SD643</td><td>6th character</td><td>5th character</td></tr><tr><td>SD644</td><td>8th character</td><td>7th character</td></tr><tr><td>SD645</td><td>1st character of extension</td><td>2EH(.)</td></tr><tr><td>SD646</td><td>3rd character of the extension</td><td>2nd character of the extension</td></tr></table></td><td>S (Status change)</td><td>New</td><td>Qn(H)
QnPH
QnPRH
QnU*3</td></tr>
<tr><td></td><td></td><td></td><td>• Stores file register file name (MAIN.QDR) selected at parameters as ASCII code.
<table><tr><th></th><th>b15 to b8</th><th>b7 to b0</th></tr><tr><td>SD641</td><td>2nd character (A)</td><td>1st character (M)</td></tr><tr><td>SD642</td><td>4th character (N)</td><td>3rd character (I)</td></tr><tr><td>SD643</td><td>6th character ( )</td><td>5th character ( )</td></tr><tr><td>SD644</td><td>8th character ( )</td><td>7th character ( )</td></tr><tr><td>SD645</td><td>1st character of the extension (Q)</td><td>2EH(.)</td></tr><tr><td>SD646</td><td>3rd character of the extension (R)</td><td>2nd character of the extension (D)</td></tr></table></td><td>S (Initial)</td><td>New</td><td>Q00J/Q00/Q01</td></tr>
<tr><td>SD647</td><td>File register capacity</td><td>File register capacity</td><td>• Stores the data capacity of the currently selected file register in 1 k word units.</td><td>S (Status change)</td><td>New</td><td>Qn(H)
QnPH
QnPRH
QnU*3</td></tr>
<tr><td></td><td></td><td></td><td></td><td>S (Initial)</td><td></td><td>Q00J/Q00/Q01</td></tr>
<tr><td>SD648</td><td>File register block number</td><td>File register block number</td><td>• Stores the currently selected file register block number.</td><td>S (Status change) *10</td><td>D9035</td><td>Q00J/Q00/Q01
Qn(H)
QnPH
QnPRH
QnU*3</td></tr>
<tr><td>SD650</td><td>Comment drive</td><td>Comment drive number</td><td>• Stores the comment drive number selected at the parameters or by the QCDSET instruction.</td><td>S (Status change)</td><td>New</td><td rowspan="7">Qn(H)
QnPH
QnPRH
QnU</td></tr>
<tr><td>SD651
SD652
SD653
SD654
SD655
SD656</td><td>Comment file name</td><td>Comment file name</td><td>• Stores the comment file name (with extension) selected at the parameters or by the QCDSET instruction in ASCII code.
<table><tr><th></th><th>b15 to b8</th><th>b7 to b0</th></tr><tr><td>SD651</td><td>2nd character</td><td>1st character</td></tr><tr><td>SD652</td><td>4th character</td><td>3rd character</td></tr><tr><td>SD653</td><td>6th character</td><td>5th character</td></tr><tr><td>SD654</td><td>8th character</td><td>7th character</td></tr><tr><td>SD655</td><td>1st character of the extension</td><td>2EH(.)</td></tr><tr><td>SD656</td><td>3rd character of the extension</td><td>2nd character of the extension</td></tr></table></td><td>S (Status change)</td><td>New</td></tr>
<tr><td>SD660</td><td rowspan="7">Boot operation designation file</td><td>Boot designation file drive number</td><td>• Stores the drive number where the boot designation file (*.QBT) is being stored.</td><td>S (Initial)</td><td>New</td></tr>
<tr><td>SD661
SD662
SD663
SD664
SD665
SD666</td><td>File name of boot designation file</td><td>• Stores the file name of the boot designation file (*.QBT).
<table><tr><th></th><th>b15 to b8</th><th>b7 to b0</th></tr><tr><td>SD661</td><td>2nd character</td><td>1st character</td></tr><tr><td>SD662</td><td>4th character</td><td>3rd character</td></tr><tr><td>SD663</td><td>6th character</td><td>5th character</td></tr><tr><td>SD664</td><td>8th character</td><td>7th character</td></tr><tr><td>SD665</td><td>1st character of the extension</td><td>2EH(.)</td></tr><tr><td>SD666</td><td>3rd character of the extension</td><td>2nd character of the extension</td></tr></table></td><td>S (Initial)</td><td>New</td><td>Qn(H)
QnPH
QnPRH
QnU*4</td></tr>
</table>





*3: The Universal model QCPU except the Q00UJCPU.

*4: The Universal model QCPU except the Q00UJCPU, Q00UCPU, and Q01UCPU.

*10: On the Basic model QCPU, data is set at STOP to RUN or RSET instruction execution after parameter execution.

Table12.23 Special register

<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SD670</td><td>Parameter enable drive information</td><td>Parameter enable drive No.</td><td>• Stores information of parameter storage destination drive which is enabled.
0: Drive 0 (Program memory)
1: Drive 1 (SRAM card)
2: Drive 2 (Flash card/ATA card)
4: Drive 4 (Standard ROM)
(Only drive 0 and drive 4 are valid in the Q00UJCPU, Q00UCPU, and Q01UCPU.)</td><td>S (Initial)</td><td>New</td><td rowspan="6"></td></tr>
<tr><td>SD671</td><td>Status of latch data backup function</td><td>Status display</td><td>Indicates the status of the latch data backup function.
<table>
<tr><th colspan="2">Status</th><th>Presence/ absence of backup data</th><th>Restore operation at turning power supply ON from OFF</th></tr>
<tr><td>0</td><td>No backup data</td><td>Absent</td><td>Restoring not executed</td></tr>
<tr><td>1</td><td>Restore ready completion</td><td rowspan="4">Present</td><td>Restoring executed when turning power supply ON from OFF the following time</td></tr>
<tr><td>2</td><td>Restore execution completion</td><td>Restoring not executed</td></tr>
<tr><td>3</td><td>Backup execution wait</td><td>Restoring not executed</td></tr>
<tr><td>4</td><td>Restore repeated execution ready completion</td><td>Restoring executed when turning power supply ON from OFF</td></tr>
</table>
• "2 Restore ready completion" is a status immediately after restoring data.
"3 Backup execution wait" is a status after turning power supply ON from OFF at "2 Restore ready completion".</td><td>S (Status change)</td><td>New</td></tr>
<tr><td>SD672</td><td rowspan="4">Backup information</td><td>Backup time (Year and month)</td><td>• Stores the last 2 digits of year and month when backup is performed in 2-digit BCD code.
 
</td><td rowspan="4">S (At write)</td><td rowspan="4">New</td><td rowspan="4">QnU</td></tr>
<tr><td>SD673</td><td>Backup time (Day and hour)</td><td>• Stores the day and hour when backup is performed in 2-digit BCD code.
 
</td></tr>
<tr><td>SD674</td><td>Backup time (Minute and second)</td><td>• Stores the minute and second when backup is performed in 2-digit BCD code.
 
</td></tr>
<tr><td>SD675</td><td>Backup time (Year and day of week)</td><td>• Stores the first 2 digits of year and day of week when backup is performed in BCD code.
 
</td></tr>
</table>

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD676	Backup data restration information	Restore time (Year and month)	• Stores the last 2 digits of year and month when data is restored in 2-digit BCD code.  Example: July, 1993 → 9307H	S (Initial)	New	QnU
SD677		Restore time (Day and time)	• Stores the day and time when data is restored in 2-digit BCD code.  Example: 31st, 10 a.m. → 3110H			
SD678		Restore time (Minute and second)	• Stores the minute and second when data is restored in 2-digit BCD code.  Example: 35 min., 48 sec. → 3548H			
SD679		Restore time (Year and day of week)	• Stores the first 2 digits of year and day of week when data is restored in BCD code.  Example: 1993, Friday → 1905H Day of the week: 0 Sunday, 1 Monday, 2 Tuesday, 3 Wednesday, 4 Thursday, 5 Friday, 6 Saturday			
SD681	Program memory write (transfer) status	Write (transfer) status display (percentage)	Displays the status of writing (transferring) the program memory (flash ROM) in percentage. (0 to 100%) "0" is set when the write direction is set.	S (At write)	New	
SD682 SD683	Program memory write count index	Write count index up to present	• Stores the index value for the number of write operations to the program memory (flash ROM) up to the present in BIN 32-bit value. When the index value exceeds 100 thousand times, "FLASH ROM ERROR" (error code: 1610) occurs. (The index value is calculated even when exceeding 100 thousand times.) Note) The write count does not equal to the index value.(Since a flash ROM write life is prolonged by the system, 1 is added to the write count index when writing is performed twice or so.).	S (At write)	New	
SD686	Standard ROM write (transfer) status	Write (transfer) status display (percentage)	Displays the status of writing (transferring) the standard ROM (flash ROM) in percentage. (0 to 100%) "0" is set when the write direction is set.	S (At write)	New	
SD687 SD688	Standard ROM write count index	Write count index up to present	• Stores the index value for the number of write operations to the standard ROM (flash ROM) up to the present in BIN 32-bit value. When the index value exceeds 100 thousand times, "FLASH ROM ERROR" (error code: 1610) occurs. (The index value is calculated even when exceeding 100 thousand times.) Note) The write count does not equal to the index value. (Since a flash ROM write life is prolonged by the system, 1 is added to the write count index when the total write capacity after the previous count up reaches about 1M byte.)	S (At write)	New	
SD689	Backup error factor	Backup error factor	Stores the factor of the error that occurred in the backup. 0H : No error 100H: Memory card not inserted 200H: Size of backup target data exceeded 300H: Memory card write inhibit setting 400H: Memory card write error 500H: Backup target data read error (from program memory) 503H: Backup target data read error (from standard RAM) 504H: Backup target data read error (from standard ROM) 510H: Backup target data read error (from system data)	S (Backup error occurrence)	New	QnU*1
SD690	Backup status	Backup status	Stores the current backup status. 0 : Before backup start 1 : Backup start prepared 2 : Backup start preparation completed 3 : Backup in execution 4 : Backup completed FF: Backup error	S (Status change)	New	

*1: The module whose first 5 digits of serial No. is "10102" or later. (Except the Q00UJCPU, Q00UCPU, and Q01UCPU)

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU D9□□□	Corresponding CPU
SD691	Backup execution status	Backup execution status display (Percentage)	• Displays the execution status of data backup to the memory card in percentage (0 to 100%). • "0" is set when the backup starts.	S (Status change)	New	QnU*1
SD692	Restoration error factor	Factor of error occurred in the restoration	Stores the factor of an error that occurred in the restoration. Each error factor is as follows: 800H: The CPU module model name is not matched. 801H: The file password is set only for the restoration destination data or is not matched. 810H: The verified backup data file is not matched or the backup data read failed.	S (Error occurrence)	New	
SD693	Restoration status	Current restoration status	Stores the current restoration execution status. Each error factor is as follows: 0 : Before restoration start 1 : Restoration in execution 2 : Restoration completed FF: Restoration error Sets "0" (Before restoring), however, when the restoration is completed only during the automatic restoration.	S (Status change)	New	
SD694	Restoration execution status	Restoration execution status display (Percentage)	• Displays the execution status of restoration to the CPU module in percentage (0 to 100%). • "0" is set before the restoration. Sets "0" (Before restoring), however, when the restoration is completed only during the automatic restoration.	S (Status change)	New	
SD695	Specification of writing to standard ROM instruction count	Specification of writing to standard ROM instruction count	• Specifies the maximum number of executions of the writing to standard ROM instruction (SP.DEVST) to write to the standard ROM per day. • When the number of executions of the writing to standard ROM instruction exceeds the number of times set by SD695, “OPERATION ERROR” (error code: 4113) occurs. • The setting range for SD695 is 1 to 32767. If 0 or value outside the range is set, “OPERATION ERROR” (error code: 4113) occurs at execution of the writing to standard ROM instruction.	U	New	QnU
SD696	Available memory in memory card	Available memory in memory card	Stores the available memory in memory card. (Stores the value in 32-bit binary.)	S (Backup in operation)	New	QnU*1
SD697						
SD698	Backup data capacity	Backup data capacity	Stores the backup data capacity. (Stores the value in 32-bit binary.)			
SD699						

*1: The module whose first 5 digits of serial No. is "10102" or later. (Except the Q00UJCPU, Q00UCPU, and Q01UCPU)

(6) Instruction-Related Registers

Table12.24 Special register

<table>
<tr><th>Number</th><th>Name</th><th>Meaning</th><th>Explanation</th><th>Set by (When Set)</th><th>Corres-ponding ACPU D9□□□</th><th>Corresponding CPU</th></tr>
<tr><td>SD705
SD706</td><td>Mask pattern</td><td>Mask pattern</td><td>• During block operations, turning SM705 ON makes it possible to use the mask pattern being stored at SD705 (or at SD705 and SD706 if double words are being used) to operate on all data in the block with the masked values.</td><td>U</td><td>New</td><td>Q00J/Q00/Q01
Qn(H)
QnPH
QnPRH</td></tr>
<tr><td>SD715
SD716
SD717</td><td>IMASK instruction mask pattern</td><td>Mask pattern</td><td>• Patterns masked by use of the IMASK instruction are stored in the following manner:
<table><tr><th></th><th>b15</th><th></th><th>b1</th><th>b0</th></tr><tr><td>SD715</td><td>I15</td><td>to</td><td>I1</td><td>I0</td></tr><tr><td>SD716</td><td>I31</td><td>to</td><td>I17</td><td>I16</td></tr><tr><td>SD717</td><td>I47</td><td>to</td><td>I33</td><td>I32</td></tr></table></td><td>S (During execution)</td><td>New</td><td rowspan="3">QCPU</td></tr>
<tr><td>SD718
SD719</td><td>Accumulator</td><td>Accumulator</td><td>• For use as replacement for accumulators used in A series programs.</td><td>S/U</td><td>New</td></tr>
<tr><td>SD720</td><td>Program No. designation for PLOADP instruction</td><td>Program No. designation for PLOADP instruction</td><td>Stores the program number of the program to be loaded by the PLOADP instruction when designated.
Designation range: 1 to 124</td><td>U</td><td>New</td><td>Qn(H)
QnPH</td></tr>
<tr><td>SD738
SD739
SD740
SD741
SD742
SD743
SD744
SD745
SD746
SD747
SD748
SD749
SD750
SD751
SD752
SD753
SD754
SD755
SD756
SD757
SD758
SD759
SD760
SD761
SD762
SD763
SD764
SD765
SD766
SD767
SD768
SD769</td><td>Message storage</td><td>Message storage</td><td>• Stores the message designated by the MSG instruction.
<table><tr><th></th><th>b15 to b8</th><th>b7 to b0</th></tr><tr><td>SD738</td><td>2nd character</td><td>1st character</td></tr><tr><td>SD739</td><td>4th character</td><td>3rd character</td></tr><tr><td>SD740</td><td>6th character</td><td>5th character</td></tr><tr><td>SD741</td><td>8th character</td><td>7th character</td></tr><tr><td>SD742</td><td>10th character</td><td>9th character</td></tr><tr><td>SD743</td><td>12th character</td><td>11th character</td></tr><tr><td>SD744</td><td>14th character</td><td>13th character</td></tr><tr><td>SD745</td><td>16th character</td><td>15th character</td></tr><tr><td>SD746</td><td>18th character</td><td>17th character</td></tr><tr><td>SD747</td><td>20th character</td><td>19th character</td></tr><tr><td>SD748</td><td>22nd character</td><td>21st character</td></tr><tr><td>SD749</td><td>24th character</td><td>23rd character</td></tr><tr><td>SD750</td><td>26th character</td><td>25th character</td></tr><tr><td>SD751</td><td>28th character</td><td>27th character</td></tr><tr><td>SD752</td><td>30th character</td><td>29th character</td></tr><tr><td>SD753</td><td>32nd character</td><td>31st character</td></tr><tr><td>SD754</td><td>34th character</td><td>33rd character</td></tr><tr><td>SD755</td><td>36th character</td><td>35th character</td></tr><tr><td>SD756</td><td>38th character</td><td>37th character</td></tr><tr><td>SD757</td><td>40th character</td><td>39th character</td></tr><tr><td>SD758</td><td>42nd character</td><td>41st character</td></tr><tr><td>SD759</td><td>44th character</td><td>43rd character</td></tr><tr><td>SD760</td><td>46th character</td><td>45th character</td></tr><tr><td>SD761</td><td>48th character</td><td>47th character</td></tr><tr><td>SD762</td><td>50th character</td><td>49th character</td></tr><tr><td>SD763</td><td>52nd character</td><td>51st character</td></tr><tr><td>SD764</td><td>54th character</td><td>53rd character</td></tr><tr><td>SD765</td><td>56th character</td><td>55th character</td></tr><tr><td>SD766</td><td>58th character</td><td>57th character</td></tr><tr><td>SD767</td><td>60th character</td><td>59th character</td></tr><tr><td>SD768</td><td>62nd character</td><td>61st character</td></tr><tr><td>SD769</td><td>64th character</td><td>63rd character</td></tr></table></td><td>S (During execution)</td><td>New</td><td>QCPU</td></tr>
</table>

Table12.24 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU D9□□□	Corresponding CPU
SD774 to SD775	PID limit setting (for complete derivative)	0: With limit 1: Without limit	• Specify the limit of each PID loop as shown below. b15 … b1 b0 SD774: Loop16 to Loop2 Loop1 SD775: Loop32 to Loop18 Loop17	U	New	Qn(H) QnPRH QnU
SD774	PID limit setting (for complete derivative)	0: With limit 1: Without limit	• Specify the limit of each PID loop as shown below. b15 to b8 b7 to b1 b0 SD774: Loop8 to Loop2 Loop1	U	New	Q00J/Q00/Q01*9
SD778	Refresh processing selection when the COM/ CCOM instruction is executed	b0 to b14: 0: Do not refresh 1: Refresh b15 bit 0: Communication with CPU module is executed 1: Communication withCPU module is nonexecuted	• Selects whether or not the data is refreshed when the COM instruction is executed. • Designation of SD778 is made valid when SM775 turns ON. b15 b14 to b5 b4 b3 b2 b1 b0 SD778: 0/1 0 0/1 0/1 0/1 0/1 0/1 b4: I/O refresh b3: CC-Link refresh b2: MELSECNET/H refresh b1: Automatic refresh of intelligent function modules b0: Automatic refresh of CPU shared memory (Fixed to "0" for Redundant CPU) b15: Execution/non-execution of communication with CPU module • Refresh between multiple CPUs by COM instruction is performed under the following occasion. Receiving operation from other device: b4 of SD778(refresh in the CPU shared memory) is turned to 1. Sending operation from host CPU : b15 of SD778(communication with peripheral device is executed/nonexecuted) is turned to 0.	U	New	Q00J/Q00/Q01*9 Qn(H)*11
			• Selects whether or not the data is refreshed when the COM instruction is executed. • Designation of SD778 is made valid when SM775 turns ON. b15 b14 to b6 b5 b4 b3 b2 b1 b0 SD778: 0/1 0 0/1 0/1 0/1 0/1 0/1 0/1 b5: I/O refresh b4: CC-Link refresh b3: CC-Link IE controller network or MELSECNET/H refresh b2: Automatic refresh of intelligent function modules b1: Reading input/output from group outside multiple CPU system b0: Auto refresh using the multiple CPU high speed transmission area of multiple CPU system b15: Execution/non-execution of communication with CPU module • Refresh between multiple CPUs by COM instruction is performed under the following occasion. Receiving operation from other device: b4 of SD778(refresh in the CPU shared memory) is turned to 1. Sending operation from host CPU : b15 of SD778(communication with peripheral device is executed/nonexecuted) is turned to 0. • When b2 (refresh of the CC-Link IE controller network and MELSECNET/H) of SD778 is 1, the CC-Link IE controller network and MELSECNET/H perform refresh. Therefore, if there are many refresh points, processing time for the COM instruction will be extended.	U	New	Qn(H)*13 QnPH*12 QnPRH

*9: Function version is B or later.
*11: The module whose first 5 digits of serial No. is "04012" or later.
*12: The module whose first 5 digits of serial No. is "07032" or later.
*13: The module whose first 5 digits of serial No. is "09012" or later.

Table12.24 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD778	Refresh processing selection when the COM/ CCOM instruction is executed	b0 to b14: 0: Do not refresh 1: Refresh b15 bit 0: communication with peripheral device is executed 1: communication with peripheral device is nonexecuted	• Selects whether or not the data is refreshed when the COM, CCOM instruction is executed. • Designation of SD778 is made valid when SM775 turns ON. b15 b14 to b6 b5 b4 b3 b2 b1 b0 SD778 0/1 0 0/1 0/1 0/1 0/1 0/1 0/1 I/O refresh CC-Link refresh Refresh of MELSECNET/H and CC-Link IE controller network Automatic refresh of intelligent function modules Auto refresh using QCPU standard area of multiple CPU system and reading input/output from group outside. Auto refresh using the multiple CPU high speed transmission area of multiple CPU system Execution/non-execution of communication with CPU module	U	New	QnU
SD781 to SD793	Mask pattern of IMASK instruction	Mask pattern	• Stores the mask patterns masked by the IMASK instruction as follows: b15 b1 b0 SD781 I63 to I49 I48 SD782 I79 to I65 I64 to SD793 I255 to I241 I240 (The Q00UJCPU, Q00UCPU, and Q01UCPU cannot use the special registers SD786 to SD793.)	S (During execution)	New	Qn(H) QnPH QnPRH QnU
SD781 to SD785	Mask pattern of IMASK instruction	Mask pattern	• Stores the mask patterns masked by the IMASK instruction as follows: b15 b1 b0 SD781 I63 to I49 I48 SD782 I79 to I65 I64 to to SD785 I127 to I113 I112	S (During execution)	New	Q00J/Q00/Q01
SD794 to SD795	PID limit setting (for incomplete derivative)	0: With limit 1: Without limit	• Specify the limit of each PID loop as shown below. b15 b1 b0 SD794 Loop16 to Loop2 Loop1 SD795 Loop32 to Loop18 Loop17	U	New	Qn(H)*13 QnPRH QnU
SD794	PID limit setting (for incomplete derivative)	0: With limit 1: Without limit	• Specify the limit of each PID loop as shown below. b15 to b8 b7 b1 b0 SD794 Loop8 to Loop2 Loop1	U	New	Q00J/Q00/Q01*9

*9: Function version is B or later.
*13: The module whose first 5 digits of serial No. is "09012" or later.

Table12.24 Special register


Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD796	Maximum number of blocks used for the multiple CPU high-speed transmission dedicated instruction setting (for CPU No.1)	Maximum number of blocks range for dedicated instructions Range: 1 to 7 (Default: 2 Or when setting other than 1 to 7, the register operates as 7).	• Specifies the maximum number of blocks used for the multiple CPU high-speed transmission dedicated instruction (target CPU=CPU No.1). When the dedicated instruction of Multiple CPU transmission is executed to the CPU No.1, and the number of empty blocks of the dedicated instruction transmission area is less than the setting value of this register, SM796 is turned ON, which is used as the interlock signal for consecutive execution of the dedicated instruction of Multiple CPU transmission.	U (At 1 scan after RUN)	New	QnU*14*15
SD797	Maximum number of blocks used for the multiple CPU high-speed transmission dedicated instruction setting (for CPU No.2)		• Specifies the maximum number of blocks used for the multiple CPU high-speed transmission dedicated instruction (target CPU=CPU No.2). When the dedicated instruction of Multiple CPU transmission is executed to the CPU No.2, and the number of empty blocks of the dedicated instruction transmission area is less than the setting value of this register, SM797 is turned ON, which is used as the interlock signal for consecutive execution of the dedicated instruction of Multiple CPU transmission.	U (At 1 scan after RUN)	New	
SD798	Maximum number of blocks used for the multiple CPU high-speed transmission dedicated instruction setting (for CPU No.3)		• Specifies the maximum number of blocks used for the multiple CPU high-speed transmission dedicated instruction (target CPU=CPU No.3). When the dedicated instruction of Multiple CPU transmission is executed to the CPU No.3, and the number of empty blocks of the dedicated instruction transmission area is less than the setting value of this register, SM798 is turned ON, which is used as the interlock signal for consecutive execution of the dedicated instruction of Multiple CPU transmission.	U (At 1 scan after RUN)	New	
SD799	Maximum number of blocks used for the multiple CPU high-speed transmission dedicated instruction setting (for CPU No.4)		• Specifies the maximum number of blocks used for the multiple CPU high-speed transmission dedicated instruction (target CPU=CPU No.4). When the dedicated instruction of Multiple CPU transmission is executed to the CPU No.4, and the number of empty blocks of the dedicated instruction transmission area is less than the setting value of this register, SM799 is turned ON, which is used as the interlock signal for consecutive execution of the dedicated instruction of Multiple CPU transmission.	U (At 1 scan after RUN)	New	

*14: The Universal model QCPU except the Q00UJCPU, Q00UCPU, Q01UCPU, and Q02UCPU.

*15: The range is from 1 to 9 for the Q03UDCPU, Q04UDCPU, and Q06UDHCP whose first 5 digits of serial number is "10012" or earlier.
(Default: 2 Or when setting other than 1 to 9, the register operates as 9).

(7) Debug

Table12.25 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD840	Debug function usage	Debug function usage	Stores the status of the debug function usage as shown below. 0: Forced ON/OFF for external I/O 1: Executional conditioned device test 2 to 15:Absent (0 fix)  (0: Not used, 1: Used)	S (Status change)	New	QnU*1

*1: The module whose first 5 digits of serial No. is "10042" or later.

(8) Redundant CPU information (host system CPU information*1)

Table12.26 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD952	History of memory copy from control system to standby system	Latest status of memory copy from control system to standby system	Stores the completion status of the memory copy from control system to standby system executed last. 1) Stores the same value as stored into SD1596 at normal completion/ abnormal completion of the memory copy from control system to standby system. 2) Backed up for a power failure, this special register holds the status of memory copy from control system to standby system executed last. 3) Cleared to 0 by latch clear operation.	S (Status change)	New	QnPRH

*1: The host system CPU information is stored.

(9) Remote password count

Table12.27 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD979	Direct MELSOFT connection	Count of unlock processing failures	Stores the count of unlock processing failures. Range: 0 to FFFEH (FFFFH when the limit is exceeded)	S(Status change)	New	QnU*1
SD980 to SD995	Connection 1 to 16					
SD998	MELSOFT connection using TCP port					
SD999	FTP communi cation port					

*1: This applies to the Built-in Ethernet port QCPU.

(10) A to Q conversion

ACPU special registers D9000 to D9255 correspond to Q special registers SD1000 to SD1255 after A to Q/QnA conversion.
(However, the Basic model QCPU and Redundant CPU do not support the A to Q conversion.)
These special registers are all set by the system, and cannot be set by the user program. To set data by the user program, correct the program for use of the QCPU special registers. However, some of SD1200 to SD1255 (corresponding to D9200 to 9255 before conversion) can be set by the user program if they could be set by the user program before conversion. For details on the ACPU special registers, refer to the user's manual for the corresponding CPU, and MELSECNET or MELSECNET/B Data Link System Reference Manuals.

Point

Check "Use special relay/special register from SM/SD1000" for "A-PLC" on the PLC system tab of PLC parameter in GX Developer when the converted special registers are used with the High Performance model QCPU, Process CPU, and Universal model QCPU.
When not using the converted special registers, uncheck "Use special relay/special registers from SM/SD1000" to save the time taken for processing special registers.

Remark

Supplemental explanation on "Special Register for Modification" column

① For the device numbers for which a special register for modification is specified, modify it to the special register for QCPU.

② For the device numbers for which [–] is specified, special register after conversion can be used.


③ Device numbers for which [×] is specified do not function for QCPU.

Table12.28 Special register

<table>
<tr><th>ACPU Special Register</th><th>Special Register after Conversion</th><th>Special Register for Modification</th><th>Name</th><th>Meaning</th><th>Details</th><th>Corresponding CPU</th></tr>
<tr><td>D9000</td><td>SD1000</td><td>–</td><td>Fuse blown</td><td>Number of module with blown fuse</td><td>• When fuse blown modules are detected, the first I/O number of the lowest number of the detected modules is stored in hexadecimal. (Example: When fuses of Y50 to 6F output modules have blown, "50" is stored in hexadecimal)
To monitor the number by peripheral devices, perform monitor operation given in hexadecimal.
(Cleared when all contents of SD1100 to SD1107 are reset to 0.)
• Fuse blow check is executed also to the output modules of remote I/O stations.</td><td>Qn(H)
QnPH
QnU*1</td></tr>
<tr><td>D9001</td><td>SD1001</td><td>–</td><td>Fuse blown</td><td>Number of module with blown fuse</td><td>• Stores the module numbers corresponding to setting switch numbers or base slot numbers when fuse blow occurred.
<table><tr><th colspan="2">AJ02 I/O module</th><th colspan="2">Extension base unit</th></tr><tr><th>Setting switch</th><th>Stored data</th><th>Base unit slot No.</th><th>Stored data</th></tr><tr><td>0</td><td>0</td><td>0</td><td>4</td></tr><tr><td>1</td><td>1</td><td>1</td><td>5</td></tr><tr><td>2</td><td>2</td><td>2</td><td>6</td></tr><tr><td>3</td><td>3</td><td>3</td><td>7</td></tr><tr><td>4</td><td>4</td><td></td><td></td></tr><tr><td>5</td><td>5</td><td></td><td></td></tr><tr><td>6</td><td>6</td><td></td><td></td></tr><tr><td>7</td><td>7</td><td></td><td></td></tr></table>• For the remote I/O station, the value of (module I/O No./10H) + 1 is stored.</td><td>Qn(H)
QnPH</td></tr>
<tr><td>D9002</td><td>SD1002</td><td>–</td><td>I/O module verify error</td><td>I/O module verify error module number</td><td>• If I/O modules, of which data are different from data entered, are detected when the power is turned on, the first I/O number of the lowest number unit among the detected units is stored in hexadecimal. (Storing method is the same as that of SD1000.)
To monitor the number by peripheral devices, perform monitor operation given in hexadecimal.
(Cleared when all contents of SD1116 to SD1123 are reset to 0.)
• I/O module verify check is executed also to the modules of remote I/O terminals.</td><td>Qn(H)
QnPH
QnU*1</td></tr>
<tr><td rowspan="2">D9005</td><td rowspan="2">SD1005</td><td rowspan="2">–</td><td rowspan="2">AC DOWN counter</td><td rowspan="2">Number of times for AC DOWN</td><td>• When the AC power supply module is used, 1 is added at occurrence of an instantaneous power failure of within 20ms. (The value is stored in BIN code.) It is reset when the power supply is switched from OFF to ON.</td><td>Qn(H)
QnPH
QnU*1</td></tr>
<tr><td>• When the DC power supply module is used, 1 is added at occurrence of an instantaneous power failure of within 10ms. (The value is stored in BIN code.) It is reset when the power supply is switched from OFF to ON.</td><td>Qn(H)
QnPH
QnU*1</td></tr>
<tr><td>D9008</td><td>SD1008</td><td>SD0</td><td>Self-diagnostic error</td><td>Self-diagnostic error number</td><td>• When error is found as a result of self-diagnosis, error number is stored in BIN code.</td><td>Qn(H)
QnPH
QnU*1</td></tr>
</table>

*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

Table12.28 Special register

ACPU Special Register	Special Register after Conversion	Special Register for Modification	Name	Meaning	Details	Corresponding CPU
D9009	SD1009	SD62	Annunciator detection	F number at which external failure has occurred	• When one of F0 to 2047 is turned on by OUT F or SET F instruction, the F number, which has been detected earliest among the F numbers which have turned on, is stored in BIN code. • SD1009 can be cleared by RST F or LEDR instruction. If another F number has been detected, the clearing of SD1009 causes the next number to be stored in SD1009.	Qn(H) QnPH QnU*1
D9010	SD1010	×	Error step	Step number at which operation error has occurred.	• When operation error has occurred during execution of application instruction, the step number, at which the error has occurred, is stored in BIN code. Thereafter, each time operation error occurs, the contents of SD1010 are renewed.	Qn(H) QnPH
D9011	SD1011	×	Error step	Step number at which operation error has occurred.	• When operation error has occurred during execution of application instruction, the step number, at which the error has occurred, is stored in BIN code. Since the step number is stored into SD1011 when SM1011 turns from OFF to ON, the data of SD1011 is not updated unless SM1011 is cleared by a user program.	
D9014	SD1014	×	I/O control mode	I/O control mode number	• The I/O control mode set is returned in any of the following numbers: 0: Both input and output in direct mode 1: Input in refresh mode, output in direct mode 3: Both input and output in refresh mode	
D9015	SD1015	SD203	Operating status of CPU	Operating status of CPU	• The operation status of CPU as shown below are stored in SD1015.  *1: When the CPU mdoule is in RUN mode and SM1040 is off, the CPU module remains in RUN mode if changed to PAUSE mode.	Qn(H) QnPH QnU*1




*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

Table12.28 Special register

ACPU Special Register	Special Register after Conversion	Special Register for Modification	Name	Meaning	Details	Corresponding CPU
D9016	SD1016	×	Program number	0: Main program (ROM) 1: Main program (RAM) 2: Subprogram 1 (RAM) 3: Subprogram 2 (RAM) 4: Subprogram 3 (RAM) 5: Subprogram 1 (ROM) 6: Subprogram 2 (ROM) 7: Subprogram 3 (ROM) 8: Main program (E^2PROM) 9: Subprogram 1 (E^2PROM) A: Subprogram 2 (E^2PROM) B: Subprogram 3 (E^2PROM)	• Indicates which sequence program is run presently. One value of 0 to B is stored in BIN code.	Qn(H) QnPH
D9017	SD1017	SD524	Scan time	Minimum scan time (10 ms units)	• If scan time is smaller than the content of SD1017, the value is newly stored at each END. Namely, the minimum value of scan time is stored into SD1017 in BIN code.	Qn(H) QnPH QnU*1
D9018	SD1018	SD520	Scan time	Scan time (10 ms units)	• At every END, the scan time is stored in BIN code and always rewritten.	
D9019	SD1019	SD526	Scan time	Maximum scan time (10 ms units)	• If scan time is larger than the content of SD1019, the value is newly stored at each END. Namely, the maximum value of scan time is stored into SD1019 in BIN code.	
D9020	SD1020	×	Constant scan	Constant scan time (User sets in 10 ms units)	• Sets the interval between consecutive program starts in multiples of 10 ms. 0 : No setting 1 to 200 : Set. Program is executed at intervals of (set value) × 10 ms.	Qn(H) QnPH
D9021	SD1021	–	Scan time	Scan time (1 ms units)	• At every END, the scan time is stored in BIN code and always rewritten.	Qn(H) QnPH QnU*1
D9022	SD1022	SD412	1 second counter	Count in units of 1s.	• When the PC CPU starts running, it starts counting 1 every second. • It starts counting up from 0 to 32767, then down to -32768 and then again up to 0. Counting repeats this routine.	
D9025	SD1025	–	Clock data	Clock data (year, month)	• The year (last two digits) and month are stored as BCD code as shown below. b15 to b12 b11 to b8 b7 to b4 b3 to b0 Example: 1987, July H8707 Year Month	
D9026	SD1026	–	Clock data	Clock data (day, hour)	• The day and hour are stored as BCD code as shown below. b15 to b12 b11 to b8 b7 to b4 b3 to b0 Example: 31st, 10 a.m. H3110 Day Hour	
D9027	SD1027	–	Clock data	Clock data (minute, second)	• The minute and second are stored as BCD code as shown below. b15 to b12 b11 to b8 b7 to b4 b3 to b0 Example: 35 min, 48 sec. H3548 Minute Second	



*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

Table12.28 Special register

ACPU Special Register	Special Register after Conversion	Special Register for Modification	Name	Meaning	Details	Corresponding CPU
D9028	SD1028	–	Clock data	Clock data (day of week)	• The day of the week is stored as BCD code as shown below. 	Qn(H) QnPH QnU*1
D9035	SD1035	SD648	Extension file register	Use block No.	• Stores the block No. of the extension file register being used in BCD code.	
D9036	SD1036	×	Extension file registerfor designation of device number	Device number when individual devices from extension file register are directly accessed	• Designate the device number for the extension file register for direct read and write in 2 words at SD1036 and SD1037 in BIN data. Use consecutive numbers beginning with R0 of block No. 1 to designate device numbers. 	Qn(H) QnPH
D9037	SD1037	×				
D9038	SD1038	SD207	LED display priority ranking	Priorities 1 to 4	• Sets priority of ERROR LEDs which illuminate (or flicker) to indicate errors with error code numbers. • Configuration of the priority setting areas is as shown below.  • For details, refer to the applicable CPUs User's Manual and the ACPU Programming manual (Fundamentals).	
D9039	SD1039	SD208		Priorities 5 to 7		
D9044	SD1044	×	For sampling trace	Step or time during sampling trace	• Turned on/off with a peripheral device. When STRA or STRAR instruction is executed, the value stored in SD1044 is used as the sampling trace condition. At scanning--------0 At time----------Time (10 msec unit) The value is stored into SD1044 in BIN code.	
D9049	SD1049	×	Work area for SFC	Block number of extension file register	• Stores the block number of the expansion file register which is used as the work area for the execution of a SFC program in a binary value. • Stores "0" if an empty area of 16K bytes or smaller, which cannot be expansion file register No. 1, is used or if SM320 is OFF.	
D9050	SD1050	×	SFC program error number	Error code generated by SFC program	• Stores error code of errors occurred in the SFC program in BIN code. 0 : No error 80: SFC program parameter error 81: SFC code error 82: Number of steps of simultaneous execution exceeded 83: Block start error 84: SFC program operation error	
D9051	SD1051	×	Error block	Block number where error occurred	• Stores the block number in which an error occurred in the SFC program in BIN code. In the case of error 83 the starting block number is stored.	
D9052	SD1052	×	Error step	Step number where error occurred	• Stores the step number, where error code 84 occurred in an SFC program, in BIN value. • Stores "0" when error code 80, 81 or 82 occurred. • Stores the block stating step number when error code 83 occurs.	




*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

Table12.28 Special register

ACPU Special Register	Special Register after Conversion	Special Register for Modification	Name	Meaning	Details	Corresponding CPU
D9053	SD1053	×	Error transition	Transition condition number where error occurred	• Stores the transition condition number, where error code 84 occurred in an SFC program, in BIN value. Stores "0" when error code 80, 81, 82 or 83 occurred.	Qn(H) QnPH
D9054	SD1054	×	Error sequence step	Sequence step number where error occurred	• Stores the sequence step number of transfer condition and operation output in which error 84 occurred in the SFC program in BIN code.	
D9055	SD1055	SD812	Status latch execution step number	Status latch step	• Stores the step number when status latch is executed. • Stores the step number in a binary value if status latch is executed in a main sequence program. • Stores the block number and the step number if status latch is executed in a SFC program. 	
D9072	SD1072	×	PLC communication check	Data check of serial communication module	• In the self-loopback test of the serial communication module, the serial communication module writes/reads data automatically to make communication checks.	Qn(H) QnPH
D9085	SD1085	×	Register for setting time check value	1 s to 65535 s	• Sets the time check time of the data link instructions (ZNRD, ZNWR) for the MELSECNET/10. • Setting range : 1 s to 65535 s (1 to 65535) • Setting unit : 1 s • Default value : 10 s (If 0 has been set, default 10 s is applied)	Qn(H) QnPH
D9090	SD1090	×	Number of special functions modules over	Number of special functions modules over	• For details, refer to the manual of each microcomputer program package.	
D9091	SD1091	×	Detailed error code	Self-diagnosis detailed error code	• Stores the detail code of cause of an instruction error.	Qn(H) QnPH QnU*1
D9094	SD1094	SD251	Head I/O number of I/O module to be replaced	Head I/O number of I/O module to be replaced	• Stores the first two digits of the head I/O number of the I/O module, which will be dismounted/mounted online (with power on), in BIN value. Example) Input module X2F0 → H2F	Qn(H) QnPH
D9095	SD1095	SD200	DIP switch information	DIP switch information	• The DIP switch information of the CPU module is stored in the following format. 0: OFF 1: ON 	Qn(H) QnPH

*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU

Table12.28 Special register

ACPU Special Register	Special Register after Conversion	Special Register for Modification	Name	Meaning	Details	Corresponding CPU
D9100	SD1100	–	Fuse blown module	Bit pattern in units of 16 points, indicating the modules whose fuses have blown	• Output module numbers (in units of 16 points), of which fuses have blown, are entered in bit pattern. (Preset output module numbers when parameter setting has been performed.)  • Fuse blow check is executed also to the output module of remote I/O station. (If normal status is restored, clear is not performed. Therefore, it is required to perform clear by user program.)	Qn(H) QnPH QnU*1
D9101	SD1101					
D9102	SD1102					
D9103	SD1103					
D9104	SD1104					
D9105	SD1105					
D9106	SD1106					
D9107	SD1107					
D9108	SD1108	–	Step transfer monitoring timer setting	Timer setting valve and the F number at time out	• Set the value of the step transition monitoring timer and the annunciator number (F number) that will be turned ON when the monitoring timer times out.  • By turning ON any of SM1108 to SM1114, the monitoring timer starts. If the transition condition following a step which corresponds to the timer is not established within set time, set annunciator (F) is turned on.)	Qn(H) QnPH
D9109	SD1109					
D9110	SD1110					
D9111	SD1111					
D9112	SD1112					
D9113	SD1113					
D9114	SD1114					
D9116	SD1116	–	I/O module verification error	Bit pattern, in units of 16 points, indicating the modules with verification errors.	• When I/O modules, of which data are different from those entered at power-ON, have been detected, the I/O module numbers (in units of 16 points) are entered in bit pattern. (Preset I/O module numbers set in parmeters when parameter setting has been performed.)  • I/O module verify check is executed also to remote I/O station modules. (If normal status is restored, clear is not performed. Therefore, it is required to perform clear by user program.)	Qn(H) QnPH QnU*1
D9117	SD1117					
D9118	SD1118					
D9119	SD1119					
D9120	SD1120					
D9121	SD1121					
D9122	SD1122					
D9123	SD1123					
D9124	SD1124	SD63	Number of annuciator detections	Number of annuciator detections	• When one of F0 to 255 (F0 to 2047 for AuA and AnU) is turned on by SET F instruction 1 is added to the contents of SD63. When RST F or LEDR instruction is executed, 1 is subtracted from the contents of SD63. • Quantity, which has been turned on by SET F instruction is stored into SD63 in BIN code. The value of SD63 is maximum 16.	

*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU






Table12.28 Special register

<table>
<tr><th>ACPU Special Register</th><th>Special Register after Conversion</th><th>Special Register for Modification</th><th>Name</th><th>Meaning</th><th>Details</th><th>Corresponding CPU</th></tr>
<tr><td>D9125</td><td>SD1125</td><td>SD64</td><td rowspan="9">Annunciator detection number</td><td rowspan="9">Annunciator detection number</td><td rowspan="9">• When any of F0 to 2047 is turned on by SET F instruction, the annunciator numbers (F numbers) that are turned on in order are registered into SD1125 to SD1132.
• The F number turned off by RST F instruction is erased from any of SD1125 to SD1132, and the F numbers stored after the erased F number are shifted to the preceding registerers.
By executing LEDR instruction, the contents of SD1125 to SD1132 are shifted upward by one.
When there are 8 annunciator detections, the 9th one is not stored into SD1125 to SD1132 even if detected.
SET F50 SET F25 SET F99 RST F25 SET F15 SET F70 SET F65 SET F38 SET F110 SET F151 SET F210 LEDR
<table><tr><td>SD1009</td><td>0</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>99</td></tr><tr><td>SD1124</td><td>0</td><td>1</td><td>2</td><td>3</td><td>2</td><td>3</td><td>4</td><td>5</td><td>6</td><td>7</td><td>8</td><td>8</td><td>8</td></tr><tr><td>SD1125</td><td>0</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>50</td><td>99</td></tr><tr><td>SD1126</td><td>0</td><td>0</td><td>25</td><td>25</td><td>99</td><td>99</td><td>99</td><td>99</td><td>99</td><td>99</td><td>99</td><td>99</td><td>15</td></tr><tr><td>SD1127</td><td>0</td><td>0</td><td>0</td><td>99</td><td>0</td><td>15</td><td>15</td><td>15</td><td>15</td><td>15</td><td>15</td><td>15</td><td>70</td></tr><tr><td>SD1128</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>70</td><td>70</td><td>70</td><td>70</td><td>70</td><td>70</td><td>65</td></tr><tr><td>SD1129</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>65</td><td>65</td><td>65</td><td>65</td><td>65</td><td>38</td></tr><tr><td>SD1130</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>38</td><td>38</td><td>38</td><td>38</td><td>110</td></tr><tr><td>SD1131</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>110</td><td>110</td><td>110</td><td>151</td></tr><tr><td>SD1132</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>0</td><td>151</td><td>151</td><td>210</td></tr></table></td><td rowspan="9">Qn(H)
QnPH
QnU*1</td></tr>
<tr><td>D9126</td><td>SD1126</td><td>SD65</td></tr>
<tr><td>D9127</td><td>SD1127</td><td>SD66</td></tr>
<tr><td>D9128</td><td>SD1128</td><td>SD67</td></tr>
<tr><td>D9129</td><td>SD1129</td><td>SD68</td></tr>
<tr><td>D9130</td><td>SD1130</td><td>SD69</td></tr>
<tr><td>D9131</td><td>SD1131</td><td>SD70</td></tr>
<tr><td>D9132</td><td>SD1132</td><td>SD71</td></tr>
</table>

*1: The relevant modules are as follows:
- The Universal model QCPU whose serial number (first five digits) is "10102" or later.
- Q00UJCPU, Q00UCPU, Q01UCPU





(11) QCPU with built-in Ethernet port

Table12.29 Special register

Number	Name		Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD1270	Time setting function	Operation result	Stores operationresult.	Stores the operation result of the time setting function. 0: Not executed 1: Success FFFFH: Failure	S (status change)	New	QnU*1
SD1271		Execution time	Stores time acquired with time setting function.	Stores years (last two digits of the Christian Era) and monthes by two digits of BCD code. 			
SD1272				Stores dates and hours acquired with time setting function by two digits of BCD code. 			
SD1273				Stores minutes and seconds acquired with time setting function by two digits of BCD code. 			
SD1274				Stores years (first two digits of the Christian Era) and days acquierd with time setting function. 			
SD1275		Required response time	Stores time required for clock time aquisition.	Stores time taken from transmission to SNTP server to clook time setup at CPU. Range: 0 to FFFEH (Unit: ms) FFFFH when the above limit is exceeded.			
SD1276	Forced connection invalidation		Specifies forced connection invalidation.	Specify this when a connection is to be invalidated forcibly on the user program. If invalidation is specified for a connection, it stops communication and does not respond. (When a remote password is used and frequent unlock processing errors have occurred on a connection, this is useful for temporarily inhibiting access to the connection.)  0: Valid (default) 1: Invalid This register is to be invalidated if a socket communication is used as an open system.	U		
SD1277							

*1: This applies to the Built-in Ethernet port QCPU.


Table12.30 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD1282	Open completion signal	Stores open completion status	Open completion status of connections (whose open system is socket communication) using socket communication functions is stored. All bits corresponding to connections using any communications other than the socket communication are fixed to "0".  0 : Open processing is not completed. 1 : Open processing is completed.	S (Status change)	New	QnU*2
SD1284	Open request signal	Stores open request status	Open request status of connections using socket communication functions is stored. All bits corresponding to connections using any communications other than the socket communication are fixed to "0".  0 : No open requests 1 : In open request	S (Status change)	New	QnU*2
SD1286	Reception status signal	Stores reception status	Reception status of connections using socket communication functions is stored. All bits corresponding to connections using any communications other than the socket communication are fixed to "0".  For TCP (Normal reception mode) 0 : Data have not been received. 1 : Data have been received. For TCP (Fixed length reception mode) 0 : Data have not been received ,or received data size has not been reached to valid buffer size. 1 : Received data size has been reached to valid buffer size. For UDP 0 : Data have not been received. 1 : Data have been received.	S (Status change)	New	QnU*2
SD1288	Built-in Ethernet port connection status	Stores connection status of built-in Ethernet port	Connection status of built-in Ethernet port is stored.  It may take several seconds for the QCPU to determine whether to connect or disconnect a built-in Ethernet port.	S (Status change)	New	QnU*2

*2: The built-in Ethernet port QCPU whose serial number (first five digits) is "11012" or later is targeted.


(12) Fuse blown module

Table12.31 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU D9□□□	Corresponding CPU
SD1300	Fuse blown module	Bit pattern in units of 16 points, indicating the modules whose fuses have blown 0 : No blown fuse 1 : Blown fuse present	• The numbers of output modules whose fuses have blown are input as a bit pattern (in units of 16 points). (If the module numbers are set by parameter, the parameter-set numbers are stored.) • Also detects blown fuse condition at remote station output modules  • Not cleared even if the blown fuse is replaced with a new one. This flag is cleared by error resetting operation.	S (Error)	D9100	Qn(H) QnPH QnPRH QnU
SD1301					D9101	
SD1302					D9102	
SD1303					D9103	
SD1304					D9104	
SD1305					D9105	
SD1306					D9106	
SD1307					D9107	
SD1308					New	
SD1309 to SD1330					New	
SD1331					New	


(13) I/O module verification

Table12.32 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU D9□□□	Corresponding CPU
SD1400	I/O module verify error	Bit pattern, in units of 16 points, indicating the modules with verification errors. 0 : No I/O verification errors 1 : I/O verification error present	• When the I/O modules whose I/O module information differs from that registered at power-ON are detected, the numbers of those I/O modules are entered in bit pattern. (If the I/O numbers are set by parameter, the parameter-set numbers are stored.) • Also detects I/O module information.  • Not cleared even if the blown fuse is replaced with a new one. This flag is cleared by error resetting operation.	S (Error)	D9116	Qn(H) QnPH QnPRH QnU
SD1401					D9117	
SD1402					D9118	
SD1403					D9119	
SD1404					D9120	
SD1405					D9121	
SD1406					D9122	
SD1407					D9123	
SD1408					New	
SD1409 to SD1430					New	
SD1431					New	

(14) Process control instructions



Table12.33 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corresponding ACPU D9□□□	Corresponding CPU
SD1500 SD1501	Basic period	Basic period tome	• Set the basic period (1 second units) use for the process control instruction using floating point data. Floating point data = SD1501 SD1500	U	New	QnPH
SD1502	Process control instruction detail error code	Process control instruction detail error code	• Shows the detailed error contents for the error that occurred in the process control instruction.	S (Error)	New	
SD1503	Process control instruction generated error location	Process control instruction generated error location	• Shows the error process block that occurred in the process control instruction.	S (Error)	New	
SD1506 SD1507	Dummy device	Dummy device	• Used to specify dummy devices by a process control instruction.	U	New	QnPH QnPRH
SD1508	Function availability selection for process control instruction	b0 Bumpless function availability setting for the S.PIDP instrunction 0: Enabled 1: Disabled (Default: 0)	• Selects the availability (enabled/disabled) of the function for process control instructions. 	U	New	QnPH QnPRH

(15) For redundant systems (Host system CPU information *1)

SD1510 to SD1599 are only valid for redundant systems.
They are all set to 0 for stand-alone systems.

Table12.34 Special register


Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD1585	Redundant system LED status	4 LED states • BACKUP • CONTROL • SYSTEM A • SYSTEM B	The LED status for BACKUP, CONTROL, SYSTEM A, SYSTEM B is stored in the following format: 	S (status change)	New	QnPRH
SD1588	Reason(s) for system switch-ing	Reason(s) for system switching that occurred in host station	Stores the reason(s) for system switching on the host system. The following values are stored corresponding to the methods for system switching: Initialized to 0 when the power supply is switched off and then on or the RESET switch is set to the RESET position and then to the neutral position. 0: Initial value (control system has not been switched) 1: Power off, Reset, H/W failure, WDT error, 2: CPU stop error (except WDT) 3: System switching request from network module 16: System switching dedicated instruction 17: System switching request from GX Developer	S (when condition occurs)	○	
SD1589	Reason(s) for system switching failure conditions	Reason(s) for system switching failure No.	• Stores the reason(s) for system switching failure. 0: System switching normal (default) 1: Tracking cable is not connected , tracking cable error, FPGA circuit failure. 2: H/W failure, power-OFF, Reset, WDT error on the standby system 3: H/W failure, power-OFF, Reset, WDT error on the Control system 4: Tracking data transfer initialization 5: Communication timeout 6: Serious error(except WDT error) on the Standby system 7: There is difference between both systems (detected as Backup mode only) 8: During memory copy from control system to standby system 9: During online program change 10: During detection of intelligent function module failure on the standby system 11: System switching being executed • Resets to "0" when host system is powered on. • Resets to "0" once system has been switched successfully.	S(when system is switched)	○	QnPRH
SD1590	Network module head address, which requested system switching	Network module head address, which requested system switching	• Stores head address of network module which a system switch request was initiated. • Turns off automatically by system, after network error is reset by user.  • Please refer to SD1690 which stores the corresponding head address of network module on other system.	S (Error/Status change)	New	QnPRH
SD1595	Memory copy target I/O number	Memory copy target I/O number	• Stores the memory copy target I/O No.(Standby system CPU module: 3D1H) of before SM1595 is turned from OFF to ON.	U	New	
SD1596	Memory copy status	Memory copy status	• Stores the execution result of Memory copy function. 0 : Memory copy successfully completed 4241H : Standby system power supply off 4242H : Tracking cable is disconnected or is damaged 4247H : Memory copy function is being executed 4248H : Unsupported memory copy destination I/O Number	S (Status change)	New	

*1: The information of the host CPU module is stored.

(16) For redundant systems (Other system CPU information [*1])



SD1600 to SD1659 is only valid during the back up mode for redundant systems, and refresh cannot be done when in the separate mode.
SD1651 to SD1699 are valid in either the backup mode or separate mode.
When a stand-alone system SD1600 to SD1699 are all 0.

Table12.35 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU SD□□*2	Corresponding CPU
SD1600	System error information	System error information	• If an error is detected by the error check for redundant system, the corresponding bit shown below turns ON. That bit turns OFF when the error is cleared after that.  • If any of b0, b1, b2 and b15 is ON, the other bits are all OFF. • In the debug mode, b0, b1, b2 and b15 are all OFF.	S(Every END)	–	QnPRH
SD1601	System switching results	System switching results	Stores the reasons for system switching. • Stores the reasons for system switching into SD1601 of both systems when system switching occarred. • Initialized to 0 at power OFF to ON/reset to unreset. • The following shows values stored into this register. 0: Initial value (System switching has not occurred) 1: Power-OFF, Reset, H/W failure, WDT error,(*) 2: CPU stop error (except WDT) 3: System switching request by network module 16: System switching dedicated instruction 17: System switching request from GX Developer *: When the system is switched by the power OFF/reset of the control system, "1" is not stored into SD1601 of the new standby system.	S(when system is switched)		
SD1602	System switching dedicated instruction parameter	System switching dedicated instruction parameter	• Stores the parameters for system switching dedicated instruction SP.CONTSW. (The parameters (SD1602) for SP.CONTSW are stored in both systems A&B) • SD1602 is only valid when "16" is stored in SD1601. • This SD1602 is updated once system switch instruction SP.CONTSW is activated.	S(when system is switched)		
SD1610	Other system diagnostic error	Diagnostic error code	• The error value sorted in BIN code. • Stores SD0 of the other system CPU module	S(Every END)	SD0	
SD1611 SD1612 SD1613	Other system diagnostic error occurrence time	Diagnostic error occurrence time	• Stores the date and time when diagnostics error occurred corresponding to error code stored in SD1610. • Data format is the same as SD1 to SD3. • Also, stores the value to SD1 to SD3.	S(Every END)	SD1 to SD3	
SD1614	Other system error information category	Error information category code	• Stores the category code corresponding to the error comment information/individual information code. • Data format is the same as SD4. • Also, stores the value to SD4.	S(Every END)	SD4	
SD1615 to SD1625	Other system error common information	Error common information	• Stores the common information corresponding to the error code stored in this system CPU. • Data composition is the same as SD5 to SD15. • Also, stores the value to SD5 to SD15.	S(Every END)	SD5 to SD15	
SD1626 to SD1636	Other system error individual information	Error individual information	• Stores the individual information corresponding to the error code stored in this system CPU. • Data composition is the same as SD16 to SD26. • Also, stores the value to SD16 to SD26.	S(Every END)	SD16 to SD26	

*2: Shows the special register (SD□ □) for the host system CPU module.

Table12.35 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU SD□□*2	Corresponding CPU
SD1649	Standby system error cancel command	Error code of error to be cleared	• Stores the error code of the error to be cleared by clearing a standby system error. • Stores the error code of the error to be cleared into this register and turn SM1649 from OFF to ON to clear the standby system error. • The value in the lowest digit (1 place) of the error code is ignored when stored into this register. (By storing 4100 in this register and resetting the error, errors 4100 to 4109 can be cleared.)	S(Every END)	–	QnPRH
SD1650	Other system operating information	Other system operating information	Stores the operation information of the other system CPU module in the following format. "00FFH" I stored when a communication error occurs, or when in debug mode.  Note : A communication error is caused by the following:. • When the power supply is switched off, or when the other system is reset. • H/W error occurs on either of system A or B. • WDT error occurs. • Tracking cable is not connected. • Tracking cable is disconnected or damaged.	S(Every END)		
SD1690	Network module head address, which requested system switching on host (control) system	Network module head address, which requested system switching on host (control) system	• Stores head address of network module which a system switch request was initiated, using the following format. • Turns off automatically by system, after network error is reset by user.  • Please refer to SD1590 which stores the corresponding head address of network module on host system.	S(Every END)		

*2 : Shows the special register (SD□ □) for the host system CPU.

(17) For redundant systems (Trucking)

SD1700 to SD1779 is valid only for redundant systems.

These are all 0 for stand-alone systems.

Table12.36 Special register



Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD1700	Tracking error detection count	Tracking error detection count	• When the tracking error is detected, count is added by one. • The counter repeats an increment and decrement of the value; 0 → 32767 → - 32768 → 0	S(Error)		QnPRH
SD1710	Waiting time for online program change (standby system)	Waiting time for online program change (standby system)	• Set in seconds the waiting time of the standby system CPU module from when online program change to the control system CPU module is completed by the online program change for redundancy function until the online program change to the standby system CPU module starts. • If no online program change request is issued to the standby system CPU module within the preset time after completion of the online program change to the control system CPU module, both system CPU modules judge it as the failure of the online program change for redundancy. In this case, both system CPU modules resume the consistency check between system A & B suspended during the online program change. Also, the control system CPU module is set to accept a new request of online program change for redundancy. • When both systems are powered on, 90 seconds are set to SD1710 as the default value. • Set the value within the range 90 to 3600 seconds. When the setting is 0 to 89 seconds, it is regarded as 90 seconds for operation. If the setting is outside the allowed range, it is regarded other than 0 to 3600 seconds for operation. • The waiting time for a start of online program change to the standby system CPU module is checked according to the SD1710 setting during online change of multiple blocks and online change of batch of files for redundancy.	U/ S (Initial)	New	QnPRH

(18) Redundant power supply module information

SD1780 to SD1789 are valid only for a redundant power supply system.

The bits are all 0 for a singular power supply system.

Table12.37 Special register

Number	Name	Meaning	Explanation	Set by (When Set)	Corres-ponding ACPU D9□□□	Corresponding CPU
SD1780	Power supply off detection status	Power supply off detection status	• Stores the status of the redundant power supply module with input power OFF in the following bit pattern. • Stores 0 when the main base unit is not the redundant power main base unit (Q38RB).  • When configuring multiple CPU, the status is stored to 1st CPU module.	S(Every END)	New	Qn(H)*2 QnPH*2 QnPRH QnU*3
SD1781	Power supply failure detection status	Power supply failure detection status	• Stores the failure detection status of the redundant power supply module in the following bit pattern. (The corresponding bit is cleared to 0 when the input power to the faulty redundant power supply module is switched OFF after detection of the redundant power supply module failure.) • Stores 0 when the main base unit is not the redundant power main base unit (Q38RB).  • When configuring multiple CPU, the status is stored to 1st CPU module.	S(Every END)	New	
SD1782	Momentary power failure detection counter for power supply 1*1	Momentary power failure detection count for power supply 1	• Counts the number of times of momentary power failure of the power supply 1/2. • Monitors the status of the power supply 1/ 2 mounted on the redundant power main base unit (Q38RB) and counts the number of times of momentary power failure. Status of power supply 1/power supply 2 mounted on the redundant extension base unit is not monitored. • When the CPU module starts, the counter of the power supply 1/ 2 is cleared to 0. • If the input power to one of the redundant power supply modules is turned OFF, the corresponding counter is cleared to 0. The counter is incremented by 1 every time the momentary power failure of the power supply 1/ 2 is detected.(The counter repeats increment and decrement of the value; 0 → 32767 → – 32768 → 0 (The system monitor of GX Developer shows the counter within the range between 0 and 65535. • Stores 0 when the main base unit is not the redundant power main base unit (Q38RB). • When configuring multiple CPU, the status is stored to 1st CPU module. • The counter repeats increment and decrement of the value, 0 → 32767 → – 32768 → 0 (The system monitor of GX Developer shows the counter within the range between 0 and 65535.	S(Every END)	New	
SD1783	Momentary power failure detection counter for power supply 2*1	Momentary power failure detection count for power supply 2		S(Every END)	New	

*1: The "power supply 1" in dicates the redundant power supply module mounted on the POWER 1 slot of the redundant base unit (Q38RB/68RB/Q65WRB).
The "power supply 2" indicates the redundant power supply module mounted on the POWER 2 slot of the redundant base unit (Q38RB/68RB/Q65WRB).

*2: The module whose first 5 digits of serial No. is "07032" or later.
However, for the multiple CPU system configuration, this applies to all CPU modules whose first 5 digits of serial No. are "07032" or later.

*3: The module whose first 5 digits of serial No. is "10042" or later.

APPENDICES

Appendix 1 List of Parameter Numbers

Each parameter number will be stored in the special register (SD16 to SD26) when an error occurs in the parameter settings.

TableApp.1 lists the parameter items and corresponding parameter numbers.

For explanation of M and N shown in the "Parameter No." column, refer to Section 8.2.

TableApp.1 List of parameter numbers

Item		Parameter No.	Reference
Label		0000H	Section 8.1(1)
Comment		0001H	
I/O assignment	Type	0400H	Section 4.2.2, 8.1 (9)
	Model name		
	Points		
	Start XY (Start I/O number)		
Base setting	Base model name	0401H	Section 4.2.1, Section 8.1(9)
	Power model name		
	Extension cable		
	Slots		
Detailed setting	Error time output mode	0403H	Section 6.8, Section 8.1(9)
	I/O response time	0405H	Section 6.8, Section 8.1(9)
	Control PLC	0406H	Section 8.1 (9), QCPU User's Manual (Muitiple CPU System)
No. of PLC		0E00H	Section 8.1 (12), QCPU User's Manual (Muitiple CPU System)
Operating mode		0E01H	
I/O sharing when using Multiple CPUs	All CPUs can read all inputs	0E04H	
	All CPUs can read all outputs		
Timer limit setting	Low speed	1000H	Section 8.1(2)
	High speed		
RUN-PAUSE contacts	RUN	1001H	Section 6.6.1, Section 8.1(2)
	PAUSE		Section 6.6.2, Section 8.1(2)
Remote reset		1002H	Section 6.6.3, Section 8.1(2)
Output mode at STOP to RUN		1003H	Section 6.4, Section 8.1(2)
Common pointer No.		1005H	Section 9.10.2, Section 8.1(2)
Points occupied by empty slot		1007H	Section 4.4.2, Section 8.1(2)
Interrupt program/Fixed scan program setting		1008H	Section 2.2.3, 2.3.4, 8.1 (2)
System interrupt settings	Fixed scan interval (n : 28 to 31)		Section 8.1(2)
Intelligent function module setting (Interrupt pointer setting)		100AH	Section 9.11, Section 8.1(2)
Module synchronization		100CH	Section 8.1(2)

(To the next page)

TableApp.1 List of parameter numbers (continued)

Item		Parameter No.	Reference
Use serial communication		100EH	Section 6.23, Section 8.1(10)
Transmission speed			
Sum check			
Transmission wait time			
RUN write setting			
Service processing setting		1013H	Section 6.24.1, Section 8.1(2)
Latch data backup operation valid contact		1014H	Section 6.28, Section 8.1(2)
File register		1100H	Section 9.7, Section 8.1(3)
Comment file used in a command		1101H	Section 8.1(3)
Initial Device value		1102H	Section 6.25, Section 8.1(3)
File for local device		1103H	Section 9.14.2, Section 8.1(3)
Transfer to Standard ROM at Latch data backup operation		1104H	Section 6.28, Section 8.1(3)
File used for SP.DEVST/S.DEVLD instruction		1105H	Section 6.29, Section 8.1(5)
Device points		2000H	Section 9.1, Section 8.1(5)
Latch (1) start/end		2001H	Section 3.4, 6.3, Section 8.1(3)
Latch (2) start/end		2002H	
Local device start/end		2003H	Section 9.14.2, Section 8.1(5)
File register extended setting	Device points	2000H	Section 9.8, Section 8.1(5)
	Latch (1) start/end	2004H	
	Latch (2) start/end	2005H	
	32 bit Indexing	2000H	Section 8.1(5)
WDT (watchdog timer) setting	WDT setting	3000H	Section 6.16, Section 8.1(4)
	Initial execution monitoring time		Section 2.3.1, Section 8.1(4)
Error check	Carry out battery check	3001H	Section 6.17, Section 8.1(4)
	Carry out fuse blown check		
	Verify module		
	Check device range at indexing		
	Diagnose redundant power supply system		
Operating mode when there is an error	Computation error	3002H	
	Expanded command error		
	Fuse blown		
	Module verify error		
	Intelligent module program execution error		
	File access error		
	Memory card operation error		
	External power supply OFF		
Constant scanning		3003H	Section 6.2, Section 8.1(4)
Detailed setting	H/W error time PLC operation mode	4004H	Section 6.9, Section 8.1(9)

(To the next page)

TableApp.1 List of parameter numbers (continued)

Item		Parameter No.	Reference
Number of modules on MELSECNET/H		5000H	Section 8.2(2)
Valid module during other station access		5001H	
Interlink transmission parameters		5002H	
Routing parameters		5003H	
Starting I/O No.		5NM0H	
Network No.			
Total stations			
Mode		5NM0H	
Refresh parameters		5NM1H	
Common parameters		5NM2H	
Station inherent parameters		5NM3H	
Sub-master parameters		5NM5H	
Common parameters 2		5NMAH	
Station inherent parameters 2		5NMBH	
Interrupt settings			
Program		7000H	Section 2.3, Section 8.1(6)
Boot option	Clear program memory	7000H	Section 5.1.2, 5.1.8, Section 8.1(7)
	Auto Download all Data from Memory card to Standard ROM		
Boot file setting			
SFC program start mode		8002H	Section 8.1(8)
Start conditions		8003H	
Output mode when the block is stopped		8006H	
Number of modules on Ethernet		9000H	Section 8.2(3)
Starting I/O No.		9N00H	
Network No.			
Group No.			
Station No.			
Operational settings			
Initial settings		9N01H	
Open settings		9N02H	
Router relay parameter		9N03H	
Station No.<->IP information		9N05H	
FTP Parameters		9N06H	
E-mail settings		9N07H	
	News setting	9N08H	
Interrupt settings		9N09H	
Routing parameters		9N04H	

(To the next page)

TableApp.1 List of parameter numbers (continued)

Item	Parameter No.	Reference
Number of modules on CC-Link IE controller network	A000H	Section 8.2(1)
Interlink transmission parameters	A002H	
Routing parameters	A003H	
Starting I/O No.	ANM0H	
Network No.		
Total stations		
Station No.		
Mode	ANM0H	
Refresh parameters	ANM1H	
Common parameters	ANM2H	
Station inherent parameters	ANM3H	
Number of modules	C000H	Section 8.2(4)
Remote input (RX)	CNM1H	
Remote output (RY)		
Remote register (RWr)		
Remote register (RWw)		
Ver.2 Remote input (RX)		
Ver.2 Remote output (RY)		
Ver.2 Remote register (RWr)		
Ver.2 Remote register (RWw)		
Special relay (SB)		
Special register (SW)		
Operational setting	CNM2H	
All connect count		
Retry count		
Automatic reconnection station count		
Standby master station No.		
PLC down select		
Scan mode setting		
Delay information setting		
Station information setting		
Remote device station initial setting		
Interrupt setting		

(To the next page)

TableApp.1 List of parameter numbers (continued)

Item		Parameter No.	Reference
Communication area setting (refresh setting)		E002H, E003H	Section 8.1 (12), QCPU User's Manual (Muitiple CPU System)
Online module change		E006H	
Refresh parameter detailed device specification		E007H	
Multiple CPU high speed transmission area setting	CPU specific send range	E008H	
	Auto refresh setting	E009H	
Multiple CPU synchronous startup setting		E00BH	
Host CPU number		E00CH	

Appendix 2 Functions Added or Changed by Version Upgrade

The Universal model QCPU is upgraded when some functions are added or specifications are changed.
Therefore, the functions and specifications differdepending on the function version and serial number.

(1) Function added and supported CPU module and GX Developer versions

TableApp.2 Functions added and supported CPU module and GX Developer versions

Function	Function version	First 5 digits of serial No.	Supported GX Developer
Use of the PC CPU module*1 (☞ QCPU User's Manual (Multiple CPU System))	B	"09072" or later	–
Setting of whether to use local device for each program (☞ Section 9.14.2)		"10012" or later	Version 8.62Q or later
Program batch transfer execution status (SM165) (☞ Section 5.1.3)			
Multiple CPU high speed transmission dedicated instruction*1 (☞ QCPU Programming Manual (Common Instructions))			–
Amount of battery consumption display (☞ QCPU User's Manual (Hardware Design, Maintenance and Inspection))			
Bit device extension (☞ Section 9.2)		"10042" or later	Version 8.68W or later
Executional conditioned device test (☞ Section 6.11.4)			
Auto start sampling trace function*1 (☞ Section 6.14)			
CC-Link IE group cyclic transmission function (☞ CC-Link IE Controller Network Reference Manual)			
Scan time measurement (☞ Section 6.13.3)			
External input/output forced on/off (☞ Section 6.11.3)			
Monitor condition setting*1 (☞ Section 6.11.3)			
Redundant power supply system-compatible *1 (☞ Section 6.20)			
32-bit index modification using "ZZ" (☞ QCPU Programming Manual (Common Instructions))			
Extended data register (D) and extended link register (W)*1 *2 (☞ Section 9.8)		"09042" or later *1	Version 8.70Y or later
Serial Communication Function*1 (☞ Section 6.23)		"10102" or later	Version 8.78G or later
CPU module change function with memory card*1 (☞ Section 6.30)			
Local device setting of the index register *1 (☞ Section 9.14.2)			
Communication using the A-compatible 1C/1E frame (MC protocol)*3 *4 (☞ Q Corresponding MELSEC Communication Protocol Reference Manual)			
Socket communication function (☞ QnUCPU User's Manual (Communication via Built-in Ethernet Port))*1		"11012" or later	

– : Not related to GX Developer

*1: Some models do not support the function. For details, refer to the corresponding reference.
*2: Data of the extended data register (D) and extended link register (W) can be retained in the standard ROM by using the latch data backup to standard ROM function (☞ Section 6.28) if the serial number (first five digits) of the Universal model QCPU is "10042" or later.
*3: Communication using the A-compatible 1E frame is available only via any Ethernet module.
If the module is connected to the built-in Ethernet port of the CPU module, this function is not available.
*4: Communication using the A-compatible 1C frame is available only via any serial communication module.
If the module is connected to the built-in RS-232 interface of the CPU module, this function is not available.

Appendix 3 Method of Replacing Basic Model QCPU or High Performance Model QCPU with Universal Model QCPU

Appendix 3.1 Replacement Precautions

This section describes precautions for replacing the Basic model QCPU or High Performance model QCPU with the Universal model QCPU and the replacement methods.

Appendix 3.1.1 Replacing Basic model QCPU with Universal model QCPU

(1) System configuration

TableApp.3 Precautions for replacement and replacement methods (System configuration)

Item	Precautions	Replacement method	Reference
GOT	GOT900 series cannot be connected.	Use GOT1000 series.	---
Applicable products and software	Products and software compatible with the Universal model QCPU must be used.	Products need to be replaced for the compatibility with the Universal model QCPU and software need to be upgraded for the communication with the Universal model QCPU are described in Appendix 3.2.	Appendix 3.2
Multiple CPU system	To configure a multiple CPU system, CPU modules compatible with the Universal model QCPU must be used.	CPU modules compatible with the Universal model QCPU are described in Appendix 3.2.	Appendix 3.2

(2) Program

TableApp.4 Precautions for replacement and replacement methods (Program)

Item	Precautions	Replacement method	Reference
Language and instruction	Some instructions are not supported.	Replace the instructions not supported in the Universal model QCPU are described in Appendix 3.3.	Appendix 3.3
Floating-point operation	When using the floating-point data comparison instructions, LDE□, ANDE□, ORE□, LDED□, ANDED□, and ORED□, if the comparison source data are -0, nonnumeric, unnormalized number, or ±∞, "OPERATION ERROR" (error code: 4101) is detected. (□indicates one of the followings; =,<>,<=,>=,<,>.)	When the floating-point data comparison instructions are used, modify the program as described in Appendix 3.4.2.	Section 2.4.4, Appendix 3.4.2
Device range check at index modification	When a device number exceeds a setting range due to index modification, "OPERATION ERROR" (error code: 4101) is detected.	Deselect the "Check device range at indexing" checkbox in the PLC RAS tab of the PLC parameter dialog box so that checking is not performed.	Section 6.17, Appendix 3.4.3

(To the next page)

TableApp.4 Precautions for replacement and replacement methods (Program) (Continued)

Item	Precautions	Replacement method	Reference
Latch setting	If latch ranges of internal user devices are specified, the processing time is added in proportion to the device points set to be latched.	The latch function of the Universal model QCPU is enhanced. (1) Large-capacity file register (R, ZR) (2) Writing/reading device data to the standard ROM (SP.DEVST and S(P).DEVLD instructions) (3) Latch range specification of internal devices Change the latch method to the method described in (1) to (3) above according to the application.	Section 6.3, Appendix 3.4.4
Interrupt counter	Interrupt counter is not supported.	Check the numbers of executions for interrupt programs on the Interrupt program monitor list screen of GX Developer.	Section 6.13.2, 9.2.11
SCJ instruction	When the SCJ instruction is used in the Universal model QCPU, the AND SM400 (or NOP instruction) needs to be inserted immediately before the SCJ instruction.	Insert the AND SM400 (or NOP instruction) immediately before the SCJ instruction when the SCJ instruction is used.	Section 6.5.1 in the QCPU Programming Manual (Common Instructions)
JP/GP.SREAD and JP/GP.SWRITE instructions	Use of the completion notification device of the target station specified in D3 when the SREAD and SWRITE instructions are used is available. (The Basic model QCPU ignores the device specified in D3.)	To get the same operation as the Basic model QCPU, omit D3 or use the READ instruction instead of the SREAD instruction.	Section 8.3.2 in the QCPU Programming Manual (Common Instructions)
ZPUSH instruction	The number of index registers is increased to 20 for the Universal model QCPU. The area for saving the data in the index register with the ZPUSH instruction is increased as well.	Increase the save area used for the ZPUSH instruction as needed.	Section 7.18.8 in the QCPU Programming Manual (Common Instructions)
Use of the annunciator (SET F□ and OUT F□ instructions)	When the annunciator is turned on by the SET F□or OUT F□ instruction, the USER LED turns on. (The ERR.LED does not turn on.)	---	---
I/O refresh between programs	I/O refresh between programs cannot be executed.	Execute I/O refresh at the start or end of each program with the RFS or COM instruction. (When the COM instruction is used, I/O refresh to be executed can be specified in SD778 by turning on SM774.)	---
SM/SD	Usage of a part of the special relay and special register is different.	Replace the corresponding special relay and special register as described in Appendix 3.5.	Appendix 3.5
Multiple CPU system	The start address for the user setting area (auto refresh) in the CPU shared memory is changed.	If the user setting area in the CPU shared memory is specified in the program, change the address for the user setting area by performing an operation for replacing a device in GX Developer. (Example: "MOV D0 U3E0\G192" → "MOV D0U3E0\G2048")	---

(To the next page)

TableApp.4 Precautions for replacement and replacement methods (Program) (Continued)

Item	Precautions	Replacement method	Reference
File register	To use the file register, capacity setting is required.	Set the capacity of the file register used in the PLC file tab of the PLC parameter.	Section 8.1
SFC program	The following settings are required for using SFC programs. • Program setting (when both sequence programs and SFC programs exist.) • Common pointer No. setting (to execute the CALL instruction from SFC programs)	• Set program details in the Program tab of the PLC parameter dialog box. • Enter a common pointer number in the PLC system of the PLC parameter dialog box.	

(3) Drive and file

TableApp.5 Precautions for replacement and replacement methods (Drive and file)

Item	Precautions	Replacement method	Reference
Boot file setting	The boot file setting is not supported.	Since the Universal model QCPU holds the data in the program memory even when the battery voltage drops, the boot file setting is not necessary. Move files with the boot setting (from the standard ROM to the program memory) to the program memory.	Section 5.1.8

(4) External communication (Service processing)

TableApp.6 Precautions for replacement and replacement methods (External communication (Service processing))

Item	Precautions	Replacement method	Reference
Time reserved for communication processing	The time reserved for communication processing (SM315/SD315) is not supported.	Set service processing time in the PLC system tab of the PLC parameter dialog box.	Section 6.24.1

(5) Battery installation position

TableApp.7 Precautions for replacement and replacement methods (Battery installation position)

Item	Precautions	Replacement method	Reference
Battery installation position	The battery replacement method is different. The battery installation position varies depending on the model. • Q00JCPU, Q00CPU, Q01CPU ...On the front of the module. • Q00UJCPU, Q00UCPU, Q01UCPU ...At the bottom of the module.	For the battery replacement method, refer to the in the Reference column.	Section 7.2 in the QCPU User's Manual (Hardware Design, Maintenance and Inspection)

(6) Program size

TableApp.8 Precautions for replacement and replacement methods (Program size)

Item	Precautions	Replacement method	Reference
Program size	Data in the program memory of the Basic model QCPU may exceed the size of the program memory of the Universal model QCPU.	Store parameter and device comment files in the standard ROM.	---

Appendix 3.1.2 Replacing High Performance model QCPU with Universal model QCPU

(1) System configuration

TableApp.9 Precautions for replacement and replacement methods (System configuration)

Item	Precautions	Replacement method	Reference
Use of AnS/A series module	AnS/A series modules are not supported.	Use Q series modules.	---
GOT	GOT900 series cannot be connected.	Use GOT1000 series.	---
Programming tool connection	Applicable USB cables are different. • High Performance model QCPU ... A-B type • Universal model QCPU ... A-miniB type	Use USB cables of A-miniB type. Or, use USB conversion adapters of B-miniB type.	---
Applicable products and software	Products and softwares compatible with the Universal model QCPU must be used.	Products need to be replaced for the compatibility with the Universal model QCPU and software need to be upgraded for the communication with the Universal model QCPU are described in Appendix 3.2.	Appendix 3.2
Multiple CPU system	To configure a multiple CPU system, CPU modules compatible with the Universal model QCPU must be used.	CPU modules compatible with the Universal model QCPU are described in Appendix 3.2.	Appendix 3.2
	In a multiple CPU system using the Motion CPU, an existing auto refresh area and user setting area cannot be used for data communication with the Motion CPU.	For data communication with the Motion CPU, use an auto refresh area and user setting area in the multiple CPU high-speed transmission area.	Chapter 4 in the QCPU User's Manual (Multiple CPU System)
Redundant power supply system*1	In a redundant power supply system using the Q38RB redundant power supply main base unit and the Q68RB redundant power supply extension base unit, the status of the power supply module cannot be stored in the special relay and special register (SM1780 to SM1783/SD1780 to SD1783). The status cannot be displayed on the system monitor screen.	Check the status of the power supply module by the LED on the front of the module.	Section 5.3 in the QCPU User's Manual (Hardware Design, Maintenance and Inspection)
MELSECNET/H	The simple dual-structured network function is not supported.	---	Section 7.7 in the Q Corresponding MELSECNET/H Network System Reference Manual (PLC to PLC network)

*1: The serial number (first five digits) of the applicable module (Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, and Q26UDHCPU) must be "10041" or earlier.

(2) Program

TableApp.10 Precautions for replacement and replacement methods (Program)

Item	Precautions	Replacement method	Reference
Language and instruction	Some instructions are not supported.	Replace the instructions not supported in the Universal model QCPU are described in Appendix 3.3.	Appendix 3.3
Floating-point operation	The Universal model QCPU performs program operations of floating-point data in single precision.	Instructions for floating-point double-precision operations are added for the Universal model QCPU. Replace the instructions if floating-point double-precision operations ares required, as described in Appendix 3.4.	Section 2.4.4, Appendix 3.4, Appendix 3.4.2
	When using the floating-point data comparison instructions, LDE□, ANDE□, ORE□, LDED□, ANDED□, and ORED□, if the comparison source data are -0, nonnumeric, unnormalized number, or ±∞, "OPERATION ERROR " (error code: 4101) is detected. (□indicates one of the followings; =,<>,<=,>=,<,>.)	When the floating-point data comparison instructions are used, modify the program as described in Appendix 3.4.2.	
Device range check at index modification	When a device number exceeds a setting range due to index modification, "OPERATION ERROR" (error code: 4101) is detected.	Deselect the "Check device range at indexing" checkbox in the PLC RAS tab of the PLC parameter dialog box so that checking is not performed.	Section 6.17, Appendix 3.4.3
Program execution type	Low-speed execution type programs are not supported.	Use scan execution type programs or fixed scan execution type programs.	Section 2.3
	A program execution type cannot be changed by remote operation.	Use instructions for switching program execution types, such as PSTOP, POFF, and PSCAN.	Section 2.3
Latch setting	If latch ranges of internal user devices are specified, the processing time is added in proportion to the device points set to be latched. (For example, if 8K points are latched for the latch relay (L), the processing time of 28.6 μs is required.)	The latch function of the Universal model QCPU is enhanced. (1) Large-capacity file register (R, ZR) (2) Writing/reading device data to the standard ROM (SP.DEVST and S(P).DEVLD instructions) (3) Latch range specification of internal devices Change the latch method to the method described in (1) to (3) above according to the application.	Section 6.3, Appendix 3.4.4

(To the next page)

TableApp.9 Precautions for replacement and replacement methods (Program) (Continued)

Item	Precautions	Replacement method	Reference
Interrupt program	The interrupt pointer (I49) for the high-speed interrupt function is not supported.	Consider the use of interrupt pointers for fixed scan interrupt (I28 to I31).	Section 6.13.2, 9.2.11
	Interrupt counter is not supported.	Check the numbers of executions for interrupt programs on the Interrupt program monitor list screen of GX Developer.	
	The interrupt pointers (I32 to I40) due to an error are not supported.	---	Section 9.11
SCJ instruction	When the SCJ instruction is used in the Universal model QCPU, the AND SM400 (or NOP instruction) needs to be inserted immediately before the SCJ instruction.	Insert the AND SM400 (or NOP instruction) immediately before the SCJ instruction when the SCJ instruction is used.	Section 6.5.1 in the QCPU Programming Manual (Common Instructions)
ZPUSH instruction	The number of index registers is increased to 20 for the Universal model QCPU. The area for saving the data in the index register with the ZPUSH instruction is increased as well.	Increase the save areas used for the ZPUSH instruction as needed.	Section 7.18.8 in the QCPU Programming Manual (Common Instructions)
File usability setting for each program	The following file usability setting for each program is not available.*1 • File register • Initial device value • Comment	When file usability is set, modify the program as described in Appendix 3.4.	Section 2.3, Appendix 3.4.5
I/O refresh setting for each program	I/O refresh setting for each program is not available.	Use the RFS instruction if I/O refresh setting for each program is required.	• Section 2.3 • QCPU Programming Manual (Common Instructions)
SM/SD	Usage of a part of the special relay and special register is different.	Replace the corresponding special relay and special register as described in Appendix 3.5.	Appendix 3.5
	A sereis-compatible special relay and special register are not supported. (SM1000 to SM1255/SD1000 to SD1255)	Using GX Developer, A series-compatible special relay and special register can be replaced with the Universal model QCPU-compatible special relay and special register. Note, however, that the ones which are not compatible with the Universal model QCPU are replaced with SM1255 and SD1255. Modify programs as needed.	Chapter 12
Processing time	Scan time and each processing time are different.	Modify programs as needed, checking the processing timing.	---

* 1: Even the local device file usability setting is not available for the Q02UCPU, Q03UDCPU, Q04UDHCPU, and Q06UDHCPU if the serial number (first five digits) is "10011" or earlier.

(3) Drive and file

TableApp.11 Precautions for replacement and replacement methods (Drive and file)

Item	Precautions	Replacement method	Reference
Boot file setting	Files in the standard ROM cannot be booted to the program memory.	Since the Universal model QCPU holds the data in the program memory even when the battery voltage drops, the boot file setting is not necessary. Move files with the boot setting (from the standard ROM to the program memory) to the program memory.	Section 5.1.8, 5.1.10, Appendix 3.4.6
	Booting operation is different.	Replacement method when the parameter-valid drive and the boot file setting are set in the High Performance model QCPU is described in Appendix 3.4.6.	
Automatic all data write from memory card to standard ROM	The setting method of this function is different.	In the Boot file tab of the PLC parameter dialog box, select "standard ROM" for the transfer destination. Note, however, that the transfer destination of "program" is fixed to "program memory". (Setting by DIP switches is not necessary.)	Section 5.1.8

(4) External communication

TableApp.12 Precautions for replacement and replacement methods (External communication)

Item	Precautions	Replacement method	Reference
Module service interval time read	The module service interval time cannot be read.	---	Section 6.24.1
MC protocol	The following frame types cannot be used when accessing the Universal model QCPU.*1 • A-compatible 1C frame • A-compatible 1E frame	Use the frame types below. • QnA-compatible 2C/3C/4C frame • QnA-compatible 3E frame • 4E frame	Q Corresponding MELSEC Communication Protocol Reference Manual

*1: The serial number (first five digits) of the applicable module (Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, and Q26UDHCPU) must be "10101" or earlier.

(5) Diagnostic function

TableApp.13 Precautions for replacement and replacement methods (Diagnostic function)

Item	Precautions	Replacement method	Reference
Error history	Error history data cannot be stored in the memory card.	The Universal model QCPU stores all storable data (up to 100) in the built-in memory.	Section 6.18
LED indication priority setting	LED indication priority cannot be set. Only LED indication setting at error occurrence is supported.	---	Section 6.21.2

(6) Debugging

TableApp.14 Precautions for replacement and replacement methods (Debugging)

Item	Precautions	Replacement method	Reference
Monitor*3	The monitoring condition cannot be set.	Use the sampling trace function for checking device data under the specified monitoring condition. With this function, changes of the specified device data can be recorded at the following timings: • at execution of the specified step • on the rising/falling edge of bit devices • when the value of word devices coincide with the setting value • at every specified time (settable range: 1 to 5000ms)	Section 6.11.1, 6.14
Scan time measurement by GX Developer*3	Time required for executing a part of the program cannot be measured using the scan time measurement function.*1	Calculate the time using instruction processing time described in the manual.	• Section 6.13.3 • Appendix 1.4 in the QCPU Programming Manual (Common Instructions)
External input/output forced on/off*3	The external input/output forced on/off function is not supported.*2	The function can be replaced with the programs described in Appendix 3.4.7. Note, however, that replacement method described does not apply in the following cases: • Input and output targeted for forced on/off are referred to or changed using the direct input device (DX) and direct output device (DY). • Input and output targeted for forced on/off are referred to or changed within an interrupt program.	Section 6.11.3, Appendix 3.4.7

* 1: Scan time of each program can be checked on the Program monitor list screen.
* 2: Device test by GX Developer can be performed.
* 3: The serial number (first five digits) of the applicable module (Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, and Q26UDHCPU) must be "10041" or earlier.

(7) Switch on the front of the CPU module

TableApp.15 Precautions for replacement and replacement methods (Switch on the front of the CPU module)

Item	Precautions	Replacement method	Reference
Switch on the front of the CPU module	The operation method with the RESET/ RUN/STOP switch is modified.	The RESET/STOP/RUN switch of the Universal model QCPU can be used for the reset operation of the CPU module and switching between the STOP and RUN status.	Section 4.4 in the QCPU User's Manual (Hardware Design, Maintenance and Inspection)
	Latch data cannot be cleared by the switch.	To clear latch data, use the remote latch clear operation of GX Developer.	Section 4.4 in the QCPU User's Manual (Hardware Design, Maintenance and Inspection)
	The system protect cannot be set by the switch.	Data in the files can be protected by setting a password for each file. Password for each file can be registered with GX Developer.	Section 6.19
	The parameter-valid drive setting is not necessary.	The Universal model QCPU automatically determines the parameter-valid drive. Change the setting as described in Appendix 3.4.5 when the parameter-valid drive is set to other than the program memory in the High Performance model QCPU.	• Appendix 3.4.6 • Section 4.4 in the QCPU User's Manual (Hardware Design, Maintenance and Inspection)

(8) SFC

TableApp.16 Precautions for replacement and replacement methods (SFC)

Item	Precautions	Replacement method	Reference
Step transition monitoring timer	The step transition monitoring timer is not supported.	Change the program as described in Appendix 3.1 in the manual in the Reference column.	Section 4.6 and Appendix 3.1 in the QCPU (Q Mode)/ QnACPU Programming Manual (SFC)
SFC operation mode setting	The periodic execution block setting is not supported.	Change the program as described in Appendix 3.2 in the manual in the Reference column.	Section 4.7.4 and Appendix 3.2 in the QCPU (Q Mode)/ QnACPU Programming Manual (SFC)
	An operation mode at double block START cannot be selected. (Fixed to “WAIT”.)	---	Section 4.7.5 in the QCPU (Q Mode)/ QnACPU Programming Manual (SFC)
	An operation mode at transition to active step cannot be selected. (Fixed to “TRANSFER”.)	---	Section 4.7.6 in the QCPU (Q Mode)/ QnACPU Programming Manual (SFC)
SFC program for program execution management	SFC programs for program execution management are not supported.	---	Section 5.2.3 in the QCPU (Q Mode)/ QnACPU Programming Manual (SFC)
SFC control instruction	Some SFC control instructions are not supported.	SFC control instructions not supported in the Universal model QCPU and replacing methods are described in Appendix 3.3.	• Appendix 3.3 • Section 4.4 in the QCPU (Q Mode)/ QnACPU Programming Manual (SFC)
SFC comment readout instruction	The following SFC comment readout instructions are not supported. • S(P).SFCSCOMR (SFC step comment readout instruction) • S(P).SFCTCOMR (SFC transition condition comment readout instruction)	---	Section 4.8 in the QCPU (Q Mode)/ QnACPU Programming Manual (SFC)
Method of SFC program change	SFC program files cannot be written to the running CPU module. (Programs in SFC Figure can be changed online.)	Write program data to the CPU module after changing the Universal model QCPU status to STOP.	Section 6.6 in the QCPU (Q Mode)/ QnACPU Programming Manual (SFC)

Appendix 3.2 Applicable devices and software

(1) Products need to be replaced for the compatibility with the Universal model QCPU

The following tables show products need to be replaced for the compatibility with the Universal model QCPU. (As for products not listed in the tables below, replacement is not required.)

TableApp.17 Product need to be replaced (Communication module)

Product	Model	Serial number (first five digits) of the product compatible with the Universal model QCPU*2	
		Used with Q02U/Q03UD/Q04UDH/ Q06UDHCPU	Used with Q00UJ/Q00U/Q01UCPU/ Q10UDH/Q13UDH/Q20UDH/ Q26UDHCPU, or Built-in Ethernet port QCPU
Web server module*1	• QJ71WS96	"09042" or later.	"10012" or later.
MES interface module	• QJ71MES96	"09042" or later.	"10012" or later.

*1: The Universal model QCPU does not operate normally when the Web server module on which GX RemoteService-I is installed is used.
*2: The Universal model QCPU does not operate normally when a product not compatible with the Universal model QCPU is used.

TableApp.18 Product need to be replaced (Personal computer board)

Product		Model	Dedicated software package version compatible with the Universal model QCPU*1		
			Used with Q02U/Q03UD/ Q04UDH/Q06UDHCPU	Used with Q13UDH/ Q26UDHCPU	Used with Q00UJ/Q00U/ Q01U/Q10UDH/ Q20UDHCPU, or Built-in Ethernet port QCPU
CC-Link IE controller network interface board		• Q80BD-J71GP21-SX • Q80BD-J71GP21S-SX	No restrictions	Version 1.03D or later	Version 1.06G or later
MELSECNET/H interface board	SI/QSI/H-PCF optical cable	• Q80BD-J71LP21-25 • Q80BD-J71LP21S-25	Version 15R or later	Version 18U or later	Version 20W or later
		• Q81BD-J71LP21-25	Version 19V or later	Version 19V or later	
	GI optical cable	• Q80BD-J71LP21G	Version 15R or later	Version 18U or later	
	Coaxial cable	• Q80BD-J71BR11			
CC-Link system master/local interface board		• Q80BD-J61BT11N	Version 1.02C or later	Version 1.05F or later	Version 1.07H or later
		• Q81BD-J61BT11	Version 1.06G or later	Version 1.06G or later	

*1: No restrictions on the board itself.

TableApp.19 Product need to be replaced (GOT)

Product	Model	OS version provided with GT Designer2 compatible with the Universal model QCPU*1				
		Used with Q00UJ/ Q00U/Q01U/ Q10UDH/ Q20UDHCPU	Used with Q02U/ Q03UD/Q04UDH/ Q06UDHCPU	Used with Q13UDH/ Q26UDHCPU	Used with Q03UDE/ Q04UDEH/Q06UDEH/ Q13UDEH/ Q26UDEHCPU	Used with Q10UDEH/ Q20UDEHCPU
GOT1000	GT15□- GT11□-□	Version 2.91V or later	Version 2.60N or later	Version 2.76E or later	Version 2.81K or later	Version 2.91V or later
	GT10□-□	Version 2.91V or later	Version 2.76E or later	Version 2.76E or later	---	---

*1: No restrictions on GOT itself.

TableApp.20 Product need to be replaced (Network module and serial communication module)

Product	Model	Module version compatible with the Universal model QCPU	
		Used with Q00UJ/Q00U/Q01U/Q02U/ Q03UD/Q04UDH/Q06UDH/Q10UDH/ Q13UDH/Q20UDH/Q26UDHCPU	Used with Built-in Ethernet port QCPU
MELSECNET/H model	• QJ71LP21-25 • QJ71LP21S-25 • QJ71LP21G • QJ71BR11	No restrictions	Some restrictions depending on use conditions*1
Serial communication module	• QJ71C24N • QJ71C24N-R2 • QJ71C24N-R4		Serial number (first five digits) "10042" or later
Modem interface module	• QJ71CMON		

*1: The serial number (first five digits) of the MELSECNET/H module must be "10042" or later if all conditions 1) to 4) described below are satisfied.

1) A multiple CPU system including Built-in Ethernet port QCPU is configured.
2) GX Developer or GOT is connected to an Ethernet port of the Built-in Ethernet port QCPU.
3) GX Developer or GOT accesses the CPU module on another station via the MELSECNET/H module controlled by another CPU.
4) The access target on another station is A/QnA series CPU module.

(2) CPU modules that can configure a multiple CPU system with the Universal model QCPU

CPU modules that can configure a multiple CPU system with the Universal model QCPU are shown below.

(a) For the QnUD(H)CPU or Built-in Ethernet port QCPU

TableApp.21 CPU module that can configure a multiple CPU system with the QnUD(H)CPU or Built-in Ethernet port QCPU

CPU module	Model	Applicable version			Restrictions
		Configured with Q03UD/Q04UDH/ Q06UDHCPU	Configured with Q13UDH/Q26UDH, Q03UDE/Q04UDEH, Q06UDEH/Q13UDEH/ Q26UDEHCPU	Configured with Q10UDH/Q20UDH/ Q10UDEH/ Q20UDEHCPU	
Motion CPU	• Q172DCPU • Q173DCPU	No restrictions			Use only the multiple CPU high-speed main base unit (Q3☐DB) as a main base unit.
PC CPU module	• PPC-CPU852(MS)	Driver S/W (PPC-DRV-02) version 1.01 or later	Driver S/W (PPC-DRV-02) version 1.02 or later	Driver S/W (PPC-DRV-02) version 1.03 or later	---
C Controller module	• Q06CCPU-V • Q06CCPU-V-B	No restrictions	Serial number (first five digits) "10012" or later	Serial number (first five digits) "10102" or later.	---
High Performance model QCPU	• Q02CPU • Q02HCPU • Q06HCPU • Q12HCPU • Q25HCPU	Function version B or later			---
Process CPU	• Q02PHCPU • Q06PHCPU • Q12PHCPU • Q25PHCPU	No restrictions			---

(b) For the Q00UCPU, Q01UCPU, or Q02UCPU

TableApp.22 CPU module that can configure a multiple CPU system with Q00UCPU, Q01UCPU, or Q02UCPU

CPU module	Model	Applicable version		Restrictions
		Configured with Q00U/ Q01UCPU	Configured with Q02UCPU	
Motion CPU	• Q172CPUN(-T) • Q173CPUN(-T) • Q172HCPU(-T) • Q173HCPU(-T)	No restrictions		The multiple CPU high-speed main base unit (Q3☐DB) cannot be used as a main base unit.
PC CPU module	• PPC-CPU852(MS)	Driver S/W (PPC-DRV-02) version 1.03 or later	Driver S/W (PPC-DRV-02) version 1.01 or later	---
C Controller module	• Q06CCPU-V • Q06CCPU-V-B	Serial number (first five digits) "10102" or later	No restrictions	---

(3) Software need to be upgraded for the compatibility with the Universal model QCPU

The following table shows software need to be upgraded for the communication with the Universal model QCPU. (As for software not listed in the table below, version upgrade is not required.)
The latest version can be downloaded from the MELFANSweb.

TableApp.23 Software need to be upgraded for the compatibility with the Universal model QCPU

Product	Model	Version compatible with the Universal model QCPU			
		Used with Q02U/ Q03UD/Q04UDH/ Q06UDHCPU	Used with Q13UDH/ Q26UDHCPU	Used with Q03UDE/ Q04UDEH/Q06UDEH/ Q13UDEH/ Q26UDEHCPU	Used with Q00UJ/Q00U/ Q01U/Q10UDH/ Q20UDH/Q10UDEH/ Q20UDEHCPU
GX Developer	SW8D5C-GPPW-E	Version 8.48A or later	Version 8.62Q or later	Version 8.68W or later	Version 8.78G or later
GX Configurator-AD	SW2D5C-QADU-E	Version 2.05F or later*1	Version 2.05F or later*2	Version 2.05F or later*3	Version 2.05F or later*4
GX Configurator-DA	SW2D5C-QDAU-E	Version 2.06G or later*1	Version 2.06G or later*2	Version 2.06G or later*3	Version 2.06G or later*4
GX Configurator-SC	SW2D5C-QSCU-E	Version 2.12N or later*1	Version 2.12N or later*2	Version 2.17T or later*3	Version 2.17T or later*4
GX Configurator-CT	SW0D5C-QCTU-E	Version 1.25AB or later*1	Version 1.25AB or later*2	Version 1.25AB or later*3	Version 1.25AB or later*4
GX Configurator-TI	SW1D5C-QTIU-E	Version 1.24AA or later*1	Version 1.24AA or later*2	Version 1.24AA or later*3	Version 1.24AA or later*4
GX Configurator-TC	SW0D5C-QTCU-E	Version 1.23Z or later*1	Version 1.23Z or later*2	Version 1.23Z or later*3	Version 1.23Z or later*4
GX Configurator-FL	SW0D5C-QFLU-E	Version 1.23Z or later*1	Version 1.23Z or later*2	Version 1.23Z or later*3	Version 1.23Z or later*4
GX Configurator-QP	SW2D5C-QD75P-E	Version 2.25B or later	Version 2.29F or later	Version 2.29F or later*5	Not available
GX Configurator-PT	SW1D5C-QPTU-E	Version 1.23Z or later*1	Version 1.23Z or later*2	Version 1.23Z or later*3	Version 1.23Z or later*4
GX Configurator-AS	SW1D5C-QASU-E	Version 1.21X or later*1	Version 1.21X or later*2	Version 1.21X or later*3	Version 1.21X or later*4
GX Configurator-MB	SW1D5C-QMBU-E	Version 1.08J or later*1	Version 1.08J or later*2	Version 1.08J or later*3	Version 1.08J or later*4
GX Configurator-DN	SW1D5C-QDNU-E	Version 1.23Z or later*1	Version 1.23Z or later*2	Version 1.24AA or later*3	Version 1.24AA or later*4
MX Component	SW3D5C-ACT-E	Version 3.09K or later	Version 3.10L or later	Version 3.11M or later	Version 3.12N or later
GX Simulator	SW7D5C-LLT-J	Version 7.23Z or later*4	Version 7.23Z or later*4	Version 7.23Z or later*4	Version 7.23Z or later*4

*1: The software can be used by installing GX Developer Version 8.48A or later.
*2: The software can be used by installing GX Developer Version 8.62Q or later.
*3: The software can be used by installing GX Developer Version 8.68W or later.
*4: The software can be used by installing GX Developer Version 8.78G or later.
*5: The software can be used only by connecting USB.

(4) Software not supported in the Universal model QCPU

The following table shows software not supported in the Universal model QCPU.

TableApp.24 Software not supported in the Universal model QCPU

Product	Model
GX Explorer	SW□D5C-EXP-E
GX Converter	SW□D5C-CNVW-E

Appendix 3.3 Instructions

Appendix 3.3.1 Instructions not supported in the Universal model QCPU and replacing methods

The Universal model QCPU does not support instructions listed in the TableApp.24. and TableApp.25. Instructions need to be replaced using replacing methods described in the tables. (If no instruction in the list is used, replacement is not required.)

TableApp.25 Instructions not supported in the Universal model QCPU and replacing methods

Symbol	Instruction	Replacing method	Reference
IX	Index modification of entire ladder	Instructions can be replaced using a replacement program.	Appendix 3.3.3 (1)
IXEND			
IXDEV	Modification value specification in index modification of entire ladder	Change the program so that the device offset values specified by the IXSET instruction are directly set to the index modification table using the MOV instruction.	Appendix 3.3.3 (2)
IXSET			
PR	Print ASCII code instruction	• It is recommended to use GOT as an ASCII code display device. ASCII codes stored in devices are directly displayed as characters on GOT. • Instructions can be replaced using a replacement program.	Appendix 3.3.3 (3)
PRC	Print comment instruction	• It is recommended to use GOT as an ASCII code display device.Device comments can be displayed on GOT. • Comment data can be output to a display device in the replacement program of the PR instruction after reading data using the reading device comment data instruction (COMRD(P)).	
CHKST	Specific format failure check instruction	Instructions can be replaced using a replacement program.	Appendix 3.3.3 (4)
CHK			
CHKCIR	Format change instruction for CHK instruction	Failure detection ladder patterns can be changed in a replacement program.	
CHKEND			
PLOW	Program low-speed execution registration instruction	• Use the PSCAN instruction instead of this instruction when low-speed execution type programs are replaced with scan execution type programs. • No instruction can be used if low-speed execution type programs are replaced with fixed scan execution type programs.	---
PCHK	Program execution status check instruction	Check a program execution status on the Program monitor list screen of GX Developer. For details, refer to Section 6.13.1 in this manual.	---
KEY	Numerical key input instruction	• It is recommended to use GOT as a numeral input device. • Instructions can be replaced using a replacement program.	Appendix 3.3.3 (5)
PLOADP	Load program from memory card	Store all programs to be executed in the program memory. The Universal model QCPU can neither add programs to the program memory nor change them with other programs during RUN. If the capacity of the program memory is not enough, store parameters, device comments, and initial device values in the program memory into the standard ROM or a memory card instead.	---
PUNLOADP	Unload program from memory card		
PSWAPP	Load + Unload		

TableApp.26 SFC control instructions not supported in the Universal model QCPU and replacing methods

Symbol	Instruction	Replacing method
LD TRn	Forced transition check instruction	When the programmable controller type is changed, these instructions are converted into SM1255. Modify programs as needed.
AND TRn		
OR TRn		
LDI TRn		
ANDI TRn		
ORI TRn		
LD BLm\TRn		
AND BLm\TRn		
OR BLm\TRn		
LDI BLm\TRn		
ANDI BLm\TRn		
ORI BLm\TRn		
SCHG(D)	Active step change instruction	Refer to Appendix 3 "Restrictions and replacing method of the Basic model QCPU and Universal model QCPU" in the QCPU (Q Mode)/QnACPU Programming Manual (SFC).
SET TRn	Transition control instruction	Refer to Appendix 3 "Restrictions and replacing method of the Basic model QCPU and Universal model QCPU" in the QCPU (Q Mode)/QnACPU Programming Manual (SFC).
SET BLm\TRn		
RST TRn		
RST BLm\TRn		
BRSET(S)	Block switching instruction	When the programmable controller type is changed, these instructions are converted into SM1255. Modify programs as needed.

Appendix 3.3.2 Replacing programs using multiple CPU transmission dedicated instructions

(1) Replacing the module with the QnUD(H)CPU or Built-in Ethernet port QCPU

TableApp.26 shows instructions need to be replaced and corresponding alternative instructions. For the specifications of each instruction, refer to the manuals for the Motion CPU.

TableApp.27 SFC instructions not supported in the QnUD(H)CPU and Built-in Ethernet port QCPU and thier alternatives

Symbol	Instruction description	Symbol of alternative instruction
S(P).DDWR	Write other CPU device data into host CPU	D(P).DDWR
S(P).DDRD	Read other CPU device data into host CPU	D(P).DDRD
S(P).SFCS	Request of motion SFC program startup	D(P).SFCS
S(P).SVST	Request of servo program startup	D(P).SVST
S(P).CHGA	Current value change of halted axis/synchronized encoder/cam axis	D(P).CHGA
S(P).CHGV	Axis speed change during positioning and JOG operation	D(P).CHGV
S(P).CHGT	Torque control value change during operation and suspension in real mode	D(P).CHGT
S(P).GINT	Request of other CPU interrupt program startup	D(P).GINT

(2) Replacing the module with the Q00UCPU, Q01UCPU, or Q02UCPU

The Q00UCPU, Q01UCPU, and Q02UCPU support the same multiple CPU transmission dedicated instructions used in the Basic model QCPU.

The alternative instructions in TableApp.27 are not available for these CPU modules.

Appendix 3.3.3 Program replacement examples

This section shows program replacement examples for the instructions of which replacement programs are available in Appendix 3.3. (Skip this section if instructions listed in Appendix 3.3.1 are not used.)

(1) Replacement example of the IX and IXEND instructions

Since index registers are saved using the ZPUSH instruction, a 23-word index register save area is required.

(a) Example of device assignment

TableApp.28 Example of device assignment

Before replacement	
Application	**Device**
Index modification table	D100 to D115

After replacement	
Application	**Device**
Index modification table	D100 to D115
Index register save area	D200 to D222

If the device numbers in the example above are used for other applications, assign unused device numbers instead.

(b) Program before replacement




Figure App.1 Sample program

(c) Program after replacement

- Replace the IX instruction with the ZPUSH instruction and the processing for setting the contents of index modification table to index registers.
- Replace the IXEND instruction with the ZPOP instruction.




Figure App.2 Sample program

(2) Replacement example of the IXDEV and IXSET instructions

Change the program so that the device offset value specified by the contacts between the IXDEV and the IXSET instructions are directly set to the index modification table using the MOV instruction.

For the devices whose device offset value is not specified by the IXDEV and IXSET instructions, set the device offset value to 0 in the program after replacement.

Figure App.3 shows how the device offset value is set in the program before and after replacement.




Figure App.3 Device offset value specification and index modification table

*1: Device numbers are represented in hexadecimal. Use hexadecimal constants (H□) when setting values in the index modification table.

*2: Start I/O numbers (U□) are represented in hexadecimal. Use hexadecimal constants (H□) when setting values in the index modification table.

*3: Devices B, W, X, or Y can be specified following J\□. Set device numbers for B, W, X, and Y as device offset values of each device in the index modification table.
For example, if "J10\Y220" is specified by the IXDEV and IXSET instructions, set "K10" in (D)+13 and "H220" in (D)+3 in the replacement program. ((D) indicates the start device in the index modification table.)

(a) Program before replacement




Figure App.4 Sample program

(b) Program after replacement




Figure App.5 Sample program

(3) Replacement example of the PR instruction

The number of output characters can be switched by the on/off status of SM701.

(a) Example of device assignment

TableApp.29 Example of device assignment

Before replacemen	
Application	**Device**
Output string	D0 to D3
ASCII code output signal	Y100 to Y107
Strobe signal	Y108
In-execution flag	Y109

After replacement	
Application	**Device**
Output string	D0 to D3
ASCII code output signal	Y100 to Y107
Strobe signal	Y108
In-execution flag	Y109
Output string storage address (BIN32)	D20 to D21
Output string storage address (BIN32) (Used for sub-routine programs and interrupt programs)	D200 to D201
Number of output characters	D202
Output module start Y number	D203
Character extraction position	D204
Number of extracted characters	D205
String output status value	D206
Result of string extraction by the MIDR instruction	D207
String output in-execution flag	M200
For index modification	Z0

If the device numbers in the example above are used for other applications, assign unused device numbers instead.

(b) Program before replacement




Figure App.6 Sample program

(c) Program after replacement

In the sequence program after replacement, three programs are required as shown below.




Figure App.7 Program execution

1) Main routine program

- Replace the PR instruction with the CALL instruction so that a subroutine program is called.
- Output string storage device ("D0" in the program below) cannot be specified directly with the CALL instruction.
- Use the ADRSET instruction to acquire the indirect address for the CALL instruction.
- Y device ("Y100" in the program before replacement shown in (b)) cannot be specified directly as output Y number with the CALL instruction. Specify the output Y number in integer.
- An interrupt program is used to output character codes via the output module. Enable the execution of interrupt programs using the EI instruction.




Figure App.8 Sample program

2) Subroutine program

- In the subroutine program, the data for outputting ASCII codes using a fixed scan interrupt program (10ms) are set to work devices. Also, the flag for activating the processing in the fixed scan interrupt program is turned on.
- Specify the following arguments for the subroutine program.

First argument	Output string storage address	(Input)
Second argument	Output module start Y number	(Input)




Figure App.9 Sample program

3) Interrupt program

The following processing is added to a fixed scan interrupt program (10ms).

The fixed scan interrupt program outputs ASCII codes from the output module and controls the strobe signal.




Figure App.10 Sample program

(4) Replacement example of the CHKST and CHK instructions

In the example below, if the replacement program for the CHKST and CHK instructions detects a failure, a failure number (contact number + coil number) is stored in D200 and the annunciator F200 is turned on.

(a) Example of device assignment

TableApp.30 Example of device assignment

Before replacement	
Application	**Device**
Advance end detection sensor input 1	X100
Retract end detection sensor input 1	X101
Advance end detection sensor input 2	X102
Retract end detection sensor input 2	X103
Advance end detection sensor input 3	X104
Retract end detection sensor input 3	X105
Advance end detection sensor input 4	X106
Retract end detection sensor input 4	X107
Failure detection output 1	Y100
Failure detection output 2	Y102
Failure detection output 3	Y104
Failure detection output 4	Y106

After replacement	
Application	**Device**
Advance end detection sensor input 1	X100
Retract end detection sensor input 1	X101
Advance end detection sensor input 2	X102
Retract end detection sensor input 2	X103
Advance end detection sensor input 3	X104
Retract end detection sensor input 3	X105
Advance end detection sensor input 4	X106
Retract end detection sensor input 4	X107
Failure detection output 1	Y100
Failure detection output 2	Y102
Failure detection output 3	Y104
Failure detection output 4	Y106
Coil number (failure type detected)	D100
Contact number	D101
Failure number	D200
Failure detection display	F200
For index modification	Z0

If the device numbers in the example above are used for other applications, assign unused device numbers instead.

When the advance end detection sensor input performs a failure detection of Xn, assign device numbers for the retract end detection sensor input and the failure detection output as described below.

Advance end detection sensor input	Xn
Retract end detection sensor input	Xn+1
Failure detection output	Yn

(b) Program before replacement




Figure App.11 Sample program

(c) Program after replacement

In the sequence program after replacement, two programs are required as shown below.




Figure App.12 Program execution

1) Main routine program

- Replace the CHKST and CHK instructions with the CALL instructions so that a subroutine program is called.
- One CALL instruction is required for each device specified as check condition in front of the CHK instruction. (In the program before replacement shown in (b), four CALL instructions need to be added since there are four check conditions in front of the CHK instruction.)
- Device number and contact number of X devices (check condition) are specified in each CALL instruction.
- Contact number is used to display failure number when a failure is detected.



Figure App.13 Sample program

2) Subroutine program

- In the subroutine program, an failure status is checked using a failure detection ladder pattern.
- If a failure is detected, a failure number is stored in D200 and the annunciator F200 is turned on.
- Specify the following arguments for the subroutine program.

First argument	Device number of X device targeted for failure check	(Input)
Second argument	Contact number of X device targeted for failure check	(Input)




Figure App.14 Sample program

(d) Replacement method when failure detection ladder patterns are changed by the CHKCIR and CHKEND instructions

Failure detection ladder patterns can be changed in the subroutine program described in (c).

(5) Replacement example of the KEY instruction

(a) Example of device assignment

TableApp.31 Example of device assignment

Before replacemen	
Application	**Device**
Numeric input execution instruction	M0
Input complete flag	M1
Input data area	D200 to D203
ASCII code input signal	X100 to X107
Strobe signal	X108

After replacement	
Application	**Device**
Numeric input execution instruction	M0
Input complete flag	M1
Input data area	D200 to D203
ASCII code input signal	X100 to X107
Strobe signal	X108
Input data area address (BIN32)	D210 to D211
(Input data area + 0) address (BIN32)	D212 to D213
(Input data area + 1) address (BIN32)	D214 to D215
(Input data area + 2) address (BIN32)	D216 to D217
For shifting input data	D218
For converting input data	D219 to D220

If the device numbers in the example above are used for other applications, assign unused device numbers instead.

(b) Program before replacement




Figure App.15 Sample program

(c) Program after replacement

In the sequence program after replacement, two programs are required as shown below.




Figure App.16 Program execution

1) Main routing program

- Set "0" in the input data area on the rising edge of the execution instruction ("M0" in the program below) and initialize the program.
- Execute the CALL instruction on every rising edge of the strobe signal ("X108" in the program below) so that a subroutine program is called.
- In the subroutine program, input codes are added to the input data area and the completion status is checked.
- Pass the following data to the subroutine program at execution of the CALL instruction.
  1) ASCII code input values from the input module (Xn0 to Xn7)
  2) Number of digits to be input
  3) Indirect address of the input data area (Use the ADRSET instruction to acquire the indirect address for the input data area.)
  4) Bit devices to be turned on when input is completed




Figure App.17 Sample program

2) Subroutine program

- In the subroutine program, ASCII codes specified by an argument are added to the input data area and the completion status is checked.
- Specify the following arguments for the subroutine program.

First argument	ASCII code input from the input module (K2Xn)	(Input)
Second argument	Number of digits to be input	(Input)
Third argument	Indirect address of the input data area	(Input)
Fourth argument	Bit device to be turned on when input is completed	(Output)




Figure App.18 Sample program

Appendix 3.4 Functions

Appendix 3.4.1 Floating-point operation instructions

(1) Differences between High Performance model QCPU and Universal model QCPU

(a) High Performance model QCPU

The High Performance model QCPU can perform only the single-precision floating-point operation instructions. Note, however, that internal operation processing can be performed in double precision by selecting the item shown below (default: selected).




Figure App.19 PLC system tab

(b) Universal model QCPU

The Universal model QCPU supports the double-precision floating-point operation instructions.

The operation can be performed either in single precision or double precision depending on the data. Therefore, the "Perform internal arithmetic operations in double precision" item in the PLC system tab of the PLC parameter dialog box cannot be selected.

Because of this new function, operation results (both in single precision and double precision) slightly differ between the High Performance model QCPU and the Universal model QCPU if "Perform internal arithmetic operations in double precision" is selected in the High Performance model QCPU.

If higher accuracy is required in floating-point operations, replace the floating-point operation instructions as described in (4).

However, if six or less digits are used as significant digits for the floating-point operation instructions, replacement is not necessary. The single-precision floating-point operation results in the Universal model QCPU can be used as they are in the system. When not replacing instructions, make sure that it does not cause any problems in the system.

(2) Floating-point operation instructions for the Universal model QCPU

TableApp.30 lists floating-point operation instructions for the Universal model QCPU.

Specifications of the single-precision floating-point operation instructions are compatible with those for the High Performance model QCPU.

TableApp.32 List of floating-point operation instructions supported in the Universal model QCPU

Instruction name		Instruction symbol		Remarks
		Single-precision floating-point data	Double-precision floating-point data	
Comparison	Floating-point data comparison	LDE□	LDED□	□ indicates one of the followings; <>,=,<,>,<=,>=
		ANDE□	ANDED□	
		ORE□	ORED□	
Data transfer	Floating-point data transfer	EMOV(P)	EDMOV(P)	---
Four arithmetic operation	Floating-point data addition	E+(P)	ED+(P)	---
	Floating-point data subtraction	E-(P)	ED-(P)	
	Floating-point data multiplication	E*(P)	ED*(P)	
	Floating-point data division	E/(P)	ED/(P)	
Data conversion	Conversion from BIN 16-bit data to floating-point data	FLT(P)	FLTD(P)	---
	Conversion from BIN 32-bit data to floating-point data	DFLT(P)	DFLTD(P)	
	Conversion from floating-point data to BIN 16-bit data	INT(P)	INTD(P)	
	Conversion from floating-point data to BIN 32-bit data	DINT(P)	DINTD(P)	
	Floating-point sign inversion	ENEG(P)	EDNEG(P)	
Special function	SIN operation	SIN(P)	SIND(P)	---
	COS operation	COS(P)	COSD(P)	
	TAN operation	TAN(P)	TAND(P)	
	SIN-1 operation	ASIN(P)	ASIND(P)	
	COS-1 operation	ACOS(P)	ACOSD(P)	
	TAN-1operation	ATAN(P)	ATAND(P)	
	Conversion from angle to radian	RAD(P)	RADD(P)	
	Conversion from radian to angle	DEG(P)	DEGD(P)	
	Square root	SQR(P)	SQRD(P)	
	Exponential operation	EXP(P)	EXPD(P)	
	Natural logarithm operation	LOG(P)	LOGD(P)	

Floating-point data can be converted mutually between single precision and double precision using instructions in TableApp.33.

TableApp.33 Floating-point data conversion instructions (single precision↔double precision)

Instruction name	Instruction symbol
Single precision to double precision conversion	ECON(P)
Double precision to single precision conversion	EDCON(P)

(3) Advantages and disadvantages when using the double-precision floating-point data of the Universal model QCPU

TableApp.32 shows the advantages and disadvantages when executing the double-precision floating-point operation instructions in the Universal model QCPU.

If higher accuracy is required in floating-point operations, it is recommended to replace the instructions with the double-precision floating-point operation instructions.

TableApp.34 Advantages and disadvantages when using the double-precision floating-point operation instructions

Advantage	Disadvantage
The results are more accurate than those of the single-precision floating-point operation instructions.	The instruction processing speed is slower than that of the single-precision floating-point operation instructions.*1 Double-precision floating-operation data use twice as many word device points as single-precision floating-operation data.

*1: The processing speed of the double-precision floating-point operation instructions in the Universal model QCPU is higher than that of floating-point operation instructions using internal double-precision operations in the High Performance model QCPU.

TableApp.33 shows the comparison between single-precision and double precision floating-point data.

TableApp.35 Comparison between single-precision and double precision floating-point data

Item		Single-precision floating-point data	Double-precision floating-point data
Word point required for data retention		2 words	4 words
Setting range		$-2^{128}<N \leqq -2^{-126}$, 0, $2^{-126} \leqq N<2^{128}$	$-2^{1024}<N \leqq -2^{-1022}$, 0, $2^{-1022} \leqq N<2^{1024}$
Precision (number of bits)	Mantissa	23 bits	52 bits
	Exponent	8 bits	11 bits
	Sign	1 bits	1 bits
Instruction processing speed (Q04UDHCPU/ Q06UDHCPU) (Maximum)	Data comparison (Conductive status) (LDE>= / LDED>=)	5.5 μs	9.0 μs
	Data transfer (EMOV/EDMOV)	0.019 μs	5.0 μs
	Addition (3 devices) (E+ / ED+)	0.0665 μs	9.2 μs
	SIN operation (SIN/SIND)	5.7 μs	13.8 μs

(4) Replacing the High Performance model QCPU with the Universal model QCPU

(a) Replacing all single-precision floating-point operation instructions with double-precision floating-point operation instructions

Single-precision floating-point data occupy two points of word device per data.
On the other hand, four points are required per double-precision floating-point data.
Therefore, all device numbers for storing floating-point data need to be reassigned.

Example **Replacing the floating-point operation [A × B+C] (Changing all floating-point data into double precision.)**

1) Device assignment

TableApp.36 Device assignment

Before replacement		
Application	**Device**	**Data type**
Data A	D0 to D1	Floating-point data (single precision)
Data B	D2 to D3	
Data C	D4 to D5	
Result	D6 to D7	

After replacement		
Application	**Device**	**Data type**
Data A	D0 to D3	Floating-point data (double precision)
Data B	D4 to D7	
Data C	D8 to D11	
Result	D12 to D15	

2) Program before replacement




Figure App.20 Sample program

3) Program after replacement




Figure App.21 Sample program

(b) Replacing a part of floating-point operation instructions with double-precision floating-point operation instructions

Only operations that require high accuracy are replaced with double-precision floating-point operation instructions.

Using the ECON and EDCON instructions, convert floating-point data mutually between single precision and double-precision. The flow of a replacement program is as follows:

- Data required for operations are converted from single precision to double precision using the ECON instruction.
- Operations are performed in double precision using the double-precision floating-point operation instructions.
- Operation results are converted from double precision to single precision using the EDCON instruction.

A program example that floating-point data are converted mutually between single precision and double precision before and after operations is shown below.

Example **Replacing the floating-point operation [A × B+C] (Using the ECON and EDCON instructions)**

1) Device assignment

TableApp.37 Device assignment

Before replacement		
Application	**Device**	**Data type**
Data A	D0 to D1	Floating-point data (single precision)
Data B	D2 to D3	
Data C	D4 to D5	
Result	D6 to D7	

After replacement		
Application	**Device**	**Data type**
Data A	D0 to D1	Floating-point data (single precision)
Data B	D2 to D3	
Data C	D4 to D5	
Result	D6 to D7	
Data A	D10 to D13	Floating-point data (double precision)
Data B	D14 to D17	
Data C	D18 to D21	
Result	D22 to D25	

2) Program before replacement




Figure App.22 Sample program

3) Program after replacement



Figure App.23 Sample program

(c) Replacing a part of floating-point operation instructions with double-precision floating-point operation instructions using subroutine programs

The flow of a replacement program described in (b) can be regarded as one subroutine program.
Create a subroutine program for each floating-point operation instruction and then replace the original floating-point operation instructions with the CALL(P) instruction so that the corresponding subroutine program is called.
With this method, changes in the program are minimized, but the processing for calling subroutine programs increases the scan time.
In addition, since conversions from double precision to single precision are performed for each instruction, rounding-off errors generated during operations are larger than those in the replacement program described in (b).

Example **Replacing the floating-point operation[A × B+C] (Using a subroutine program)**

1) Device assignment

TableApp.38 Device assignment

Before replacement		
Application	**Device**	**Data type**
Data A	D0 to D1	Floating-point data (single precision)
Data B	D2 to D3	
Data C	D4 to D5	
Result	D6 to D7	

After replacement		
Application	**Device**	**Data type**
Data A	D0 to D1	Floating-point data (single precision)
Data B	D2 to D3	
Data C	D4 to D5	
Result	D6 to D7	
Subroutine input data 1	D900 to D903	Floating-point data (double precision)
Subroutine input data 2	D904 to D907	
Subroutine operation result	D908 to D911	

2) Program before replacemennt




Figure App.24 Sample program

3) Program after replacement




Figure App.25 Sample program

Appendix 3.4.2 Error check processing for floating-point data comparison instructions

(1) Input data check

Error check processing for floating-point data comparison instructions performed in the Universal model QCPU are enhanced. Input of a "special value" (-0, nonnumeric, unnormalized number, or ±∞) is checked, and if those special values are input, the CPU module detects “OPERATION ERROR” (error code: 4140).

When the LDE□, ANDE□, ORE□, LDED□, ANDED□, and/or ORED□ instructions (□ indicates one of the followings; =,<>,<,>,<=,>=) are used in the program, “OPERATION ERROR” (error code: 4140) may be detected if invalid floating-point data exist. This occurs even when interlocks are provided using the valid data flags (the signal which shows the floating-point validity).


Invalid floating-point data are not stored in the result of operations performed in the Universal model QCPU. Those invalid data are considered to be stored in the following cases:

- The same device is used for storing floating-point data and other data, such as binary values, BCD values, and strings.
  → Use different devices for storing floating-point data and data other than floating-point data.
- Floating-point data externally written are invalid.
  → Take measures on the external-source side so that valid data are written.

If an error occurs in the floating-point data comparison instructions, take appropriate measures to remove error causes described above.

Example 1) **Detecting “OPERATION ERROR” (error code: 4140) in the LDE□ instruction**

[Ladder mode]



[List mode]

```
100  LD     M100
101  EMOV   D90    D100
103  OUT    M101
104  LD     M101
105  LDE<=  D100   E10
109  ORE>=  D100   E200
113  ANB
114  OUT    M102
```

In the ladder block starting from the step 104, the floating-point data comparison instructions of the step 105 and 109 are not executed when the M101 (valid data flag) is off.


However, the LDE<= instruction of the step 105 and the ORE>= instruction of the step 109 are executed regardless of the execution result of the LD instruction of the step 104 in the program above.

Therefore, even when the M101 is off, “OPERATION ERROR” (error code: 4140) will be detected in the LDE<= instruction of the step 105 if a "special value" is stored in D100.

For the method of avoiding “OPERATION ERROR”, refer to(2) in this section.

Example 2) **Not detecting “OPERATION ERROR” (error code: 4140) in the ANDE instruction**

[Ladder mode]




[List mode]

```
100  LD      M100
101  EMOV    D90     D100
103  OUT     M101
104  LD      M101
105  ANDE<=  D100    E10
109  OUT     M102
```

In the ladder block starting from the step 104, the ANDE<= instruction of the step 105 is not executed when the M101 (valid data flag) is off.
The ANDE<= instruction of the step 105 is not executed when the M101 is off in the LD instruction of the step 104 in the program above. Therefore, when the M101 is off, “OPERATION ERROR” (error code: 4140) will not be detected even if a "special value" is stored in D100.

Example 3) **Detecting "OPERATION ERROR" (error code: 4140) in the ANDE instruction**

[Ladder mode]



[List mode]

```
100  LD      M100
101  EMOV    D90     D100
103  OUT     M101
104  LD      M101
105  LD      M90
106  ANDE<=  D100    E10
110  ORE>=   D100    E200
114  ANB
115  OUT     M102
```


In the ladder block starting from the step 104, the ANDE<= instruction of the step 106 and the OR>= instruction of the step 110 are not executed when the M101 (valid data flag) is off.
However, if the M90 is on in the LD instruction of the step 105, the ANDE<= instruction of the step 106 is executed. Therefore, even when the M101 is off, "OPERATION ERROR" (error code: 4140) will be detected in the ANDE<= instruction of the step 106 if the M90 is on and a "special value" is stored in D100.
For the method of avoiding “OPERATION ERROR”, refer to (2) in this section.

(2) Method of avoiding "OPERATION ERROR" (error code: 4140) in the floating-point data comparison instructions


As shown in the modification examples below, connect the contacts of valid data flag in series for each floating-point data comparison instruction. (Use AND connection for connecting the contact of the valid data flag and the floating-point data comparison instruction.)

Make sure that there is no line (OR connection) between the valid data flag and the floating-point data comparison instruction.

<Modification example 1>




<Modification example 2>



Program examples after modification for Example 1) and 3) in (1) are shown below.


Example 4) **Program after modification for Example 1) ("OPERATION ERROR" (error code: 4140) is no longer detected.)**

[Ladder mode] **[List mode]**



Example 5) **Program after modification for Example 3) ("OPERATION ERROR" (error code: 4140) is no longer detected.)**

[Ladder mode] **[List mode]**




Appendix 3.4.3 Range check processing for index-modified devices

(1) Device range check

Error check processing at index modification of devices has been enhanced for the Universal model QCPU.
Each index-modified device range is checked, and if the check target device is outside the device range before index modification, the CPU module detects "OPERATION ERROR" (error code: 4101).

Example 1) **Detecting "OPERATION ERROR" (error code: 4101) by error check processing at index modification of devices**



In Example 1), when the contact (M0) is on and the value, -1 or less, is specified in Z1, the device D0Z1 is included in the C device range, exceeding the D device range, as shown in Figure App.26.
As a result, "OPERATION ERROR" (error code: 4101) will be detected.





Figure App.26 Device D0Z1 when the value of Z1 is -1

When an error is detected, check the index modification value (value of Z1 in the above example) and remove the error cause.
Examples of the cases where an error is detected and not detected are shown below.

Example 2) **Detecting "OPERATION ERROR" (error code: 4101)**

[Ladder mode]




[List mode]

```
15  LD      M0
16  LD      M1
17  AND<>   D10Z1   K5
20  LD      M2
21  AND<>   D10Z1   K10
24  ORB
25  ANB
26  MOV     D0      D1
28  INC     D2
```

In Example 2, in the ladder block starting from the step 15, the AND<> instruction of the step 17 or 21 is supposed to be not executed when M0 (valid data flag) is off.
However, since the LD instruction which is always executed is used in the step 16 and 20, the AND<> instruction of the step 17 or 21 is executed regardless of the execution status of the LD instruction in the step 15 when M1 or M2 is on.
For this reason, even when M0 is off, if the D10Z1 value is outside the D device range, "OPERATION ERROR" (error code: 4101) will be detected in the AND<> instruction of the step 17.
Note that the step 26 (MOV D0 D1) and the step 28 (INC D2) are not executed.
For the method of avoiding "OPERATION ERROR" (error code: 4101), refer to (2) in this section.

Example 3) **Not detecting "OPERATION ERROR" (error code: 4101)**

[Ladder mode]



[List mode]

```
15  LD      M0
16  AND<>   D10Z1   K5
19  MOV     D0      D1
```


In Example 3, the AND<> instruction of the step 16 is not executed when M0 (valid data flag) of the step 15 is off.
For this reason, "OPERATION ERROR" (error code: 4101) will not be detected no matter what the D10Z1 value is.

(2) Method of avoiding "OPERATION ERROR" (error code: 4101)

When the index-modified device range does not need to be checked, use the method 1).
When the index-modified device range needs to be checked, use the method 2).

1) Deselect the "Check device range at indexing" item in the PLC RAS tab of the PLC parameter dialog box so that the index-modified device range will not be checked.
2) As shown in the modification examples below, connect the contacts of valid data flag in series for each instruction that checks the index-modified device range.

<Modification example>



In the program before modification (on the left), the instruction immediately before the AND<> instruction is regarded as the LD instruction. However, in the program after modification (on the right), the same instruction will be regarded as the AND instruction.
In the program after modification, only when both contacts of M0 and M1 (or M2) turn on, the AND<> instruction is executed. As a result, no error will be detected during index-modified device range check processing.

Appendix 3.4.4 Device latch function

(1) Overview

The device latch function[*1] for the Universal model QCPU is more enhanced compared to that for the Basic model QCPU and High performance model QCPU.
This section describes the enhanced device latch function in the Universal model QCPU.

*1: The latch function is used to hold device data even when the CPU module is powered off or reset.

(2) Device data latch methods

Device data of the Universal model QCPU can be latched by:

- using the large-capacity file register (R, ZR),
- writing/reading device data to the standard ROM (with the SP.DEVST and S(P).DEVLD instructions), or
- specifying a latch range of internal user devices.

(3) Details of each latch method

(a) Large-capacity file register (R, ZR)

Data in the file register can be latched by batteries.
File register size is larger and processing speed is higher in the Universal model QCPU, compared to the Basic model QCPU and High Performance model QCPU.
To latch a lot of data (many device points), use of the file register is effective.

TableApp.39 shows the file register size available for each CPU module.

TableApp.39 File register size available for each CPU module

Model	File register (R, ZR) size in the standard RAM
Q00UCPU,Q01UCPU,Q02UCPU	64K points
Q03UDCPU,Q03UDECPU	96K points
Q04UDHCPU,Q04UDEHCPU	128K points
Q06UDHCPU,Q06UDEHCPU	384K points
Q10UDHCPU,Q13UDHCPU,Q10UDEHCPU,Q13UDEHCPU	512K points
Q20UDHCPU,Q20UDHCPU,Q26UDEHCPU,Q26UDEHCPU	640K points

(b) Writing/reading device data to the standard ROM (SP.DEVST and S(P).DEVLD instructions)

Device data of the Universal model QCPU can be latched using the SP.DEVST and S (P).DEVLD instructions (instructions for writing/reading data to/from the standard ROM).
Utilizing the standard ROM allows data backup without batteries.
This method is effective for latching data that will be updated less frequently.

(c) Specifying the latch range of internal user devices

Device data of the Universal model QCPU can be latched by specifying a latch range of internal user devices in the same way as for the Basic model QCPU and High Performance model QCPU.
The ranges can be set in the Device tab of the PLC parameter dialog box.
Internal user devices that can be latched are as follows:

- Latch relay (L)
- Link relay (B)
- Annunciator (F)
- Edge relay (V)
- Timer (T)
- Retentive timer (ST)
- Counter (C)
- Data register (D)
- Link register (W)

Point

- If latch ranges of internal user devices are specified in the Universal model QCPU, the processing time will be added to the scan time in proportion to the device points set to be latched. (For example, if 8K points are latched for the latch relay (L), the scan time will be 28.6 μ s.) To shorten the scan time, remove unnecessary latch device points to minimize the latch range.
- The scan time will not increase when a latch range of the file register (R, ZR) is specified.

(4) How to shorten the scan time

When data to be latched are stored in the file register (R, ZR), the processing time is shorter than that for latching internal user device.

Example **Reducing the latch points of the data register (D) from 8K points to 2K points, and using the file register (ZR) instead (when the Q06UDHCPU is used)**

TableApp.40 Differences between before and after moving latch points of the data register (D) to the file register (ZR)

Item		Before	After
Latch points of the data register (D)		8192 (8K) points	2048 (2K) points (6K points are moved to the file register.)
Number of devices in the program	Data register (D) (Latch range)	400	100
	File register (ZR) (Standard RAM)	0	300
Additional scan time		0.41ms	0.13ms*1
Number of steps increased		---	300 steps

*1: Time indicates the time required additionally when the file register is stored in the standard RAM.

Appendix 3.4.5 File usability setting

(1) Differences between High Performance model QCPU and Universal model QCPU

(a) High Performance model QCPU

In the High Performance model QCPU, file usability ("Use PLC file setting" or "Not used") of the following files can be set for each program on the screen opened by clicking the "File usability setting" button on the Program tab of the PLC parameter dialog box.

- File register
- Initial device value
- Comment
- Local device




Figure App.27 Program tab

(b) Universal model QCPU

In the Universal model QCPU, file usability of the following files*1 cannot be set for each program on the screen opened by clicking the "File usability setting" button on the Program tab of the PLC parameter dialog box.

- File register
- Initial device value
- Comment




Figure App.28 File usability setting screen


*1: Even file usability of local device file cannot be set if the serial number (first five digits) of the Q02UCPU, Q03UDCPU, Q04UDHCPU, or Q06UDHCPU is "10011" or earlier.
If the local device is set to be used in the PLC file tab of the PLC parameter dialog box in the High Performance model QCPU, all the programs use the local device in the Universal model QCPU after replacement.

When the file usability setting is set in the High Performance model QCPU, change the setting as described below.

(2) Method of replacing High Performance model QCPU with Universal model QCPU

Replacement method varies depending on the settings in the PLC file tab of the PLC parameter dialog box.

TableApp.41 Replacement method

Setting in the PLC file tab	Setting in Universal model QCPU
"Not used." is selected.	No change in parameter settings is required. Operation of the Universal model QCPU is the same regardless of the file usability setting in the High Performance model QCPU.
"Use the same file name as the program." is selected.	When file usability is set to "Not used." in the High Performance model QCPU, delete the corresponding program file (file register, initial device value, or comment), which uses the same name as the program, from the target memory. The Universal model QCPU executes a program without using a program file if no program file that uses the same name as the program exists in the target memory. 
"Use the following file." is selected.	No change in parameter settings is required. Operation of the Universal model QCPU is the same regardless of the file usability setting in the High Performance model QCPU.

Appendix 3.4.6 Parameter-valid drive and boot file setting

(1) Differences between High Performance model QCPU and Universal model QCPU

(a) High Performance model QCPU

The parameter-valid drive is specified by the switches on the front panel of the High Performance model QCPU.

(b) Universal model QCPU

The Universal model QCPU automatically determines the parameter-valid drive, depending on the existence of parameters in the drive (program memory, memory card, or standard ROM).
Therefore, when replacing the High Performance model QCPU with the Universal model QCPU, changing the boot file setting for parameter and/or moving files to another drive may be required.
When replacing the module, change the setting as described below.

(2) Method of replacing High Performance model QCPU with Universal model QCPU

(a) When the parameter-valid drive is set to the standard ROM in the High Performance model QCPU

TableApp.42 When the parameter-valid drive is set to the standard ROM

<table>
<tr><th colspan="2">Setting in High Performance model QCPU
Setting in the Boot file tab of the PLC parameter dialog box</th><th>Setting in Universal model QCPU</th></tr>
<tr><td colspan="2">No boot file setting</td><td>Change the setting so that the Universal model QCPU can refer to the parameters in the standard ROM.
• Changes in parameter settings are not required.
• Delete parameters that exist in the program memory and memory card.*2</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>Program</td><td>Standard ROM</td><td>Program memory</td></tr></table>(No boot file setting for parameters)</td><td>Change the setting so that programs are stored in the program memory in the first place, instead of booting from the standard ROM.
• Delete all settings for parameter in the Boot file tab of the PLC parameter dialog box.
• Delete parameters that exist in the program memory and memory card.*2
• Move the programs with boot setting into the program memory from the standard ROM.*1</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>Program</td><td>Standard ROM</td><td>Program memory</td></tr><tr><td>Parameter</td><td>Standard ROM</td><td>Program memory</td></tr></table></td><td>Change the setting so that programs and parameters are stored in the program memory in the first place, instead of booting from the standard ROM.
• Move the programs and parameters with boot setting into the program memory from the standard ROM.*1
• Delete all settings for parameter in the Boot file tab of the PLC parameter dialog box.</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>Program</td><td>Memory card</td><td>Program memory</td></tr></table>(No boot file setting for parameters)</td><td>Change the setting so that the Universal model QCPU can refer to the parameters in the memory card, and programs are booted from the memory card to the program memory.
• Move the parameters in the standard ROM into the memory card.
• Make setting so that programs are booted from the memory card to the program memory in the Boot file tab of the PLC parameter dialog box.*3</td></tr>
</table>

(To the next page)

TableApp.42 When the parameter-valid drive is set to the standard ROM (Continued)

<table>
<tr><th colspan="2">Setting in High Performance model QCPU
Setting in the Boot file tab of the PLC parameter dialog box</th><th>Setting in Universal model QCPU</th></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><th>Type</th><th>Transfer from</th><th>Transfer to</th></tr><tr><td>Program</td><td>Memory card</td><td>Program memory</td></tr><tr><td>Parameter</td><td>Memory card</td><td>Program memory</td></tr></table></td><td>Change the setting so that the Universal model QCPU can refer to the parameters in the memory card, and programs and parameters are booted from the memory card to the program memory.
• Move the parameters in the standard ROM into the memory card.
• Make setting so that programs and parameters are booted from the memory card to the program memory in the Boot file tab of the PLC parameter dialog box.*3</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><th>Type</th><th>Transfer from</th><th>Transfer to</th></tr><tr><td>(Data other than program and parameter)</td><td>Memory card</td><td>Program memory</td></tr></table></td><td rowspan="2">Delete all settings for data other than programs and parameters in the boot file setting.
Since these data can be used even not stored in the program memory, it is not necessary to transfer them to the program memory. Or, change the setting so that they are stored in the program memory in the first place.
• Delete all settings for data other than programs and parameters in the Boot file tab of the PLC parameter dialog box.
• Move the data other than programs and parameters into the program memory as needed.</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><th>Type</th><th>Transfer from</th><th>Transfer to</th></tr><tr><td>(Data other than program and parameter)</td><td>Standard ROM</td><td>Program memory</td></tr></table>(Data other than program and parameter indicate initial device value, device comment, and label program.)</td></tr>
</table>

*1: Since the Universal model QCPU holds the data in the program memory even when the battery voltage drops, the boot file setting is not necessary.

*2: The Universal model QCPU searches for parameters in order of in the program memory, in the memory card, and in the standard ROM. Then, the module uses the parameters found first.
If parameters exist in the program memory or the memory card, the Universal model QCPU cannot use the parameters in the standard ROM.

*3: The Universal model QCPU ignores the boot file setting for parameters in the standard ROM.

(b) When the parameter-valid drive is set to the memory card (RAM) or memory card (ROM) in the High Performance model QCPU

TableApp.43 When the parameter-valid drive is set to the memory card (RAM) or memory card (ROM)

<table>
<tr><th colspan="2">Setting in High Performance model QCPU
Setting in the Boot file tab of the PLC parameter dialog box</th><th>Setting in Universal model QCPU</th></tr>
<tr><td colspan="2">No boot file setting</td><td>Change the setting so that the Universal model QCPU can refer to the parameters in the memory card.
• Changes in parameter settings are not required.
• Delete parameters that exist in the program memory.*2</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>Program</td><td>Memory card</td><td>Program memory</td></tr></table>(No boot file setting for parameters)</td><td>Change the setting so that the Universal model QCPU can refer to the parameters in the memory card.
• Changes in parameter settings are not required.
• Delete parameters that exist in the program memory.*2</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>Program</td><td>Memory card</td><td>Program memory</td></tr><tr><td>Parameter</td><td>Memory card</td><td>Program memory</td></tr></table></td><td>No changes are required.</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>Program</td><td>Standard ROM</td><td>Program memory</td></tr></table>(No boot file setting for parameters)</td><td>Change the setting so that programs are stored in the program memory in the first place, instead of booting from the standard ROM.
• Move the programs targeted for booting from the standard ROM into the program memory.*1
• Delete all settings for program in the Boot file tab of the PLC parameter dialog box.
• Delete parameters that exist in the program memory.*2</td></tr>
<tr><td colspan="2">Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>Program</td><td>Standard ROM</td><td>Program memory</td></tr><tr><td>Parameter</td><td>Memory card</td><td>Program memory</td></tr></table></td><td>Change the setting so that programs are stored in the program memory in the first place, instead of booting from the standard ROM.
• Move the programs targeted for booting from the standard ROM into the program memory.*1
• Delete all settings for program in the Boot file tab of the PLC parameter dialog box.</td></tr>
<tr><td>Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>(Data other than program and parameter)</td><td>Memory card</td><td>Program memory</td></tr></table></td><td>Settings in the Boot file tab
<table><tr><td>Type</td><td>Transfer from</td><td>Transfer to</td></tr><tr><td>(Data other than program and parameter)</td><td>Standard ROM</td><td>Program memory</td></tr></table>(Data other than program and parameter indicate initial device value, device comment, and label program.)</td><td>Delete all settings for data other than programs and parameters in the boot file setting.
Since these data can be used even not stored in the program memory, it is not necessary to transfer them to the program memory. Or, change the setting so that they are stored in the program memory in the first place.
• Delete all settings for data other than programs and parameters in the Boot file tab of the PLC parameter dialog box.
• Move the data other than programs and parameters into the program memory as needed.</td></tr>
</table>

*1: Since the Universal model QCPU holds the data in the program memory even when the battery voltage drops, the boot file setting is not necessary.

*2: The Universal model QCPU searches for parameters in order of in the program memory, in the memory card, and in the standard ROM. Then, the module uses the parameters found first.
If parameters exist in the program memory or the memory card, the Universal model QCPU cannot use the parameters in the standard ROM.

Appendix 3.4.7 External input/output forced on/off function

(1) Differences between High Performance model QCPU and Universal model QCPU

(a) High Performance model QCPU

External input/output can be forcibly turned on/off on the screen opened by selecting [Online] → [Debug] → [Forced input output registration/cancellation] in GX Developer.

(b) Universal model QCPU

The external input/output forced on/off function is not supported in the Universal model QCPU. NoteApp.1
External input/output can be forcibly turned on/off by using the replacement program described below.

(2) Method of replacing High Performance model QCPU with Universal model QCPU

As shown in Figure App.29, add programs, "SETX" and "SETY", in the Program tab of the PLC parameter dialog box.




Figure App.29 Modification in the Program tab of the PLC parameter setting

The following table shows the program setting of the "SETX" and "SETY".

TableApp.44 ÅgProgram setting of "SETX" and "SETY"

Program name	Execution type	Position where program is added
SETX	Scan	Start of Program setting (No.1)
SETY	Scan	End of Program setting

NoteApp.1 Universal


When performing an external input/output forced on/off operation for the Q02UCPU, Q03UDCPU, Q04UDHCPU, Q06UDHCPU, Q13UDHCPU, or Q26UDHCPU, check the versions of the CPU module and GX Develover.

(☞ Appendix 2)

Example) **Forcibly turning X40, X77, and X7A on, and X41 and Y7B off**

The programs, "SETX" and "SETY", turns on or off the X and Y devices, which have been registered for forced on/off using the external input/output forced on/off function, at each scan using the SET and RST instructions.

High Performance model QCPU



Universal model QCPU

• Program example of “SETX”




• Program example of “SETY”




(3) Replacing the COM instruction

If the COM instruction is used, add subroutine calls for P10 and P11 before and after the COM instruction. (P10 and P11 are pointers shown in the program examples in (2).) When SM775 is on (Executes refresh set by SD778) and also the 0 bit of SD778 is off (Do not execute I/O refresh), replacement of the instruction is not necessary.

(a) Program before replacement



(b) Program after replacement




(4) Replacing the RFS instruction

If any I/O numbers targeted for forced on/off are included in the partial refresh range specified by the RFS instruction, add subroutine calls for P10 and P11 before and after the RFS instruction. (P10 and P11 are pointers shown in the program examples in (2).)

If no I/O number targeted for forced on/off is included, addition of subroutine calls for P10 and P11 is not necessary.


(a) When partial refresh for input (X) is executed by the RFS instruction

Add a subroutine call that executes forced input after the RFS instruction.



(b) When partial refresh for output (Y) is executed by the RFS instruction

Add a subroutine call that executes forced output before the RFS instruction.



(5) Restrictions

Replacements described in (2) to (4) do not apply in the following cases.

- Input and output targeted for forced on/off are referred to or changed using the direct input device (DX) and direct output device (DY).
- Input and output targeted for forced on/off are referred to or changed within an interrupt program.

Appendix 3.5 Special Relay and Special Register

The Universal model QCPU does not support the use of the special relay and special register described in Appendix 3.5.1 and Appendix 3.5.2.
Replace them using the method described in the table or delete the corresponding sections.

Appendix 3.5.1 Special relay list

TableApp.41 lists the special relay not supported in the Universal model QCPU and measures to be taken.

TableApp.45 Special relay not supported by the Universal model QCPU and measures

Number	Name/Description		Measures
SM80	CHK detection		The Universal model QCPU does not support the CHK instruction. For the replacing method of the CHK instruction, refer to Appendix 3.3.3.
SM91	Step transition monitoring timer start		The Universal model QCPU does not support the step transition monitoring timer function. For the replacing method of this function, refer to “Appendix 3. Restrictions and replacing method of the Basic model QCPU and Universal model QCPU" in the QCPU (Q Mode)/QnACPU Programming Manual (SFC).
SM92			
SM93			
SM94			
SM95			
SM96			
SM97			
SM98			
SM99			
SM250	Largest mounted I/O number read		Operation of SD250 is not necessary. The Universal model QCPU always stores the largest mounted I/O number in SD250. Delete the corresponding sections.
SM255	MELSECNET/H module 1 information	Indicates operative network or standby network	These are special relays for the simple dual-structured network function. Since the Universal model QCPU does not support this function, there is no application for these special relays. Delete the corresponding sections.
SM256		At refresh from link module to CPU, selects whether to read data from the link module.	
SM257		At refresh from CPU to link module, selects whether to write data to the link module.	
SM260	MELSECNET/H module 2 information	Indicates operative network or standby network	
SM261		At refresh from link module to CPU, selects whether to read data from the link module.	
SM262		At refresh from CPU to link module, selects whether to write data to the link module.	
SM265	MELSECNET/H module 3 information	Indicates operative network or standby network	
SM266		At refresh from link module to CPU, selects whether to read data from the link module.	
SM267		At refresh from CPU to link module, selects whether to write data to the link module.	
SM270	MELSECNET/H module 4 information	Indicates operative network or standby network	
SM271		At refresh from link module to CPU, selects whether to read data from the link module.	
SM272		At refresh from CPU to link module, selects whether to write data to the link module.	

(To the next page)

TableApp.45 Special relay not supported in the Universal model QCPU and measures (Continued)

Number	Name/Description	Measures
SM280	CC-Link error	Replace the relay with the I/O signals (Xn0, Xn1, and XnF) of the mounted CC-Link module.
SM315	Communication reserved time delay enable/disable flag	Set a service processing time value in the PLC system tab of the PLC parameter dialog box.
SM330	Operation mode for low-speed execution type program	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections.
SM331	Normal SFC program execution status	The Universal model QCPU supports only normal SFC programs. Delete SM331 and SM332, which are used as interlocks, or replace them with SM321.
SM332	Program execution management SFC program execution status	
SM390	Access execution flag	Modify the program that Module ready signal (Xn) is used as an interlock, according to sample programs described in the manual for each module.
SM404	ON for only 1 scan after RUN of low-speed execution type programs	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections or replace them with the special relays for scan execution type programs (SM402 and SM403).
SM405	Off for only 1 scan after RUN of low-speed execution type programs	
SM430	User timing clock No.5 (for low-speed execution type programs)	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections or replace them with the special relays for scan execution type programs (SM420 and SM424).
SM431	User timing clock No.6 (for low-speed execution type programs)	
SM432	User timing clock No.7 (for low-speed execution type programs)	
SM433	User timing clock No.8 (for low-speed execution type programs)	
SM434	User timing clock No.9 (for low-speed execution type programs)	
SM510	Low-speed execution type program executing flag	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections.
SM551	Module service interval time read	The Universal model QCPU does not support the service interval measurement function. Delete the corresponding sections.
SM580	Program to program I/O refresh	Perform I/O refresh at the start or end of each program with the RFS or COM instruction.
SM660	Boot operation	Move files with a boot setting (from the standard ROM or a memory card to the program memory) to the program memory.
SM672	Memory card file register access range flag	When outside the range of the file register in the memory card is accessed, the Universal model QCPU detects "OPERATION ERROR" (error code: 4101). Programming for detecting errors using this special realy is not necessary. Delete the corresponding sections.
SM710	CHK instruction priority flag	The Universal model QCPU does not support the CHK instruction. For the replacing method of the CHK instruction, refer to Appendix 3.3.
SM734	XCALL instruction execution condition specification	The Universal model QCPU executes the XCALL instruction on the rising edge of execution condition as well. There is no application for this special relay. Delete the corresponding sections.
SM735	SFC comment readout instruction in-execution flag	The Universal model QCPU does not support the following instructions: • SFC step comment readout instruction (S(P).SFCSCOMR) • SFC transition condition comment readout instruction (S(P).SFCTCOMR) Delete the corresponding sections.

(To the next page)

TableApp.45 Special relay not supported in the Universal model QCPU and measures (Continued)

Number	Name/Description	Measures
SM1780*1	Power supply off detection flag	The Universal model QCPU does not store redundant power supply system information in SM1780 to SM1783. Delete the corresponding sections. (SM1780 to SM1783 are always off.)
SM1781*1	Power supply failure detection flag	
SM1782*1	Momentary power failure detection flag for power supply 1	
SM1783*1	Momentary power failure detection flag for power supply 2	

*1: The special relay can be used if the serial number (first five digits) of the Universal model QCPU is "10042" or later.

Appendix 3.5.2 Special register list

TableApp.42 lists the special register not supported in the Universal model QCPU and measures to be taken

TableApp.46 Special register not supported in the Universal model QCPU and measures

Number	Name/Description	Measures
SD80	CHK number	The Universal model QCPU does not support the CHK instruction. For the replacing method of the CHK instruction, refer to Appendix 3.3.
SD90	Step transition monitoring timer setting value	The Universal model QCPU does not support the step transition monitoring timer function. For the replacing method of this function, refer to "Appendix 3. Restrictions and replacing method of the Basic model QCPU and Universal model QCPU" in the QCPU (Q Mode)/QnACPU Programming Manual (SFC).
SD91		
SD92		
SD93		
SD94		
SD95		
SD96		
SD97		
SD98		
SD99		
SD130 to SD137	Fuse blown module	Replace SD130 to SD137 with SD1300 to SD1307.
SD150 to SD157	I/O module verify error	Replace SD150 to SD157 with SD1400 to SD1407.
SD245	No. of base slots (Mounting status)	Replace SD245 and SD246 with SD243 and SD244, respectively.
SD246		
SD280	CC-Link error	Replace these registers with the I/O signals (Xn0, Xn1, and XnF) of the mounted CC-Link module.
SD281		
SD315	Time reserved for communication processing	Service processing setting is available for the Universal model QCPU on the PLC system setting tab of the PLC parameter dialog box. Select "Specify service process time." for the service processing setting parameter and set the service processing time. Other setting methods can be selected as well.
SD394	CPU mounting information	• Check the type and model of other CPU modules mounted on the System monitor screen of GX Developer. • Check the mounting status of other CPU modules in SD396 to SD398.
SD430	Low-speed scan counter	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections or replace them with the special register for scan execution type programs (SD420).
SD510	Low-speed execution type program number	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections or replace them with the special register for scan execution type programs (SD500).
SD528	Current scan time for low-speed execution type programs	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections or replace them with the special register for scan execution type programs (SD520 and SD521).
SD529		
SD532	Minimum scan time for low-speed execution type programs	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections or replace them with the special registers for scan execution type programs (SD524 to SD527).
SD533		
SD534	Maximum scan time for low-speed execution type programs	
SD535		
SD544	Cumulative execution time for low-speed execution type programs	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections.
SD545		
SD546	Execution time for low-speed execution type programs	The Universal model QCPU does not support low-speed execution type programs. Delete the corresponding sections.
SD547		

(To the next page)

TableApp.46 Special register not supported in the Universal model QCPU and measures (Continued)

Number	Name/Description	Measures
SD550	Service interval measurement module	The Universal model QCPU does not support the service interval measurement function. Delete the corresponding sections.
SD551	Service interval time	
SD552		
SD720	Program No. specification for PLAODP instruction	The Universal model QCPU does not support the PLAODP instruction. Delete the corresponding sections.
SD1780 *1	Power supply off detection status	The Universal model QCPU does not store redundant power supply system information in SD1780 to SD1783. Delete the corresponding sections. (SD1780 to SD1783 are always off.)
SD1781 *1	Power supply failure detection status	
SD1782 *1	Momentary power failure detection counter for power supply 1	
SD1783 *1	Momentary power failure detection counter for power supply 1	

*1: The special register can be used if the serial number (first five digits)of the Universal model QCPU is "10042" or later.

Appendix 4 Device Point Assignment Sheet

TableApp.47 Device point assignment sheet

Device name	Symbol	Numeric notation	Number of device point *2		Restriction check	
			Points	Range	Size (words)*3	Points (bits)*2
Input relay*1	X	Hexadecimal	8K (8192)	X0000 to X1FFF	/16 512	× 1 8192
Output relay*1	Y	Hexadecimal	8K (8192)	Y0000 to Y1FFF	/16 512	× 1 8192
Internal relay	M	Decimal	K ( )	M0 to	/16	× 1
Latch relay	L	Decimal	K ( )	L0 to	/16	× 1
Link relay	B	Hexadecimal	K ( )	B0000 to	/16	× 1
Annunciator	F	Decimal	K ( )	F0 to	/16	× 1
Link special relay	SB	Hexadecimal	K ( )	SB0000 to	/16	× 1
Edge relay	V	Decimal	K ( )	V0 to	/16	× 1
Step relay*1	S	Decimal	8K (8192)	S0 to S8191	/16 512	× 1 8192
Timer	T	Decimal	K ( )	T0 to	$\times \frac{18}{16}$	× 2
Retentive timer	ST	Decimal	K ( )	ST0 to	$\times \frac{18}{16}$	× 2
Counter	C	Decimal	K ( )	C0 to	$\times \frac{18}{16}$	× 2
Data register	D	Decimal	K ( )	D0 to	× 1	
Link register	W	Hexadecimal	K ( )	W0000 to	× 1	
Link special register	SW	Hexadecimal	K ( )	SW0000 to	× 1	
Total					(29696 or less)	(65536 or less)

*1: The points are fixed for the system. (Cannot be changed)
The points for the step relay (S) can be changed to 0 if the Universal model QCPU whose serial number (first five digits) is "10042" or later.

*2: Up to 32K points can be set for each device.
However, up to 60K points can be set for each device of the internal relay and link relay if the Universal model QCPU whose serial number (first five digits) is "10042" or later,

*3: Enter the values multiplied (or divided) by the number shown in the Size (words) column.

INDEX

[A]

Acknowledge XY assignment 8-15
Annunciator (F)
  Processing after annunciator off 9-14
  Processing after annunciator on 9-12
ASCII code 2-43
Auto mode 4-1
Auto refresh setting 7-2

[B]

B (Link relay) 9-16
Backup data restoration function 6-157
Backup function to memory card 6-149
Base unit. A-21
Battery life-prolonging function 6-139
BCD (Binary-coded decimal) 2-38
BIN (Binary code) 2-35
BL (SFC block device) 9-78
Boot operation 5-23
Built-in Ethernet port of the CPU module 1-12
Built-in Ethernet port setting 8-18

[C]

C (Counter) 9-27
CC-Link. A-22
Changing clock data 6-14
Changing the program execution type 2-30
Character string 9-83
Checking the function version 1-13
Checking the serial number 1-13
Clearing
  Clearing data in the latch relay 9-10
  Clearing local device data 9-94
  Clearing the counter value 9-28
  Clearing the error history data 6-105
  Clearing the file register data 9-54
  Clearing the retentive timer value 9-22
  Remote latch clear 6-25
Clock function 6-13
Common pointer 9-74
Communications with the FROM and TO instructions 7-5
Constant scan. 6-4
Counter (C)
  Counting 9-27
  Resetting the counter 9-28
CPU module change function with memory card 6-147
Cyclic transmission area device (U3En\G□) . . . 9-45

[D]

D (Data register) 9-31
Data clear processing 3-6
Data register (D) 9-31
Debug execution
  Operation procedure 6-92
Debug function from multiple GX Developers. . . 6-91
Decimal constant (K) 9-81
Detail mode. 4-1
Device list 9-1
Device point assignment sheet. App-72
Device setting 8-7
Direct access input 3-12
Direct access input (DX) 3-12
Direct access output 3-12
Direct access output (DY) 3-12
Direct mode 3-12
Double-precision floating-point data 2-41
Duty 9-30
DX (Direct access input) 3-12
DY (Direct access output) 3-12

[E]

E (Real number) 9-82
Edge relay (V) 9-15
END processing 3-2
Error
  Clearing errors 6-104
  Error time output mode setting 6-29
  Operating mode when there is an error 8-6
Error history 6-105
Ethernet A-22
Execution time measurement 6-69
Executional conditioned device test 6-48
Extended data register (D) 9-64
Extended link register (W) 9-64
Extension base unit A-21
External input/output forced on/off 6-43

[F]

F (Annunciator) 9-11
FD (Function register) 9-36
File 5-30
File register
  Accesses available for the file register 9-55
  Block switching method. 9-61
  Clearing the file register data 9-54
  Serial number access method. 9-61
File size. 5-34
File usability setting 2-15
Fixed scan execution type program 2-26
Floating-point data 2-39
Forced on/off. 6-43
Formatting
  Formatting the ATA card 5-15
  Formatting the SRAM card 5-15

Memory card clear 5-15
Function devices (FX, FY, FD) 9-35
Function list 6-1
FX (Function input) 9-35
FY (Function output) 9-36

[G]

Global device 9-84
GOT A-22
GX Configurator 7-2
GX Developer A-22

[H]

H (Hexadecimal constant) 9-81
H/W error time PLC operation mode 6-30
H/W error time PLC operation mode setting 6-30
Hardware check 11-3
HEX (Hexadecimal) 2-37
Hexadecimal constant (H) 9-81
High-speed timer (T) 9-21

[I]

I (Interrupt pointer) 9-76
I/O assignment 4-8
I/O assignment on remote I/O stations 4-6
I/O No. specification device (U) 9-79
I/O number 4-1
I/O number assignment 4-1
I/O processing and response delay 3-8
I/O response time 6-27
Index register (Z)
  Restoring the index register data 9-49
  Saving the index register data 9-49
Initial device value 6-135
Initial execution monitoring time 2-19
Initial execution type program 2-17
Initial processing 3-1
Initial setting 7-2,7-5
Input (X) 9-6
Intelligent function module
  Intelligent function module dedicated instructions 7-8
  Intelligent function module device (U□\G□) . . 9-43
  Intelligent function module switch setting 6-31
  Interrupt form intelligent function module 6-119
Intelligent function module setting 8-3
Internal relay (M) 9-9
Internal system device 9-35
Internal user device 9-3
Interrupt
  Interrupt form intelligent function module 6-119
  Interrupt module 6-27
  Interrupt pointer (I) 9-76
  Interrupt pointer setting 8-3
  Interrupt program 2-6
  Interrupt program monitor list 6-72
  List of interrupt factors 9-77
Interrupt program/Fixed scan program setting 8-4

[J]

J (Network No. specification device) 9-78
J□\□ (Link direct device) 9-40

[K]

K (Decimal constant) 9-81

[L]

L (Latch relay) 9-10
Ladder mode 2-2,6-58
Latch 6-7
Latch clear 3-7
Latch clear operation disable range (Latch (2) start/end) 3-7
Latch clear operation enable range (Latch (1) start/end) 3-7
Latch data backup to standard ROM function 6-141
Latch function 6-7
Latch relay (L) 9-10
LED
  Methods for turning off the LEDs 6-116
Link direct device (J□\□) 9-40
Link register (W) 9-32
Link relay (B) 9-16
Link special register (SW) 9-34
Link special relay (SB) 9-18
List mode 2-2
Local device 9-85
  Clearing local device data 9-94
  Local device monitor 6-40
Local pointer 9-72
Low-speed timer (T) 9-21

[M]

M (Internal relay) 9-9
Macro instruction argument device (VD) 9-80
Main base unit A-21
Main routine program 2-4
Maximum counting speed 9-30
MELSECNET/H A-22
Memory capacities of files 5-34
Memory capacity 5-34
Memory card 5-14
Memory check function 6-140
Memory composition 5-1
Module service interval 6-128
Momentary power failure 3-5
Monitor 6-33
Monitor condition setting 6-34
Motion CPU A-21

Multiple CPU high speed transmission area setting 8-17
Multiple CPU settings 8-16
Multiple CPU synchronous interrupt 9-76

[N]

N (Nesting) 9-70
Nesting 9-70
Network No. specification device (J) 9-78
Network parameters 8-20

[O]

Online change 6-58
  Online change (files) 6-61
  Online change (ladder mode) 6-58
Online change from multiple GX Developers . . . 6-93
Output mode at STOP to RUN 6-11

[P]

P (Pointer) 9-71
Parameters
  Network parameters 8-20
  PLC 8-2
Password 6-106
PAUSE status 3-3
PC CPU module A-21
PC RAS (1) setting 8-6
PLC file setting 8-5
PLC name setting 8-2
PLC parameters 8-2
Pointer
  Common pointer 9-74
  Interrupt pointer 9-76
  Local pointer 9-72
Points occupied by empty slot 8-4
Procedure
  Procedure for boot run 5-24
  Procedure for writing a program 5-19
Program cache memory 5-8
Program monitor list 6-69
Program setting 8-9
Protection
  Password registration 6-106
  Remote password 6-108

[Q]

Q series power supply module A-22
Q3□B A-21
Q3□DB A-21
Q3□RB A-21
Q3□SB A-21
Q5□B A-21
Q6□B A-21
Q6□RB A-21
QI60 6-27
QnUD(H)CPU A-21

[R]

R (File register) 9-53
Reading clock data 6-15
Redundant power extension base unit A-21
Redundant power main base unit A-21
Refresh mode 3-9
Remote latch clear 6-25
Remote operation 6-18
Remote password 6-108
Remote PAUSE 6-21
Remote RESET 6-23
Remote RUN/STOP 6-18
RUN status 3-3

[S]

S (Step relay) 9-19
Sampling trace 6-77
SB (Link special relay) 9-18
Scan execution type program 2-20
Scan time 2-18
Scan time accuracy 2-18
Scan time measurement 6-73
SD (Special register) 9-38
Self-diagnostic function 6-97
Serial communication function 6-120
Serial setting 8-14
Service processing 6-128
Service processing setting 6-128
Setting in GX Configurator 7-2
SFC block device (BL) 9-78
SFC setting 8-11
Single-precision floating-point data 2-39
Size (file capacity) 5-34
Slim type main base unit A-21
Slim type power supply module A-22
SM (Special relay) 9-38
Special register (SD) 9-38
Special relay (SM) 9-38
ST (Retentive timer) 9-22
Standard device register (Z) 9-48
Standard RAM 5-12
Standard ROM 5-11
Stand-by type program 2-21
Step relay (S) 9-19
STOP status 3-3
Subroutine program 2-5
SW (Link special register) 9-34
Switch setting
  Intelligent function module switch setting 6-31
System protection 6-106

[T]

T (Timer) 9-20
Timer (T)

Accuracy 9-24
Processing 9-23
Timer limit setting 8-3
Transferring data to the program memory 5-9

[U]

U (I/O No. specification device) 9-79
U3En\G□ (Cyclic transmission area device) 9-45
Units 5-36
Units of file sizes 5-36
U□\G□ (Intelligent function module device) 9-43
User setting system area 5-5

[V]

V (Edge relay) 9-15
VD (Macro instruction argument device) 9-80

[W]

W (Link register) 9-32
Watchdog timer (WDT) 6-95
WDT (Watchdog timer) 6-95
WDT setting 6-95
Write the program memory to ROM 5-18
Write to PLC (Flash ROM) 5-20
Writing
Writing data to the memory card 5-16
Writing data to the program memory 5-7
Writing data to the standard RAM 5-13
Writing data to the standard ROM 5-11
Writing/reading device data to/from standard ROM 6-146

[X]

X (Input) 9-6

[Y]

Y (Output) 9-8

[Z]

Z (Index register) 9-46
Z (Standard device register) 9-48
ZR (Serial number access method of file register) 9-61

Memo

Warranty

Please confirm the following product warranty details before using this product.

1. Gratis Warranty Term and Gratis Warranty Range

If any faults or defects (hereinafter "Failure") found to be the responsibility of Mitsubishi occurs during use of the product within the gratis warranty term, the product shall be repaired at no cost via the sales representative or Mitsubishi Service Company.

However, if repairs are required onsite at domestic or overseas location, expenses to send an engineer will be solely at the customer's discretion. Mitsubishi shall not be held responsible for any re-commissioning, maintenance, or testing on-site that involves replacement of the failed module.

[Gratis Warranty Term]

The gratis warranty term of the product shall be for one year after the date of purchase or delivery to a designated place.

Note that after manufacture and shipment from Mitsubishi, the maximum distribution period shall be six (6) months, and the longest gratis warranty term after manufacturing shall be eighteen (18) months. The gratis warranty term of repair parts shall not exceed the gratis warranty term before repairs.

[Gratis Warranty Range]

(1) The range shall be limited to normal use within the usage state, usage methods and usage environment, etc., which follow the conditions and precautions, etc., given in the instruction manual, user's manual and caution labels on the product.

(2) Even within the gratis warranty term, repairs shall be charged for in the following cases.

1. Failure occurring from inappropriate storage or handling, carelessness or negligence by the user. Failure caused by the user's hardware or software design.
2. Failure caused by unapproved modifications, etc., to the product by the user.
3. When the Mitsubishi product is assembled into a user's device, Failure that could have been avoided if functions or structures, judged as necessary in the legal safety measures the user's device is subject to or as necessary by industry standards, had been provided.
4. Failure that could have been avoided if consumable parts (battery, backlight, fuse, etc.) designated in the instruction manual had been correctly serviced or replaced.
5. Failure caused by external irresistible forces such as fires or abnormal voltages, and Failure caused by force majeure such as earthquakes, lightning, wind and water damage.
6. Failure caused by reasons unpredictable by scientific technology standards at time of shipment from Mitsubishi.
7. Any other failure found not to be the responsibility of Mitsubishi or that admitted not to be so by the user.

2. Onerous repair term after discontinuation of production

(1) Mitsubishi shall accept onerous product repairs for seven (7) years after production of the product is discontinued.

Discontinuation of production shall be notified with Mitsubishi Technical Bulletins, etc.

(2) Product supply (including repair parts) is not available after production is discontinued.

3. Overseas service

Overseas, repairs shall be accepted by Mitsubishi's local overseas FA Center. Note that the repair conditions at each FA Center may differ.

4. Exclusion of loss in opportunity and secondary loss from warranty liability

Regardless of the gratis warranty term, Mitsubishi shall not be liable for compensation of damages caused by any cause found not to be the responsibility of Mitsubishi, loss in opportunity, lost profits incurred to the user by Failures of Mitsubishi products, special damages and secondary damages whether foreseeable or not , compensation for accidents, and compensation for damages to products other than Mitsubishi products, replacement by the user, maintenance of on-site equipment, start-up test run and other tasks.

5. Changes in product specifications

The specifications given in the catalogs, manuals or technical documents are subject to change without prior notice.

6. Product application

(1) In using the Mitsubishi MELSEC programmable controller, the usage conditions shall be that the application will not lead to a major accident even if any problem or fault should occur in the programmable controller device, and that backup and fail-safe functions are systematically provided outside of the device for any problem or fault.

(2) The Mitsubishi programmable controller has been designed and manufactured for applications in general industries, etc. Thus, applications in which the public could be affected such as in nuclear power plants and other power plants operated by respective power companies, and applications in which a special quality assurance system is required, such as for Railway companies or Public service purposes shall be excluded from the programmable controller applications.

In addition, applications in which human life or property that could be greatly affected, such as in aircraft, medical applications, incineration and fuel devices, manned transportation, equipment for recreation and amusement, and safety devices, shall also be excluded from the programmable controller range of applications.

However, in certain cases, some applications may be possible, providing the user consults their local Mitsubishi representative outlining the special requirements of the project, and providing that all parties concerned agree to the special circumstances, solely at the users discretion.

Microsoft, Windows, Windows NT, Windows Vista are registered trademarks of Microsoft Corporation in the United States and other countries.
Pentium and Celeron are trademarks of Intel Corporation in the United States and other countries.
Ethernet is a trademark of Xerox Co., Ltd. in the United States.
CompactFlash is a trademark of SanDisk Corporation.
VxWorks, Tornado, WindPower, WindSh and WindView are registered trademarks of Wind River Systems, Inc.
Other company names and product names used in this document are trademarks or registered trademarks of respective owners.

SH(NA)-080807ENG-B

QnUCPU
User's Manual

Function Explanation, Program Fundamentals

MODEL	QNUCPU-U-KP-E
MODEL CODE	13JZ27
SH(NA)-080807ENG-B(0903)MEE	

MITSUBISHI ELECTRIC CORPORATION

HEAD OFFICE : TOKYO BUILDING, 2-7-3 MARUNOUCHI, CHIYODA-KU, TOKYO 100-8310, JAPAN
NAGOYA WORKS : 1-14 , YADA-MINAMI 5-CHOME , HIGASHI-KU, NAGOYA , JAPAN

When exported from Japan, this manual does not require application to the Ministry of Economy, Trade and Industry for service transaction permission.

Specifications subject to change without notice.